



American National Standard for

# Rotodynamic Pumps

for Pump Intake Design



**ANSI/HI 9.8–2018**

American National Standard for  
**Rotodynamic Pumps**  
for Pump Intake Design

Sponsor  
**Hydraulic Institute**  
[www.Pumps.org](http://www.Pumps.org)

Approved January 8, 2018  
**American National Standards Institute, Inc.**

## American National Standard

Approval of an American National Standard requires verification by ANSI that the requirements for due process, consensus and other criteria for approval have been met by the standards developer.

Consensus is established when, in the judgment of the ANSI Board of Standards Review, substantial agreement has been reached by directly and materially affected interests. Substantial agreement means much more than a simple majority, but not necessarily unanimity. Consensus requires that all views and objections be considered, and that a concerted effort be made toward their resolution.

The use of American National Standards is completely voluntary; their existence does not in any respect preclude anyone, whether he has approved the standards or not, from manufacturing, marketing, purchasing, or using products, processes, or procedures not conforming to the standards.

The American National Standards Institute does not develop standards and will in no circumstances give an interpretation of any American National Standard. Moreover, no person shall have the right or authority to issue an interpretation of an American National Standard in the name of the American National Standards Institute. Requests for interpretations should be addressed to the secretariat or sponsor whose name appears on the title page of this standard.

**CAUTION NOTICE:** This American National Standard may be revised or withdrawn at any time. The procedures of the American National Standards Institute require that action be taken periodically to reaffirm, revise, or withdraw this standard. Purchasers of American National Standards may receive current information on all standards by calling or writing the American National Standards Institute.

Published By

**Hydraulic Institute**  
**6 Campus Drive, First Floor North**  
**Parsippany, NJ 07054-4406**  
**[www.Pumps.org](http://www.Pumps.org)**

Copyright © 2018 Hydraulic Institute  
All rights reserved.

No part of this publication may be reproduced in any form, in an electronic retrieval system or otherwise, without prior written permission of the publisher.

Printed in the United States of America  
ISBN 978-1-935762-71-3



## Contents

Page

Foreword . . . . .	xi
9.8 Pump intake design . . . . .	1
9.8.1 Introduction. . . . .	1
9.8.1.1 Purpose . . . . .	1
9.8.1.2 Scope . . . . .	1
9.8.1.3 Nomenclature, primary symbols, and units . . . . .	1
9.8.2 Design objectives . . . . .	8
9.8.3 Intake structures for clear liquids . . . . .	10
9.8.3.1 Rectangular intakes . . . . .	10
9.8.3.1.1 Approach flow patterns. . . . .	10
9.8.3.1.2 Open versus partitioned structures . . . . .	10
9.8.3.1.3 Trash racks and screens. . . . .	10
9.8.3.1.4 Recommendations for dimensioning rectangular intake structures . . . . .	11
9.8.3.2 Formed suction intakes . . . . .	16
9.8.3.2.1 General. . . . .	16
9.8.3.2.2 Recommended dimensions for FSI . . . . .	17
9.8.3.2.3 Application standards . . . . .	18
9.8.3.2.4 Alternative FSI designs . . . . .	18
9.8.3.3 Circular pump stations (clear liquids) . . . . .	18
9.8.3.3.1 General. . . . .	18
9.8.3.3.2 Recommendations for dimensioning circular pump stations . . . . .	20
9.8.3.3.2.1 Nomenclature. . . . .	20
9.8.3.3.2.2 Floor clearance $C_f$ . . . . .	20
9.8.3.3.2.3 Wall clearance $C_w$ . . . . .	20
9.8.3.3.2.4 Inlet bell clearance $C_b$ . . . . .	20
9.8.3.3.2.5 Sump diameter $D_s$ . . . . .	20
9.8.3.3.2.6 Inlet bell or volute diameter $D_b$ . . . . .	20
9.8.3.3.2.7 Inflow pipe . . . . .	20
9.8.3.4 Trench-type intakes (clear liquids) . . . . .	21

9.8.3.4.1	General . . . . .	21
9.8.3.4.2	Objectives . . . . .	21
9.8.3.4.3	Orientation . . . . .	21
9.8.3.4.4	Approach flow . . . . .	22
9.8.3.4.5	Width . . . . .	22
9.8.3.4.6	Intake submergence . . . . .	22
9.8.3.4.7	End wall clearance . . . . .	22
9.8.3.4.8	Floor clearance . . . . .	22
9.8.3.4.9	Centerline spacing . . . . .	22
9.8.3.4.10	Inlet conduit elevation . . . . .	22
9.8.3.5	Tanks – pump suction . . . . .	22
9.8.3.5.1	General . . . . .	22
9.8.3.5.2	Objectives . . . . .	23
9.8.3.5.3	Discussion . . . . .	23
9.8.3.5.4	Submergence . . . . .	23
9.8.3.5.5	Application options . . . . .	24
9.8.3.5.6	NPSH considerations . . . . .	25
9.8.3.5.7	Simultaneous inflow and outflow . . . . .	25
9.8.3.5.8	Multiple inlets or outlets . . . . .	25
9.8.3.6	Can vertical turbine pump intakes (clear liquids), including those with submersible motors (refer to Appendix G) . . . . .	26
9.8.3.6.1	General . . . . .	26
9.8.3.6.2	Objective . . . . .	26
9.8.3.6.3	Design considerations . . . . .	26
9.8.3.6.4	Open bottom can intakes (Figure 9.8.3.6.4) . . . . .	26
9.8.3.6.5	Closed bottom can (Figure 9.8.3.6.5) . . . . .	28
9.8.3.7	Unconfined intakes (Figure 9.8.3.7) . . . . .	30
9.8.3.7.1	Scope . . . . .	30
9.8.3.7.2	Cross-flow velocities and pump location . . . . .	30
9.8.3.7.3	Debris and screens . . . . .	31
9.8.3.7.4	Submergence . . . . .	31

9.8.4	Intake structures for solids-bearing liquids . . . . .	32
9.8.4.1	General. . . . .	32
9.8.4.1.1	Scope . . . . .	32
9.8.4.1.2	Objectives. . . . .	32
9.8.4.1.3	Principles . . . . .	32
9.8.4.1.4	Vertical transitions . . . . .	33
9.8.4.1.5	Horizontal surfaces near inlet. . . . .	34
9.8.4.1.6	Cleaning procedures . . . . .	34
9.8.4.1.7	Wet-well volume . . . . .	34
9.8.4.2	Trench-type wet wells for solids-bearing liquids . . . . .	34
9.8.4.2.1	General. . . . .	34
9.8.4.2.2	Objectives. . . . .	34
9.8.4.2.3	Approach flow. . . . .	35
9.8.4.2.3.1	Inlet transition. . . . .	35
9.8.4.2.3.2	Inlet floor clearance . . . . .	35
9.8.4.2.3.3	Inlet splitters and cones . . . . .	36
9.8.4.2.3.4	Anti-rotation baffle and vanes. . . . .	36
9.8.4.2.3.5	Cleaning procedure . . . . .	36
9.8.4.3	Circular plan wet pit for solids-bearing liquids . . . . .	36
9.8.4.3.1	Wet-pit design . . . . .	36
9.8.4.3.2	Accessories . . . . .	36
9.8.4.3.3	Cleaning procedure and low liquid level. . . . .	37
9.8.4.3.4	Floor clearance C. . . . .	37
9.8.4.4	Rectangular wet wells for solids-bearing liquids. . . . .	40
9.8.4.4.1	General. . . . .	40
9.8.4.4.2	Objectives. . . . .	40
9.8.4.4.3	Control of sediments . . . . .	40
9.8.4.4.4	Confined wet-well design . . . . .	40
9.8.4.4.4.1	Suction inlet clearance . . . . .	41
9.8.4.4.4.2	Anti-rotation baffle . . . . .	41
9.8.4.4.4.3	Cleaning procedure . . . . .	41

9.8.5	Inlet bell design diameter ( <i>D</i> ) . . . . .	42
9.8.5.1	General. . . . .	42
9.8.5.2	Objective . . . . .	42
9.8.6	Required submergence for minimizing surface vortices. . . . .	44
9.8.6.1	General. . . . .	44
9.8.6.2	Controlling parameters. . . . .	45
9.8.6.3	Application considerations . . . . .	46
9.8.7	Physical model studies of intake structures and pump suction piping . . . . .	48
9.8.7.1	Need for a physical model study . . . . .	48
9.8.7.2	Physical model study objectives. . . . .	48
9.8.7.3	Physical model similitude and scale selection . . . . .	49
9.8.7.4	Physical model study scope. . . . .	51
9.8.7.5	Instrumentation and measuring techniques . . . . .	51
9.8.7.6	Test plan. . . . .	53
9.8.7.7	Acceptance criteria. . . . .	54
9.8.7.8	Report preparation . . . . .	54
9.8.8	Use of computational fluid dynamics (CFD). . . . .	55
9.8.8.1	General. . . . .	55
9.8.8.2	Simulation methods . . . . .	55
9.8.8.3	Acceptable uses of CFD modeling in pump suction hydraulics . . . . .	55
Appendices . . . . .		56
Appendix A	Remedial measures for problem intakes (informative) . . . . .	56
A.1	Introduction. . . . .	56
A.2	Approach flow patterns. . . . .	56
A.2.1	Open versus partitioned structures . . . . .	57
A.3	Controlling cross-flow . . . . .	58
A.4	Expanding concentrated flows . . . . .	62
A.4.1	Free surface approach . . . . .	62
A.4.2	Closed conduit approach . . . . .	62
A.5	Pump inlet disturbances. . . . .	65

A.5.1	Free surface vortices . . . . .	65
A.5.2	Subsurface vortices . . . . .	66
A.5.3	Pre-swirl . . . . .	66
A.5.4	Velocities in pump bell throat . . . . .	67
A.6	Deviations from standard dimensions . . . . .	68
A.7	Tanks – pump suction. . . . .	69
A.7.1	General. . . . .	69
A.7.2	Vertical tank, simultaneous inflow and outflow . . . . .	69
A.7.3	Horizontal tank, simultaneous inflow and outflow. . . . .	69
Appendix B	Sump volume (informative). . . . .	72
B.1	Scope . . . . .	72
B.2	General. . . . .	72
B.3	Construction of a graph . . . . .	73
B.4	Example for a simple controller . . . . .	73
B.5	Example for programmable controllers. . . . .	75
Appendix C	Intake basin entrance conditions, trench-type wet wells for solids-bearing liquids (informative) . . . . .	76
C.1	Scope . . . . .	76
C.2	Entrance conditions . . . . .	76
C.3	Variable-speed pumps in trench-type wet wells . . . . .	76
C.4	Constant-speed pumps in trench-type wet wells . . . . .	76
C.4.1	Auxiliary storage. . . . .	76
C.4.2	Approach pipes . . . . .	77
C.4.3	Transition manhole, sewer to approach pipe . . . . .	80
C.4.4	Lining . . . . .	80
C.5	Design examples . . . . .	80
Appendix D	Performance enhancements for trench-type wet wells (informative) . . . . .	81
D.1	Scope . . . . .	81
D.2	Performance of bare trenches . . . . .	81
D.2.1	Normal operation . . . . .	81
D.2.2	Cleaning operations for wastewater and stormwater wet wells . . . . .	81



D.3	Enhancing normal operation . . . . .	82
D.3.1	Inlet baffles . . . . .	82
D.3.2	Suction bell vanes . . . . .	82
D.3.3	Floor cones . . . . .	83
D.3.4	Flow splitters in wastewater wet wells . . . . .	84
D.3.5	Fillets . . . . .	85
D.3.6	Maintaining cleaning velocity . . . . .	85
D.3.7	Last pump . . . . .	85
D.3.8	Ramps . . . . .	85
D.3.9	Choice of enhancements . . . . .	85
D.3.10	Omission of enhancements . . . . .	86
Appendix E	Aspects of design of rectangular wet wells for solids-bearing liquids (informative) . . . . .	87
E.1	Introduction . . . . .	87
E.2	Design capacity . . . . .	87
E.3	Design alternatives – general . . . . .	88
E.4	Front – high-level entry intake structure . . . . .	88
E.5	Side – high-level entry intake structure . . . . .	88
E.6	Side – low-level entry intake structure . . . . .	88
E.7	Cleaning procedures . . . . .	88
E.8	Sump dimensions . . . . .	88
Appendix F	Suction bell design (informative) . . . . .	93
F.1	Introduction . . . . .	93
F.2	Bell outside diameter . . . . .	93
F.3	Ratio of bell outside diameter to throat diameter . . . . .	93
F.4	Suction bell length . . . . .	93
F.5	Bell intake shape . . . . .	93
Appendix G	Submersible pumps – well motor type (informative) . . . . .	95
G.1	Submersible pumps – well motor type . . . . .	95
Appendix H	Modification of existing pumping systems (informative) . . . . .	96
H.1	Scope . . . . .	96

H.2	Purpose . . . . .	96
H.3	Recommendations . . . . .	96
Appendix I	Alternate formed suction intake designs (informative) . . . . .	97
I.1	Stork-type formed suction intake . . . . .	97
I.2	Shoe-box-type formed suction intake . . . . .	97
Appendix J	Rectangular intakes for shallow liquid source (informative) . . . . .	100
J.1	General. . . . .	100
J.2	Entrance conditions . . . . .	100
J.3	Vertical transition . . . . .	101
J.4	Pump bay dividing walls and details near the entrance . . . . .	101
J.5	Pump bay details near the pumps . . . . .	101
Appendix K	Influence of pump selection on intake design (informative) . . . . .	104
K.1	Influence of pump selection on intake design . . . . .	104
Appendix L	Sediment and debris issues at surface water pump station intakes (informative) . . . . .	107
L.1	Issues with surface water intakes. . . . .	107
L.2	Selection of intake location. . . . .	107
L.2.1	River intakes. . . . .	107
L.2.2	Fresh water lakes, reservoirs, aqueducts, and canals . . . . .	108
L.2.3	Flow regime at the intake . . . . .	109
L.3	Sediment and debris control and removal . . . . .	109
L.3.1	Eliminating/minimizing sediment into intakes . . . . .	109
L.3.2	Collection, removal and sediment treatment . . . . .	109
Appendix M	References (informative) . . . . .	110
Appendix N	Index. . . . .	112

This page intentionally blank

## Foreword

### Purpose and aims of the Hydraulic Institute

The purpose and aims of the Hydraulic Institute are to promote the advancement of the pump manufacturing industry and further the interests of the public and to this end, among other things:

- a) Develop and publish standards.
- b) Address pump systems.
- c) Expand knowledge and resources.
- d) Educate the marketplace.
- e) Advocate for the industry.

### Purpose of Standards and Guidelines

- a) Hydraulic Institute Standards and Guidelines are adopted in the public interest and are designed to help eliminate misunderstandings between the manufacturer, the purchaser, and/or the user and to assist the purchaser in selecting and obtaining the proper product for a particular need.
- b) Use of Hydraulic Institute Standards and Guidelines is completely voluntary. Existence of Hydraulic Institute Standards does not in any respect preclude a member from manufacturing or selling products not conforming to the standards.

### Definition of a Standard of the Hydraulic Institute

Quoting from Article XV, Standards, of the By-Laws of the Institute, Section B:

“An Institute Standard defines the product, material, process or procedure with reference to one or more of the following: nomenclature, composition, construction, dimensions, tolerances, safety, operating characteristics, performance, quality, rating, testing and service for which designed.”

### Definition of a Hydraulic Institute Guideline

A Hydraulic Institute Guideline is not normative. The guideline is tutorial in nature, to help the reader better understand the subject matter.

### Comments from users

Comments from users of this standard will be appreciated, to help the Hydraulic Institute prepare even more useful future editions. Questions arising from the content of this standard may be directed to the Technical Director of the Hydraulic Institute. If appropriate, the inquiry will then be directed to the appropriate technical committee for provision of a suitable answer.

### Revisions

American National Standards of the Hydraulic Institute are subject to constant review, and revisions are undertaken whenever it is found necessary because of new developments and progress in the art. If no revisions are made for five years, the standards are reaffirmed using the ANSI canvass procedure.