

*First Printing: December 1999
Second Printing: November 2000
Third Printing: May 2001
Fourth Printing: January 2002*

ISBN # 1-892395-29-0

COPYRIGHT © 1999
by

INTERNATIONAL CODE COUNCIL, INC.

ALL RIGHTS RESERVED. This 2000 International Fire Code is a copyrighted work owned by the International Code Council, Inc. Without advance written permission from the copyright owner, no part of this book may be reproduced, distributed, or transmitted in any form or by any means, including, without limitation, electronic, optical or mechanical means (by way of example and not limitation, photocopying, or recording by or in an information storage retrieval system). For information on permission to copy material exceeding fair use, please contact: President, International Code Council, 5203 Leesburg Pike, Suite 600, Falls Church, Virginia 22041-3401. (Phone 703-931-4533).

Trademarks: "International Code Council," the "International Code Council" logo and the "2000 International Fire Code" are trademarks of the International Code Council, Inc. The "BOCA" logo is a trademark of Building Officials and Code Administrators International, Inc. The "ICBO" logo is a trademark of the International Conference of Building Officials. The "SBCCI" logo is a trademark of the Southern Building Code Congress International, Inc.

Published in cooperation with:

BUILDING OFFICIALS AND CODE ADMINISTRATORS INTERNATIONAL, INC.

4051 West Flossmoor Road • Country Club Hills, Illinois 60478-5795
(800) 214-4321 • www.bocai.org

INTERNATIONAL CONFERENCE OF BUILDING OFFICIALS

5360 Workman Mill Road • Whittier, California 90601-2298
(800) 284-4406 • www.icbo.org

SOUTHERN BUILDING CODE CONGRESS INTERNATIONAL, INC.

900 Montclair Road • Birmingham, Alabama 35213-1206
(877) 442-6337 • www.sbcci.org

PRINTED IN THE U.S.A.

PREFACE

Introduction

Internationally, code officials recognize the need for a modern, up-to-date fire code addressing conditions hazardous to life and property from fire explosion, hazardous materials storage, handling or use and the use and occupancy of buildings and premises. The *International Fire Code*®, in this 2000 edition, is designed to meet these needs through model code regulations that safeguard the public health and safety in all communities, large and small. This 2000 edition is fully compatible with all of the *International Codes*, including the *International Building Code*, *International Energy Conservation Code*, *International Fuel Gas Code*, *International Mechanical Code*, *International Plumbing Code*, *International Property Maintenance Code*, *International Private Sewage Disposal Code*, *International Residential Code*, *International Zoning Code*, and the *ICC Electrical Code*.

The *International Fire Code* provides many benefits, among which is the model code development process that offers an international forum for fire safety professionals to discuss performance-based and prescriptive code requirements. This forum provides an excellent arena to debate proposed revisions. This model code also encourages international consistency in the application of provisions.

Development

The production of the *International Fire Code* began in 1997 with the development of a first draft by a development committee consisting of representatives of Building Officials and Code Administrators International, Inc. (BOCA), International Conference of Building Officials (ICBO), and Southern Building Code Congress International, Inc. (SBCCI). The committee drafted a comprehensive set of fire safety regulations that was consistent with existing model fire codes at the time. Those codes were the then-current editions of the *BOCA National Fire Prevention Code*, the *Uniform Fire Code* and the *Standard Fire Prevention Code*. The 2000 edition of the *International Fire Code* was developed by utilizing the formal ICC Code Development Process for two successive annual code change cycles. During each cycle, public hearings were held to consider proposed changes in conjunction with hearings on proposed changes to other *International Codes* and in accordance with the ICC Code Development Procedures.

Letter Designations in Front of Section Numbers

In each code development cycle, proposed changes to this code are considered at the First Public Hearing by the International Fire Code Development Committee, whose action constitutes a recommendation to the voting membership for final action on the proposed change. Proposed changes to a code section whose number begins with a letter in brackets are considered by a different code development committee. For instance, proposed changes to code sections which have the letter [B] in front (e.g., [B] 909.1), are considered by the International Building Code Development Committee at the First Public Hearing. Where this designation is applicable to the entire content of a main section of the code, the designation appears at the main section number and title and is not repeated at every subsection in that section.

The content of sections in this code which begin with a letter designation are maintained by another code development committee in accordance with the following: [B] = International Building Code Development Committee; [M] = International Mechanical Code Development Committee; [PM] = International Property Maintenance Code Development Committee; [P] = International Plumbing Code Development Committee; [RBE] = International Residential Code Building and Energy Development Committee; [RMP] = International Residential Code Mechanical/Plumbing Development Committee; [E] = International Energy Conservation Code Development Committee; and [EL] = ICC Electrical Code Development Committee.

Adoption

The *International Fire Code* is available for adoption and use by jurisdictions internationally. Its use within a governmental jurisdiction is intended to be accomplished through adoption by reference in accordance with proceedings establishing the jurisdiction's laws. At the time of adoption, jurisdictions should insert the appropriate information in provisions requiring specific local information, such as the name of the adopting jurisdiction. These locations are shown in bracketed words in small capital letters in the code and in the sample adoption ordinance. The sample adoption ordinance on page v addresses several key elements of a code adoption ordinance, including the information required for insertion into the code text.

Maintenance

The *International Fire Code* is kept up to date through the review of proposed changes submitted by code enforcement officials, industry representatives, design professionals and other interested parties. Proposed changes are carefully considered through an open code development process in which all interested and affected parties may participate. The contents of this work are subject to change both through the Code Development Cycles and the governmental body that enacts the code into law. For more information regarding the code development process, contact: BOCA, ICBO or SBCCI.

While the development procedure of the *International Fire Code* assures the highest degree of care, BOCA, ICBO, SBCCI, their members and those participating in the development of this code do not accept any liability resulting from compliance or noncompliance with the provisions because BOCA, ICBO and SBCCI do not have the power or authority to police or enforce compliance with the contents of this code. Only the governmental body that enacts the code into law has such authority.

This is a preview of "ICC IFC-2000". [Click here to purchase the full version from the ANSI store.](#)

SAMPLE ORDINANCE FOR ADOPTION OF THE INTERNATIONAL FIRE CODE

ORDINANCE NO. _____

An ordinance of the [JURISDICTION] adopting the 2000 edition of the *International Fire Code*, regulating and governing the safeguarding of life and property from fire and explosion hazards arising from the storage, handling and use of hazardous substances, materials and devices, and from conditions hazardous to life or property in the occupancy of buildings and premises in the [JURISDICTION]; providing for the issuance of permits for hazardous uses or operations; repealing Ordinance No. _____ of the [JURISDICTION] and all other ordinances and parts of the ordinances in conflict therewith.

The [GOVERNING BODY] of the [JURISDICTION] does ordain as follows:

Section 1. That a certain document, three (3) copies of which are on file in the office of the [TITLE OF JURISDICTION'S KEEPER OF RECORDS] of [NAME OF JURISDICTION], being marked and designated as the *International Fire Code*, including Appendix Chapters [FILL IN THE APPENDIX CHAPTERS BEING ADOPTED] (see *International Fire Code* Section 101.2.1, 2000 edition), as published by the International Code Council, be and is hereby adopted as the code of the [JURISDICTION] for regulating and governing the safeguarding of life and property from fire and explosion hazards arising from the storage, handling and use of hazardous substances, materials and devices, and from conditions hazardous to life or property in the occupancy of buildings and premises in the [JURISDICTION] and providing for the issuance of permits for hazardous uses or operations; and each and all of the regulations, provisions, conditions and terms of such *International Fire Code*, 2000 edition, published by the International Code Council, on file in the office of the [JURISDICTION] are hereby referred to, adopted and made a part hereof as if fully set out in this ordinance.

Section 2. That the following sections are hereby revised:

Section 101.1 Insert: [NAME OF JURISDICTION]

Section 109.3. Insert: [OFFENSE, DOLLAR AMOUNT, NUMBER OF DAYS]

Section 111.4. Insert: [DOLLAR AMOUNT IN TWO LOCATIONS]

Section 3. That the limits referred to in certain sections of the 2000 *International Fire Code* are hereby established as follows:

Section 3204.3.1.1 (limits in which the storage of flammable cryogenic fluids in stationary containers is prohibited): [JURISDICTION TO SPECIFY]

Section 3404.2.9.5.1 (limits in which the storage of Class I and Class II liquids in above-ground tanks outside of buildings is prohibited): [JURISDICTION TO SPECIFY]

Section 3406.2.4.4 (limits in which the storage of Class I and Class II liquids in above-ground tanks is prohibited): [JURISDICTION TO SPECIFY]

Section 3804.2 (limits in which the storage of liquefied petroleum gas is restricted for the protection of heavily populated or congested areas): [JURISDICTION TO SPECIFY]

Section 4. That Ordinance No. _____ of [JURISDICTION] entitled [FILL IN HERE THE COMPLETE TITLE OF THE PRESENT FIRE PREVENTION ORDINANCE OR ORDINANCES IN EFFECT AT THE PRESENT TIME SO THAT THEY WILL BE REPEALED BY DEFINITE MENTION] and all other ordinances or parts of ordinances in conflict herewith are hereby repealed.

Section 5. That if any section, subsection, sentence, clause or phrase of this ordinance is, for any reason, held to be unconstitutional, such decision shall not affect the validity of the remaining portions of this ordinance. The [GOVERNING BODY] hereby declares that it would have passed this ordinance, and each section, subsection, clause or phrase thereof, irrespective of the fact that any one or more sections, subsections, sentences, clauses and phrases be declared unconstitutional.

Section 6. That the [JURISDICTION'S KEEPER OF RECORDS] is hereby ordered and directed to cause this ordinance to be published. (*An additional provision may be required to direct the number of times the ordinance is to be published and to specify that it is to be in a newspaper in general circulation. Posting may also be required.*)

Section 7. That this ordinance and the rules, regulations, provisions, requirements, orders and matters established and adopted hereby shall take effect and be in full force and effect [TIME PERIOD] from and after the date of its final passage and adoption.

This is a preview of "ICC IFC-2000". Click here to purchase the full version from the ANSI store.

TABLE OF CONTENTS

<p>CHAPTER 1 ADMINISTRATION 1</p> <p>Section</p> <p>101 General 1</p> <p>102 Applicability 1</p> <p>103 Department of Fire Prevention 2</p> <p>104 General Authority and Responsibilities 2</p> <p>105 Permits 3</p> <p>106 Inspections 10</p> <p>107 Maintenance 10</p> <p>108 Board of Appeals 11</p> <p>109 Violations 11</p> <p>110 Unsafe Buildings 12</p> <p>111 Stop Work Order 12</p> <p>CHAPTER 2 DEFINITIONS 13</p> <p>Section</p> <p>201 General 13</p> <p>202 General Definitions 13</p> <p>CHAPTER 3 GENERAL PRECAUTIONS AGAINST FIRE 25</p> <p>Section</p> <p>301 General 25</p> <p>302 Definitions 25</p> <p>303 Asphalt Kettles 25</p> <p>304 Combustible Waste Material 25</p> <p>305 Ignition Sources 26</p> <p>306 Motion Picture Film and Screens 26</p> <p>307 Open Burning 26</p> <p>308 Open Flames 27</p> <p>309 Powered Industrial Trucks 28</p> <p>310 Smoking 28</p> <p>311 Vacant Premises 29</p> <p>312 Vehicle Impact Protection 29</p> <p>313 Fueled Equipment 30</p> <p>314 Indoor Displays 30</p> <p>315 Miscellaneous Combustible Materials Storage .. 30</p> <p>CHAPTER 4 EMERGENCY PLANNING AND PREPAREDNESS 33</p> <p>Section</p> <p>401 General 33</p> <p>402 Definitions 33</p>	<p>403 Public Assemblages and Events 33</p> <p>404 Fire Safety and Evacuation Plans 33</p> <p>405 Emergency Evacuation Drills 34</p> <p>406 Employee Training and Response Procedures ... 35</p> <p>407 Hazard Communication 35</p> <p>408 Use and Occupancy-Related Requirements 35</p> <p>CHAPTER 5 FIRE SERVICE FEATURES 39</p> <p>Section</p> <p>501 General 39</p> <p>502 Definitions 39</p> <p>503 Fire Apparatus Access Roads 39</p> <p>504 Access to Building Openings and Roofs 40</p> <p>505 Premises Identification 40</p> <p>506 Key Boxes 40</p> <p>507 Hazards to Fire Fighters 41</p> <p>508 Fire Protection Water Supplies 41</p> <p>509 Fire Command Center 41</p> <p>510 Fire Department Access to Equipment 42</p> <p>CHAPTER 6 BUILDING SERVICES AND SYSTEMS 43</p> <p>Section</p> <p>601 General 43</p> <p>602 Definitions 43</p> <p>603 Fuel-Fired Appliances 43</p> <p>604 Emergency and Standby Power Systems 45</p> <p>605 Electrical Equipment, Wiring and Hazards 47</p> <p>606 Mechanical Refrigeration 48</p> <p>607 Elevator Recall and Maintenance 49</p> <p>608 Stationary Lead-Acid Battery Systems 50</p> <p>609 Commercial Kitchen Hoods 50</p> <p>CHAPTER 7 FIRE-RESISTANCE-RATED CONSTRUCTION 53</p> <p>Section</p> <p>701 General 53</p> <p>702 Definitions 53</p> <p>703 Fire-Resistance-Rated Construction 53</p> <p>704 Floor Openings and Shafts 53</p>
--	--

TABLE OF CONTENTS

CHAPTER 8 INTERIOR FINISH, DECORATIVE MATERIALS AND FURNISHINGS 55

Section

801 General 55
 802 Definitions 55
 803 Furnishings 55
 804 Decorative Vegetation 57
 805 Decorations and Trim 57
 806 Interior Finish and Decorative Materials 58

CHAPTER 9 FIRE PROTECTION SYSTEMS 61

Section

901 General 61
 902 Definitions 62
 903 Automatic Sprinkler Systems 64
 904 Alternative Automatic Fire-Extinguishing Systems 69
 905 Standpipe Systems 72
 906 Portable Fire Extinguishers 74
 907 Fire Alarm and Detection Systems 75
 908 Emergency Alarm Systems 84
 909 Smoke Control Systems 84
 910 Smoke and Heat Vents 91
 911 Explosion Control 93
 912 Fire Department Connections 94
 913 Fire Pumps 95

CHAPTER 10 MEANS OF EGRESS 97

Section

1001 General 97
 1002 Definitions 97
 1003 General Means of Egress 98
 1004 Exit Access 113
 1005 Exits 117
 1006 Exit Discharge 121
 1007 Miscellaneous Means of Egress Requirements 122
 1008 Assembly 123
 1009 Emergency Escape and Rescue 127
 1010 Means of Egress for Existing Buildings 128
 1011 Maintenance of the Means of Egress 132

CHAPTER 11 AVIATION FACILITIES 133

Section

1101 General 133
 1102 Definitions 133
 1103 General Precautions 133
 1104 Aircraft Maintenance 133
 1105 Portable Fire Extinguishers 134
 1106 Aircraft Fueling 134
 1107 Helistops and Heliports 139

CHAPTER 12 DRY CLEANING 141

Section

1201 General 141
 1202 Definitions 141
 1203 Classifications 141
 1204 General Requirements 141
 1205 Operating Requirements 142
 1206 Spotting and Pretreating 142
 1207 Dry Cleaning Systems 143
 1208 Fire Protection 143

CHAPTER 13 COMBUSTIBLE DUST-PRODUCING OPERATIONS 145

Section

1301 General 145
 1302 Definitions 145
 1303 Precautions 145
 1304 Explosion Protection 145

CHAPTER 14 FIRE SAFETY DURING CONSTRUCTION AND DEMOLITION 147

Section

1401 General 147
 1402 Definitions 147
 1403 Temporary Heating Equipment 147
 1404 Precautions Against Fire 147
 1405 Flammable and Combustible Liquids 147
 1406 Flammable Gases 148
 1407 Explosive Materials 148
 1408 Owner's Responsibility for Fire Protection 148
 1409 Fire Alarm Reporting 148
 1410 Access for Fire Fighting 148
 1411 Means of Egress 148
 1412 Standpipes 148
 1413 Automatic Sprinkler System 149

1414 Portable Fire Extinguishers 149
 1415 Motorized Equipment 149
 1416 Safeguarding Roofing Operations 149

CHAPTER 15 FLAMMABLE FINISHES 151

Section

1501 General 151
 1502 Definitions 151
 1503 Protection of Operations 151
 1504 Spray Finishing 153
 1505 Dipping Operations 156
 1506 Electrostatic Apparatus 157
 1507 Powder Coating 158
 1508 Automobile Undercoating 159
 1509 Organic Peroxides and Dual-Component
 Coatings 159
 1510 Floor Surfacing and Finishing Operations 159
 1511 Manufacturing of Glass-Fiber-Reinforced
 Plastics 159

CHAPTER 16 FRUIT AND CROP RIPENING 161

Section

1601 General 161
 1602 Definitions 161
 1603 Ethylene Gas 161
 1604 Sources of Ignition 161
 1605 Combustible Waste 161
 1606 Ethylene Generators 161
 1607 Warning Signs 161

**CHAPTER 17 FUMIGATION AND THERMAL
 INSECTICIDAL FOGGING 163**

Section

1701 General 163
 1702 Definitions 163
 1703 Fire Safety Requirements 163

**CHAPTER 18 SEMICONDUCTOR FABRICATION
 FACILITIES 165**

Section

1801 General 165
 1802 Definitions 165
 1803 General Safety Provisions 165
 1804 Storage 169
 1805 Use and Handling 169

**CHAPTER 19 LUMBER YARDS AND
 WOODWORKING FACILITIES . . . 173**

Section

1901 General 173
 1902 Definitions 173
 1903 General Requirements 173
 1904 Fire Protection 173
 1905 Plywood, Veneer and Composite Board
 Mills 174
 1906 Log Storage Areas 174
 1907 Storage of Wood Chips and Hogged Material in
 Association With Timber and Lumber
 Production Facilities 174
 1908 Storage and Processing of Wood Chips, Hogged
 Material, Fines, Compost and Raw Product in
 Association With Yard Waste and Recycling
 Facilities 174
 1909 Exterior Storage of Finished Lumber
 Products 175

**CHAPTER 20 MANUFACTURE OF ORGANIC
 COATINGS 177**

Section

2001 General 177
 2002 Definitions 177
 2003 General Precautions 177
 2004 Electrical Equipment and Protection 177
 2005 Process Structures 178
 2006 Process Mills and Kettles 178
 2007 Process Piping 178
 2008 Raw Materials in Process Areas 179
 2009 Raw Materials and Finished Products 179

CHAPTER 21 INDUSTRIAL OVENS 181

Section

2101 General 181
 2102 Definitions 181
 2103 Location 181
 2104 Fuel Piping 181
 2105 Interlocks 181
 2106 Fire Protection 182
 2107 Operation and Maintenance 182

**CHAPTER 22 SERVICE STATIONS AND REPAIR
 GARAGES 183**

Section

2201 General 183
 2202 Definitions 183

TABLE OF CONTENTS

2203 Location of Dispensing Devices 183
 2204 Dispensing Operations 184
 2205 Operational Requirements 184
 2206 Flammable and Combustible Liquids 185
 2207 Liquefied Petroleum Gas Motor-Vehicle
 Fuel-Dispensing Stations 189
 2208 Compressed Natural Gas Motor-Vehicle
 Fuel-Dispensing Stations 190
 2209 Marine Service Stations 191
 2210 Repair Garages 192

CHAPTER 23 HIGH-PILED COMBUSTIBLE STORAGE 195

Section

2301 General 195
 2302 Definitions 195
 2303 Commodity Classification 196
 2304 Designation of High-Piled Storage Areas 199
 2305 Housekeeping and Maintenance 199
 2306 General Fire Protection and Life Safety
 Features 199
 2307 Solid-Piled and Shelf Storage 201
 2308 Rack Storage 201
 2309 Automated Storage 202
 2310 Specialty Storage 203

CHAPTER 24 TENTS AND OTHER MEMBRANE STRUCTURES 205

Section

2401 General 205
 2402 Definitions 205
 2403 Access, Location and Parking 205
 2404 Structural Stability 206
 2405 Air-Supported and Air-Inflated Structures 206
 2406 Fire Safety Requirements 206
 2407 Fire Extinguisher and Other Fire Protection
 Equipment 207
 2408 Occupant Load 207
 2409 Seating 207
 2410 Means of Egress 207
 2411 Heating and Cooking Equipment 208
 2412 LP-Gas 208
 2413 Flammable and Combustible Liquids 208
 2414 Liquid- and Gas-Fueled Vehicles 209
 2415 Generators 209
 2416 Standby Personnel 209
 2417 Housekeeping 209

CHAPTER 25 TIRE REBUILDING AND TIRE STORAGE 211

Section

2501 General 211
 2502 Definitions 211
 2503 Tire Rebuilding 211
 2504 Precautions Against Fire 211
 2505 Outdoor Storage 211
 2506 Fire Department Access 212
 2507 Fencing 212
 2508 Fire Protection 212
 2509 Indoor Storage Arrangement 212

CHAPTER 26 WELDING AND OTHER HOT WORK 213

Section

2601 General 213
 2602 Definitions 213
 2603 General Requirements 213
 2604 Fire Safety Requirements 213
 2605 Gas Welding and Cutting 214
 2606 Electric Arc Hot Work 215
 2607 Calcium Carbide Systems 215
 2608 Acetylene Generators 215
 2609 Piping Manifolds and Hose Systems for
 Fuel Gases and Oxygen 215

CHAPTER 27 HAZARDOUS MATERIALS—GENERAL PROVISIONS 217

Section

2701 General 217
 2702 Definitions 218
 2703 General Requirements 220
 2704 Storage 232
 2705 Use, Dispensing and Handling 235

CHAPTER 28 AEROSOLS 239

Section

2801 General 239
 2802 Definitions 239
 2803 Classification of Aerosol Products 239
 2804 Inside Storage of Aerosol Products 239
 2805 Outside Storage 241
 2806 Retail Display 242
 2807 Manufacturing Facilities 242

CHAPTER 29 COMBUSTIBLE FIBERS 243

Section
 2901 General 243
 2902 Definitions 243
 2903 General Precautions 243
 2904 Loose Fiber Storage 243
 2905 Baled Storage 243

CHAPTER 30 COMPRESSED GASES 245

Section
 3001 General 245
 3002 Definitions 245
 3003 General Requirements 245
 3004 Storage of Compressed Gases 247
 3005 Use and Handling of Compressed Gases 247
 3006 Medical Gas Systems 248

CHAPTER 31 CORROSIVE MATERIALS 249

Section
 3101 General 249
 3102 Definitions 249
 3103 General Requirements 249
 3104 Storage 249
 3105 Use 249

CHAPTER 32 CRYOGENIC FLUIDS 251

Section
 3201 General 251
 3202 Definitions 251
 3203 General Requirements 251
 3204 Storage 253
 3205 Use and Handling 254

CHAPTER 33 EXPLOSIVES AND FIREWORKS 257

Section
 3301 General 257
 3302 Definitions 258
 3303 Record Keeping and Reporting 260
 3304 Explosive Materials Storage and Handling 261
 3305 Manufacture, Assembly and Testing of Explosives, Explosive Materials and Fireworks 267
 3306 Small Arms Ammunition 269
 3307 Blasting 270
 3308 Fireworks Display 271

CHAPTER 34 FLAMMABLE AND COMBUSTIBLE LIQUIDS 273

Section
 3401 General 273
 3402 Definitions 273
 3403 General Requirements 274
 3404 Storage 278
 3405 Dispensing, Use, Mixing and Handling 298
 3406 Special Operations 302

CHAPTER 35 FLAMMABLE GASES 311

Section
 3501 General 311
 3502 Definitions 311
 3503 General Requirements 311
 3504 Storage 312
 3505 Use 312

CHAPTER 36 FLAMMABLE SOLIDS 313

Section
 3601 General 313
 3602 Definitions 313
 3603 General Requirements 313
 3604 Storage 313
 3605 Use 313
 3606 Magnesium 313

CHAPTER 37 HIGHLY TOXIC AND TOXIC MATERIALS 315

Section
 3701 General 315
 3702 Definitions 315
 3703 Highly Toxic and Toxic Solids and Liquids 316
 3704 Highly Toxic and Toxic Compressed Gases 317
 3705 Ozone Gas Generators 321

CHAPTER 38 LIQUEFIED PETROLEUM GASES 323

Section
 3801 General 323
 3802 Definitions 323
 3803 Installation of Equipment 323
 3804 Location of Containers 324
 3805 Prohibited Use of LP-Gas 325
 3806 Dispensing and Overfilling 325
 3807 Safety Precautions and Devices 325

TABLE OF CONTENTS

3808 Fire Protection 325
 3809 Storage of Portable LP-Gas Containers Awaiting
 Use or Resale 325
 3810 Containers Not in Service 326
 3811 Parking and Garaging 327

CHAPTER 39 ORGANIC PEROXIDES 329

Section

3901 General 329
 3902 Definitions 329
 3903 General Requirements 329
 3904 Storage 329
 3905 Use 331

CHAPTER 40 OXIDIZERS 333

Section

4001 General 333
 4002 Definitions 333
 4003 General Requirements 333
 4004 Storage 334
 4005 Use 335

CHAPTER 41 PYROPHORIC MATERIALS 337

Section

4101 General 337
 4102 Definitions 337
 4103 General Requirements 337
 4104 Storage 337
 4105 Use 337
 4106 Silane Gas 338

**CHAPTER 42 PYROXYLIN (CELLULOSE
 NITRATE) PLASTICS 341**

4201 General 341
 4202 Definitions 341
 4203 General Requirements 341
 4204 Storage and Handling 341

**CHAPTER 43 UNSTABLE (REACTIVE)
 MATERIALS 343**

Section

4301 General 343
 4302 Definitions 343
 4303 General Requirements 343
 4304 Storage 344
 4305 Use 344

**CHAPTER 44 WATER-REACTIVE SOLIDS AND
 LIQUIDS 345**

Section

4401 General 345
 4402 Definitions 345
 4403 General Requirements 345
 4404 Storage 345
 4405 Use 346

CHAPTER 45 REFERENCED STANDARDS 347

APPENDIX A BOARD OF APPEALS 355

Section

A101 General 355

**APPENDIX B FIRE-FLOW REQUIREMENTS FOR
 BUILDINGS 357**

Section

B101 General 357
 B102 Definitions 357
 B103 Modifications 357
 B104 Fire Area 357
 B105 Fire-Flow Requirements for Buildings 357

**APPENDIX C FIRE HYDRANT LOCATIONS AND
 DISTRIBUTION 359**

Section

C101 General 359
 C102 Location 359
 C103 Number of Fire Hydrants 359
 C104 Consideration of Existing Fire Hydrants 359
 C105 Distribution of Fire Hydrants 359

**APPENDIX D FIRE APPARATUS ACCESS
 ROADS 361**

Section

D101 General 361
 D102 Required Access 361
 D103 Minimum Specifications 361
 D104 Commercial and Industrial Developments 362
 D105 Aerial Fire Apparatus Access Roads 362
 D106 Multiple-Family Residential Developments ... 362
 D107 One- or Two-Family Residential
 Developments 363

APPENDIX E HAZARD CATEGORIES	365
Section	
E101 General	365
E102 Hazard Categories	365
E103 Evaluation of Hazards	368
APPENDIX F HAZARD RANKING	371
Section	
F101 General	371
APPENDIX G CRYOGENIC FLUIDS—WEIGHT AND VOLUME EQUIVALENTS ...	373
Section	
G101 General	373
INDEX	375

This is a preview of "ICC IFC-2000". [Click here to purchase the full version from the ANSI store.](#)

CHAPTER 1

ADMINISTRATION

SECTION 101 GENERAL

101.1 Title. These regulations shall be known as the *Fire Code* of [NAME OF JURISDICTION], hereinafter referred to as “this code.”

101.2 Scope. This code establishes regulations affecting or relating to structures, processes and premises and safeguards from the hazard of fire and explosion arising from the storage, handling or use of structures, materials or devices; from conditions hazardous to life, property or public welfare in the occupancy of structures or premises from fire hazards in the structure or on the premise from occupancy or operation; and, matters related to the construction, extension, repair, alteration or removal of fire suppression and alarm systems.

101.2.1 Appendices. Provisions in the appendices shall not apply unless specifically adopted.

101.3 Intent. The purpose of this code is to establish the minimum requirements consistent with nationally recognized good practice for providing a reasonable level of life safety and property protection from the hazards of fire, explosion or dangerous conditions in new and existing buildings, structures and premises.

101.4 Severability. If a section, subsection, sentence, clause or phrase of this code is, for any reason, held to be unconstitutional, such decision shall not affect the validity of the remaining portions of this code.

101.5 Validity. In the event any part or provision of this code is held to be illegal or void, this shall not have the effect of making void or illegal any of the other parts or provisions hereof, which are determined to be legal; and it shall be presumed that this code would have been passed without such illegal or invalid parts or provisions.

SECTION 102 APPLICABILITY

102.1 Construction and design provisions. The construction and design provisions of this code shall apply to:

1. Structures, facilities and conditions arising after the adoption of this code.
2. Existing structures, facilities and conditions not legally in existence at the time of adoption of this code.
3. Existing structures, facilities and conditions when identified in specific sections of this code.
4. Existing structures, facilities and conditions which, in the opinion of the code official, constitute a distinct hazard to life or property.

102.2 Administrative, operational and maintenance provisions. The administrative, operational and maintenance provisions of this code shall apply to:

1. Conditions and operations arising after the adoption of this code.
2. Existing conditions and operations.

102.3 Change of use or occupancy. No change shall be made in the use or occupancy of any structure that would place the structure in a different division of the same group or occupancy or in a different group of occupancies, unless such structure is made to comply with the requirements of this code and the *International Building Code*. Subject to the approval of the code official, the use or occupancy of an existing structure shall be permitted to be changed and the structure is allowed to be occupied for purposes in other groups without conforming to all the requirements of this code and the *International Building Code* for those groups, provided the new or proposed use is less hazardous, based on life and fire risk, than the existing use.

102.4 Application of building code. The design and construction of new structures shall comply with the *International Building Code*; and any alterations, additions, changes in use or changes in structures required by this code which are within the scope of the *International Building Code* shall be made in accordance therewith.

102.5 Historic buildings. The provisions of this code relating to the construction, alteration, repair, enlargement, restoration, relocation or moving of buildings or structures shall not be mandatory for existing buildings or structures identified and classified by the state or local jurisdiction as historic buildings when such buildings or structures do not constitute a distinct hazard to life or property. Fire protection in designated historic buildings and structures shall be provided in accordance with an approved fire protection plan developed in accordance with the provisions of NFPA 909.

102.6 Referenced codes and standards. The codes and standards referenced in this code shall be those that are listed in Chapter 45 and such codes and standards shall be considered part of the requirements of this code to the prescribed extent of each such reference. Where differences occur between the provisions of this code and the referenced standards, the provisions of this code shall apply.

102.7 Subjects not regulated by this code. Where no applicable standards or requirements are set forth in this code, or are contained within other laws, codes, regulations, ordinances or bylaws adopted by the jurisdiction, compliance with applicable standards of the National Fire Protection Association or other nationally recognized fire safety standards as are approved shall be deemed as prima facie evidence of compliance with the intent of this code. Nothing herein shall derogate from the authority of the code official to determine compliance with codes or standards for those activities or installations within the code official’s jurisdiction or responsibility.

102.8 Matters not provided for. Requirements that are essential for the public safety of an existing or proposed activity, building or structure, or for the safety of the occupants thereof,

which are not specifically provided for by this code shall be determined by the code official.

102.9 Conflicting provisions. Where there is a conflict between a general requirement and a specific requirement, the specific requirement shall be applicable.

SECTION 103 DEPARTMENT OF FIRE PREVENTION

103.1 General. The department of fire prevention is established within the jurisdiction under the direction of the code official. The function of the department shall be the implementation, administration and enforcement of the provisions of this code.

103.2 Appointment. The code official shall be appointed by the chief appointing authority of the jurisdiction; and the code official shall not be removed from office except for cause and after full opportunity to be heard on specific and relevant charges by and before the appointing authority.

103.3 Deputies. In accordance with the prescribed procedures of this jurisdiction and with the concurrence of the appointing authority, the code official shall have the authority to appoint a deputy code official, other related technical officers, inspectors and other employees.

103.4 Liability. The code official, officer or employee charged with the enforcement of this code, while acting for the jurisdiction, shall not thereby be rendered liable personally, and is hereby relieved from all personal liability for any damage accruing to persons or property as a result of an act required or permitted in the discharge of official duties.

103.4.1 Legal defense. Any suit instituted against any officer or employee because of an act performed by that officer or employee in the lawful discharge of duties and under the provisions of this code shall be defended by the legal representative of the jurisdiction until the final termination of the proceedings. The code official or any subordinate shall not be liable for costs in an action, suit or proceeding that is instituted in pursuance of the provisions of this code; and any officer of the department of fire prevention, acting in good faith and without malice, shall be free from liability for acts performed under any of its provisions or by reason of any act or omission in the performance of official duties in connection therewith.

SECTION 104 GENERAL AUTHORITY AND RESPONSIBILITIES

104.1 General. The code official is hereby authorized to enforce the provisions of this code and shall have the authority to render interpretations of this code, and to adopt policies, procedures, rules and regulations in order to clarify the application of its provisions. Such interpretations, policies, procedures, rules and regulations shall be in compliance with the intent and purpose of this code and shall not have the effect of waiving requirements specifically provided for in this code.

104.2 Applications and permits. The code official is authorized to receive applications, review construction documents and issue permits for construction regulated by this code, issue

permits for operations regulated by this code, inspect the premises for which such permits have been issued and enforce compliance with the provisions of this code.

104.3 Right of entry. Whenever it is necessary to make an inspection to enforce the provisions of this code, or whenever the code official has reasonable cause to believe that there exists in a building or upon any premises any conditions or violations of this code which make the building or premises unsafe, dangerous or hazardous, the code official shall have the authority to enter the building or premises at all reasonable times to inspect or to perform the duties imposed upon the code official by this code. If such building or premises is occupied, the code official shall present credentials to the occupant and request entry. If such building or premises is unoccupied, the code official shall first make a reasonable effort to locate the owner or other person having charge or control of the building or premises and request entry. If entry is refused, the code official has recourse to every remedy provided by law to secure entry.

104.3.1 Warrant. When the code official has first obtained a proper inspection warrant or other remedy provided by law to secure entry, an owner or occupant or person having charge, care or control of the building or premises shall not fail or neglect, after proper request is made as herein provided, to permit entry therein by the code official for the purpose of inspection and examination pursuant to this code.

104.4 Identification. The code official shall carry proper identification when inspecting structures or premises in the performance of duties under this code.

104.5 Notices and orders. The code official is authorized to issue such notices or orders as are required to affect compliance with this code in accordance with Sections 109.1 and 109.2.

104.6 Official records. The code official shall keep official records as required by Sections 104.6.1 through 104.6.4. Such official records shall be retained for not less than five years or for as long as the structure or activity to which such records relate remains in existence, unless otherwise provided by other regulations.

104.6.1 Approvals and variances. A record of approvals and variances granted shall be maintained by the code official and shall be available for public inspection during business hours in accordance with applicable laws.

104.6.2 Inspections. The code official shall keep a record of each inspection made, including notices and orders issued, showing the findings and disposition of each.

104.6.3 Fire records. The fire department shall keep a record of fires occurring within its jurisdiction and of facts concerning the same, including statistics as to the extent of such fires and the damage caused thereby, together with other information as required by the code official.

104.6.4 Administrative. Application for modification, alternative methods or materials and the final decision of the code official shall be in writing and shall be officially recorded in the permanent records of the code official.

104.7 Approved materials and equipment. All materials, equipment and devices approved by the code official shall be constructed and installed in accordance with such approval.

104.7.1 Material and equipment reuse. Materials, equipment and devices shall not be reused or reinstalled unless such elements have been reconditioned, tested and placed in good and proper working condition and approved.

104.7.2 Technical assistance. To determine the acceptability of technologies, processes, products, facilities, materials and uses attending the design, operation or use of a building or premises subject to the inspection of the department, the code official is authorized to require the owner or agent to provide, without charge to the jurisdiction, a technical opinion and report. The opinion and report shall be prepared by a qualified engineer, specialist, laboratory or fire safety specialty organization acceptable to the code official and shall analyze the fire safety properties of the design, operation or use of the building or premises and the facilities and appurtenances situated thereon, to recommend necessary changes. The code official is authorized to require design submittals to be prepared by, and bear the stamp of, a registered design professional.

104.8 Modifications. Whenever there are practical difficulties involved in carrying out the provisions of this code, the code official shall have the authority to grant modifications for individual cases, provided the code official shall first find that special individual reason makes the strict letter of this code impractical and the modification is in compliance with the intent and purpose of this code and that such modification does not lessen health, life and fire safety requirements. The details of action granting modifications shall be recorded and entered in the files of the fire department.

104.9 Alternative materials and methods. The provisions of this code are not intended to prevent the installation of any material or to prohibit any method of construction not specifically prescribed by this code, provided that any such alternative has been approved. The code official is authorized to approve an alternative material or method of construction where the code official finds that the proposed design is satisfactory and complies with the intent of the provisions of this code, and that the material, method or work offered is, for the purpose intended, at least the equivalent of that prescribed in this code in quality, strength, effectiveness, fire resistance, durability and safety.

104.10 Fire investigations. The code official, the fire department or other responsible authority shall have the authority to investigate the cause, origin and circumstances of any fire, explosion or other hazardous condition. Information that could be related to trade secrets or processes shall not be made part of the public record except as directed by a court of law.

104.10.1 Assistance from other agencies. Police and other enforcement agencies shall have authority to render necessary assistance in the investigation of fires when requested to do so.

104.11 Authority at fires and other emergencies. The fire chief or officer of the fire department in charge at the scene of a fire or other emergency involving the protection of life or property or any part thereof, shall have the authority to direct such operation as necessary to extinguish or control any fire, perform any rescue operation, investigate the existence of suspected or reported fires, gas leaks or other hazardous

conditions or situations, or take any other action necessary in the reasonable performance of duty. In the exercise of such power, the fire chief is authorized to prohibit any person, vehicle, vessel or thing from approaching the scene and is authorized to remove, or cause to be removed or kept away from the scene, any vehicle, vessel or thing which could impede or interfere with the operations of the fire department and, in the judgment of the fire chief, any person not actually and usefully employed in the extinguishing of such fire or in the preservation of property in the vicinity thereof.

104.11.1 Barricades. The fire chief or officer of the fire department in charge at the scene of an emergency is authorized to place ropes, guards, barricades or other obstructions across any street, alley, place or private property in the vicinity of such operation so as to prevent accidents or interference with the lawful efforts of the fire department to manage and control the situation and to handle fire apparatus.

104.11.2 Obstructing operations. No person shall obstruct the operations of the fire department in connection with extinguishment or control of any fire, or actions relative to other emergencies, or disobey any lawful command of the fire chief or officer of the fire department in charge of the emergency, or any part thereof, or any lawful order of a police officer assisting the fire department.

104.11.3 Systems and devices. No person shall render a system or device inoperative during an emergency unless by direction of the fire chief or fire department official in charge of the incident.

SECTION 105 PERMITS

105.1 General. Permits shall be in accordance with Section 105.

105.1.1 Permits required. Permits required by this code shall be obtained from the code official. Permit fees, if any, shall be paid prior to issuance of the permit. Issued permits shall be kept on the premises designated therein at all times and shall be readily available for inspection by the code official.

105.1.2 Types of permits. There shall be two types of permits as follows:

1. Operational permit. An operational permit allows the applicant to conduct an operation or a business for which a permit is required by Section 105.6 for either:
 - 1.1. A prescribed period.
 - 1.2. Until renewed or revoked.
2. Construction permit. A construction permit allows the applicant to install or modify systems and equipment for which a permit is required by Section 105.7.

105.1.3 Permits for the same location. When more than one permit is required for the same location, the code official is authorized to consolidate such permits into a single permit provided that each provision is listed in the permit.

105.2 Application. Application for a permit required by this code shall be made to the code official in such form and detail as prescribed by the code official. Applications for permits

shall be accompanied by such plans as prescribed by the code official.

105.2.1 Refusal to issue permit. If the application for a permit describes a use that does not conform to the requirements of this code and other pertinent laws and ordinances, the code official shall not issue a permit, but shall return the application to the applicant with the refusal to issue such permit. Such refusal shall, when requested, be in writing and shall contain the reasons for refusal.

105.2.2 Inspection authorized. Before a new operational permit is approved, the code official is authorized to inspect the receptacles, vehicles, buildings, devices, premises, storage spaces or areas to be used to determine compliance with this code or any operational constraints required.

105.2.3 Time limitation of application. An application for a permit for any proposed work or operation shall be deemed to have been abandoned six months after the date of filing, unless such application has been diligently prosecuted or a permit shall have been issued; except that the code official is authorized to grant one or more extensions of time for additional periods not exceeding 90 days each if there is reasonable cause.

105.2.4 Action on application. The code official shall examine or cause to be examined applications for permits and amendments thereto within a reasonable time after filing. If the application or the construction documents do not conform to the requirements of pertinent laws, the code official shall reject such application in writing, stating the reasons therefor. If the code official is satisfied that the proposed work or operation conforms to the requirements of this code and laws and ordinances applicable thereto, the code official shall issue a permit therefore as soon as practicable.

105.3 Conditions of a permit. A permit shall constitute permission to maintain, store or handle materials; or to conduct processes which produce conditions hazardous to life or property; or to install equipment utilized in connection with such activities; or to install or modify any fire protection system or equipment or any other construction, equipment installation or modification in accordance with the provisions of this code where a permit is required by Section 105.6. Such permission shall not be construed as authority to violate, cancel or set aside any of the provisions of this code or other applicable regulations or laws of the jurisdiction.

105.3.1 Expiration. An operational permit shall remain in effect until reissued, renewed, or revoked or for such a period of time as specified in the permit. Construction permits shall automatically become invalid unless the work authorized by such permit is commenced within 180 days after its issuance, or if the work authorized by such permit is suspended or abandoned for a period of 180 days after the time the work is commenced. Before such work recommences, a new permit shall be first obtained and the fee, if any, shall be one-half the amount required for a new permit for such work, provided no changes have been made or will be made in the original construction documents for such work, and provided further that such suspension or abandonment has not exceeded one year. Permits are not transferable and any

change in occupancy, operation, tenancy or ownership shall require that a new permit be issued.

105.3.2 Extensions. A permittee holding an unexpired permit shall have the right to apply for an extension of the time within which the permittee will commence work under that permit when work is unable to be commenced within the time required by this section for good and satisfactory reasons. The code official is authorized to grant, in writing, one or more extensions of the time period of a permit for periods of not more than 90 days each. Such extensions shall be requested by the permit holder in writing and justifiable cause demonstrated.

105.3.3 Occupancy prohibited before approval. The building or structure shall not be occupied prior to the code official issuing a permit that indicates that applicable provisions of this code have been met.

105.3.4 Conditional permits. Where permits are required and upon the request of a permit applicant, the code official is authorized to issue a conditional permit to occupy the premises or portion thereof before the entire work or operations on the premises is completed, provided that such portion or portions will be occupied safely prior to full completion or installation of equipment and operations without endangering life or public welfare. The code official shall notify the permit applicant in writing of any limitations or restrictions necessary to keep the permit area safe. The holder of a conditional permit shall proceed only to the point for which approval has been given, at the permit holder's own risk and without assurance that approval for the occupancy or the utilization of the entire premises, equipment or operations will be granted.

105.3.5 Posting the permit. Issued permits shall be kept on the premises designated therein at all times and shall be readily available for inspection by the code official.

105.3.6 Compliance with code. The issuance or granting of a permit shall not be construed to be a permit for, or an approval of, any violation of any of the provisions of this code or of any other ordinance of the jurisdiction. Permits presuming to give authority to violate or cancel the provisions of this code or other ordinances of the jurisdiction shall not be valid. The issuance of a permit based on construction documents and other data shall not prevent the code official from requiring the correction of errors in the construction documents and other data. Any addition to or alteration of approved construction documents shall be approved in advance by the code official, as evidenced by the issuance of a new or amended permit.

105.3.7 Information on the permit. The code official shall issue all permits required by this code on an approved form furnished for that purpose. The permit shall contain a general description of the operation or occupancy and its location and any other information required by the code official. Issued permits shall bear the signature of the code official.

105.4 Construction documents. Construction documents shall be in accordance with this section.

105.4.1 Submittals. Construction documents shall be submitted in one or more sets and in such form and detail as re-

quired by the code official. The construction documents shall be prepared by a registered design professional where required by the statutes of the jurisdiction in which the project is to be constructed.

105.4.2 Information on construction documents. Construction documents shall be drawn to scale upon suitable material. Electronic media documents are allowed to be submitted when approved by the code official. Construction documents shall be of sufficient clarity to indicate the location, nature and extent of the work proposed and show in detail that it will conform to the provisions of this code and relevant laws, ordinances, rules and regulations as determined by the code official.

105.4.3 Applicant responsibility. It shall be the responsibility of the applicant to ensure that the construction documents include all of the fire protection requirements and the shop drawings are complete and in compliance with the applicable codes and standards.

105.4.4 Approved documents. Construction documents approved by the code official are approved with the intent that such construction documents comply in all respects with this code. Review and approval by the code official shall not relieve the applicant of the responsibility of compliance with this code.

105.4.5 Corrected documents. Where field conditions necessitate any substantial change from the approved construction documents, the code official shall have the authority to require the corrected construction documents to be submitted for approval.

105.4.6 Retention of construction documents. One set of construction documents shall be retained by the code official until final approval of the work covered therein. One set of approved construction documents shall be returned to the applicant, and said set shall be kept on the site of the building or work at all times during which the work authorized thereby is in progress.

105.5 Revocation. The code official is authorized to revoke a permit issued under the provisions of this code when it is found by inspection or otherwise that there has been a false statement or misrepresentation as to the material facts in the application or construction documents on which the permit or approval was based including, but not limited to, any one of the following:

1. The permit is used for a location or establishment other than that for which it was issued.
2. The permit is used for a condition or activity other than that listed in the permit.
3. Conditions and limitations set forth in the permit have been violated.
4. There have been any false statements or misrepresentations as to the material fact in the application for permit or plans submitted or a condition of the permit.
5. The permit is used by a different person or firm than the name for which it was issued.
6. The permittee failed, refused or neglected to comply with orders or notices duly served in accordance with the provisions of this code within the time provided therein.

7. The permit was issued in error or in violation of an ordinance, regulation or this code.

105.6 Required operational permits. The code official is authorized to issue operational permits for the operations set forth in Sections 105.6.1 through 105.6.46.

105.6.1 Aerosol products. An operational permit is required to manufacture, store or handle an aggregate quantity of Level 2 or Level 3 aerosol products in excess of 500 pounds (227 kg) net weight.

105.6.2 Amusement buildings. An operational permit is required to operate a special amusement building.

105.6.3 Aviation facilities. An operational permit is required to use a Group H or Group S occupancy for aircraft servicing or repair and aircraft fuel-servicing vehicles. Additional permits required by other sections of this code include, but are not limited to, hot work, hazardous materials and flammable or combustible finishes.

105.6.4 Carnivals and fairs. An operational permit is required to conduct a carnival or fair.

105.6.5 Battery systems. A permit is required to install stationary lead-acid battery systems having a liquid capacity of more than 50 gallons (189 L).

105.6.6 Cellulose nitrate film. An operational permit is required to store, handle or use cellulose nitrate film in a Group A occupancy.

105.6.7 Combustible dust-producing operations. An operational permit is required to operate a grain elevator, flour starch mill, feed mill, or a plant pulverizing aluminum, coal, cocoa, magnesium, spices or sugar, or other operations producing combustible dusts as defined in Chapter 2.

105.6.8 Combustible fibers. An operational permit is required for the storage and handling of combustible fibers in quantities greater than 100 cubic feet (2.8 m³).

Exception: A permit is not required for agricultural storage.

105.6.9 Compressed gases. An operational permit is required for the storage, use or handling at normal temperature and pressure (NTP) of compressed gases in excess of the amounts listed in Table 105.6.9.

Exception: Vehicles equipped for and using compressed gas as a fuel for propelling the vehicle.

**TABLE 105.6.9
PERMIT AMOUNTS FOR COMPRESSED GASES**

TYPE OF GAS	AMOUNT (cubic feet at NTP)
Corrosive	200
Flammable (except cryogenic fluids and liquefied petroleum gases)	200
Highly toxic	Any Amount
Inert and simple asphyxiant	6,000
Oxidizing (including oxygen)	504
Toxic	Any Amount

For SI: 1 cubic foot = 0.02832 m³.

105.6.10 Covered mall buildings. An operational permit is required for:

1. The placement of retail fixtures and displays, concession equipment, displays of highly combustible goods and similar items in the mall.
2. The display of liquid- or gas-fired equipment in the mall.
3. The use of open-flame or flame-producing equipment in the mall.

105.6.11 Cryogenic fluids. An operational permit is required to produce, store, transport on site, use, handle or dispense cryogenic fluids in excess of the amounts listed in Table 105.6.11.

Exception: Permits are not required for vehicles equipped for and using cryogenic fluids as a fuel for propelling the vehicle or for refrigerating the lading.

**TABLE 105.6.11
PERMIT AMOUNTS FOR CRYOGENIC FLUIDS**

TYPE OF CRYOGENIC FLUID	INSIDE BUILDING (gallons)	OUTSIDE BUILDING (gallons)
Flammable	More than 1	60
Inert	60	500
Oxidizing (includes oxygen)	10	50
Physical or health hazard not indicated above	Any Amount	Any Amount

For SI: 1 gallon = 3.785 L.

105.6.12 Cutting and welding. An operational permit is required to conduct cutting or welding operations within the jurisdiction.

105.6.13 Dry cleaning plants. An operational permit is required to engage in the business of dry cleaning or to change to a more hazardous cleaning solvent used in existing dry cleaning equipment.

105.6.14 Exhibits and trade shows. An operational permit is required to operate exhibits and trade shows.

105.6.15 Explosives. An operational permit is required for the manufacture, storage, handling, sale or use of any quantity of explosive, explosive material, fireworks, or pyrotechnic special effects within the scope of Chapter 33.

105.6.16 Fire hydrants and valves. An operational permit is required to use or operate fire hydrants or valves intended for fire suppression purposes which are installed on water systems and accessible to a fire apparatus access road that is open to or generally used by the public.

Exception: A permit is not required for authorized employees of the water company that supplies the system or the fire department to use or operate fire hydrants or valves.

105.6.17 Flammable and combustible liquids. An operational permit is required:

1. To use or operate a pipeline for the transportation within facilities of flammable or combustible liquids. This requirement shall not apply to the off-site transportation in pipelines regulated by the Department of Transportation (DOTn) nor does it apply to piping systems.
2. To store, handle or use Class I liquids in excess of 5 gallons (19 L) in a building or in excess of 10 gallons (37.9 L) outside of a building, except that a permit is not required for the following:
 - 2.1. The storage or use of Class I liquids in the fuel tank of a motor vehicle, aircraft, motorboat, mobile power plant or mobile heating plant, unless such storage, in the opinion of the code official, would cause an unsafe condition.
 - 2.2. The storage or use of paints, oils, varnishes or similar flammable mixtures when such liquids are stored for maintenance, painting or similar purposes for a period of not more than 30 days.
3. To store, handle or use Class II or Class IIIA liquids in excess of 25 gallons (95 L) in a building or in excess of 60 gallons (227 L) outside a building, except for fuel oil used in connection with oil-burning equipment.
4. To remove Class I or Class II liquids from an underground storage tank used for fueling motor vehicles by any means other than the approved, stationary on-site pumps normally used for dispensing purposes.
5. To operate tank vehicles, equipment, tanks, plants, terminals, wells, fuel-dispensing stations, refineries, distilleries and similar facilities where flammable and combustible liquids are produced, processed, transported, stored, dispensed or used.
6. To install, alter, remove, abandon, place temporarily out of service (for more than 90 days) or otherwise dispose of an underground, protected above-ground or above-ground flammable or combustible liquid tank.
7. To change the type of contents stored in a flammable or combustible liquid tank to a material which poses a greater hazard than that for which the tank was designed and constructed.
8. To manufacture, process, blend or refine flammable or combustible liquids.

105.6.18 Floor finishing. An operational permit is required for floor finishing or surfacing operations exceeding 350 square feet (33 m²) using Class I or Class II liquids.

105.6.19 Fruit and crop ripening. An operational permit is required to operate a fruit-, or crop-ripening facility or conduct a fruit-ripening process using ethylene gas.

105.6.20 Fumigation and thermal insecticidal fogging. An operational permit is required to operate a business of fu-

migation or thermal insecticidal fogging and to maintain a room, vault or chamber in which a toxic or flammable fumigant is used.

105.6.21 Hazardous materials. An operational permit is required to store, transport on site, dispense, use or handle hazardous materials in excess of the amounts listed in Table 105.6.21.

105.6.22 HPM facilities. An operational permit is required to store, handle or use hazardous production materials.

105.6.23 High-piled storage. An operational permit is required to use a building or portion thereof as a high-piled storage area exceeding 500 square feet (46 m²).

105.6.24 Hot work operations. An operational permit is required for hot work including, but not limited to:

1. Public exhibitions and demonstrations where hot work is conducted.
2. Use of portable hot work equipment inside a structure.

Exception: Work that is conducted under a construction permit.

3. Fixed-site hot work equipment such as welding booths.
4. Hot work conducted within a hazardous fire area.
5. Application of roof coverings with the use of an open-flame device.
6. When approved, the code official shall issue a permit to carry out a Hot Work Program. This program allows approved personnel to regulate their facility's hot work operations. The approved personnel shall be trained in the fire safety aspects denoted in this chapter and shall be responsible for issuing permits requiring compliance with the requirements found in this chapter. These permits shall be issued only to their employees or hot work operations under their supervision.

105.6.25 Industrial ovens. An operational permit is required for operation of industrial ovens regulated by Chapter 21.

105.6.26 Lumber yards and woodworking plants. An operational permit is required for the storage or processing of lumber exceeding 100,000 board feet (8,333 ft³) (236 m³).

105.6.27 Liquid- or gas-fueled vehicles or equipment in assembly buildings. An operational permit is required to display, operate or demonstrate liquid- or gas-fueled vehicles or equipment in assembly buildings.

105.6.28 LP-gas. An operational permit is required for:

1. Storage and use of LP-gas.

Exception: A permit is not required for individual containers with a 500-gallon (1893 L) water capacity or less serving occupancies in Group R-3.

2. Operation of cargo tankers that transport LP-gas.

105.6.29 Magnesium. An operational permit is required to melt, cast, heat treat or grind more than 10 pounds (4.54 kg) of magnesium.

105.6.30 Miscellaneous combustible storage. An operational permit is required to store in any building or upon any premises in excess of 2,500 cubic feet (71 m³) gross volume of combustible empty packing cases, boxes, barrels or similar containers, rubber tires, rubber, cork or similar combustible material.

105.6.31 Open burning. An operational permit is required for the kindling or maintaining of an open fire or a fire on any public street, alley, road, or other public or private ground. Instructions and stipulations of the permit shall be adhered to.

Exception: Recreational fires.

105.6.32 Open flames and candles. An operational permit is required to remove paint with a torch; use a torch or open-flame device in a hazardous fire area; or to use open flames or candles in connection with assembly areas, dining areas of restaurants or drinking establishments.

105.6.33 Organic coatings. An operational permit is required for any organic-coating manufacturing operation producing more than 1 gallon (4 L) of an organic coating in one day.

105.6.34 Places of assembly. An operational permit is required to operate a place of assembly.

105.6.35 Private fire hydrants. An operational permit is required for the removal from service, use or operation of private fire hydrants.

Exception: A permit is not required for private industry with trained maintenance personnel, private fire brigade or fire departments to maintain, test and use private hydrants.

105.6.36 Pyrotechnic special effects material. An operational permit is required for use and handling of pyrotechnic special effects material.

105.6.37 Pyroxylin plastics. An operational permit is required for storage or handling of more than 25 pounds (11 kg) of cellulose nitrate (pyroxylin) plastics and for the assembly or manufacture of articles involving pyroxylin plastics.

105.6.38 Refrigeration equipment. An operational permit is required to operate a mechanical refrigeration unit or system regulated by Chapter 6.

105.6.39 Repair garages and service stations. An operational permit is required for operation of repair garages and automotive, marine and fleet service stations.

105.6.40 Rooftop heliports. An operational permit is required for the operation of a rooftop heliport.

105.6.41 Spraying or dipping. An operational permit is required to conduct a spraying or dipping operation utilizing flammable or combustible liquids or the application of combustible powders regulated by Chapter 15.

105.6.42 Storage of scrap tires and tire byproducts. An operational permit is required to establish, conduct or maintain storage of scrap tires and tire byproducts that exceeds 2,500 cubic feet (71 m³) of total volume of scrap tires and for indoor storage of tires and tire byproducts.

**TABLE 105.6.21
PERMIT AMOUNTS FOR HAZARDOUS MATERIALS**

TYPE OF MATERIAL	AMOUNT
Combustible liquids	See Section 105.6.17
Corrosive materials Gases Liquids Solids	See Section 105.6.9 55 gallons 1000 pounds
Explosive materials	See Section 105.6.15
Flammable materials Gases Liquids Solids	See Section 105.6.9 See Section 105.6.17 100 pounds
Highly toxic materials Gases Liquids Solids	See Section 105.6.9 Any Amount Any Amount
Oxidizing materials Gases Liquids Class 4 Class 3 Class 2 Class 1 Solids Class 4 Class 3 Class 2 Class 1	See Section 105.6.9 Any Amount 1 gallon 10 gallons 55 gallons Any Amount 10 pounds 100 pounds 500 pounds
Organic peroxides Liquids Class I Class II Class III Class IV Class V Solids Class I Class II Class III Class IV Class V	Any Amount Any Amount 1 gallon 2 gallons No Permit Required Any Amount Any Amount 10 pounds 20 pounds No Permit Required
Pyrophoric materials Gases Liquids Solids	See Section 105.6.9 Any Amount Any Amount
Toxic materials Gases Liquids Solids	See Section 105.6.9 10 gallons 100 pounds

(continued)

TABLE 105.6.21—continued
PERMIT AMOUNTS FOR HAZARDOUS MATERIALS

TYPE OF MATERIAL	AMOUNT
Unstable (reactive) materials Liquids Class 4 Class 3 Class 2 Class 1 Solids Class 4 Class 3 Class 2 Class 1	Any Amount Any Amount 5 gallons 10 gallons Any Amount Any Amount 50 pounds 100 pounds
Water-reactive Materials Liquids Class 3 Class 2 Class 1 Solids Class 3 Class 2 Class 1	Any Amount 5 gallons 55 gallons Any Amount 50 pounds 500 pounds

For SI: 1 gallon = 3.785 L, 1 pound = 0.454 kg.

105.6.43 Temporary membrane structures, tents and canopies. An operational permit is required to operate an air-supported temporary membrane structure or a tent having an area in excess of 200 square feet (19 m²), or a canopy in excess of 400 square feet (37 m²).

Exceptions:

1. Tents used exclusively for recreational camping purposes.
2. Fabric canopies and awnings open on all sides which comply with all of the following:
 - 2.1. Individual canopies shall have a maximum size of 700 square feet (65 m²).
 - 2.2. The aggregate area of multiple canopies placed side by side without a fire break clearance of 12 feet (3658 mm) shall not exceed 700 square feet (65 m²) total.
 - 2.3. A minimum clearance of 12 feet (3658 mm) to structures and other tents shall be provided.

105.6.44 Tire-rebuilding plants. An operational permit is required for the operation and maintenance of a tire-rebuilding plant.

105.6.45 Waste handling. An operational permit is required for the operation of wrecking yards, junk yards and waste material-handling facilities.

105.6.46 Wood products. An operational permit is required to store chips, hogged material, lumber or plywood in excess of 200 cubic feet (6 m³).

105.7 Required construction permits. The code official is authorized to issue construction permits for work as set forth in Sections 105.7.1 through 105.7.12.

105.7.1 Automatic fire-extinguishing systems. A construction permit is required for installation of or modification to an automatic fire-extinguishing system. Maintenance performed in accordance with this code is not considered a modification and does not require a permit.

105.7.2 Compressed gases. When the compressed gases in use or storage exceed the amounts listed in Table 105.6.9, a construction permit is required to install, repair damage to, abandon, remove, place temporarily out of service, or close or substantially modify a compressed gas system.

Exceptions:

1. Routine maintenance.
2. For emergency repair work performed on an emergency basis, application for permit shall be made within two working days of commencement of work.

The permit applicant shall apply for approval to close storage, use or handling facilities at least 30 days prior to the termination of the storage, use or handling of compressed or liquefied gases. Such application shall include any change or alteration of the facility closure plan filed pursuant to Section 2701.5.3. The 30-day period is not applicable when approved based on special circumstances requiring such waiver.

105.7.3 Fire alarm and detection systems and related equipment. A construction permit is required for installation of or modification to fire alarm and detection systems and related equipment. Maintenance performed in accordance with this code is not considered a modification and does not require a permit.

105.7.4 Fire pumps and related equipment. A construction permit is required for installation of or modification to fire pumps and related fuel tanks, jockey pumps, controllers, and generators. Maintenance performed in accordance with this code is not considered a modification and does not require a permit.

105.7.5 Flammable and combustible liquids. A construction permit is required:

1. To repair or modify a pipeline for the transportation of flammable or combustible liquids.
2. To install, construct or alter tank vehicles, equipment, tanks, plants, terminals, wells, fuel-dispensing stations, refineries, distilleries and similar facilities where flammable and combustible liquids are produced, processed, transported, stored, dispensed or used.
3. To install, alter, remove, abandon, place temporarily out of service or otherwise dispose of a flammable or combustible liquid tank.

105.7.6 Hazardous materials. A construction permit is required to install, repair damage to, abandon, remove, place temporarily out of service, or close or substantially modify a storage facility or other area regulated by Chapter 27 when the hazardous materials in use or storage exceed the amounts listed in Table 105.6.21.

Exceptions:

1. Routine maintenance.
2. For emergency repair work performed on an emergency basis, application for permit shall be made within two working days of commencement of work.

105.7.7 Industrial ovens. A construction permit is required for installation of industrial ovens covered by Chapter 21.

Exceptions:

1. Routine maintenance.
2. For repair work performed on an emergency basis, application for permit shall be made within two working days of commencement of work.

105.7.8 LP-gas. A construction permit is required for installation of or modification to an LP-gas system.

105.7.9 Private fire hydrants. A construction permit is required for the installation or modification of private fire hydrants.

105.7.10 Spraying or dipping. A construction permit is required to install or modify a spray room, dip tank or booth.

105.7.11 Standpipe systems. A construction permit is required for the installation, modification, or removal from service of a standpipe system. Maintenance performed in accordance with this code is not considered a modification and does not require a permit.

105.7.12 Temporary membrane structures, tents and canopies. A construction permit is required to erect an air-supported temporary membrane structure or a tent having

an area in excess of 200 square feet (19 m²), or a canopy in excess of 400 square feet (37 m²).

Exceptions:

1. Tents used exclusively for recreational camping purposes.
2. Funeral tents and curtains or extensions attached thereto, when used for funeral services.
3. Fabric canopies and awnings open on all sides which comply with all of the following:
 - 3.1. Individual canopies shall have a maximum size of 700 square feet (65 m²).
 - 3.2. The aggregate area of multiple canopies placed side by side without a fire break clearance of 12 feet shall not exceed 700 square feet (3658 mm) total.
 - 3.3. A minimum clearance of 12 feet (3658 mm) to structures and other tents shall be maintained.

**SECTION 106
INSPECTIONS**

106.1 Inspection authority. The code official is authorized to enter and examine any building, structure, marine vessel, vehicle, or premises in accordance with Section 104.3 for the purpose of enforcing this code.

106.2 Inspections. The code official is authorized to conduct such inspections as are deemed necessary to determine the extent of compliance with the provisions of this code and to approve reports of inspection by approved agencies or individuals. All reports of such inspections shall be prepared and submitted in writing for review and approval. Inspection reports shall be certified by a responsible officer of such approved agency or by the responsible individual. The code official is authorized to engage such expert opinion as deemed necessary to report upon unusual, detailed or complex technical issues subject to the approval of the governing body.

106.3 Concealed work. Whenever any installation subject to inspection prior to use is covered or concealed without having first been inspected, the code official shall have the authority to require that such work be exposed for inspection.

**SECTION 107
MAINTENANCE**

107.1 Maintenance of safeguards. Whenever or wherever any device, equipment, system, condition, arrangement, level of protection, or any other feature is required for compliance with the provisions of this code, or otherwise installed, such device, equipment, system, condition, arrangement, level of protection, or other feature shall thereafter be continuously maintained in accordance with this code and applicable referenced standards.

107.2 Testing and operation. Equipment requiring periodic testing or operation to ensure maintenance shall be tested or operated as specified in this code.

107.2.1 Test and inspection records. Required test and inspection records shall be available to the code official at all times or such records as the code official designates shall be filed with the code official.

107.2.2 Reinspection and testing. Where any work or installation does not pass an initial test or inspection, the necessary corrections shall be made so as to achieve compliance with this code. The work or installation shall then be re-submitted to the code official for inspection and testing.

107.3 Supervision. Maintenance and testing shall be under the supervision of a responsible person who shall ensure that such maintenance and testing are conducted at specified intervals in accordance with this code.

107.4 Rendering equipment inoperable. Portable or fixed fire-extinguishing systems or devices and fire-warning systems shall not be rendered inoperative or inaccessible except as necessary during emergencies, maintenance, repairs, alterations, drills or prescribed testing.

107.5 Owner/occupant responsibility. Correction and abatement of violations of this code shall be the responsibility of the owner. If an occupant creates, or allows to be created, hazardous conditions in violation of this code, the occupant shall be held responsible for the abatement of such hazardous conditions.

SECTION 108 BOARD OF APPEALS

108.1 Board of appeals established. In order to hear and decide appeals of orders, decisions or determinations made by the code official relative to the application and interpretation of this code, there shall be and is hereby created a board of appeals consisting of members who are qualified by experience and training to pass on matters pertaining to this code and who are not employees of the jurisdiction. The code official shall be an ex officio member of said board but shall have no vote on any matter before the board. The board of appeals shall be appointed by the governing body and shall hold office at its pleasure. The board shall adopt rules of procedure for conducting its business, and shall render all decisions and findings in writing to the appellant with a duplicate copy to the code official.

108.2 Limitations on authority. An application for appeal shall be based on a claim that the intent of this code or the rules legally adopted thereunder have been incorrectly interpreted, the provisions of this code do not fully apply, or an equivalent method of protection or safety is proposed. The board shall have no authority to waive requirements of this code.

108.3 Administration. The code official shall take action in accordance with the decision of the board.

SECTION 109 VIOLATIONS

109.1 Unlawful acts. It shall be unlawful for a person, firm or corporation to erect, construct, alter, repair, remove, demolish

or utilize a building, occupancy, premises or system regulated by this code, or cause same to be done, in conflict with or in violation of any of the provisions of this code.

109.2 Notice of violation. When the code official finds a building, premises, vehicle, storage facility or outdoor area that is in violation of this code, the code official is authorized to prepare a written notice of violation describing the conditions deemed unsafe and, when compliance is not immediate, specifying a time for reinspection.

109.2.1 Service. A notice of violation issued pursuant to this code shall be served upon the owner, operator, occupant, or other person responsible for the condition or violation, either by personal service, mail, or by delivering the same to, and leaving it with, some person of responsibility upon the premises. For unattended or abandoned locations, a copy of such notice of violation shall be posted on the premises in a conspicuous place at or near the entrance to such premises and the notice of violation shall be mailed by certified mail with return receipt requested or a certificate of mailing, to the last known address of the owner, occupant or both.

109.2.2 Compliance with orders and notices. A notice of violation issued or served as provided by this code shall be complied with by the owner, operator, occupant or other person responsible for the condition or violation to which the notice of violation pertains.

109.2.3 Prosecution of violations. If the notice of violation is not complied with promptly, the code official is authorized to request the legal counsel of the jurisdiction to institute the appropriate legal proceedings at law or in equity to restrain, correct or abate such violation or to require removal or termination of the unlawful occupancy of the structure in violation of the provisions of this code or of the order or direction made pursuant thereto.

109.2.4 Unauthorized tampering. Signs, tags or seals posted or affixed by the code official shall not be mutilated, destroyed or tampered with or removed without authorization from the code official.

109.3 Violation penalties. Persons who shall violate a provision of this code or shall fail to comply with any of the requirements thereof or who shall erect, install, alter, repair or do work in violation of the approved construction documents or directive of the code official, or of a permit or certificate used under provisions of this code, shall be guilty of a [SPECIFY OFFENSE], punishable by a fine of not more than [AMOUNT] dollars or by imprisonment not exceeding [NUMBER OF DAYS], or both such fine and imprisonment. Each day that a violation continues after due notice has been served shall be deemed a separate offense.

109.3.1 Abatement of violation. In addition to the imposition of the penalties herein described, the code official is authorized to institute appropriate action to prevent unlawful construction or to restrain, correct or abate a violation; or to prevent illegal occupancy of a structure or premises; or to

stop an illegal act, conduct of business or occupancy of a structure on or about any premises.

SECTION 110 UNSAFE BUILDINGS

110.1 General. If during the inspection of a premises, a building or structure or any building system, in whole or in part, constitutes a clear and inimical threat to human life, safety or health, the code official shall issue such notice or orders to remove or remedy the conditions as shall be deemed necessary in accordance with this section and shall refer the building to the building department for any repairs, alterations, remodeling, removing or demolition required.

110.1.1 Unsafe conditions. Structures or existing equipment that are or hereafter become unsafe or deficient because of inadequate means of egress or which constitute a fire hazard, or are otherwise dangerous to human life or the public welfare, or which involve illegal or improper occupancy or inadequate maintenance, shall be deemed an unsafe condition. A vacant structure which is not secured against unauthorized entry as required by Section 311 shall be deemed unsafe.

110.1.2 Structural hazards. When an apparent structural hazard is caused by the faulty installation, operation or malfunction of any of the items or devices governed by this code, the code official shall immediately notify the building code official in accordance with Section 110.1.

110.2 Evacuation. The code official or the fire department official in charge of an incident shall be authorized to order the immediate evacuation of any occupied building deemed unsafe when such building has hazardous conditions that present imminent danger to building occupants. Persons so notified shall immediately leave the structure or premises and shall not enter or re-enter until authorized to do so by the code official or the fire department official in charge of the incident.

110.3 Summary abatement. Where conditions exist that are deemed hazardous to life and property, the code official or fire department official in charge of the incident is authorized to abate summarily such hazardous conditions that are in violation of this code.

110.4 Abatement. The owner, operator, or occupant of a building or premises deemed unsafe by the code official shall abate or cause to be abated or corrected such unsafe conditions either by repair, rehabilitation, demolition, or other approved corrective action.

SECTION 111 STOP WORK ORDER

111.1 Order. Whenever the code official finds any work regulated by this code being performed in a manner contrary to the provisions of this code or in a dangerous or unsafe manner, the code official is authorized to issue a stop work order.

111.2 Issuance. A stop work order shall be in writing and shall be given to the owner of the property, or to the owner's agent, or to the person doing the work. Upon issuance of a stop work order, the cited work shall immediately cease. The stop work or-

der shall state the reason for the order, and the conditions under which the cited work is authorized to resume.

111.3 Emergencies. Where an emergency exists, the code official shall not be required to give a written notice prior to stopping the work.

111.4 Failure to comply. Any person who shall continue any work after having been served with a stop work order, except such work as that person is directed to perform to remove a violation or unsafe condition, shall be liable to a fine of not less than [AMOUNT] dollars or more than [AMOUNT] dollars.

CHAPTER 2

DEFINITIONS

SECTION 201 GENERAL

201.1 Scope. Unless otherwise expressly stated, the following words and terms shall, for the purposes of this code, have the meanings shown in this chapter.

201.2 Interchangeability. Words used in the present tense include the future; words stated in the masculine gender include the feminine and neuter; the singular number includes the plural and the plural, the singular.

201.3 Terms defined in other codes. Where terms are not defined in this code and are defined in the *International Building Code*, *International Fuel Gas Code*, *International Mechanical Code* or *International Plumbing Code*, such terms shall have the meanings ascribed to them as in those codes.

201.4 Terms not defined. Where terms are not defined through the methods authorized by this section, such terms shall have ordinarily accepted meanings such as the context implies.

SECTION 202 GENERAL DEFINITIONS

[B] ACCESSIBLE MEANS OF EGRESS. See Section 1002.1.

AEROSOL. See Section 2802.1.

Level 1 aerosol products. See Section 2802.1.

Level 2 aerosol products. See Section 2802.1.

Level 3 aerosol products. See Section 2802.1.

AEROSOL CONTAINER. See Section 2802.1.

AEROSOL WAREHOUSE. See Section 2802.1.

AGENT. A person who shall have charge, care or control of any structure as owner, or agent of the owner, or as executor, executrix, administrator, administratrix, trustee or guardian of the estate of the owner. Any such person representing the actual owner shall be bound to comply with the provisions of this code to the same extent as if that person was the owner.

AIR-SUPPORTED STRUCTURE. See Section 2402.1.

AIRCRAFT OPERATION AREA (AOA). See Section 1102.1.

AIRPORT. See Section 1102.1.

[B] AISLE ACCESSWAY. See Section 1002.1.

ALARM NOTIFICATION APPLIANCE. See Section 902.1.

ALARM SIGNAL. See Section 902.1.

ALARM VERIFICATION FEATURE. See Section 902.1.

[B] ALTERNATING TREAD DEVICE. See Section 1002.1.

AMMONIUM NITRATE. See Section 3302.1.

ANNUNCIATOR. See Section 902.1.

APPROVED. Acceptable to the code official.

[B] AREA OF REFUGE. See Section 1002.1.

ARRAY. See Section 2302.1.

ARRAY, CLOSED. See Section 2302.1.

AUDIBLE ALARM NOTIFICATION APPLIANCE. See Section 902.1.

AUTOMATIC. See Section 902.1.

AUTOMATIC FIRE-EXTINGUISHING SYSTEM. See Section 902.1.

AUTOMATIC SPRINKLER SYSTEM. See Section 902.1.

AUTOMOTIVE SERVICE STATION. See Section 2202.1.

AVERAGE AMBIENT SOUND LEVEL. See Section 902.1.

BARRICADE. See Section 3302.1.

Artificial barricade. See Section 3302.1.

Natural barricade. See Section 3302.1.

BARRICADED. See Section 3302.1.

BATTERY, LEAD ACID. See Section 602.1.

BATTERY SYSTEM, STATIONARY LEAD ACID. See Section 602.1.

BIN BOX. See Section 2302.1.

BLAST AREA. See Section 3302.1.

BLAST SITE. See Section 3302.1.

BLASTER. See Section 3302.1.

BLASTING AGENT. See Section 3302.1.

[B] BLEACHERS. See Section 1002.1.

BOILING POINT. See Section 2702.1.

BONFIRE. See Section 302.1.

BRITISH THERMAL UNIT (BTU). The heat necessary to raise the temperature of 1 pound (0.454 kg) of water by 1°F (0.5565°C).

BULK OXYGEN SYSTEM. See Section 4002.1.

BULK PLANT OR TERMINAL. See Section 3402.1.

BULK TRANSFER. See Section 3402.1.

BULLET RESISTANT. See Section 3302.1.

CANOPY. See Section 2402.1.

CARBON DIOXIDE EXTINGUISHING SYSTEM. See Section 902.1.

CARTON. A cardboard or fiberboard box enclosing a product.

CEILING LIMIT. See Section 2702.1.

CHEMICAL. See Section 2702.1.