

Michigan Plumbing Code

Incorporating the 2006 edition of the
International Plumbing Code

2006

**Michigan Department of Labor & Economic Growth
Bureau of Construction Codes**



Michigan Plumbing Code

Incorporating the 2006 edition of the
International Plumbing Code

2006

**Michigan Department of Labor & Economic Growth
Bureau of Construction Codes**



2006 Michigan Plumbing Code

First Printing

ISBN-13: 978-1-58001-638-4

COPYRIGHT© 2007
by
INTERNATIONAL CODE COUNCIL, INC.

ALL RIGHTS RESERVED. This 2006 *Michigan Plumbing Code* contains substantial copyrighted material from the 2006 *International Plumbing Code*, Third Printing which is a copyrighted work owned by the International Code Council, Inc. Without advance written permission from the copyright owner, no part of this book may be reproduced, distributed or transmitted in any form or by any means, including, without limitation, electronic, optical or mechanical means (by way of example and not limitation, photocopying, or recording by or in an information storage retrieval system). For information on permission to copy material exceeding fair use, please contact: Publications, 4051 West Flossmoor Road, Country Club Hills, IL 60478. Phone 1-888-ICC-SAFE (422-7233).

Trademarks: "International Code Council," the "International Code Council" logo and the "International Plumbing Code" are trademarks of the International Code Council, Inc.

PRINTED IN THE U.S.A.

PREFACE

Introduction

Internationally, code officials recognize the need for a modern, up-to-date plumbing code addressing the design and installation of plumbing systems through requirements emphasizing performance. The *International Plumbing Code*®, in this 2006 edition, is designed to meet these needs through model code regulations that safeguard the public health and safety in all communities, large and small.

This comprehensive plumbing code establishes minimum regulations for plumbing systems using prescriptive and performance-related provisions. It is founded on broad-based principles that make possible the use of new materials and new plumbing designs. This 2006 edition is fully compatible with all the *International Codes*® (I-Codes®) published by the International Code Council (ICC)®, including the *International Building Code*®, *International Energy Conservation Code*®, *International Existing Building Code*®, *International Fire Code*®, *International Fuel Gas Code*®, *International Mechanical Code*®, *ICC Performance Code*®, *International Private Sewage Disposal Code*®, *International Property Maintenance Code*®, *International Residential Code*®, *International Wildland-Urban Interface Code*™ and *International Zoning Code*®.

The *International Plumbing Code* provisions provide many benefits, among which is the model code development process that offers an international forum for plumbing professionals to discuss performance and prescriptive code requirements. This forum provides an excellent arena to debate proposed revisions. This model code also encourages international consistency in the application of provisions.

Development

The first edition of the *International Plumbing Code* (1995) was the culmination of an effort initiated in 1994 by a development committee appointed by the ICC and consisting of representatives of the three statutory members of the International Code Council at that time, including: Building Officials and Code Administrators International, Inc. (BOCA), International Conference of Building Officials (ICBO) and Southern Building Code Congress International (SBCCI). The intent was to draft a comprehensive set of regulations for plumbing systems consistent with and inclusive of the scope of the existing model codes. Technical content of the latest model codes promulgated by BOCA, ICBO and SBCCI was utilized as the basis for the development. This 2006 edition presents the code as originally issued, with changes as reflected in the subsequent editions through 2003 and with changes approved through the ICC Code Development Process through 2005. A new edition such as this is promulgated every three years.

This code is founded on principles intended to establish provisions consistent with the scope of a plumbing code that adequately protects public health, safety and welfare; provisions that do not unnecessarily increase construction costs; provisions that do not restrict the use of new materials, products or methods of construction; and provisions that do not give preferential treatment to particular types or classes of materials, products or methods of construction.

Adoption

The *International Plumbing Code* is available for adoption and use by jurisdictions internationally. Its use within a governmental jurisdiction is intended to be accomplished through adoption by reference in accordance with proceedings establishing the jurisdiction's laws. At the time of adoption, jurisdictions should insert the appropriate information in provisions requiring specific local information, such as the name of the adopting jurisdiction. These locations are shown in bracketed words in small capital letters in the code and in the sample ordinance. The sample adoption ordinance on page v addresses several key elements of a code adoption ordinance, including the information required for insertion into the code text.

Maintenance

The *International Plumbing Code* is kept up to date through the review of proposed changes submitted by code enforcing officials, industry representatives, design professionals and other interested parties. Proposed changes are carefully considered through an open code development process in which all interested and affected parties may participate.

The contents of this work are subject to change both through the Code Development Cycles and the governmental body that enacts the code into law. For more information regarding the code development process, contact the Code and Standard Development Department of the International Code Council.

While the development procedure of the *International Plumbing Code* ensures the highest degree of care, ICC and ICC's members and those participating in the development of this code do not accept any liability resulting from compliance or noncompliance with the provisions, since ICC and its members do not have the power or authority to police or enforce compliance with the contents of this code. Only the governmental body that enacts the code into law has such authority.

Letter Designations in Front of Section Numbers

In each code development cycle, proposed changes to the code are considered at the Code Development Hearings by the ICC Plumbing Code Development Committee, whose action constitutes a recommendation to the voting membership for final action on the proposed change. Proposed changes to a code section that has a number beginning with a letter in brackets are considered by a different code development committee. For example, proposed changes to code sections that have [B] in front of them (e.g. [B] 309.2) are considered by the ICC Building Code Development Committee at the code development hearings.

The content of sections in this code that begin with a letter designation are maintained by another code development committee in accordance with the following:

- [B] = International Building Code Development Committee;
- [E] = International Energy Conservation Code Development Committee;
- [F] = International Fire Code Development Committee;
- [M] = International Mechanical Code Development Committee.

Marginal Markings

Solid vertical lines in the margins within the body of the code indicate a change from the requirements of the 2003 edition except where a change was minor. Deletion indicators (■) are provided in the margin where a paragraph or item listing has been deleted if the deletion resulted in a change of requirements. Double vertical lines in the margin denote amendments and additions promulgated by the State of Michigan Department of Labor and Economic Growth, modifying the *2006 International Plumbing Code*. An asterisk in the margin identifies sections of the *2006 International Plumbing Code* not adopted by the State of Michigan.

SAMPLE ORDINANCE STATE CODE

Ordinance Number

An ordinance to designate an enforcing agency to discharge the responsibility of the _____ (County, City, Village or Township) of _____ (Name of Unit of Government) located in _____ County, under the provisions of the Stille-DeRossett-Hale Single State Construction Code Act, 1972 PA 230, MCL 125.1501 et seq.

The _____ (County, City, Village, or Township) of _____ (Name of Unit of Government) ordains:

Section 1. AGENCY DESIGNATED. Pursuant to the provisions of the Michigan _____ (Building, Electrical, Mechanical or Plumbing) Code, in accordance with Section 8b(6) of 1972 PA 230, the (Building, Electrical, Mechanical, or Plumbing) Code Official of the _____ (County, City, Village or Township) of _____ (Name of Unit of Government) is hereby designated as the enforcing agency to discharge the responsibility of the _____ (County, City, Village, or Township) of _____ (Name of Unit of Government) under 1972 PA 230, State of Michigan. The _____ (County, City, Village, or Township) of _____ (Name of Unit of Government) assumes responsibility for the administration and enforcement of said Act throughout its corporate limits.

Section 2. REPEALS. All ordinances inconsistent with the provisions of this ordinance are hereby repealed.

Section 3. PUBLICATION. This ordinance shall be effective after legal publication and in accordance with provisions of the Act governing same.

Adopted this _____ day of _____, _____ (Year). This ordinance duly adopted on _____ at a regular meeting of the _____ (adopting body) and will become effective _____.

Date: _____, _____ (Year).

Signed: _____

Clerk of the _____ (County, City, Village, or Township) of _____ (Name of Unit of Government).

Attested: _____ (Chair, Mayor, Supervisor or President) of the _____ (County, City, Village, or Township) of _____ (Name of Unit of Government).

This is a preview of "ICC MI-IPC-2006". Click [here](#) to purchase the full version from the ANSI store.

TABLE OF CONTENTS

CHAPTER 1 ADMINISTRATION	1	405 Installation of Fixtures	27
Section		406 Automatic Clothes Washers	28
101 General	1	407 Bathtubs	28
102 Applicability	1	408 Bidets	28
103 Department of Plumbing Inspection	2	409 Dishwashing Machines	28
104 Duties and Powers of the Code Official	2	410 Drinking Fountains	28
105 Approval	2	411 Emergency Showers and Eyewash Stations	28
106 Permits	3	412 Floor and Trench Drains	28
107 Inspections and Testing	4	413 Food Waste Grinder Units	29
108 Violations	5	414 Garbage Can Washers	29
109 Means of Appeal	6	415 Laundry Trays	29
CHAPTER 2 DEFINITIONS	7	416 Lavatories	29
Section		417 Showers	29
201 General	7	418 Sinks	30
202 General Definitions	7	419 Urinals	30
CHAPTER 3 GENERAL REGULATIONS	15	420 Water Closets	30
Section		421 Whirlpool Bathtubs	31
301 General	15	422 Health Care Fixtures and Equipment	31
302 Exclusion of Materials Detrimental to the Sewer System	15	423 Specialty Plumbing Fixtures	32
303 Materials	15	424 Faucets and Other Fixture Fittings	32
304 Rodentproofing	16	425 Flushing Devices for Water Closets and Urinals	32
305 Protection of Pipes and Plumbing System Components	16	426 Manual Food and Beverage Dispensing Equipment	33
306 Trenching, Excavation and Backfill	17	427 Floor Sinks	33
307 Structural Safety	17	CHAPTER 5 WATER HEATERS	35
308 Piping Support	18	Section	
309 Flood Hazard Resistance	18	501 General	35
310 Washroom and Toilet Room Requirements	19	502 Installation	35
311 Toilet Facilities for Workers	19	503 Connections	35
312 Tests and Inspections	19	504 Safety Devices	35
313 Equipment Efficiencies	20	505 Insulation	36
314 Condensate Disposal	20	CHAPTER 6 WATER SUPPLY AND DISTRIBUTION	37
CHAPTER 4 FIXTURES, FAUCETS AND FIXTURE FITTINGS	23	Section	
Section		601 General	37
401 General	23	602 Water Required	37
402 Fixture Materials	23	603 Water Service	37
403 Minimum Plumbing Facilities	23	604 Design of Building Water Distribution System	37
404 Accessible Plumbing Facilities	27	605 Materials, Joints and Connections	39

This is a preview of "ICC MI-IPC-2006". Click here to purchase the full version from the ANSI store.

606	Installation of the Building Water Distribution System	44
607	Hot Water Supply System	45
608	Protection of Potable Water Supply	46
609	Health Care Plumbing	50
610	Disinfection of Potable Water System	50
611	Drinking Water Treatment Units	50
612	Solar Systems	50
613	Temperature Control Devices and Valves	51

CHAPTER 7 SANITARY DRAINAGE..... 53

Section

701	General	53
702	Materials	53
703	Building Sewer	55
704	Drainage Piping Installation	55
705	Joints	55
706	Connections Between Drainage Piping and Fittings	58
707	Prohibited Joints and Connections	59
708	Cleanouts	59
709	Fixture Units	60
710	Drainage System Sizing	60
711	Offsets in Drainage Piping in Buildings of Five Stories or More	60
712	Sumps and Ejectors	63
713	Health Care Plumbing	64
714	Computerized Drainage Design	65
715	Backwater Valves	65

CHAPTER 8 INDIRECT/SPECIAL WASTE 67

Section

801	General	67
802	Indirect Wastes	67
803	Special Wastes	68
804	Materials, Joints and Connections	68

CHAPTER 9 VENTS..... 69

Section

901	General	69
902	Materials	69
903	Outdoor Vent Extension	69
904	Vent Terminals	69
905	Vent Connections and Grades	70
906	Fixture Vents	70
907	Individual Vent	70

908	Common Vent	70
909	Wet Venting	70
910	Waste Stack Vent	71
911	Circuit Venting	71
912	Combination Drain And Vent System	72
913	Island Fixture Venting	72
914	Relief Vents—Stacks of More Than 10 Branch Intervals	72
915	Vents for Stack Offsets	73
916	Vent Pipe Sizing	73
917	Air Admittance Valves	74
918	Engineered Vent Systems	75
919	Computerized Vent Design	75

CHAPTER 10 TRAPS, INTERCEPTORS AND SEPARATORS 77

Section

1001	General	77
1002	Trap Requirements	77
1003	Interceptors and Separators	77
1004	Materials, Joints and Connections	79

CHAPTER 11 STORM DRAINAGE..... 81

Section

1101	General	81
1102	Materials	81
1103	Traps	82
1104	Conductors and Connections	82
1105	Roof Drains	82
1106	Size of Conductors, Leaders and Storm Drains	82
1107	Secondary (Emergency) Roof Drains	89
1108	Combined Sanitary and Storm System	89
1109	Values for Continuous Flow	89
1110	Controlled Flow Roof Drain Systems	89
1111	Subsoil Drains	89
1112	Building Subdrains	89
1113	Sumps and Pumping Systems	89

CHAPTER 12 SPECIAL PIPING AND STORAGE SYSTEMS 91

Section

1201	General	91
1202	Medical Gases	91
1203	Oxygen Systems	91

This is a preview of "ICC MI-IPC-2006". Click [here](#) to purchase the full version from the ANSI store.

CHAPTER 13 REFERENCED STANDARDS	93
APPENDIX B RATES OF RAINFALL FOR VARIOUS CITIES	101
APPENDIX C GRAY WATER RECYCLING SYSTEMS	103
Section	
C101 General	103
C102 Systems for Flushing Water Closets and Urinals	103
C103 Subsurface Landscape Irrigation Systems	104
APPENDIX D DEGREE DAY AND DESIGN TEMPERATURES	109
APPENDIX F STRUCTURAL SAFETY	115
Section	
F101 Cutting, Notching and Boring in Wood Members	115
APPENDIX G VACUUM DRAINAGE SYSTEM ..	117
INDEX.....	119

This is a preview of "ICC MI-IPC-2006". Click [here](#) to purchase the full version from the ANSI store.

CHAPTER 1

ADMINISTRATION

SECTION 101 GENERAL

101.1 Title. This part shall be known as the Michigan plumbing code and is hereinafter referred to as “the plumbing code” or “the code.” This part shall control all matters concerning the installation, replacement, alteration, relocation, and use of plumbing systems or plumbing materials as herein defined and shall apply to existing or proposed buildings and structures in the state.

R 408.30711

101.2 Scope. The design and installation of plumbing systems, including sanitary and storm drainage, sanitary facilities, medical gas systems, water supplies, storm water and sewage disposal in buildings, shall comply with the requirements of the code. The design and installation of gas piping, chilled water piping in connection with refrigeration process and comfort cooling, and hot water piping in connection with building heating systems shall conform to the requirements of the Michigan mechanical code. The design and installation of all fire sprinkler systems and standpipe systems shall conform to the requirements of the Michigan building code. Water and drainage connections to such installations shall be made in accordance with the requirements of the code.

Exception: Plumbing facilities within 1- and 2-family dwellings shall be constructed and maintained in accordance with the Michigan residential code for 1- and 2-family dwellings.

R 408.30711

101.3 Intent. The purpose of this code is to provide minimum standards to safeguard life or limb, health, property and public welfare by regulating and controlling the design, construction, installation, quality of materials, location, operation and maintenance or use of plumbing equipment and systems.

101.4 Severability. If any section, subsection, sentence, clause or phrase of this code is for any reason held to be unconstitutional, such decision shall not affect the validity of the remaining portions of this code.

SECTION 102 APPLICABILITY

102.1 General. The provisions of this code shall apply to all matters affecting or relating to structures, as set forth in Section 101. Where, in any specific case, different sections of this code specify different materials, methods of construction or other requirements, the most restrictive shall govern.

102.2 Existing installations. Plumbing systems lawfully in existence at the time of the adoption of this code shall be permitted to have their use and maintenance continued if the use, maintenance or repair is in accordance with the original design

and no hazard to life, health or property is created by such plumbing system.

102.3 Maintenance. All plumbing systems, materials and appurtenances, both existing and new, and all parts thereof, shall be maintained in proper operating condition in accordance with the original design in a safe and sanitary condition. All devices or safeguards required by this code shall be maintained in compliance with the code edition under which they were installed.

The owner or the owner’s designated agent shall be responsible for maintenance of plumbing systems. To determine compliance with this provision, the code official shall have the authority to require any plumbing system to be reinspected.

102.4 Additions, alterations or repairs. Additions, alterations, renovations or repairs to any plumbing system shall conform to that required for a new plumbing system without requiring the existing plumbing system to comply with all the requirements of this code. Additions, alterations or repairs shall not cause an existing system to become unsafe, insanitary or overloaded.

Minor additions, alterations, renovations and repairs to existing plumbing systems shall be permitted in the same manner and arrangement as in the existing system, provided that such repairs or replacement are not hazardous and are approved.

102.5 Change in occupancy. It shall be unlawful to make any change in the occupancy of any structure that will subject the structure to any special provision of this code without approval of the code official. The code official shall certify that such structure meets the intent of the provisions of law governing building construction for the proposed new occupancy and that such change of occupancy does not result in any hazard to the public health, safety or welfare.

102.6 Historic buildings. The provisions of this code relating to the construction, alteration, repair, enlargement, restoration, relocation or moving of buildings or structures shall not be mandatory for existing buildings or structures identified and classified by the state or local jurisdiction as historic buildings when such buildings or structures are judged by the code official to be safe and in the public interest of health, safety and welfare regarding any proposed construction, alteration, repair, enlargement, restoration, relocation or moving of buildings.

102.7 Moved buildings. Except as determined by Section 102.2, plumbing systems that are a part of buildings or structures moved into or within the jurisdiction shall comply with the provisions of this code for new installations.

102.8 Referenced codes and standards. The codes and standards referenced in this code shall be those that are listed in Chapter 13 and such codes and standards shall be considered as part of the requirements of this code to the prescribed extent of each such reference. Where differences occur between provi-

sions of this code and the referenced standards, the provisions of this code shall be the minimum requirements.

102.9 Requirements not covered by code. Any requirements necessary for the strength, stability or proper operation of an existing or proposed plumbing system, or for the public safety, health and general welfare, not specifically covered by this code shall be determined by the code official.

SECTION 103 DEPARTMENT OF PLUMBING INSPECTION

103.1 General. The position of plumbing inspector is created. The plumbing inspector shall be appointed in accordance with 1986 PA 54, MCL 338.2301 et seq.

R 408.30714

* **103.3 Deputies.** In accordance with the prescribed procedures of this jurisdiction and with the concurrence of the appointing authority, the code official shall have the authority to appoint a deputy code official, other related technical officers, inspectors and other employees.

*

SECTION 104 DUTIES AND POWERS OF THE CODE OFFICIAL

104.1 General. The code official shall enforce all of the provisions of the code and shall act on any question relative to the installation, alteration, repair, maintenance, or operation of all plumbing systems, devices, and equipment except as specifically provided for by statutory requirements or as provided for in sections 104.3 through 104.8.

R 408.30717

* **104.3 Applications and permits.** The code official shall receive applications and issue permits for the installation and alteration of plumbing, inspect the premises for which such permits have been issued, and enforce compliance with the provisions of this code.

104.4 Inspections. The code official shall make all the required inspections, or shall accept reports of inspection by approved agencies or individuals. All reports of such inspections shall be in writing and be certified by a responsible officer of such approved agency or by the responsible individual. The code official is authorized to engage such expert opinion as deemed necessary to report on unusual technical issues that arise, subject to the approval of the appointing authority.

104.5 Right of entry. In the discharge of duties, the code official may enter any building, structure, or premises in the jurisdiction to enforce the provisions of the act and the code.

R 408.30717

104.6 Identification. The code official shall carry proper identification when inspecting structures or premises in the performance of duties under this code.

104.7 Notices and orders. The code official shall issue all necessary notices or orders to ensure compliance with this code.

104.8 Department records. The code official shall keep official records of applications received, permits and certificates issued, fees collected, reports of inspections, and notices and

orders issued. Such records shall be retained in the official records as long as the building or structure to which such records relate remains in existence unless otherwise provided for by other regulations.

SECTION 105 APPROVAL

105.1 Modifications. Whenever there are practical difficulties involved in carrying out the provisions of this code, the code official shall have the authority to grant modifications for individual cases, provided the code official shall first find that special individual reason makes the strict letter of this code impractical and the modification is in conformity with the intent and purpose of this code and that such modification does not lessen health, life and fire safety requirements. The details of action granting modifications shall be recorded and entered in the files of the plumbing inspection department.

105.2 Alternative materials, methods and equipment. The provisions of this code are not intended to prevent the installation of any material or to prohibit any method of construction not specifically prescribed by this code, provided that any such alternative has been approved. An alternative material or method of construction shall be approved where the code official finds that the proposed design is satisfactory and complies with the intent of the provisions of this code, and that the material, method or work offered is, for the purpose intended, at least the equivalent of that prescribed in this code in quality, strength, effectiveness, fire resistance, durability and safety.

105.3 Required testing. Whenever there is insufficient evidence of compliance with the provisions of this code, or evidence that a material or method does not conform to the requirements of this code, or in order to substantiate claims for alternate materials or methods, the code official shall have the authority to require tests as evidence of compliance to be made at no expense to the jurisdiction.

105.3.1 Test methods. Test methods shall be as specified in this code or by other recognized test standards. In the absence of recognized and accepted test methods, the code official shall approve the testing procedures.

105.3.2 Testing agency. All tests shall be performed by an approved agency.

105.3.3 Test reports. Reports of tests shall be retained by the code official for the period required for retention of public records.

105.4 Alternative engineered design. The design, documentation, inspection, testing and approval of an alternative engineered design plumbing system shall comply with Sections 105.4.1 through 105.4.6.

105.4.1 Design criteria. An alternative engineered design shall conform to the intent of the provisions of this code and shall provide an equivalent level of quality, strength, effectiveness, fire resistance, durability and safety. Material, equipment or components shall be designed and installed in accordance with the manufacturer's installation instructions.

105.4.2 Submittal. The registered design professional shall indicate on the permit application that the plumbing system is an alternative engineered design. The permit and permanent permit records shall indicate that an alternative engineered design was part of the approved installation.

105.4.3 Technical data. The registered design professional shall submit sufficient technical data to substantiate the proposed alternative engineered design and to prove that the performance meets the intent of this code.

105.4.4 Construction documents. The registered design professional shall submit to the code official two complete sets of signed and sealed construction documents for the alternative engineered design. The construction documents shall include floor plans and a riser diagram of the work. Where appropriate, the construction documents shall indicate the direction of flow, all pipe sizes, grade of horizontal piping, loading, and location of fixtures and appliances.

105.4.5 Design approval. Where the code official determines that the alternative engineered design conforms to the intent of this code, the plumbing system shall be approved. If the alternative engineered design is not approved, the code official shall notify the registered design professional in writing, stating the reasons thereof.

105.4.6 Inspection and testing. The alternative engineered design shall be tested and inspected in accordance with the requirements of Sections 107 and 312.

105.5 Material and equipment reuse. Materials, equipment and devices shall not be reused unless such elements have been reconditioned, tested, placed in good and proper working condition and approved.

SECTION 106 PERMITS

106.1 When required. Any owner, authorized agent or contractor who desires to construct, enlarge, alter, repair, move, demolish or change the occupancy of a building or structure, or to erect, install, enlarge, alter, repair, remove, convert or replace any plumbing system, the installation of which is regulated by this code, or to cause any such work to be done, shall first make application to the code official and obtain the required permit for the work.

106.2 Exempt work. The following work shall be exempt from the requirement for a permit:

1. The stopping of leaks in drains, water, soil, waste or vent pipe provided, however, that if any concealed trap, drainpipe, water, soil, waste or vent pipe becomes defective and it becomes necessary to remove and replace the same with new material, such work shall be considered as new work and a permit shall be obtained and inspection made as provided in this code.
2. The clearing of stoppages or the repairing of leaks in pipes, valves or fixtures, and the removal and reinstallation of water closets, provided such repairs do not involve or require the replacement or rearrangement of valves, pipes or fixtures.

Exemption from the permit requirements of this code shall not be deemed to grant authorization for any work to be done in violation of the provisions of this code or any other laws or ordinances of this jurisdiction.

106.3 Application for permit. Each application for a permit, with the required fee, shall be filed with the code official on a form furnished for that purpose and shall contain a general description of the proposed work and its location. The application shall be signed by the owner or an authorized agent. The permit application shall indicate the proposed occupancy of all parts of the building and of that portion of the site or lot, if any, not covered by the building or structure and shall contain such other information required by the code official.

106.3.1 Construction documents. Construction documents, engineering calculations, diagrams and other such data shall be submitted in two or more sets with each application for a permit. The code official shall require construction documents, computations and specifications to be prepared and designed by a registered design professional when required by state law. Construction documents shall be drawn to scale and shall be of sufficient clarity to indicate the location, nature and extent of the work proposed and show in detail that the work conforms to the provisions of this code. Construction documents for buildings more than two stories in height shall indicate where penetrations will be made for pipe, fittings and components and shall indicate the materials and methods for maintaining required structural safety, fire-resistance rating and fireblocking.

Exception: The code official shall have the authority to waive the submission of construction documents, calculations or other data if the nature of the work applied for is such that reviewing of construction documents is not necessary to determine compliance with this code.

106.4 By whom application is made. Application for a permit shall be made by a plumbing contractor licensed in accordance with 2002 PA 733, MCL 338.3511 et seq.

Exceptions:

1. Water service permits.
2. Building sewer and private sewer permits.
3. Minor repair.

R 408.30715

Rule 792 Plumbing contractor.

- (1) To obtain plumbing permits, an applicant shall do all of the following:
 - (a) Be a plumbing contractor in this state.
 - (b) Be active in the business of serving the public as a plumbing contractor in a county, city, village, or township in this state.
 - (c) Operate 1 or more branches in this state bearing the same firm name, when a licensed master plumber is in charge and has the responsibility of supervision at each branch. The names of the authorized master plumbers representing a firm shall be on record with the state plumbing board.

- (2) To become a plumbing contractor, an application shall be made on a form furnished by the state plumbing board and filed with the board at Okemos, Michigan. An incomplete application will be returned to the applicant.

R 408.30792

106.5 Permit issuance. The application, construction documents and other data filed by an applicant for permit shall be reviewed by the code official. If the code official finds that the proposed work conforms to the requirements of this code and all laws and ordinances applicable thereto, and that the fees specified in Section 106.6 have been paid, a permit shall be issued to the applicant.

106.5.1 Approved construction documents. When the code official issues the permit where construction documents are required, the construction documents shall be endorsed in writing and stamped "APPROVED." Such approved construction documents shall not be changed, modified or altered without authorization from the code official. All work shall be done in accordance with the approved construction documents.

The code official shall have the authority to issue a permit for the construction of a part of a plumbing system before the entire construction documents for the whole system have been submitted or approved, provided adequate information and detailed statements have been filed complying with all pertinent requirements of this code. The holders of such permit shall proceed at their own risk without assurance that the permit for the entire plumbing system will be granted.

106.5.2 Validity. The issuance of a permit or approval of construction documents shall not be construed to be a permit for, or an approval of, any violation of any of the provisions of this code or any other ordinance of the jurisdiction. No permit presuming to give authority to violate or cancel the provisions of this code shall be valid.

The issuance of a permit based upon construction documents and other data shall not prevent the code official from thereafter requiring the correction of errors in said construction documents and other data or from preventing building operations being carried on thereunder when in violation of this code or of other ordinances of this jurisdiction.

106.5.3 Expiration. Each permit issued by the code official under the provisions of the code shall expire by limitation and become null and void if the work authorized by such permit is not commenced within 180 days from the date of such permit, or if the work authorized by such permit is suspended or abandoned at any time after the work is commenced for a period of 180 days. Before such work may be recommenced, a new permit shall be first obtained for such work, provided no changes have been made or will be made in the original construction document for such work and provided further that such suspension or abandonment has not exceeded 1 year.

106.5.4 Extensions. Any permittee holding an unexpired permit shall have the right to apply for an extension of the time within which the permittee will commence work under

that permit when work is unable to be commenced within the time required by this section for good and satisfactory reasons. The code official shall extend the time for action by the permittee for a period not exceeding 180 days if there is reasonable cause. No permit shall be extended more than once.

R 408.30715

106.5.5 Suspension or revocation of permit. The code official shall revoke a permit or approval issued under the provisions of this code in case of any false statement or misrepresentation of fact in the application or on the construction documents upon which the permit or approval was based.

106.5.6 Retention of construction documents. One set of construction documents shall be retained by the code official until final approval of the work covered therein. One set of approved construction documents shall be returned to the applicant, and said set shall be kept on the site of the building or work at all times during which the work authorized thereby is in progress.

106.6 Fees. The fees prescribed by the act shall be paid to the enforcing agency of the jurisdiction before a permit to begin work for new construction, alteration, removal, demolition, or other building operation may be issued. In addition, an amendment to a permit necessitating an additional fee shall not be approved until the additional fee is paid.

R 408.30716

*

SECTION 107 INSPECTIONS AND TESTING

107.1 Required inspections and testing. The code official, upon notification from the permit holder or the permit holder's agent, shall make the following inspections and such other inspections as necessary, and shall either release that portion of the construction or shall notify the permit holder or an agent of any violations that must be corrected. The holder of the permit shall be responsible for the scheduling of such inspections.

1. Underground inspection shall be made after trenches or ditches are excavated and bedded, piping installed, and before any backfill is put in place.
2. Rough-in inspection shall be made after the roof, framing, fireblocking, firestopping, draftstopping and bracing is in place and all sanitary, storm and water distribution piping is roughed-in, and prior to the installation of wall or ceiling membranes.
3. Final inspection shall be made after the building is complete, all plumbing fixtures are in place and properly connected, and the structure is ready for occupancy.

107.1.1 Approved agencies. Test reports submitted to the code official for consideration shall be developed by approved agencies that have satisfied the requirements as to qualifications and reliability.

107.2 Special inspections. Special inspections of alternative engineered design plumbing systems shall be conducted in accordance with Sections 107.2.1 and 107.2.2.

*

107.2.1 Periodic inspection. The registered design professional or designated inspector shall periodically inspect and observe the alternative engineered design to determine that the installation is in accordance with the approved construction documents. All discrepancies shall be brought to the immediate attention of the plumbing contractor for correction. Records shall be kept of all inspections.

107.2.2 Written report. The registered design professional shall submit a final report in writing to the code official upon completion of the installation, certifying that the alternative engineered design conforms to the approved construction documents. A notice of approval for the plumbing system shall not be issued until a written certification has been submitted.

107.3 Testing. Plumbing work and systems shall be tested as required in Section 312 and in accordance with Sections 107.3.1 through 107.3.3. Tests shall be made by the permit holder and observed by the code official.

107.3.1 New, altered, extended or repaired systems. New plumbing systems and parts of existing systems that have been altered, extended or repaired shall be tested as prescribed herein to disclose leaks and defects, except that testing is not required in the following cases:

1. In any case that does not include addition to, replacement, alteration or relocation of any water supply, drainage or vent piping.
2. In any case where plumbing equipment is set up temporarily for exhibition purposes.

107.3.2 Equipment, material and labor for tests. All equipment, material and labor required for testing a plumbing system or part thereof shall be furnished by the permit holder.

107.3.3 Reinspection and testing. Where any work or installation does not pass any initial test or inspection, the necessary corrections shall be made to comply with this code. The work or installation shall then be resubmitted to the code official for inspection and testing.

107.4 Approval. After the prescribed tests and inspections indicate that the work complies in all respects with this code, a notice of approval shall be issued by the code official.

107.5 Temporary connection. The code official shall have the authority to authorize the temporary connection of the building or system to the utility source for the purpose of testing plumbing systems or for use under a temporary certificate of occupancy.

SECTION 108 VIOLATIONS

108.1 Unlawful acts. It shall be unlawful for any person, firm or corporation to erect, construct, alter, repair, remove, demolish or utilize any plumbing system, or cause same to be done, in conflict with or in violation of any of the provisions of this code.

108.2 Notice of violation. The code official shall serve a notice of violation or order to the person responsible for the erection,

installation, alteration, extension, repair, removal or demolition of plumbing work in violation of the provisions of this code, or in violation of a detail statement or the approved construction documents thereunder, or in violation of a permit or certificate issued under the provisions of this code. Such order shall direct the discontinuance of the illegal action or condition and the abatement of the violation.

108.3 Prosecution of violation. If the notice of violation is not complied with promptly, the code official shall request the legal counsel of the jurisdiction to institute the appropriate proceeding at law or in equity to restrain, correct or abate such violation, or to require the removal or termination of the unlawful occupancy of the structure in violation of the provisions of this code or of the order or direction made pursuant thereto.

108.4 Violation penalties. A person who violates a provision of the code, who fails to conform with any of the requirements thereof, or who erects, installs, alters, or repairs plumbing work in violation of the approved construction documents or directive of the enforcing agency, or a permit or certificate issued under the provisions of the code shall be assessed a fine in accordance with the act and 2002 PA 733, MCL 338.3511 to 338.3569.

R 408.30718

108.5 Stop work orders. Upon notice from the enforcing agency of work on any plumbing system that is being done contrary to the provisions of the code or in a dangerous or unsafe manner, the work shall immediately cease. Notice shall be in accordance with the act. A person who is served with a stop work order, except for work that the person is directed to perform to remove a violation or unsafe condition is subject to the penalty provisions prescribed by the act.

R 408.30719

108.6 Abatement of violation. The imposition of the penalties herein prescribed shall not preclude the legal officer of the jurisdiction from instituting appropriate action to prevent unlawful construction or to restrain, correct or abate a violation, or to prevent illegal occupancy of a building, structure or premises, or to stop an illegal act, conduct, business or utilization of the plumbing on or about any premises.

108.7 Unsafe plumbing. Any plumbing regulated by this code that is unsafe or that constitutes a fire or health hazard, insanitary condition, or is otherwise dangerous to human life is hereby declared unsafe. Any use of plumbing regulated by this code constituting a hazard to safety, health or public welfare by reason of inadequate maintenance, dilapidation, obsolescence, fire hazard, disaster, damage or abandonment is hereby declared an unsafe use. Any such unsafe equipment is hereby declared to be a public nuisance and shall be abated by repair, rehabilitation, demolition or removal.

108.7.1 Authority to condemn equipment. Whenever the code official determines that any plumbing, or portion thereof, regulated by this code has become hazardous to life, health or property or has become insanitary, the code official shall order in writing that such plumbing either be removed or restored to a safe or sanitary condition. A time limit for compliance with such order shall be specified in the

written notice. No person shall use or maintain defective plumbing after receiving such notice.

When such plumbing is to be disconnected, written notice as prescribed in Section 108.2 shall be given. In cases of immediate danger to life or property, such disconnection shall be made immediately without such notice.

108.7.2 Authority to disconnect service utilities. The code official shall have the authority to authorize disconnection of utility service to the building, structure or system regulated by the technical codes in case of an emergency, where necessary, to eliminate an immediate danger to life or property. Where possible, the owner and occupant of the building, structure or service system shall be notified of the decision to disconnect utility service prior to taking such action. If not notified prior to disconnecting, the owner or occupant of the building, structure or service systems shall be notified in writing, as soon as practical thereafter.

108.7.3 Connection after order to disconnect. No person shall make connections from any energy, fuel, power supply or water distribution system or supply energy, fuel or water to any equipment regulated by this code that has been disconnected or ordered to be disconnected by the code official or the use of which has been ordered to be discontinued by the code official until the code official authorizes the reconnection and use of such equipment.

When any plumbing is maintained in violation of this code, and in violation of any notice issued pursuant to the provisions of this section, the code official shall institute any appropriate action to prevent, restrain, correct or abate the violation.

SECTION 109 MEANS OF APPEAL

109.1 Means of appeal. An interested person has the right to appeal a decision of the enforcing agency to the board of appeals in accordance with the act. An application for appeal shall be based on a claim that the true intent of the code or the rules governing construction have been incorrectly interpreted, the provisions of the code do not apply, or an equal or better form of construction is proposed. The decision of a local board of appeals may be appealed to the construction code commission in accordance with the act and time frames.

R 408.30720

*

CHAPTER 2

DEFINITIONS

SECTION 201 GENERAL

201.1 Scope. Unless otherwise expressly stated, the following words and terms shall, for the purposes of this code, have the meanings shown in this chapter.

201.2 Interchangeability. Words stated in the present tense include the future; words stated in the masculine gender include the feminine and neuter; the singular number includes the plural and the plural the singular.

201.3 Terms defined in other codes. Where terms are not defined in this code and are defined in the *International Building Code*, *International Fire Code*, *Michigan Electrical Code*, *International Fuel Gas Code* or the *International Mechanical Code*, such terms shall have the meanings ascribed to them as in those codes.

201.4 Terms not defined. Where terms are not defined through the methods authorized by this section, such terms shall have ordinarily accepted meanings such as the context implies.

SECTION 202 GENERAL DEFINITIONS

ACCEPTED ENGINEERING PRACTICE. That which conforms to accepted principles, tests or standards of nationally recognized technical or scientific authorities.

ACCESS (TO). That which enables a fixture, appliance or equipment to be reached by ready access or by a means that first requires the removal or movement of a panel, door or similar obstruction (see "Ready access").

ACCESS COVER. A removable plate, usually secured by bolts or screws, to permit access to a pipe or pipe fitting for the purposes of inspection, repair or cleaning.

ACT. "Act" means 1972 PA 230, MCL 125.1501 and known as the Stille-DeRossett-Hale single state construction code act.

R 408.30791

ADAPTER FITTING. An approved connecting device that suitably and properly joins or adjusts pipes and fittings which do not otherwise fit together.

AIR ADMITTANCE VALVE. One-way valve designed to allow air to enter the plumbing drainage system when negative pressures develop in the piping system. The device shall close by gravity and seal the vent terminal at zero differential pressure (no flow conditions) and under positive internal pressures. The purpose of an air admittance valve is to provide a method of allowing air to enter the plumbing drainage system without the use of a vent extended to open air and to prevent sewer gases from escaping into a building.

AIR BREAK (Drainage System). A piping arrangement in which a drain from a fixture, appliance or device discharges

indirectly into another fixture, receptacle or interceptor at a point below the flood level rim and above the trap seal.

AIR GAP (Drainage System). The unobstructed vertical distance through the free atmosphere between the outlet of the waste pipe and the flood level rim of the receptacle into which the waste pipe is discharging.

AIR GAP (Water Distribution System). The unobstructed vertical distance through the free atmosphere between the lowest opening from any pipe or faucet supplying water to a tank, plumbing fixture or other device and the flood level rim of the receptacle.

ALTERNATIVE ENGINEERED DESIGN. A plumbing system that performs in accordance with the intent of Chapters 3 through 12 and provides an equivalent level of performance for the protection of public health, safety and welfare. The system design is not specifically regulated by Chapters 3 through 12.

ANCHORS. See "Supports."

ANTISIPHON. A term applied to valves or mechanical devices that eliminate siphonage.

APPROVED. Acceptable to the code official or other authority having jurisdiction.

APPROVED AGENCY. An established and recognized agency approved by the code official and that is regularly engaged in conducting tests or furnishing inspection services.

AREA DRAIN. A receptacle designed to collect surface or storm water from an open area.

ASPIRATOR. A fitting or device supplied with water or other fluid under positive pressure that passes through an integral orifice or constriction, causing a vacuum. Aspirators are also referred to as suction apparatus, and are similar in operation to an ejector.

BACKFLOW. Pressure created by any means in the water distribution system, which by being in excess of the pressure in the water supply mains causes a potential backflow condition.

Backpressure, low head. A pressure less than or equal to 4.33 psi (29.88 kPa) or the pressure exerted by a 10-foot (3048 mm) column of water.

Backsiphonage. The backflow of potentially contaminated water into the potable water system as a result of the pressure in the potable water system falling below atmospheric pressure of the plumbing fixtures, pools, tanks or vats connected to the potable water distribution piping.

Backwater valve. A device or valve installed in the building drain or sewer pipe where a sewer is subject to backflow, and which prevents drainage or waste from backing up into a low level or fixtures and causing a flooding condition.

Drainage. A reversal of flow in the drainage system.