

This is a preview of "S+ IEC 60730-2-8 Ed...". Click here to purchase the full version from the ANSI store.



Edition 3.0 2018-08

REDLINE VERSION



**Automatic electrical controls ~~for household and similar use~~ –
Part 2-8: Particular requirements for electrically operated water valves,
including mechanical requirements**

INTERNATIONAL
ELECTROTECHNICAL
COMMISSION

ICS 97.120

ISBN 978-2-8322-6015-9

Warning! Make sure that you obtained this publication from an authorized distributor.

CONTENTS

FOREWORD.....	4
1 Scope and normative references.....	7
2 Terms and definitions	10
3 General requirements	13
4 General notes on tests.....	13
5 Rating	14
6 Classification.....	14
7 Information.....	17
8 Protection against electric shock.....	19
9 Provision for protective earthing.....	20
10 Terminals and terminations.....	20
11 Constructional requirements	21
12 Moisture and dust resistance	21
13 Electric strength and insulation resistance.....	22
14 Heating	22
15 Manufacturing deviation and drift	23
16 Environmental stress	23
17 Endurance.....	24
18 Mechanical strength.....	25
19 Threaded parts and connections	29
20 Creepage distances, clearances and distances through insulation	29
21 Resistance to heat, fire and tracking	29
22 Resistance to corrosion	29
23 Electromagnetic compatibility (EMC) requirements – Emission.....	29
24 Components.....	29
25 Normal operation	29
26 Electromagnetic compatibility (EMC) requirements – Immunity.....	30
27 Abnormal operation	30
Annex H (normative) Requirements for electronic controls	35
Annex AA (informative) Relation between different flow coefficients	40
Annex BB (normative) Arrangement for the measurement of transient pressures caused by water valves.....	41
Annex CC (normative) Test on valve bodies of thermoplastic material intended to be connected to the water supply mains Long term pressure test for thermoplastic bodied valves.....	44
Annex DD (normative) Torque.....	46
Annex EE (normative) Arrangement for the measurement of transient pressures caused by water valves with a declared pressure of up to and including 1,0 MPa (10 bar).....	50
Bibliography	52
Figure BB.1 – Transient pressure measurement test rig schematic diagram	42
Figure DD.1 – Arrangements for carrying out the torque test.....	46

This is a preview of "S+ IEC 60730-2-8 Ed...". [Click here to purchase the full version from the ANSI store.](#)

Figure EE.1 – Transient pressure measurement test rig for valves with a declared pressure of up to and including 1,0 MPa (10 bar) schematic diagram	50
Table 1 – Required information and methods of providing information	18
Table 101 – Nominal size and thread size of end connections.....	17
Table 102 – Torque test requirement for metal valves with internal threaded end-connections	28
Table 103 – Torque test requirement for metal valves with external threaded end-connections	28
Table 104 – Maximum winding temperature (for test of blocked output conditions and valves declared under Table 1, item 113)	32
Table CC.1 – Test requirements for valves intended for uses other than the control of water for tap and shower outlets	44
Table CC.2 – Test requirements for valves intended for the control of water for tap and shower outlets	45
Table DD.1 . 2.1 – Required torque for test	47
Table DD.6 DD.2 – Tightening torque in newton metres (Nm) for bolts and screws for adaptors	48

INTERNATIONAL ELECTROTECHNICAL COMMISSION

**AUTOMATIC ELECTRICAL
CONTROLS ~~FOR HOUSEHOLD AND SIMILAR USE~~ –**

**Part 2-8: Particular requirements for electrically operated water valves,
including mechanical requirements**

FOREWORD

- 1) The International Electrotechnical Commission (IEC) is a worldwide organization for standardization comprising all national electrotechnical committees (IEC National Committees). The object of IEC is to promote international co-operation on all questions concerning standardization in the electrical and electronic fields. To this end and in addition to other activities, IEC publishes International Standards, Technical Specifications, Technical Reports, Publicly Available Specifications (PAS) and Guides (hereafter referred to as "IEC Publication(s)"). Their preparation is entrusted to technical committees; any IEC National Committee interested in the subject dealt with may participate in this preparatory work. International, governmental and non-governmental organizations liaising with the IEC also participate in this preparation. IEC collaborates closely with the International Organization for Standardization (ISO) in accordance with conditions determined by agreement between the two organizations.
- 2) The formal decisions or agreements of IEC on technical matters express, as nearly as possible, an international consensus of opinion on the relevant subjects since each technical committee has representation from all interested IEC National Committees.
- 3) IEC Publications have the form of recommendations for international use and are accepted by IEC National Committees in that sense. While all reasonable efforts are made to ensure that the technical content of IEC Publications is accurate, IEC cannot be held responsible for the way in which they are used or for any misinterpretation by any end user.
- 4) In order to promote international uniformity, IEC National Committees undertake to apply IEC Publications transparently to the maximum extent possible in their national and regional publications. Any divergence between any IEC Publication and the corresponding national or regional publication shall be clearly indicated in the latter.
- 5) IEC itself does not provide any attestation of conformity. Independent certification bodies provide conformity assessment services and, in some areas, access to IEC marks of conformity. IEC is not responsible for any services carried out by independent certification bodies.
- 6) All users should ensure that they have the latest edition of this publication.
- 7) No liability shall attach to IEC or its directors, employees, servants or agents including individual experts and members of its technical committees and IEC National Committees for any personal injury, property damage or other damage of any nature whatsoever, whether direct or indirect, or for costs (including legal fees) and expenses arising out of the publication, use of, or reliance upon, this IEC Publication or any other IEC Publications.
- 8) Attention is drawn to the Normative references cited in this publication. Use of the referenced publications is indispensable for the correct application of this publication.
- 9) Attention is drawn to the possibility that some of the elements of this IEC Publication may be the subject of patent rights. IEC shall not be held responsible for identifying any or all such patent rights.

DISCLAIMER

This Redline version is not an official Standard and is intended to provide the user with an indication of what changes have been made to the previous version. Only the IEC International Standard provided in this package is to be considered the official Standard.

This Redline version provides you with a quick and easy way to compare all the changes between this standard and its previous edition. A vertical bar appears in the margin wherever a change has been made. Additions are in green text, deletions are in strikethrough red text.

This is a preview of "S+ IEC 60730-2-8 Ed...". [Click here to purchase the full version from the ANSI store.](#)

International Standard IEC 60730-2-8 has been prepared by IEC technical committee 72: Automatic electrical controls.

This third edition cancels and replaces the second edition published in 2000, Amendment 1:2002 and its Amendment 2:2015. This edition constitutes a technical revision.

This edition includes the following significant technical changes with respect to the previous edition:

- alignment of the text with IEC 60730-1 fifth edition (2013) including Amendment 1:2015;
- introduction of specific requirements for thermoplastic bodied valves for the control of water for tap and shower outlets (18.101.4.3 and Annex CC);
- removal of Subclause 18.102 Wetted material specifications.

Future standards in this series will carry the new general title as cited above. Titles of existing standards in this series will be updated at the time of the next edition.

The text of this International Standard is based on the following documents:

CDV	Report on voting
72/1077/CDV	72/1120/RVC

Full information on the voting for the approval of this International Standard can be found in the report on voting indicated in the above table.

This document has been drafted in accordance with the ISO/IEC Directives, Part 2.

This part 2-8 is intended to be used in conjunction with IEC 60730-1. It was established on the basis of the fifth edition (2013) including Amendment 1 (2015) of that publication.

This part 2-8 supplements or modifies the corresponding clauses in IEC 60730-1 so as to convert that publication into the IEC standard: *Safety requirements for electrically operated water valves, including mechanical requirements.*

Where this part 2-8 states "addition", "modification" or "replacement", the relevant requirement, test specification or explanatory matter in part 1 should be adapted accordingly.

Where no change is necessary, part 2-8 indicates that the relevant clause or subclause applies.

In the development of a fully international standard, it has been necessary to take into consideration the differing requirements resulting from practical experience in various parts of the world and to recognize the variation in national electrical systems and wiring rules.

The "in some countries" notes regarding differing national practices are contained in the following elements:

- Table 1, footnotes ab and ac
- Table 13, footnote aa
- 1.1.4
- 16.2.1
- 18.101.3
- 27.2.3.1
- 27.101
- Table DD. 1, footnote a
- Table DD.2, footnote a

This is a preview of "S+ IEC 60730-2-8 Ed...". [Click here to purchase the full version from the ANSI store.](#)

In this publication:

1) The following print types are used:

- Requirements proper: in roman type.
- *Test specifications: in italic type.*
- Notes: in smaller roman type.
- Defined terms: in **bold type**

2) Subclauses, notes, tables or figures which are additional to those in part 1 are numbered starting from 101, additional annexes are lettered AA, BB, etc.

The committee has decided that the contents of this document will remain unchanged until the stability date indicated on the IEC website under "<http://webstore.iec.ch>" in the data related to the specific document. At this date, the document will be

- reconfirmed,
- withdrawn,
- replaced by a revised edition, or
- amended.

IMPORTANT – The “colour inside” logo on the cover page of this publication indicates that it contains colours which are considered to be useful for the correct understanding of its contents. Users should therefore print this publication using a colour printer.

AUTOMATIC ELECTRICAL CONTROLS ~~FOR HOUSEHOLD AND SIMILAR USE~~ –

Part 2-8: Particular requirements for electrically operated water valves, including mechanical requirements

1 Scope and normative references

This clause of Part 1 is ~~replaced~~ applicable except as follows:

1.1 Scope

Replacement:

~~1.1 This part 2-8 applies to electrically operated water valves for use in, on or in association with equipment for household and similar use that may use electricity, gas, oil, solid fuel, solar thermal energy, etc. or a combination thereof, including heating, air-conditioning and similar applications.~~

~~This part 2-8 is also applicable to electrically operated water valves for appliances within the scope of IEC 60335.~~

~~1.1.1 This part 2-8 contains requirements for electrical features of water valves and requirements for mechanical features of valves that affect their intended operation.~~

~~1.1.2 This part 2-8 applies to the inherent safety, to the operating values, operating sequences where such are associated with equipment protection, and to the testing of automatic electrical controls used in, on or in association with household and similar equipment.~~

~~Electrically operated valves for equipment not intended for normal household use but which may nevertheless be used by the public, such as equipment intended to be used by laymen in shops, in light industry and on farms, are within the scope of this part 2-8.~~

~~This part 2-8 does not apply to electrically operated water valves designed exclusively for industrial applications.~~

This part of IEC 60730 applies to electrically operated water valves for use in, on or in association with equipment for household and similar use, including heating, air-conditioning and similar applications. The equipment can use electricity, gas, oil, solid fuel, solar thermal energy, etc., or a combination thereof.

NOTE 1 Throughout this document, the word "equipment" means "appliances and equipment."

This document is applicable to electrically operated water valves for building automation within the scope of ISO 16484.

This document also applies to automatic electrically operated water valves for equipment that can be used by the public, such as equipment intended to be used in shops, offices, hospitals, farms and commercial and industrial applications.

EXAMPLE 1: Electrically operated water valves for commercial catering, heating and air-conditioning equipment.

This document does not apply to electrically operated water valves intended exclusively for industrial process applications unless explicitly mentioned in the relevant equipment standard.

This document applies to electrically operated water valves powered by primary or secondary batteries, requirements for which are contained within the standard, including Annex V.

This document does not cover the prevention of contamination of drinking water as a result of contact with materials.

1.1.1 This document applies to the inherent safety, to the operating values, operating times and operating sequences where such are associated with equipment safety, and to the testing of automatic electrical control devices used in, on or in association with, household and similar equipment.

This document contains requirements for electrical features of water valves and requirements for mechanical features of valves that affect their intended operation.

This document is also applicable to electrically operated water valves for appliances within the scope of the IEC 60335 series of standards.

This document does not apply to:

- electrically operated water valves of nominal connection size above DN 50;
- electrically operated water valves for admissible nominal pressure rating above 1,6 MPa;
- food dispensers;
- detergent dispensers;
- steam valves;
- electrically operated water valves designed exclusively for industrial applications.

Throughout this document, where it can be used unambiguously, the term:

- "valve" is used to denote an electrically operated water valve (including actuator and valve body assembly);
- "actuator" means "electrically operated mechanism or prime mover";
- "valve body" means "valve body assembly";
- "equipment" includes "appliance" and "control system".

1.1.2 This document applies to electrically operated water valves, responsive to or controlling such characteristics as temperature, pressure, passage of time, humidity, light, electrostatic effects, flow, or liquid level, current, voltage, acceleration, or combinations thereof.

1.1.3 This document also applies to actuators and to valve bodies which are designed to be fitted to each other.

1.1.4 This document applies to individual valves, valves utilized as part of a system and valves mechanically integral with multi-functional controls having non-electrical outputs.

NOTE Attention is drawn to the fact that, in many countries, additional test requirements and by-laws have been established by the water authorities or companies.

1.1.5 This document applies to AC or DC powered electrically operated water valves with a rated voltage not exceeding 690 V AC or 600 V DC.

1.1.6 This document does not take into account the **response value** of an **automatic action** of a valve, if such a **response value** is dependent upon the method of mounting the valve in

the equipment. Where a **response value** is of significant purpose for the protection of the **user**, or surroundings, the value defined in the appropriate equipment standard or as determined by the manufacturer shall apply.

1.1.7 This document applies also to electrically operated water valves incorporating **electronic devices**, requirements for which are contained in Annex H.

1.1.8 This document applies also to electrically operated water valves using NTC or PTC **thermistors**, requirements for which are contained in Annex J.

1.1.9 This document applies to the electrical and **functional safety** of electrically operated water valves capable of receiving and responding to communications signals, including signals for power billing rate and demand response.

The signals can be transmitted to or received from external units being part of the valve (wired), or to and from external units which are not part of the valve (wireless) under test.

1.1.10 This document does not address the integrity of the output signal to the network devices, such as interoperability with other devices unless it has been evaluated as part of the **control system**.

1.2 Normative references

This clause of Part 1 is applicable except as follows:

Addition:

ISO 7-1:1994, *Pipe threads where pressure-tight joints are made on the threads – Part 1: Dimensions, tolerances and designation*

ISO 65:1981, *Carbon steel tubes suitable for screwing in accordance with ISO 7-1*

ISO 228-1:~~1994~~, *Pipe threads where pressure-tight joints are not made on the threads – Part 1: Dimensions, tolerances and designation*

ISO 630:~~1995~~, ¹ *Structural steels – Plates, wide flats, bars sections and profiles*

~~ISO 1179:1981, *Pipe connections threaded to ISO 228-1 for plain end steel and other metal tubes in industrial applications*~~

ISO 1179-1, *Connections for general use and fluid power – Ports and stud ends with ISO 228-1 threads with elastomeric or metal-to-metal sealing – Part 1: Threaded ports*

ISO 4144:~~1979~~, *Pipework – Stainless steel fittings threaded ~~to~~ in accordance with ISO 7-1*

~~ISO 4400:1994, *Fluid power systems and components – Three-pin electrical plug connectors with earth contact – Characteristics and requirements*~~

~~ISO 6952:1994, *Fluid power systems and components – Two-pin electrical plug connectors with earth contact – Characteristics and requirements*~~

¹ ISO 630 has been withdrawn.



INTERNATIONAL STANDARD

**Automatic electrical controls –
Part 2-8: Particular requirements for electrically operated water valves,
including mechanical requirements**



CONTENTS

FOREWORD.....	4
1 Scope and normative references.....	7
2 Terms and definitions	9
3 General requirements	13
4 General notes on tests.....	13
5 Rating	13
6 Classification.....	13
7 Information.....	16
8 Protection against electric shock.....	17
9 Provision for protective earthing.....	18
10 Terminals and terminations.....	18
11 Constructional requirements	19
12 Moisture and dust resistance	19
13 Electric strength and insulation resistance.....	19
14 Heating	20
15 Manufacturing deviation and drift	21
16 Environmental stress	21
17 Endurance.....	22
18 Mechanical strength.....	23
19 Threaded parts and connections	26
20 Creepage distances, clearances and distances through insulation	26
21 Resistance to heat, fire and tracking	26
22 Resistance to corrosion	26
23 Electromagnetic compatibility (EMC) requirements – Emission.....	26
24 Components.....	27
25 Normal operation	27
26 Electromagnetic compatibility (EMC) requirements – Immunity.....	27
27 Abnormal operation	27
28 Guidance on the use of electronic disconnection	30
Annex H (normative) Requirements for electronic controls	31
Annex AA (informative) Relation between different flow coefficients	36
Annex BB (normative) Arrangement for the measurement of transient pressures caused by water valves.....	37
Annex CC (normative) Long term pressure test for thermoplastic bodied valves	40
Annex DD (normative) Torque	42
Annex EE (normative) Arrangement for the measurement of transient pressures caused by water valves with a declared pressure of up to and including 1,0 MPa (10 bar)	46
Bibliography	48
Figure BB.1 – Transient pressure measurement test rig schematic diagram	38
Figure DD.1 – Arrangements for carrying out the torque test.....	42

This is a preview of "S+ IEC 60730-2-8 Ed...". [Click here to purchase the full version from the ANSI store.](#)

Figure EE.1 – Transient pressure measurement test rig for valves with a declared pressure of up to and including 1,0 MPa (10 bar) schematic diagram	46
Table 1 – Required information and methods of providing information	16
Table 101 – Nominal size and thread size of end connections.....	16
Table 102 – Torque test requirement for metal valves with internal threaded end-connections	25
Table 103 – Torque test requirement for metal valves with external threaded end-connections	26
Table 104 – Maximum winding temperature (for test of blocked output conditions and valves declared under Table 1, item 113)	28
Table CC.1 – Test requirements for valves intended for uses other than the control of water for tap and shower outlets	40
Table CC.2 – Test requirements for valves intended for the control of water for tap and shower outlets	41
Table DD.1 – Required torque for test	43
Table DD.2 – Tightening torque in newton metres (Nm) for bolts and screws for adaptors	44

INTERNATIONAL ELECTROTECHNICAL COMMISSION

AUTOMATIC ELECTRICAL CONTROLS –

**Part 2-8: Particular requirements for electrically operated water valves,
including mechanical requirements**

FOREWORD

- 1) The International Electrotechnical Commission (IEC) is a worldwide organization for standardization comprising all national electrotechnical committees (IEC National Committees). The object of IEC is to promote international co-operation on all questions concerning standardization in the electrical and electronic fields. To this end and in addition to other activities, IEC publishes International Standards, Technical Specifications, Technical Reports, Publicly Available Specifications (PAS) and Guides (hereafter referred to as "IEC Publication(s)"). Their preparation is entrusted to technical committees; any IEC National Committee interested in the subject dealt with may participate in this preparatory work. International, governmental and non-governmental organizations liaising with the IEC also participate in this preparation. IEC collaborates closely with the International Organization for Standardization (ISO) in accordance with conditions determined by agreement between the two organizations.
- 2) The formal decisions or agreements of IEC on technical matters express, as nearly as possible, an international consensus of opinion on the relevant subjects since each technical committee has representation from all interested IEC National Committees.
- 3) IEC Publications have the form of recommendations for international use and are accepted by IEC National Committees in that sense. While all reasonable efforts are made to ensure that the technical content of IEC Publications is accurate, IEC cannot be held responsible for the way in which they are used or for any misinterpretation by any end user.
- 4) In order to promote international uniformity, IEC National Committees undertake to apply IEC Publications transparently to the maximum extent possible in their national and regional publications. Any divergence between any IEC Publication and the corresponding national or regional publication shall be clearly indicated in the latter.
- 5) IEC itself does not provide any attestation of conformity. Independent certification bodies provide conformity assessment services and, in some areas, access to IEC marks of conformity. IEC is not responsible for any services carried out by independent certification bodies.
- 6) All users should ensure that they have the latest edition of this publication.
- 7) No liability shall attach to IEC or its directors, employees, servants or agents including individual experts and members of its technical committees and IEC National Committees for any personal injury, property damage or other damage of any nature whatsoever, whether direct or indirect, or for costs (including legal fees) and expenses arising out of the publication, use of, or reliance upon, this IEC Publication or any other IEC Publications.
- 8) Attention is drawn to the Normative references cited in this publication. Use of the referenced publications is indispensable for the correct application of this publication.
- 9) Attention is drawn to the possibility that some of the elements of this IEC Publication may be the subject of patent rights. IEC shall not be held responsible for identifying any or all such patent rights.

International Standard IEC 60730-2-8 has been prepared by IEC technical committee 72: Automatic electrical controls.

This third edition cancels and replaces the second edition published in 2000, Amendment 1:2002 and its Amendment 2:2015. This edition constitutes a technical revision.

This edition includes the following significant technical changes with respect to the previous edition:

- alignment of the text with IEC 60730-1 fifth edition (2013) including Amendment 1:2015;
- introduction of specific requirements for thermoplastic bodied valves for the control of water for tap and shower outlets (18.101.4.3 and Annex CC);
- removal of Subclause 18.102 Wetted material specifications.

This is a preview of "S+ IEC 60730-2-8 Ed...". Click here to purchase the full version from the ANSI store.

Future standards in this series will carry the new general title as cited above. Titles of existing standards in this series will be updated at the time of the next edition.

The text of this International Standard is based on the following documents:

CDV	Report on voting
72/1077/CDV	72/1120/RVC

Full information on the voting for the approval of this International Standard can be found in the report on voting indicated in the above table.

This document has been drafted in accordance with the ISO/IEC Directives, Part 2.

This part 2-8 is intended to be used in conjunction with IEC 60730-1. It was established on the basis of the fifth edition (2013) including Amendment 1 (2015) of that publication.

This part 2-8 supplements or modifies the corresponding clauses in IEC 60730-1 so as to convert that publication into the IEC standard: *Safety requirements for electrically operated water valves, including mechanical requirements.*

Where this part 2-8 states "addition", "modification" or "replacement", the relevant requirement, test specification or explanatory matter in part 1 should be adapted accordingly.

Where no change is necessary, part 2-8 indicates that the relevant clause or subclause applies.

In the development of a fully international standard, it has been necessary to take into consideration the differing requirements resulting from practical experience in various parts of the world and to recognize the variation in national electrical systems and wiring rules.

The "in some countries" notes regarding differing national practices are contained in the following elements:

- Table 1, footnotes ab and ac
- Table 13, footnote aa
- 1.1.4
- 16.2.1
- 18.101.3
- 27.2.3.1
- 27.101
- Table DD. 1, footnote a
- Table DD.2, footnote a

In this publication:

- 1) The following print types are used:
 - Requirements proper: in roman type.
 - *Test specifications: in italic type.*
 - Notes: in smaller roman type.
 - Defined terms: in **bold type**
- 2) Subclauses, notes, tables or figures which are additional to those in part 1 are numbered starting from 101, additional annexes are lettered AA, BB, etc.

This is a preview of "S+ IEC 60730-2-8 Ed...". [Click here to purchase the full version from the ANSI store.](#)

The committee has decided that the contents of this document will remain unchanged until the stability date indicated on the IEC website under "<http://webstore.iec.ch>" in the data related to the specific document. At this date, the document will be

- reconfirmed,
- withdrawn,
- replaced by a revised edition, or
- amended.

A bilingual version of this publication may be issued at a later date.

AUTOMATIC ELECTRICAL CONTROLS –

Part 2-8: Particular requirements for electrically operated water valves, including mechanical requirements

1 Scope and normative references

This clause of Part 1 is applicable except as follows:

1.1 Scope

Replacement:

This part of IEC 60730 applies to electrically operated water valves for use in, on or in association with equipment for household and similar use, including heating, air-conditioning and similar applications. The equipment can use electricity, gas, oil, solid fuel, solar thermal energy, etc., or a combination thereof.

NOTE 1 Throughout this document, the word "equipment" means "appliances and equipment."

This document is applicable to electrically operated water valves for building automation within the scope of ISO 16484.

This document also applies to automatic electrically operated water valves for equipment that can be used by the public, such as equipment intended to be used in shops, offices, hospitals, farms and commercial and industrial applications.

EXAMPLE 1: Electrically operated water valves for commercial catering, heating and air-conditioning equipment.

This document does not apply to electrically operated water valves intended exclusively for industrial process applications unless explicitly mentioned in the relevant equipment standard.

This document applies to electrically operated water valves powered by primary or secondary batteries, requirements for which are contained within the standard, including Annex V.

This document does not cover the prevention of contamination of drinking water as a result of contact with materials.

1.1.1 This document applies to the inherent safety, to the operating values, operating times and operating sequences where such are associated with equipment safety, and to the testing of automatic electrical control devices used in, on or in association with, household and similar equipment.

This document contains requirements for electrical features of water valves and requirements for mechanical features of valves that affect their intended operation.

This document is also applicable to electrically operated water valves for appliances within the scope of the IEC 60335 series of standards.

This document does not apply to:

- electrically operated water valves of nominal connection size above DN 50;
- electrically operated water valves for admissible nominal pressure rating above 1,6 MPa;

- food dispensers;
- detergent dispensers;
- steam valves;
- electrically operated water valves designed exclusively for industrial applications.

Throughout this document, where it can be used unambiguously, the term:

- "valve" is used to denote an electrically operated water valve (including actuator and valve body assembly);
- "actuator" means "electrically operated mechanism or prime mover";
- "valve body" means "valve body assembly";
- "equipment" includes "appliance" and "control system".

1.1.2 This document applies to electrically operated water valves, responsive to or controlling such characteristics as temperature, pressure, passage of time, humidity, light, electrostatic effects, flow, or liquid level, current, voltage, acceleration, or combinations thereof.

1.1.3 This document also applies to actuators and to valve bodies which are designed to be fitted to each other.

1.1.4 This document applies to individual valves, valves utilized as part of a system and valves mechanically integral with multi-functional controls having non-electrical outputs.

NOTE Attention is drawn to the fact that, in many countries, additional test requirements and by-laws have been established by the water authorities or companies.

1.1.5 This document applies to AC or DC powered electrically operated water valves with a rated voltage not exceeding 690 V AC or 600 V DC.

1.1.6 This document does not take into account the **response value** of an **automatic action** of a valve, if such a **response value** is dependent upon the method of mounting the valve in the equipment. Where a **response value** is of significant purpose for the protection of the **user**, or surroundings, the value defined in the appropriate equipment standard or as determined by the manufacturer shall apply.

1.1.7 This document applies also to electrically operated water valves incorporating **electronic devices**, requirements for which are contained in Annex H.

1.1.8 This document applies also to electrically operated water valves using NTC or PTC **thermistors**, requirements for which are contained in Annex J.

1.1.9 This document applies to the electrical and **functional safety** of electrically operated water valves capable of receiving and responding to communications signals, including signals for power billing rate and demand response.

The signals can be transmitted to or received from external units being part of the valve (wired), or to and from external units which are not part of the valve (wireless) under test.

1.1.10 This document does not address the integrity of the output signal to the network devices, such as interoperability with other devices unless it has been evaluated as part of the **control system**.

1.2 Normative references

This clause of Part 1 is applicable except as follows:

Addition:

ISO 7-1:1994, *Pipe threads where pressure-tight joints are made on the threads – Part 1: Dimensions, tolerances and designation*

ISO 65:1981, *Carbon steel tubes suitable for screwing in accordance with ISO 7-1*

ISO 228-1, *Pipe threads where pressure-tight joints are not made on the threads – Part 1: Dimensions, tolerances and designation*

ISO 630,¹ *Structural steels – Plates, wide flats, bars sections and profiles*

ISO 1179-1, *Connections for general use and fluid power – Ports and stud ends with ISO 228-1 threads with elastomeric or metal-to-metal sealing – Part 1: Threaded ports*

ISO 4144, *Pipework – Stainless steel fittings threaded in accordance with ISO 7-1*

¹ ISO 630 has been withdrawn.