



Edition 3.0 2026-06

INTERNATIONAL STANDARD

**Explosive atmospheres -
Part 10-2: Classification of areas - Explosive dust atmospheres**

FOREWORD	3
INTRODUCTION	7
1 Scope	8
2 Normative references	8
3 Terms and definitions	9
4 Area classification	13
4.1 General	13
4.1.1 Basic considerations	13
4.1.2 Small quantities	14
4.1.3 Zone of negligible extent (Zone NE)	14
4.1.4 Inerting	15
4.2 Safety principles	15
4.3 Area classification objectives	16
4.4 Interior of process equipment	16
4.5 Management of change	16
4.6 Activities other than those of normal operation	17
4.7 Catastrophic failures	17
4.8 Competence of personnel	17
4.9 Area classification procedure for explosive dust atmospheres	17
5 Sources of release	19
5.1 General	19
5.2 Dust containment	19
5.3 Identification and grading of sources of release	19
6 Zones	20
6.1 General	20
6.2 Extent of zones	20
6.2.1 General	20
6.2.2 Zone 20	20
6.2.3 Zone 21	21
6.2.4 Zone 22	21
6.2.5 Zone dependence on grade of release	21
7 Dust layers	22
8 Documentation	22
8.1 General	22
8.2 Drawings, data sheets and tables	22
Annex A (informative) Suggested presentation of hazardous areas	24
A.1 Preferred symbol key for area classification zones	24
A.2 Example hazardous area classification data sheets	25
Annex B (informative) Area classification examples	27
B.1 Examples of zones	27
B.1.1 General	27
B.1.2 Zone 20	27
B.1.3 Zone 21	27
B.1.4 Zone 22	27
B.2 Bag emptying station within a building and without exhaust ventilation	28
B.3 Bag emptying station with exhaust ventilation	29

This is a preview of IEC 60079-10-2 Ed. 3.0 en:2026. Click [here](#) to purchase the full version from the ANSI store.

B.5	Drum tipper within a building without exhaust ventilation.....	31
Annex C (informative)	Dust layer hazards	33
C.1	Introductory remarks	33
C.2	Levels of housekeeping	33
C.3	Potential for hot surface ignition.....	34
Annex D (informative)	Hybrid mixtures	35
D.1	General.....	35
D.2	Ventilation	35
D.3	Explosive limits	35
D.4	Chemical reactions	35
D.5	Minimum ignition parameters	35
D.6	Final classification	35
Bibliography		36
Figure A.1	– Identification of zones on drawings	24
Figure B.1	– Bag emptying station within a building and without exhaust ventilation	29
Figure B.2	– Bag emptying station with exhaust ventilation	30
Figure B.3	– Cyclone and filter with clean outlet outside building	31
Figure B.4	– Drum tipper within a building without exhaust ventilation.....	32
Table 1	– Designation of zones depending on grade of release.....	21
Table A.1	– Hazardous area classification data sheet – Part I: Dust list and characteristics	25
Table A.2	– Hazardous area classification data sheet – Part II: List of sources of release	26

Explosive atmospheres - Part 10-2: Classification of areas - Explosive dust atmospheres

FOREWORD

- 1) The International Electrotechnical Commission (IEC) is a worldwide organization for standardization comprising all national electrotechnical committees (IEC National Committees). The object of IEC is to promote international co-operation on all questions concerning standardization in the electrical and electronic fields. To this end and in addition to other activities, IEC publishes International Standards, Technical Specifications, Technical Reports, Publicly Available Specifications (PAS) and Guides (hereafter referred to as "IEC Publication(s)"). Their preparation is entrusted to technical committees; any IEC National Committee interested in the subject dealt with may participate in this preparatory work. International, governmental and non-governmental organizations liaising with the IEC also participate in this preparation. IEC collaborates closely with the International Organization for Standardization (ISO) in accordance with conditions determined by agreement between the two organizations.
- 2) The formal decisions or agreements of IEC on technical matters express, as nearly as possible, an international consensus of opinion on the relevant subjects since each technical committee has representation from all interested IEC National Committees.
- 3) IEC Publications have the form of recommendations for international use and are accepted by IEC National Committees in that sense. While all reasonable efforts are made to ensure that the technical content of IEC Publications is accurate, IEC cannot be held responsible for the way in which they are used or for any misinterpretation by any end user.
- 4) In order to promote international uniformity, IEC National Committees undertake to apply IEC Publications transparently to the maximum extent possible in their national and regional publications. Any divergence between any IEC Publication and the corresponding national or regional publication shall be clearly indicated in the latter.
- 5) IEC itself does not provide any attestation of conformity. Independent certification bodies provide conformity assessment services and, in some areas, access to IEC marks of conformity. IEC is not responsible for any services carried out by independent certification bodies.
- 6) All users should ensure that they have the latest edition of this publication.
- 7) No liability shall attach to IEC or its directors, employees, servants or agents including individual experts and members of its technical committees and IEC National Committees for any personal injury, property damage or other damage of any nature whatsoever, whether direct or indirect, or for costs (including legal fees) and expenses arising out of the publication, use of, or reliance upon, this IEC Publication or any other IEC Publications.
- 8) Attention is drawn to the Normative references cited in this publication. Use of the referenced publications is indispensable for the correct application of this publication.
- 9) IEC draws attention to the possibility that the implementation of this document may involve the use of (a) patent(s). IEC takes no position concerning the evidence, validity or applicability of any claimed patent rights in respect thereof. As of the date of publication of this document, IEC had not received notice of (a) patent(s), which may be required to implement this document. However, implementers are cautioned that this may not represent the latest information, which may be obtained from the patent database available at <https://patents.iec.ch>. IEC shall not be held responsible for identifying any or all such patent rights.

IEC 60079-10-2 has been prepared by Subcommittee SC31J: Classification of hazardous areas and installation requirements of IEC technical committee 31: Equipment for explosive atmospheres. It is an International Standard.

This third edition of IEC 60079-10-2 cancels and replaces the second edition of IEC 60079-10-2 published in 2015. This edition constitutes a technical revision.

Users of this document are advised that interpretation sheets clarifying the interpretation of this document can be published. Interpretation sheets are available from the IEC webstore and can be found in the "history" tab of the page for each document.

Combustible dusts are hazardous because when they are dispersed in air by any means they could form explosive atmospheres. Furthermore, layers of dust could ignite and act as ignition sources for an explosive atmosphere.

This part of IEC 60079 gives guidance on the identification and classification of areas where such hazards from dust can arise. It sets out the essential criteria against which the hazards due to combustible dusts can be assessed and gives guidance on the design and control parameters which can be used in order to reduce such a hazard. General and special criteria are given for the process of identification and classification of hazardous areas.

This document contains an informative Annex B giving examples for classifying hazardous areas.

This part of IEC 60079 is concerned with the identification and classification of areas where explosive dust atmospheres and combustible dust layers are present in order to permit the proper assessment of ignition sources in such areas.

In this document, explosive dust atmospheres and combustible dust layers are treated separately. In Clause 4, area classification for explosive dust clouds is described, with dust layers acting as one of the possible sources of release. In Clause 7, other general considerations for dust layers are described.

The examples in this document are based on a system of effective housekeeping being implemented in the plant to prevent dust layers from accumulating. Where effective housekeeping is not present, the area classification includes the possible formation of explosive dust clouds from dust layers.

The principles of this document can also be followed when combustible fibres or flyings might cause a hazard.

Atmospheric conditions include variations in pressure and temperature above and below reference levels of 101,3 kPa (1 013 mbar) and 20 °C (293 K), provided that the variations have a negligible effect on the explosive properties of the combustible material. For air with normal oxygen content, typically a volume fraction of 21 % is assumed.

It does not apply to

- a) underground mining areas;
- b) dusts of explosives that do not require atmospheric oxygen for combustion such as pyrophoric substances, propellants, pyrotechnics, munitions, peroxides, oxidizers, water-reactive elements or compounds, or other similar materials;
- c) catastrophic failures or rare malfunctions which are outside the conditions dealt with in this document;
- d) rooms used for medical purposes;
- e) domestic premises;
- f) where a hazard is due to the presence of flammable gas or vapour, but the principles can be used in the assessment of a hybrid mixture (see also IEC 60079-10-1).

NOTE Additional guidance on hybrid mixtures is provided in Annex D.

This document does not consider the effects of consequential damage following a fire or an explosion.

2 Normative references

The following documents are referred to in the text in such a way that some or all of their content constitutes requirements of this document. For dated references, only the edition cited applies. For undated references, the latest edition of the referenced document (including any amendments) applies.

IEC 60079-0, *Explosive atmospheres - Part 0: Equipment - General requirements*