



INTERNATIONAL STANDARD

**Electrical installations in ships -
Part 352: Selection, installation, and operating conditions of cables**

This is a preview of IEC 60092-352 Ed. 4.0 en:2025. [Click here to purchase the full version from the ANSI store.](#)

FOREWORD	4
INTRODUCTION	6
1 Scope	7
2 Normative references	7
3 Terms and definitions	8
4 Types, construction, installation, and operating conditions of cables.....	9
4.1 Types of cables	9
4.2 Voltage rating	10
4.2.1 Power cables	10
4.2.2 Control and instrumentation cables.....	11
4.3 Current carrying capacities	11
4.3.1 Cross-sectional areas of conductors	11
4.3.2 Current carrying capacities	13
4.3.3 Current ratings for continuous service	13
4.3.4 Correction factors for different ambient air temperatures	14
4.3.5 Correction factors for short time duty	15
4.3.6 Correction factors for cable grouping	18
4.4 Voltage drop	19
4.5 Estimation of lighting loads	19
4.6 Parallel connection of cables	19
4.7 Separation of circuits	19
4.8 Short circuit capacity (withstand capability).....	19
4.9 Conductor	20
4.10 Insulation material	20
4.11 Screen, core screen or shield	20
4.12 Metallic braid or armour	20
4.13 Sheathing material.....	20
4.14 Fire performance	21
4.15 Cable runs	21
4.16 Cable installation methods in relation to electromagnetic interference.....	23
4.17 Mechanical protection	23
4.17.1 General	23
4.17.2 Earthing of metal coverings and of mechanical protection of cables.....	24
4.18 Bend radius	24
4.19 Supports and fixings	25
4.20 Cables penetrating bulkheads and decks	26
4.21 Installation in metallic pipes or conduits or trunking	26
4.22 Installation in non-metallic pipes, conduits, trunking, ducts or capping and casing.....	27
4.23 Installation in battery compartments.....	27
4.24 Installation in refrigeration spaces.....	27
4.25 Tensile stress	28
4.26 Special requirements for single-core cables for AC wiring	28
4.27 Cable ends	29
4.28 Joints and tapplings (branch circuits).....	30
4.29 Connection boxes	30

This is a preview of IEC 60092-352 Ed. 4.0 en:2025. [Click here to purchase the full version from the ANSI store.](#)

up to 1 000 MHz on board of ships and offshore units	30
4.31 Requirements for the installation of fibre optic cables on board ships and offshore units	31
4.32 Installation of cables between areas with and without explosive atmospheres.....	32
4.33 Special safety requirements from SOLAS regulations	32
Annex A (informative) Tabulated current carrying capacities – Defined installations.....	33
A.1 General.....	33
A.2 Reference methods of installation	33
A.3 Other methods of installation	34
A.4 Correction factors for cable grouping	34
A.4.1 General	34
A.4.2 Installation methods B and C	34
A.4.3 Installation methods E and F	35
Annex B (informative) Tabulated current carrying capacities – General installations	46
Annex C (normative) Fire stops.....	52
Annex D (informative) Method of preparation of a spliced connection	53
Annex E (informative) Recommendations for cable installation methods in relation to electromagnetic interference.....	54
Bibliography.....	55
Figure 1 – Correction factors for half-hour and one-hour service	16
Figure 2 – Time constant of cables	17
Figure 3 – Correction factor for intermittent service.....	18
Figure 4 – Correct cable arrangements – AC cables	29
Figure 5 – Correct cable arrangements – DC cables	29
Figure 6 – Alternation of phases – Incorrect cable arrangements	29
Table 1 – Selection of cables for AC systems	11
Table 2 – Sizes of earth conductor and equipment earthing connections.....	12
Table 3 – Correction factor for various ambient air temperatures	15
Table 4 – Bend radius for cables rated up to 1,8/3 kV	25
Table 5 – Bend radius for cables rated at 3,6/6,0 (7,2) kV and above.....	25
Table A.1 – Current carrying capacities in amperes – Copper conductor temperature: 60 °C and reference ambient air temperature: 45 °C.....	36
Table A.2 – Current carrying capacities in amperes – Copper conductor temperature: 70 °C and reference ambient air temperature: 45 °C	37
Table A.3 – Current carrying capacities in amperes – Copper conductors temperature: 85 °C and reference ambient air temperature: 45 °C.....	38
Table A.4 – Current carrying capacities in amperes – Copper conductors temperature: 90 °C and reference ambient air temperature: 45 °C.....	39
Table A.5 – Current carrying capacities in amperes – Copper conductors temperature: 95 °C and Reference ambient air temperature: 45 °C.....	40
Table A.6 – Correction factors for groups of more than one circuit or of more than one multicore cable to be used with current carrying capacities of Table A.1 to Table A.5	41
Table A.7 – Correction factors for group of more than one multicore cable to be applied to reference ratings for multicore cables in free air – Method of installation E Table A.1 to Table A.5	42

This is a preview of IEC 60092-352 Ed. 4.0 en:2025. [Click here to purchase the full version from the ANSI store.](#)

to be applied to reference rating for one circuit of single-core cables in free air – Method of installation F in Table A.1 to Table A.5	44
Table B.1 – Maximum permissible service temperature of a conductor.....	46
Table B.2 – Current carrying capacities in continuous service at maximum rated conductor temperature of 60 °C	47
Table B.3 – Current carrying capacities in continuous service at maximum rated conductor temperature of 70 °C	48
Table B.4 – Current carrying capacities in continuous service at maximum rated conductor temperature of 85 °C	49
Table B.5 – Current carrying capacities in continuous service at maximum rated conductor temperature of 90 °C	50
Table B.6 – Current carrying capacities in continuous service at maximum rated conductor temperature of 95 °C	51

Electrical installations in ships - Part 352: Selection, installation, and operating conditions of cables

FOREWORD

- 1) The International Electrotechnical Commission (IEC) is a worldwide organization for standardization comprising all national electrotechnical committees (IEC National Committees). The object of IEC is to promote international co-operation on all questions concerning standardization in the electrical and electronic fields. To this end and in addition to other activities, IEC publishes International Standards, Technical Specifications, Technical Reports, Publicly Available Specifications (PAS) and Guides (hereafter referred to as "IEC Publication(s)"). Their preparation is entrusted to technical committees; any IEC National Committee interested in the subject dealt with may participate in this preparatory work. International, governmental and non-governmental organizations liaising with the IEC also participate in this preparation. IEC collaborates closely with the International Organization for Standardization (ISO) in accordance with conditions determined by agreement between the two organizations.
- 2) The formal decisions or agreements of IEC on technical matters express, as nearly as possible, an international consensus of opinion on the relevant subjects since each technical committee has representation from all interested IEC National Committees.
- 3) IEC Publications have the form of recommendations for international use and are accepted by IEC National Committees in that sense. While all reasonable efforts are made to ensure that the technical content of IEC Publications is accurate, IEC cannot be held responsible for the way in which they are used or for any misinterpretation by any end user.
- 4) In order to promote international uniformity, IEC National Committees undertake to apply IEC Publications transparently to the maximum extent possible in their national and regional publications. Any divergence between any IEC Publication and the corresponding national or regional publication shall be clearly indicated in the latter.
- 5) IEC itself does not provide any attestation of conformity. Independent certification bodies provide conformity assessment services and, in some areas, access to IEC marks of conformity. IEC is not responsible for any services carried out by independent certification bodies.
- 6) All users should ensure that they have the latest edition of this publication.
- 7) No liability shall attach to IEC or its directors, employees, servants or agents including individual experts and members of its technical committees and IEC National Committees for any personal injury, property damage or other damage of any nature whatsoever, whether direct or indirect, or for costs (including legal fees) and expenses arising out of the publication, use of, or reliance upon, this IEC Publication or any other IEC Publications.
- 8) Attention is drawn to the Normative references cited in this publication. Use of the referenced publications is indispensable for the correct application of this publication.
- 9) IEC draws attention to the possibility that the implementation of this document may involve the use of (a) patent(s). IEC takes no position concerning the evidence, validity or applicability of any claimed patent rights in respect thereof. As of the date of publication of this document, IEC had not received notice of (a) patent(s), which may be required to implement this document. However, implementers are cautioned that this may not represent the latest information, which may be obtained from the patent database available at <https://patents.iec.ch>. IEC shall not be held responsible for identifying any or all such patent rights.

IEC 60092-352 has been prepared by IEC subcommittee 18A: Cables and cable installations, of IEC technical committee TC 18: Electrical installations of ships and of mobile and fixed offshore units. It is an International Standard.

This fourth edition cancels and replaces the third edition published in 2005. This edition constitutes a technical revision.

This edition includes the following significant technical changes with respect to the previous edition:

- a) modification of the part title;
- b) complete review of the document and establishment of the match with all other standards from the group IEC 60092-350 to IEC 60092-379;
- c) addition of terms and definitions;

This is a preview of IEC 60092-352 Ed. 4.0 en:2025. Click here to purchase the full version from the ANSI store.

transmission characteristics up to 1 000 MHz;

- e) addition of the technical requirements for the installation of fibre optic cables;
- f) addition of technical requirements for the installation of cables for installation between areas with and without explosive atmospheres;
- g) addition of technical requirements for Special safety requirements from SOLAS regulations.

The text of this International Standard is based on the following documents:

Draft	Report on voting
18A/505/FDIS	18A/508/RVD

Full information on the voting for its approval can be found in the report on voting indicated in the above table.

The language used for the development of this International Standard is English.

This document was drafted in accordance with ISO/IEC Directives, Part 2, and developed in accordance with ISO/IEC Directives, Part 1 and ISO/IEC Directives, IEC Supplement, available at www.iec.ch/members_experts/refdocs. The main document types developed by IEC are described in greater detail at www.iec.ch/publications.

A list of all parts in the IEC 60095, published under the general title *Electrical installations in ships*, can be found on the IEC website.

The committee has decided that the contents of this document will remain unchanged until the stability date indicated on the IEC website under webstore.iec.ch in the data related to the specific document. At this date, the document will be

- reconfirmed,
- withdrawn, or
- revised.

This is a preview of IEC 60092-352 Ed. 4.0 en:2025. [Click here to purchase the full version from the ANSI store.](#)

IEC 60092 forms a series of International Standards concerning electrical installations in sea-going ships and fixed or mobile offshore units, incorporating good practice and co-ordinating as far as possible existing rules.

These standards form:

- a code of practical interpretation and amplification of the requirements of the International Convention on Safety of Life at Sea;
- a guide for future regulations which can be prepared;
- a statement of practice for use by owners and builders of ships and fixed or mobile and offshore units and other appropriate organisations.

This revision of IEC 60092-352 has been prepared by Maintenance Team 2 of IEC SC 18A, to update and include developments identified in other parts of the 60092 series of standards applicable to cables for installations in ships.

NOTE Guidance for the use and installation of cables for offshore applications is being prepared jointly by SC18A, MT 2 and TC 18, MT 18, and will be issued by TC 18, MT 18.

This is a preview of IEC 60092-352 Ed. 4.0 en:2025. [Click here to purchase the full version from the ANSI store.](#)

This part of IEC 60092 provides the basic requirements for the selection, installation and operating conditions of electrical cables intended for fixed electrical systems on board ships at voltages (U) up to and including U_m 18/30 (36) kV, symmetrical category cables and fibre optic cables.

The reference to fixed systems includes those that are subjected to vibration (due to the movement of the ship) or movement (due to motion of the ship) and not to those that are intended for frequent flexing.

Cables subject to frequent or continual flexing use, which can withstand the mechanical stress and the environment they are exposed to, are detailed in other IEC specifications such as IEC 60227 and IEC 60245. Flexible cables are frequently used for retractable thrusters, elevators, moving decks, cranes, shore connections and other moving applications on board ships.

The following cable types and applications are not included:

- sub-sea and umbilical cables;
- telecommunication and radio frequency cables;
- selection and installation of cables for use on offshore platforms.

2 Normative references

The following documents are referred to in the text in such a way that some or all of their content constitutes requirements of this document. For dated references, only the edition cited applies. For undated references, the latest edition of the referenced document (including any amendments) applies.

IEC 60079 series, *Explosive atmospheres*

IEC 60092-101, *Electrical installations in ships - Part 101: Definitions and general requirements*

IEC 60092-201, *Electrical installations in ships - Part 201: System design - General*

IEC 60092-302-2, *Electrical installations in ships - Part 302-2: Low voltage switchgear and controlgear assemblies - Marine power*

IEC 60092-350:2020, *Electrical installations in ships - Part 350: General construction and test methods of power, control and instrumentation cables for shipboard and offshore applications*

IEC 60092-353:2024, *Electrical installations in ships - Part 353: Power cables for rated voltages 1 kV and 3 kV*

IEC 60092-354, *Electrical installations in ships - Part 354: Single and three-core power cables with extruded solid insulation for rated voltages 6 kV ($U_m = 7,2$ kV); up to 30 kV ($U_m = 36$ kV)*

IEC 60092-360, *Electrical installations in ships - Part 360: Insulating and sheathing materials for shipboard and offshore units, power, control, instrumentation and telecommunication cables*

IEC 60092-376, *Electrical installations in ships - Part 376: Cables for control and instrumentation circuits 150/250 V (300 V)*

IEC 60092-378, *Electrical installations in ships - Part 378: Optical fiber cables*

This is a preview of IEC 60092-352 Ed. 4.0 en:2025. [Click here to purchase the full version from the ANSI store.](#)

with transmission characteristics up to 1 000 MHz

IEC 60092-401, *Electrical installations in ships - Part 401: Installation and test of completed installation*

IEC 60228, *Conductors of insulated cables*

IEC 60287 (all parts), *Electric cables - Calculation of the current rating*

IEC 60331-1:2018, *Tests for electric cables under fire conditions - Circuit integrity - Part 1: Test method for fire with shock at a temperature of at least 830 °C for cables of rated voltage up to and including 0,6/1,0 kV and with an overall diameter exceeding 20 mm*

IEC 60331-2:2018, *Tests for electric cables under fire conditions - Circuit integrity - Part 2: Test method for fire with shock at a temperature of at least 830 °C for cables of rated voltage up to and including 0,6/1,0 kV and with an overall diameter not exceeding 20 mm*

IEC 60332-1-2:2025, *Tests on electric and optical fibre cables under fire conditions - Part 1-2: Test for vertical flame propagation for a single insulated wire or cable - Procedure for 1 kW pre-mixed flame*

IEC 60332-3-22, *Tests on electric and optical fibre cables under fire conditions - Part 3-22: Test for vertical flame spread of vertically-mounted bunched wires or cables - Category A*

IEC 60332-3-24, *Tests on electric and optical fibre cables under fire conditions - Part 3-24: Test for vertical flame spread of vertically-mounted bunched wires or cables - Category C*

IEC 60332-3-25, *Tests on electric and optical fibre cables under fire conditions - Part 3-25: Test for vertical flame spread of vertically-mounted bunched wires or cables - Category D*

IEC 60533, *Electrical and electronic installations in ships - Electromagnetic compatibility (EMC)*

IEC 60684-2, *Flexible insulating sleeving - Part 2: Methods of test*

IEC 60754-1, *Test on gases evolved during combustion of materials from cables - Part 1: Determination of the halogen acid gas content*

IEC 60754-2, *Test on gases evolved during combustion of materials from cables - Part 2: Determination of acidity (by pH measurement) and conductivity*

IEC 61034-2:2005+AMD1:2013+AMD2:2019, *Measurement of smoke density of cables burning under defined conditions - Part 2: Test procedure and requirements*