



Edition 4.0 2024-03
EXTENDED VERSION

INTERNATIONAL STANDARD



This extended version of IEC 600669-2-2:2024 includes the content of the references made to IEC 60669-1:2017

Switches for household and similar fixed electrical installations – Part 2-2: Particular requirements – Electromagnetic remote-control switches (RCS)

INTERNATIONAL
ELECTROTECHNICAL
COMMISSION

ICS 29.120.40

ISBN 978-2-8322-8529-9

Warning! Make sure that you obtained this publication from an authorized distributor.

CONTENTS

FOREWORD	7
1 Scope	10
2 Normative references	11
3 Terms and definitions	13
4 General requirements	19
5 General remarks on tests	19
5.101 Incorporated hand-operated device	21
6 Ratings	21
6.1 Rated voltage	21
6.2 Rated current	22
6.3 Preferred combinations of number of poles and ratings	22
6.101 Rated control voltage	23
7 Classification	23
8 Marking	25
8.1 General	25
8.2 Symbols	25
8.3 Visibility of markings	27
8.4 Marking on terminals for phase conductors	27
8.5 Marking on terminals for neutral and earth conductors	28
8.6 Marking of the switch position	28
8.7 Additional requirements for marking	29
8.8 Durability	29
9 Checking of dimensions	29
10 Protection against electric shock	30
10.1 Prevention of access to live parts	30
10.2 Requirements for operating parts	30
10.3 Requirements for accessible metal parts	30
10.4 Requirements for insulation of the mechanism	31
10.5 Requirements for insulation of the mechanism with respect to the surrounding environment	31
10.6 Requirements for switches operated indirectly	32
10.7 Requirements for switches with replaceable pull cord	32
11 Provision for earthing	32
11.1 General	32
11.2 Earthing terminals	32
11.3 Requirements for surface-type switches	32
11.4 Test for earthing connection	33
12 Terminals	33
12.1 General	33
12.2 Terminals with screw clamping for external copper conductors	33
12.3 Screwless terminals for external copper conductors	40
13 Constructional requirements	45
13.1 Mechanical requirements for insulating means	45
13.2 Installation requirements	46
13.3 Fixing of covers, cover plates and actuating members	47
13.4 Openings in normal use	48

13.5	Attachment of knobs	48
13.6	Mounting means	49
13.7	Combination of switches	49
13.8	Accessories combined with switches.....	49
13.9	Surface-type switches having an IP code higher than IP20	49
13.10	Installation in a box.....	50
13.11	Connection of a second current-carrying conductor.....	50
13.12	Inlet openings	50
13.13	Provision for back entry from a conduit	51
13.14	Switch provided with membranes or the like for inlet openings.....	52
13.15	Requirements for membranes in inlet openings.....	52
13.16	Pilot light units	53
13.101	Transformers intended for SELV circuits	53
14	Mechanism	53
14.1	Indication of the position	53
14.2	Rest and intermediate position.....	53
14.3	Undue arcing	53
14.4	Making and breaking.....	53
14.5	Action of the mechanism without cover or cover plate	54
14.6	Pull force for cord-operated switches	54
14.101	Hand-operated device with position indicator	54
15	Resistance to ageing, protection provided by enclosures of switches and resistance to humidity.....	54
15.1	Resistance to ageing	54
15.2	Protection provided by enclosures of switches	55
15.2.1	General	55
15.2.2	Protection against access to hazardous parts and against harmful effects due to ingress of solid foreign objects	55
15.2.3	Protection against harmful effects due to ingress of water	56
15.3	Resistance to humidity.....	57
16	Insulation resistance and electric strength	57
16.1	General.....	57
16.2	Test for measuring the insulation resistance	58
16.3	Electric strength test	60
17	Temperature rise	62
17.1	General.....	62
17.2	Switches incorporating pilot lights	64
18	Making and breaking capacity.....	64
18.1	General.....	64
18.2	Overload	65
18.3	Overload test with filament lamps	66
19	Normal operation	67
19.1	Test for switches intended for inductive loads	67
19.2	Test for switches intended for externally ballasted lamp loads	69
19.3	Test for switches intended for self ballasted lamp loads	72
19.101	RCS energized by impulses	75
19.102	RCS permanently energized	75
20	Mechanical strength	76

20.1	General.....	76
20.2	Pendulum hammer test	76
20.3	Test on the main parts of surface-type switches.....	78
20.4	Screwed glands	79
20.5	Covers, cover plates or actuating members – accessibility to live parts.....	79
20.5.1	General	79
20.5.2	Verification of the non-removal of covers, cover plates or actuating members	79
20.5.3	Verification of the removal of covers, cover plates or actuating members.....	80
20.6	Covers, cover plates or actuating members – accessibility to non-earthed metal parts separated from live parts	80
20.7	Covers, cover plates or actuating members – accessibility to insulating parts, earthed metal parts, the live parts of SELV ≤ 25 V AC and 60 V DC or metal parts separated from live parts	80
20.8	Covers, cover plates or actuating members – application of gauges.....	80
20.9	Grooves, holes and reverse tapers	80
20.10	Additional test for cord-operated switch	81
21	Resistance to heat.....	81
21.1	General.....	81
21.2	Basic heating test	81
21.3	Ball-pressure test on parts of insulating material necessary to retain current-carrying parts and parts of the earthing circuit in position.....	82
21.4	Ball-pressure test on parts of insulating material not necessary to retain current-carrying parts and parts of the earthing circuit in position.....	82
22	Screws, current-carrying parts and connections.....	82
22.1	General.....	82
22.2	Correct insertion of screws	83
22.3	Contact pressure of electrical connections	83
22.4	Screws and rivets used both as electrical and mechanical connections.....	83
22.5	Material of current-carrying parts	84
22.6	Contacts subjected to sliding actions	84
22.7	Thread-forming and thread-cutting screws	85
23	Creepage distances, clearances and distances through sealing compound.....	85
23.1	General.....	85
23.2	Insulating compound.....	89
23.101	Control circuits suitable for connections to a SELV	89
23.102	Use of enamel wires	89
24	Resistance of insulating material to abnormal heat, to fire and to tracking	89
24.1	Resistance to abnormal heat and to fire	89
24.2	Resistance to tracking.....	90
25	Resistance to rusting	91
26	EMC requirements	91
26.1	Immunity	91
26.2	Emission.....	91
101	Abnormal operation of the control circuit.....	91
Annex A (normative) Additional requirements for switches having facilities for the outlet and retention of flexible cables		112
Annex B (informative) Changes planned for the future in order to align IEC 60669-1 with the requirements of IEC 60998 (all parts), IEC 60999 (all parts) and IEC 60228		115

Annex C (informative) Circuit development (19.3)	116
C.1 Rationale	116
C.2 I_{peak} and I^2t for normal operation tests	116
C.2.1 General	116
C.2.2 Switching a single lamp	116
C.2.3 Switching multiple lamps	118
Annex D (informative) Additional requirements for insulation-piercing terminals	120
Annex E (informative) Additional requirements and tests for switches intended to be used at a temperature lower than $-5\text{ }^{\circ}\text{C}$	130
Bibliography	132
Figure 1 – Pillar terminals	93
Figure 2 – Screw head terminals and stud terminals	95
Figure 3 – Saddle terminals	95
Figure 4 – Lug terminals	96
Figure 5 – Mantle terminals	97
Figure 6 – Thread-forming screw	97
Figure 7 – Thread-cutting screw	97
Figure 8 – Classification according to connections	98
Figure 9 – Test apparatus for checking damage to conductors	99
Figure 10 – Information for deflection test	100
Figure 11 – Circuit diagrams for making and breaking capacity and normal operation	101
Figure 12 – Circuit diagrams for testing switches	102
Figure 13 – Arrangement for test on cover-plates	102
Figure 14 – Gauge (thickness: about 2 mm) for the verification of the outline of covers, cover-plates or actuating members	103
Figure 15 – Example of application of the gauge of Figure 14 on covers fixed without screws on a mounting surface or supporting surface	104
Figure 16 – Examples of applications of the gauge of Figure 14 in accordance with the requirements of 20.8	105
Figure 17 – Gauge for verification of grooves, holes and reverse tapers	106
Figure 18 – Sketch showing the direction of application of the gauge of Figure 17	106
Figure 19 – Ball-pressure apparatus	107
Figure 20 – Determining parts of insulating material to be tested – Diagrammatic representation (see 24.1)	107
Figure 21 – Test wall in accordance with the requirements of 15.2.3	108
Figure 22 – Direction for the conductor pull of 30 N for 1 min	110
Figure 23 – Examples of membranes and grommets	111
Figure C.1 – 120 V 15 W (LT spice model)	117
Figure C.2 – 230 V 15 W (LT spice model)	118
Figure C.3 – Model for multiple lamp loads	119
Figure C.4 – I_{peak} and I^2t for multiple lamp loads	119
Figure D.1 – Example of insulation-piercing terminals	128
Figure D.2 – Example of test-points	128
Figure D.3 – Temperature cycle for the voltage drop test of 12.4.11	129

Table 1 – Number of specimens needed for the tests	20
Table 2 – Relationship between rated current of the switch and rated power of the SBL circuit.....	22
Table 3 – Preferred combinations of numbers of poles and ratings	22
Table 4 – Relationship between rated currents and connectable cross-sectional areas of copper conductors	34
Table 5 – Tightening torque for the verification of the mechanical strength of screw-type terminals	36
Table 6 – Test values for flexion and pull out for copper conductors	37
Table 7 – Test values for pulling out test.....	38
Table 8 – Relationship between rated currents and connectable cross-sectional areas of copper conductors for screwless terminals.....	40
Table 9 – Test current for the verification of electrical and thermal stresses in normal use of screwless terminals	43
Table 10 – Cross-sectional areas of rigid copper conductors for deflection test of screwless terminals	45
Table 11 – Deflection test forces.....	45
Table 12 – Forces to be applied to covers, cover-plates or actuating members whose fixing is not dependent on screws	48
Table 13 – External cable diameter limits for surface type switches	51
Table 14 – Points of application of the test voltage for the verification of insulation resistance and electric strength	58
Table 15 – Test voltage, points of application and minimum values of insulating resistance for the verification of electric strength	61
Table 16 – Temperature-rise test currents and cross-sectional areas of copper conductors	62
Table 101 – Temperature-rise limits for insulated coils in air.....	64
Table 17 – Fractions of total number of operations.....	65
Table 18 – Number of operations for normal operation test	68
Table 19 – Values for I_{peak} and I^2t depending on the type of distribution system	73
Table 20 – Calculated circuit parameters	73
Table 21 – Height of fall for impact test.....	77
Table 22 – Torque for the verification of the mechanical strength of glands	79
Table 23 – Creepage distances, clearances and distances through insulating sealing compound.....	86
Table A.1 – Limits of external dimensions of flexible cables	113
Table C.1 – Lamp	116
Table D.1 – Specimens needed for Clause 12 for insulation-piercing terminals (IPTs)	121
Table D.2 – Relationship between rated currents and connectable cross-sectional areas of copper conductors for insulation-piercing terminals	123
Table D.3 – Test current for the verification of electrical and thermal stresses in normal use of insulation-piercing terminals	127

INTERNATIONAL ELECTROTECHNICAL COMMISSION

SWITCHES FOR HOUSEHOLD AND SIMILAR FIXED ELECTRICAL INSTALLATIONS –

Part 2-2: Particular requirements – Electromagnetic remote-control switches (RCS)

FOREWORD

- 1) The International Electrotechnical Commission (IEC) is a worldwide organization for standardization comprising all national electrotechnical committees (IEC National Committees). The object of IEC is to promote international co-operation on all questions concerning standardization in the electrical and electronic fields. To this end and in addition to other activities, IEC publishes International Standards, Technical Specifications, Technical Reports, Publicly Available Specifications (PAS) and Guides (hereafter referred to as "IEC Publication(s)"). Their preparation is entrusted to technical committees; any IEC National Committee interested in the subject dealt with may participate in this preparatory work. International, governmental and non-governmental organizations liaising with the IEC also participate in this preparation. IEC collaborates closely with the International Organization for Standardization (ISO) in accordance with conditions determined by agreement between the two organizations.
- 2) The formal decisions or agreements of IEC on technical matters express, as nearly as possible, an international consensus of opinion on the relevant subjects since each technical committee has representation from all interested IEC National Committees.
- 3) IEC Publications have the form of recommendations for international use and are accepted by IEC National Committees in that sense. While all reasonable efforts are made to ensure that the technical content of IEC Publications is accurate, IEC cannot be held responsible for the way in which they are used or for any misinterpretation by any end user.
- 4) In order to promote international uniformity, IEC National Committees undertake to apply IEC Publications transparently to the maximum extent possible in their national and regional publications. Any divergence between any IEC Publication and the corresponding national or regional publication shall be clearly indicated in the latter.
- 5) IEC itself does not provide any attestation of conformity. Independent certification bodies provide conformity assessment services and, in some areas, access to IEC marks of conformity. IEC is not responsible for any services carried out by independent certification bodies.
- 6) All users should ensure that they have the latest edition of this publication.
- 7) No liability shall attach to IEC or its directors, employees, servants or agents including individual experts and members of its technical committees and IEC National Committees for any personal injury, property damage or other damage of any nature whatsoever, whether direct or indirect, or for costs (including legal fees) and expenses arising out of the publication, use of, or reliance upon, this IEC Publication or any other IEC Publications.
- 8) Attention is drawn to the Normative references cited in this publication. Use of the referenced publications is indispensable for the correct application of this publication.
- 9) IEC draws attention to the possibility that the implementation of this document may involve the use of (a) patent(s). IEC takes no position concerning the evidence, validity or applicability of any claimed patent rights in respect thereof. As of the date of publication of this document, IEC had not received notice of (a) patent(s), which may be required to implement this document. However, implementers are cautioned that this may not represent the latest information, which may be obtained from the patent database available at <https://patents.iec.ch>. IEC shall not be held responsible for identifying any or all such patent rights.

This extended version (EXV) of the official IEC Standard provides the user with the comprehensive content of the Standard.

IEC 60669-2-2:2024 EXV includes the content of IEC 60669-2-2:2024, and the references made to IEC 60669-1:2017.

The specific content of IEC 60669-2-2:2024 is displayed on a **blue background.**

IEC 60669-2-2 has been prepared by subcommittee 23B: Plugs, socket-outlets and switches, of IEC technical committee 23: Electrical accessories. It is an International Standard.

This fourth edition cancels and replaces the third edition published in 2006. This edition constitutes a technical revision.

This edition includes the following significant technical changes with respect to the previous edition:

- a) Revision of the present edition with reference to IEC 60669-1:2017 (Edition 4);
- b) Introduction of a revision to Annex E "Additional requirements and tests for switches intended to be used at a temperature lower than $-5\text{ }^{\circ}\text{C}$ ".

The text of this International Standard is based on the following documents:

Draft	Report on voting
23B/1486/FDIS	23B/1500/RVD

Full information on the voting for its approval can be found in the report on voting indicated in the above table.

The language used for the development of this International Standard is English.

This document was drafted in accordance with ISO/IEC Directives, Part 2, and developed in accordance with ISO/IEC Directives, Part 1 and ISO/IEC Directives, IEC Supplement, available at www.iec.ch/members_experts/refdocs. The main document types developed by IEC are described in greater detail at www.iec.ch/publications.

This part of IEC 60669 is to be used in conjunction with IEC 60669-1:2017. It lists the changes necessary to convert that standard into a specific standard for electromagnetic remote-control switches.

When a particular subclause of IEC 60669-1:2017 is not mentioned in this document, that subclause applies as far as reasonable.

In this document, the following print types are used:

- requirements proper: in roman type;
- *test specifications: in italic type;*
- notes: in smaller roman type.

Subclauses, figures or tables or notes which are additional to those in IEC 60669-1:2017 are numbered starting from 101.

A list of all parts of IEC 60669 series, under the general title *Switches for household and similar fixed electrical installations*, can be found on the IEC website.

The committee has decided that the contents of this document will remain unchanged until the stability date indicated on the IEC website under webstore.iec.ch in the data related to the specific document. At this date, the document will be

- reconfirmed,
- withdrawn, or
- revised.

IMPORTANT – The "colour inside" logo on the cover page of this document indicates that it contains colours which are considered to be useful for the correct understanding of its contents. Users should therefore print this document using a colour printer.

SWITCHES FOR HOUSEHOLD AND SIMILAR FIXED ELECTRICAL INSTALLATIONS –

Part 2-2: Particular requirements – Electromagnetic remote-control switches (RCS)

1 Scope

This part of IEC 60669 applies to electromagnetic remote control switches (hereinafter referred to as electromagnetic RCS) with a rated voltage not exceeding 440 V AC and a rated current not exceeding 63 A, intended for household and similar fixed electrical installations, either indoors or outdoors. For the control circuit, the rated control voltage does not exceed 440 V AC or 220 V DC.

The RCS coil can be either permanently energized or not permanently energized.

Electronic RCS are within the scope of IEC 60669-2-1 but not of this document.

RCS including only passive components such as resistors, capacitors, positive temperature coefficient (PTC) and negative temperature coefficient (NTC) components and printed circuit boards are not considered to be electronic RCS.

Electromechanical contactors for household and similar purposes are within the scope of IEC 61095.

For switches provided with screwless terminals, the rated current is limited to 16 A.

NOTE 1 The rated current is limited to 16 A for switches provided with insulation piercing terminals (IPT's) according to Annex D.

Switches covered by this document are, where applicable, intended for the control in normal use of all of the following loads:

- a circuit for a tungsten filament lamp load;
- a circuit for an externally ballasted lamp load (for example LED, CFL, fluorescent lamp load);
- a circuit for a self ballasted lamp load (for example LEDi or CFLi);
- a circuit for a substantially resistive load with a power factor not less than 0,95;
- a single phase circuit for motor load with a rated current not exceeding 3 A at 250 V (750 VA) and 4,5 A at 120 V (540 VA) and a power factor not less than 0,6. This applies to both switches rated not less than 10 A that have not undergone additional tests and to momentary switches rated not less than 6 A that have not undergone additional tests.

NOTE 2 In the following country the suitability of a switch intended to control the inrush current of a motor shall be tested: AU.

This document also applies to boxes for switches, with the exception of mounting boxes for flush-type switches.

NOTE 3 General requirements for boxes for flush-type switches are given in IEC 60670-1.

It also applies to switches such as

- switches incorporating pilot lights;

- electromagnetic remote control switches (particular requirements are given in IEC 60669-2-2);
- switches incorporating a time-delay device (particular requirements are given in IEC 60669-2-3);
- combinations of switches and other functions (with the exception of switches combined with fuses);
- electronic switches (particular requirements are given in IEC 60669-2-1);
- switches having facilities for the outlet and retention of flexible cables (see Annex A);
- isolating switches (particular requirements are given in IEC 60669-2-4);
- switches and related accessories for use in home and building electronic systems (particular requirements are given in IEC 60669-2-5);
- firemen's switches (particular requirements are given in IEC 60669-2-6).

Switches complying with this document are suitable for use at ambient temperatures not normally exceeding +40 °C, but their average over a period of 24 h does not exceed +35 °C, with a lower limit of the ambient air temperature of –5 °C.

NOTE 4 For lower temperatures see Annex E.

Switches complying with this document are suitable only for incorporation in equipment in such a way and in such a place that it is unlikely that the surrounding ambient temperature exceeds +35 °C.

In locations where special conditions prevail, such as in ships, vehicles and the like and in hazardous locations, for example where explosions are liable to occur, special construction and/or additional requirements may be required.

2 Normative references

The following documents are referred to in the text in such a way that some or all of their content constitutes requirements of this document. For dated references, only the edition cited applies. For undated references, the latest edition of the referenced document (including any amendments) applies.

IEC 60038:2009, *IEC standard voltages*

IEC 60068-2-75:2014, *Environmental testing – Part 2-75: Tests – Test Eh: Hammer tests*

IEC 60085:2007, *Electrical insulation – Thermal evaluation and designation*

IEC 60112:2009, *Method for the determination of the proof and the comparative tracking indices of solid insulating materials*

IEC 60212:2010, *Standard conditions for use prior to and during the testing of solid electrical insulation materials*

IEC 60227-5:2011, *Polyvinyl chloride insulated cables of rated voltages up to and including 450/750 V – Part 5: Flexible cables (cords)*

IEC 60228:2004, *Conductors of insulated cables*

IEC 60245-4:2011, *Rubber insulated cables – Rated voltages up to and including 450/750 V – Part 4: Cords and flexible cables*

IEC 60317 (all parts), *Specifications for particular types of winding wires*

IEC 60417, *Graphical symbols for use on equipment* (available from: <http://www.graphical-symbols.info/equipment>)

IEC 60445:2021, *Basic and safety principles for man-machine interface, marking and identification – Identification of equipment terminals, conductor terminations and conductors*

IEC 60529:1989, *Degrees of protection provided by enclosures (IP Code)*
IEC 60529:1989/AMD1:1999
IEC 60529:1989/AMD2:2013

IEC 60664-1:2020, *Insulation coordination for equipment within low-voltage systems – Part 1: Principles, requirements and tests*

IEC 60664-3:2016, *Insulation coordination for equipment within low-voltage systems – Part 3: Use of coating, potting or moulding for protection against pollution*

IEC 60669-1:2017, *Switches for household and similar fixed electrical installations – Part 1: General requirements*

IEC 60669-2-1:2002, *Switches for household and similar fixed electrical installations – Part 2-1: Particular requirements – Electronic switches*
IEC 60669-2-1:2002/AMD1:2008
IEC 60669-2-1:2002/AMD2:2015

IEC 60695-2-10:2000, *Fire hazard testing – Part 2-10: Glowing/hot-wire based test methods – Glow-wire apparatus and common test procedure*

IEC 60695-2-11:2014, *Fire hazard testing – Part 2-11: Glowing/hot-wire based test methods – Glow-wire flammability test method for end-products (GWEPT)*

IEC 60998-1:2002, *Connecting devices for low-voltage circuits for household and similar purposes – Part 1: General requirements*

IEC 60998-2-1, *Connecting devices for low-voltage circuits for household and similar purposes – Part 2-1: Particular requirements for connecting devices as separate entities with screw-type clamping units*

IEC 60998-2-2, *Connecting devices for low-voltage circuits for household and similar purposes – Part 2-2: Particular requirements for connecting devices as separate entities with screwless-type clamping units*

IEC 60998-2-3, *Connecting devices for low-voltage circuits for household and similar purposes – Part 2-3: Particular requirements for connecting devices as separate entities with insulation-piercing clamping units*

IEC 60998-2-4, *Connecting devices for low-voltage circuits for household and similar purposes – Part 2-4: Particular requirements for twist-on connecting devices*

IEC 61032:1997, *Protection of persons and equipment by enclosures – Probes for verification*

IEC 61558-2-6:2021, *Safety of transformers, reactors, power supply units and combinations thereof – Part 2-6: Particular requirements and tests for safety isolating transformers and power supply units incorporating safety isolating transformers for general applications*

ISO 1456:2009, *Metallic and other inorganic coatings – Electrodeposited coatings of nickel, nickel plus chromium, copper plus nickel and of copper plus nickel plus chromium*

ISO 2081:2008, *Metallic and other inorganic coatings – Electroplated coatings of zinc with supplementary treatments on iron or steel*

ISO 2093:1986, *Electroplated coatings of tin – Specification and test methods*



INTERNATIONAL STANDARD

NORME INTERNATIONALE

**Switches for household and similar fixed electrical installations –
Part 2-2: Particular requirements – Electromagnetic remote-control switches
(RCS)**

**Interrupteurs pour installations électriques fixes domestiques et analogues –
Partie 2-2: Exigences particulières – Interrupteurs à commande à distance
(télérupteurs)**

CONTENTS

FOREWORD	3
1 Scope	5
2 Normative references	5
3 Terms and definitions	6
4 General requirements	7
5 General remarks on tests	8
6 Ratings	8
7 Classification	9
8 Marking	9
9 Checking of dimensions	10
10 Protection against electric shock	10
11 Provision for earthing	10
12 Terminals	10
13 Constructional requirements	10
14 Mechanism	11
15 Resistance to ageing, protection provided by enclosures of switches and resistance to humidity	11
16 Insulation resistance and electric strength	11
17 Temperature rise	12
18 Making and breaking capacity	12
19 Normal operation	13
20 Mechanical strength	14
21 Resistance to heat	14
22 Screws, current-carrying parts and connections	14
23 Creepage distances, clearances and distances through sealing compound	14
24 Resistance of insulating material to abnormal heat, to fire and to tracking	16
25 Resistance to rusting	16
26 EMC requirements	16
Annexes	18
Annex B (informative) Changes planned for the future in order to align IEC 60669-1 with the requirements of IEC 60998 (all parts), IEC 60999 (all parts) and IEC 60228	19
Annex E (informative) Additional requirements and tests for switches intended to be used at a temperature lower than $-5\text{ }^{\circ}\text{C}$	20
Bibliography	21
Table 1 – Number of specimens needed for the tests	8
Table 15 – Test voltage, points of application and minimum values of insulating resistance for the verification of electric strength	11
Table 101 – Temperature-rise limits for insulated coils in air	12
Table 102 – Creepage distances, clearances and distances through insulating sealing compound	15

INTERNATIONAL ELECTROTECHNICAL COMMISSION

SWITCHES FOR HOUSEHOLD AND SIMILAR FIXED ELECTRICAL INSTALLATIONS –

Part 2-2: Particular requirements – Electromagnetic remote-control switches (RCS)

FOREWORD

- 1) The International Electrotechnical Commission (IEC) is a worldwide organization for standardization comprising all national electrotechnical committees (IEC National Committees). The object of IEC is to promote international co-operation on all questions concerning standardization in the electrical and electronic fields. To this end and in addition to other activities, IEC publishes International Standards, Technical Specifications, Technical Reports, Publicly Available Specifications (PAS) and Guides (hereafter referred to as "IEC Publication(s)"). Their preparation is entrusted to technical committees; any IEC National Committee interested in the subject dealt with may participate in this preparatory work. International, governmental and non-governmental organizations liaising with the IEC also participate in this preparation. IEC collaborates closely with the International Organization for Standardization (ISO) in accordance with conditions determined by agreement between the two organizations.
- 2) The formal decisions or agreements of IEC on technical matters express, as nearly as possible, an international consensus of opinion on the relevant subjects since each technical committee has representation from all interested IEC National Committees.
- 3) IEC Publications have the form of recommendations for international use and are accepted by IEC National Committees in that sense. While all reasonable efforts are made to ensure that the technical content of IEC Publications is accurate, IEC cannot be held responsible for the way in which they are used or for any misinterpretation by any end user.
- 4) In order to promote international uniformity, IEC National Committees undertake to apply IEC Publications transparently to the maximum extent possible in their national and regional publications. Any divergence between any IEC Publication and the corresponding national or regional publication shall be clearly indicated in the latter.
- 5) IEC itself does not provide any attestation of conformity. Independent certification bodies provide conformity assessment services and, in some areas, access to IEC marks of conformity. IEC is not responsible for any services carried out by independent certification bodies.
- 6) All users should ensure that they have the latest edition of this publication.
- 7) No liability shall attach to IEC or its directors, employees, servants or agents including individual experts and members of its technical committees and IEC National Committees for any personal injury, property damage or other damage of any nature whatsoever, whether direct or indirect, or for costs (including legal fees) and expenses arising out of the publication, use of, or reliance upon, this IEC Publication or any other IEC Publications.
- 8) Attention is drawn to the Normative references cited in this publication. Use of the referenced publications is indispensable for the correct application of this publication.
- 9) IEC draws attention to the possibility that the implementation of this document may involve the use of (a) patent(s). IEC takes no position concerning the evidence, validity or applicability of any claimed patent rights in respect thereof. As of the date of publication of this document, IEC had not received notice of (a) patent(s), which may be required to implement this document. However, implementers are cautioned that this may not represent the latest information, which may be obtained from the patent database available at <https://patents.iec.ch>. IEC shall not be held responsible for identifying any or all such patent rights.

IEC 60669-2-2 has been prepared by subcommittee 23B: Plugs, socket-outlets and switches, of IEC technical committee 23: Electrical accessories. It is an International Standard.

This fourth edition cancels and replaces the third edition published in 2006. This edition constitutes a technical revision.

This edition includes the following significant technical changes with respect to the previous edition:

- a) Revision of the present edition with reference to IEC 60669-1:2017 (Edition 4);
- b) Introduction of a revision to Annex E "Additional requirements and tests for switches intended to be used at a temperature lower than -5 °C ".

The text of this International Standard is based on the following documents:

Draft	Report on voting
23B/1486/FDIS	23B/1500/RVD

Full information on the voting for its approval can be found in the report on voting indicated in the above table.

The language used for the development of this International Standard is English.

This document was drafted in accordance with ISO/IEC Directives, Part 2, and developed in accordance with ISO/IEC Directives, Part 1 and ISO/IEC Directives, IEC Supplement, available at www.iec.ch/members_experts/refdocs. The main document types developed by IEC are described in greater detail at www.iec.ch/publications.

This part of IEC 60669 is to be used in conjunction with IEC 60669-1:2017. It lists the changes necessary to convert that standard into a specific standard for electromagnetic remote-control switches.

When a particular subclause of IEC 60669-1:2017 is not mentioned in this document, that subclause applies as far as reasonable.

In this document, the following print types are used:

- requirements proper: in roman type;
- *test specifications: in italic type;*
- notes: in smaller roman type.

Subclauses, figures or tables or notes which are additional to those in IEC 60669-1:2017 are numbered starting from 101.

A list of all parts of IEC 60669 series, under the general title *Switches for household and similar fixed electrical installations*, can be found on the IEC website.

The committee has decided that the contents of this document will remain unchanged until the stability date indicated on the IEC website under webstore.iec.ch in the data related to the specific document. At this date, the document will be

- reconfirmed,
- withdrawn, or
- revised.

SWITCHES FOR HOUSEHOLD AND SIMILAR FIXED ELECTRICAL INSTALLATIONS –

Part 2-2: Particular requirements – Electromagnetic remote-control switches (RCS)

1 Scope

IEC 60669-1:2017, Clause 1 is applicable except as follows:

Replacement of the first paragraph with the following:

This part of IEC 60669 applies to electromagnetic remote control switches (hereinafter referred to as electromagnetic RCS) with a rated voltage not exceeding 440 V AC and a rated current not exceeding 63 A, intended for household and similar fixed electrical installations, either indoors or outdoors. For the control circuit, the rated control voltage does not exceed 440 V AC or 220 V DC.

The RCS coil can be either permanently energized or not permanently energized.

Electronic RCS are within the scope of IEC 60669-2-1 but not of this document.

RCS including only passive components such as resistors, capacitors, positive temperature coefficient (PTC) and negative temperature coefficient (NTC) components and printed circuit boards are not considered to be electronic RCS.

Electromechanical contactors for household and similar purposes are within the scope of IEC 61095.

2 Normative references

IEC 60669-1:2017, Clause 2 is applicable with the following additions:

IEC 60085:2007, *Electrical insulation – Thermal evaluation and designation*

IEC 60317 (all parts), *Specifications for particular types of winding wires*

IEC 60445:2021, *Basic and safety principles for man-machine interface, marking and identification – Identification of equipment terminals, conductor terminations and conductors*

IEC 60664-1:2020, *Insulation coordination for equipment within low-voltage systems – Part 1: Principles, requirements and tests*

IEC 60664-3:2016, *Insulation coordination for equipment within low-voltage systems – Part 3: Use of coating, potting or moulding for protection against pollution*

IEC 60669-1:2017, *Switches for household and similar fixed electrical installations – Part 1: General requirements*

IEC 61558-2-6:2021, *Safety of transformers, reactors, power supply units and combinations thereof – Part 2-6: Particular requirements and tests for safety isolating transformers and power supply units incorporating safety isolating transformers for general applications*

SOMMAIRE

AVANT-PROPOS	24
1 Domaine d'application	26
2 Références normatives	26
3 Termes et définitions	27
4 Exigences générales	29
5 Généralités sur les essais.....	29
6 Caractéristiques assignées.....	30
7 Classification	30
8 Marquage	31
9 Vérification des dimensions	32
10 Protection contre les chocs électriques.....	32
11 Dispositions pour assurer la mise à la terre	32
12 Bornes.....	32
13 Exigences constructives	32
14 Mécanisme	32
15 Résistance au vieillissement, protection procurée par les enveloppes des interrupteurs et résistance à l'humidité	32
16 Résistance d'isolement et rigidité diélectrique	32
17 Échauffement	33
18 Pouvoir de fermeture et de coupure.....	34
19 Fonctionnement normal	34
20 Résistance mécanique.....	35
21 Résistance à la chaleur	35
22 Vis, parties transportant le courant et connexions.....	35
23 Lignes de fuite, distances d'isolement dans l'air et distances à travers la matière de remplissage	35
24 Résistance de la matière isolante à une chaleur anormale, au feu et aux courants de cheminement	37
25 Protection contre la rouille.....	38
26 Exigences de compatibilité électromagnétique.....	38
101 Fonctionnement anormal du circuit de commande.....	38
Annexes	39
Annexe B (informative) Modifications prévues pour aligner l'IEC 60669-1 avec les exigences de l'IEC 60998 (toutes les parties), de l'IEC 60999 (toutes les parties) et de l'IEC 60228	40
Annexe E (informative) Exigences et essais supplémentaires pour les interrupteurs à utiliser à une température inférieure à -5 °C.....	41
Bibliographie.....	42
Tableau 1 – Nombre d'échantillons nécessaires pour les essais	29
Tableau 15 – Tension d'essai, points d'application et valeurs minimales de résistance d'isolement pour la vérification de la rigidité diélectrique.....	33
Tableau 101 – Limites d'échauffement des bobines isolées dans l'air	34

Tableau 23 – Lignes de fuite, distances d'isolement dans l'air et distances à travers la matière de remplissage.....	36
--	----

COMMISSION ÉLECTROTECHNIQUE INTERNATIONALE

INTERRUPTEURS POUR INSTALLATIONS ÉLECTRIQUES FIXES DOMESTIQUES ET ANALOGUES –

Partie 2-2: Exigences particulières – Interrupteurs à commande à distance (télerrupteurs)

AVANT-PROPOS

- 1) La Commission Électrotechnique Internationale (IEC) est une organisation mondiale de normalisation composée de l'ensemble des comités électrotechniques nationaux (Comités nationaux de l'IEC). L'IEC a pour objet de favoriser la coopération internationale pour toutes les questions de normalisation dans les domaines de l'électricité et de l'électronique. À cet effet, l'IEC – entre autres activités – publie des Normes internationales, des Spécifications techniques, des Rapports techniques, des Spécifications accessibles au public (PAS) et des Guides (ci-après dénommés "Publication(s) de l'IEC"). Leur élaboration est confiée à des comités d'études, aux travaux desquels tout Comité national intéressé par le sujet traité peut participer. Les organisations internationales, gouvernementales et non gouvernementales, en liaison avec l'IEC, participent également aux travaux. L'IEC collabore étroitement avec l'Organisation Internationale de Normalisation (ISO), selon des conditions fixées par accord entre les deux organisations.
- 2) Les décisions ou accords officiels de l'IEC concernant les questions techniques représentent, dans la mesure du possible, un accord international sur les sujets étudiés, étant donné que les Comités nationaux de l'IEC intéressés sont représentés dans chaque comité d'études.
- 3) Les Publications de l'IEC se présentent sous la forme de recommandations internationales et sont agréées comme telles par les Comités nationaux de l'IEC. Tous les efforts raisonnables sont entrepris afin que l'IEC s'assure de l'exactitude du contenu technique de ses publications; l'IEC ne peut pas être tenue responsable de l'éventuelle mauvaise utilisation ou interprétation qui en est faite par un quelconque utilisateur final.
- 4) Dans le but d'encourager l'uniformité internationale, les Comités nationaux de l'IEC s'engagent, dans toute la mesure possible, à appliquer de façon transparente les Publications de l'IEC dans leurs publications nationales et régionales. Toutes divergences entre toutes Publications de l'IEC et toutes publications nationales ou régionales correspondantes doivent être indiquées en termes clairs dans ces dernières.
- 5) L'IEC elle-même ne fournit aucune attestation de conformité. Des organismes de certification indépendants fournissent des services d'évaluation de conformité et, dans certains secteurs, accèdent aux marques de conformité de l'IEC. L'IEC n'est responsable d'aucun des services effectués par les organismes de certification indépendants.
- 6) Tous les utilisateurs doivent s'assurer qu'ils sont en possession de la dernière édition de cette publication.
- 7) Aucune responsabilité ne doit être imputée à l'IEC, à ses administrateurs, employés, auxiliaires ou mandataires, y compris ses experts particuliers et les membres de ses comités d'études et des Comités nationaux de l'IEC, pour tout préjudice causé en cas de dommages corporels et matériels, ou de tout autre dommage de quelque nature que ce soit, directe ou indirecte, ou pour supporter les coûts (y compris les frais de justice) et les dépenses découlant de la publication ou de l'utilisation de cette Publication de l'IEC ou de toute autre Publication de l'IEC, ou au crédit qui lui est accordé.
- 8) L'attention est attirée sur les références normatives citées dans cette publication. L'utilisation de publications référencées est obligatoire pour une application correcte de la présente publication.
- 9) L'IEC attire l'attention sur le fait que la mise en application du présent document peut entraîner l'utilisation d'un ou de plusieurs brevets. L'IEC ne prend pas position quant à la preuve, à la validité et à l'applicabilité de tout droit de brevet revendiqué à cet égard. À la date de publication du présent document, l'IEC n'avait pas reçu notification qu'un ou plusieurs brevets pouvaient être nécessaires à sa mise en application. Toutefois, il y a lieu d'avertir les responsables de la mise en application du présent document que des informations plus récentes sont susceptibles de figurer dans la base de données de brevets, disponible à l'adresse <https://patents.iec.ch>. L'IEC ne saurait être tenue pour responsable de ne pas avoir identifié de tels droits de brevets.

L'IEC 60669-2-2 a été établie par le sous-comité 23B: Prises de courant et interrupteurs, du comité d'études 23 de l'IEC: Petit appareillage. Il s'agit d'une Norme internationale.

Cette quatrième édition annule et remplace la troisième édition parue en 2006. Cette édition constitue une révision technique.

Cette édition inclut les modifications techniques majeures suivantes par rapport à l'édition précédente:

- a) révision de la présente édition avec référence à l'IEC 60669-1:2017 (Édition 4);
- b) introduction d'une révision de l'Annexe E "Exigences et essais supplémentaires pour les interrupteurs à utiliser à une température inférieure à -5 °C ".

Le texte de cette Norme internationale est issu des documents suivants:

Projet	Rapport de vote
23B/1486/FDIS	23B/1500/RVD

Le rapport de vote indiqué dans le tableau ci-dessus donne toute information sur le vote ayant abouti à son approbation.

La langue employée pour l'élaboration de cette Norme internationale est l'anglais.

Ce document a été rédigé selon les Directives ISO/IEC, Partie 2, il a été développé selon les Directives ISO/IEC, Partie 1 et les Directives ISO/IEC, Supplément IEC, disponibles sous www.iec.ch/members_experts/refdocs. Les principaux types de documents développés par l'IEC sont décrits plus en détail sous www.iec.ch/standardsdev/publications.

La présente partie de l'IEC 60669 est destinée à être utilisée conjointement avec l'IEC 60669-1:2017. Elle énumère les modifications nécessaires pour transformer cette norme en une norme spécifique pour les interrupteurs à commande à distance.

Lorsqu'un paragraphe particulier de l'IEC 60669-1:2017 n'est pas mentionné dans le présent document, ce paragraphe s'applique pour autant que cela soit raisonnable.

Dans le présent document, les caractères d'imprimerie suivants sont utilisés:

- exigences proprement dites: caractères romains;
- *modalités d'essais: caractères italiques;*
- notes: petits caractères romains.

Les paragraphes, figures, tableaux ou notes qui sont ajoutés à ceux de l'IEC 60669-1:2017 sont numérotés à partir de 101.

Une liste de toutes les parties de la série IEC 60669, publiées sous le titre général *Interrupteurs pour installations électriques fixes domestiques et analogues*, se trouve sur le site web de l'IEC.

Le comité a décidé que le contenu de ce document ne sera pas modifié avant la date de stabilité indiquée sur le site web de l'IEC sous webstore.iec.ch dans les données relatives au document recherché. À cette date, le document sera

- reconduit,
- supprimé, ou
- révisé.

INTERRUPTEURS POUR INSTALLATIONS ÉLECTRIQUES FIXES DOMESTIQUES ET ANALOGUES –

Partie 2-2: Exigences particulières – Interrupteurs à commande à distance (télérupteurs)

1 Domaine d'application

L'Article 1 de l'IEC 60669-1:2017 s'applique, avec les exceptions suivantes:

Remplacement du premier alinéa par le suivant:

La présente partie de l'IEC 60669 s'applique aux interrupteurs à commande à distance (désignés ci-après télérupteurs électromagnétiques) de tension assignée qui ne dépasse pas 440 V en courant alternatif et de courant assigné qui ne dépasse pas 63 A, prévus pour installations électriques fixes domestiques et analogues intérieures ou extérieures. Pour le circuit de commande, la tension de commande assignée ne dépasse pas 440 V en courant alternatif ou 220 V en courant continu.

La bobine du télérupteur peut être alimentée en permanence ou non alimentée en permanence.

Les télérupteurs électroniques sont couverts par le domaine d'application de l'IEC 60669-2-1, mais pas par celui du présent document.

Les télérupteurs qui comportent uniquement des composants passifs tels que des résistances, des condensateurs, des composants à coefficient de température positif (CTP) et coefficient de température négatif (CTN) et des cartes de circuits imprimés ne sont pas considérés comme des télérupteurs électroniques.

Les contracteurs électromécaniques pour usages domestiques et analogues relèvent du domaine d'application de l'IEC 61095.

2 Références normatives

L'Article 2 de l'IEC 60669-1:2017 s'applique, avec les ajouts suivants:

IEC 60085:2007, *Isolation électrique – Évaluation et désignation thermiques*

IEC 60317 (toutes les parties), *Spécifications pour types particuliers de fils de bobinage*

IEC 60445:2021, *Principes fondamentaux et de sécurité pour les interfaces homme-machines, le marquage et l'identification – Identification des bornes de matériels, des extrémités de conducteurs et des conducteurs*

IEC 60664-1:2020, *Coordination de l'isolement des matériels dans les réseaux d'énergie électrique à basse tension – Partie 1: Principes, exigences et essais*

IEC 60664-3:2016, *Coordination de l'isolement des matériels dans les systèmes (réseaux) à basse tension – Partie 3: Utilisation de revêtement, d'emboîtement ou de moulage pour la protection contre la pollution*

IEC 60669-1:2017, *Interrupteurs pour installations électriques fixes domestiques et analogues*
– *Partie 1: Exigences générales*

IEC 61558-2-6:2021, *Safety of transformers, reactors, power supply units and combinations thereof – Part 2-6: Particular requirements and tests for safety isolating transformers and power supply units incorporating safety isolating transformers for general applications* (disponible en anglais uniquement)