



Edition 3.1 2024-10
CONSOLIDATED VERSION

INTERNATIONAL STANDARD



Electrical safety in low voltage distribution systems up to 1 000 V AC and 1 500 V DC – Equipment for testing, measuring or monitoring of protective measures – Part 1: General requirements

INTERNATIONAL
ELECTROTECHNICAL
COMMISSION

ICS 17.220.20, 29.080.01, 29.240.01

ISBN 978-2-8322-9879-4

Warning! Make sure that you obtained this publication from an authorized distributor.

CONTENTS

FOREWORD.....	4
INTRODUCTION.....	6
1 Scope.....	7
2 Normative references	7
3 Terms and definitions	8
4 Requirements	12
4.1 General requirements	12
4.2 Influence quantities – Operating uncertainty (B), percentage operating uncertainty (B [%])	12
4.3 Rated operating conditions	13
4.4 Battery test facility	14
4.5 Safety	14
4.6 Electromagnetic compatibility.....	14
4.6.1 Immunity.....	14
4.6.2 Emission.....	14
4.7 Mechanical strength against vibration	15
5 Marking and operating instructions	15
5.1 General.....	15
5.2 Marking.....	15
5.3 Operating instructions	15
5.3.1 Performance requirements.....	15
5.3.2 Other information.....	15
6 Tests	16
6.1 General.....	16
6.2 Operating uncertainty.....	16
6.2.1 General	16
6.2.2 Influence of changing position	16
6.2.3 Influence of temperature.....	16
6.2.4 Influence of the supply voltage	16
6.3 Battery test facility	16
6.4 Safety tests.....	16
6.5 EMC tests	17
6.6 Mechanical requirements	17
6.7 Marking and operating instructions.....	17
6.8 Records	17
Annex A (informative) Explanation of the application of GUM in series IEC 61557	18
A.1 Overview.....	18
A.2 Basic model of evaluation of results under operational conditions	18
A.2.1 General	18
A.2.2 Standard uncertainty of a result	18
A.2.3 Expanded uncertainty	19
A.2.4 Relative operating uncertainty	19
A.2.5 Calibration uncertainty.....	19
A.3 Operating uncertainty calculations as basis for 4.1	20
A.3.1 Standard uncertainty	20
A.3.2 Operating uncertainty in accordance with 4.1.....	20

Annex B (informative) Environmental aspects	21
B.1 Overview.....	21
B.2 Guidelines to establish a material declaration and end-of-life information	21
B.2.1 General	21
B.2.2 Guidelines for material declaration	22
B.2.3 Guidelines for end-of-life (EoL).....	22
B.2.4 Example of a material declaration and end-of-life information	22
Bibliography.....	25
Figure B.1 – Components listed for EoL of a product	24
Table B.1 – Material content according to IEC 62474 material classes.....	23

INTERNATIONAL ELECTROTECHNICAL COMMISSION

ELECTRICAL SAFETY IN LOW VOLTAGE DISTRIBUTION SYSTEMS UP TO 1 000 V AC AND 1 500 V DC – EQUIPMENT FOR TESTING, MEASURING OR MONITORING OF PROTECTIVE MEASURES

Part 1: General requirements

FOREWORD

- 1) The International Electrotechnical Commission (IEC) is a worldwide organization for standardization comprising all national electrotechnical committees (IEC National Committees). The object of IEC is to promote international co-operation on all questions concerning standardization in the electrical and electronic fields. To this end and in addition to other activities, IEC publishes International Standards, Technical Specifications, Technical Reports, Publicly Available Specifications (PAS) and Guides (hereafter referred to as "IEC Publication(s)"). Their preparation is entrusted to technical committees; any IEC National Committee interested in the subject dealt with may participate in this preparatory work. International, governmental and non-governmental organizations liaising with the IEC also participate in this preparation. IEC collaborates closely with the International Organization for Standardization (ISO) in accordance with conditions determined by agreement between the two organizations.
- 2) The formal decisions or agreements of IEC on technical matters express, as nearly as possible, an international consensus of opinion on the relevant subjects since each technical committee has representation from all interested IEC National Committees.
- 3) IEC Publications have the form of recommendations for international use and are accepted by IEC National Committees in that sense. While all reasonable efforts are made to ensure that the technical content of IEC Publications is accurate, IEC cannot be held responsible for the way in which they are used or for any misinterpretation by any end user.
- 4) In order to promote international uniformity, IEC National Committees undertake to apply IEC Publications transparently to the maximum extent possible in their national and regional publications. Any divergence between any IEC Publication and the corresponding national or regional publication shall be clearly indicated in the latter.
- 5) IEC itself does not provide any attestation of conformity. Independent certification bodies provide conformity assessment services and, in some areas, access to IEC marks of conformity. IEC is not responsible for any services carried out by independent certification bodies.
- 6) All users should ensure that they have the latest edition of this publication.
- 7) No liability shall attach to IEC or its directors, employees, servants or agents including individual experts and members of its technical committees and IEC National Committees for any personal injury, property damage or other damage of any nature whatsoever, whether direct or indirect, or for costs (including legal fees) and expenses arising out of the publication, use of, or reliance upon, this IEC Publication or any other IEC Publications.
- 8) Attention is drawn to the Normative references cited in this publication. Use of the referenced publications is indispensable for the correct application of this publication.
- 9) IEC draws attention to the possibility that the implementation of this document may involve the use of (a) patent(s). IEC takes no position concerning the evidence, validity or applicability of any claimed patent rights in respect thereof. As of the date of publication of this document, IEC had not received notice of (a) patent(s), which may be required to implement this document. However, implementers are cautioned that this may not represent the latest information, which may be obtained from the patent database available at <https://patents.iec.ch>. IEC shall not be held responsible for identifying any or all such patent rights.

This consolidated version of the official IEC Standard and its amendment has been prepared for user convenience.

IEC 61557-1 edition 3.1 contains the third edition (2019-07) [documents 85/689/FDIS and 85/692/RVD] and its amendment 1 (2024-10) [documents 85/900/CDV and 85/926/RVC].

In this Redline version, a vertical line in the margin shows where the technical content is modified by amendment 1. Additions are in green text, deletions are in strikethrough red text. A separate Final version with all changes accepted is available in this publication.

International Standard IEC 61557-1 has been prepared by technical committee 85: Measuring equipment for electrical and electromagnetic quantities.

This third edition cancels and replaces the second edition published in 2007. This edition constitutes a technical revision.

This third edition includes the following significant technical changes with respect to the previous edition:

- a) terms aligned with IEC 60050;
- b) measurement of uncertainty revised according to the equations in 4.2 of ISO/IEC Guide 98-3:2008 (GUM);
- c) updated references for safety and EMC requirements;
- d) updated references for marking and operating instructions;
- e) updated references for testing safety and EMC;
- f) Annex A contains an explanation of GUM;
- g) Annex B addresses environmental aspects.

This document has been drafted in accordance with the ISO/IEC Directives, Part 2.

A list of all parts in the IEC 61557 series, published under the general title *Electrical safety in low voltage distribution systems up to 1 000 V AC and 1 500 V DC – Equipment for testing, measuring or monitoring of protective measures*, can be found on the IEC website.

The committee has decided that the contents of this document and its amendment will remain unchanged until the stability date indicated on the IEC website under webstore.iec.ch in the data related to the specific document. At this date, the document will be

- reconfirmed,
- withdrawn, or
- revised.

IMPORTANT – The 'colour inside' logo on the cover page of this publication indicates that it contains colours which are considered to be useful for the correct understanding of its contents. Users should therefore print this document using a colour printer.

INTRODUCTION

IEC 60364-6 stipulates standardized conditions for the initial test of power installations in TN, TT or IT systems for continuous monitoring and for testing these installations after modifications. In addition to general references for the performance of the tests, IEC 60364-6 contains requirements that have to be verified by measurements. Only in a few instances, for example when measuring the insulation resistance, does IEC 60364-6 contain details of the characteristics of the measuring device to be used. Circuits which are given as examples in IEC 60364-6, and referred to within the text of that document, are generally not suitable for practical use.

The tests are carried out in installations where hazardous voltages can occur and where careless use or a defect in the equipment can easily cause an accident. Therefore, the technician has to rely on measuring devices which ensure safe test methods, in addition to simplifying the measurements.

The application of the general safety regulations for electrical and electronic measuring devices (IEC 61010-1) for testing the protective measures is not sufficient in itself. The performance of measurements in the installation can cause hazards not only to the technician, but also to third persons, depending on the measuring method used.

Likewise, reliable and comparable results of measurement with measuring devices from different manufacturers are an important precondition in order to obtain an objective assessment about the installation, for example when the installation is handed over for periodic tests, for continuous insulation monitoring or in the case of performance warranty.

The IEC 61557 series has been established with the aim of stipulating common principles for measuring and monitoring equipment for testing electrical safety and measuring performances in systems with nominal voltages up to 1 000 V AC and 1 500 V DC which correspond to the above-mentioned characteristics.

For that reason, the following common requirements have been stipulated in IEC 61557-1 (other parts of IEC 61557 can specify additional requirements or deviations):

- protection against extraneous voltages;
- class II protection (except insulation monitoring devices and insulation fault location systems);
- requirements and safety precautions against hazardous touch voltages at the measuring device;
- requirements for the assessment of connection configurations with respect to wiring errors in the tested equipment;
- special mechanical requirements;
- measuring methods;
- measured quantity;
- specification of the maximum operating uncertainty;
- requirements for testing the influencing quantity and the calculation of the operating uncertainty;
- uncertainties of the measuring device at the thresholds specified in the respective standards;
- specification of the nature of type and routine tests and the required conditions for testing.

Contrary to the usual convention, terms and definitions that occur more than once in another part of the series are listed in IEC 61557-1:2019, Clause 3. Only terms and definitions specific to the respective part of IEC 61557 are listed in Clause 3 of that part.

ELECTRICAL SAFETY IN LOW VOLTAGE DISTRIBUTION SYSTEMS UP TO 1 000 V AC AND 1 500 V DC – EQUIPMENT FOR TESTING, MEASURING OR MONITORING OF PROTECTIVE MEASURES

Part 1: General requirements

1 Scope

This part of IEC 61557 specifies the general requirements applicable to measuring and monitoring equipment for testing the electrical safety in low-voltage distribution systems with nominal voltages up to 1 000 V AC and 1 500 V DC.

When measuring equipment or measuring installations involve measurement tasks of various measuring equipment covered by this series of standards, then the part of this series relevant to each of the measurement tasks is applicable.

NOTE The term "measuring equipment" will hereafter be used to designate "testing, measuring and monitoring equipment".

Other parts of IEC 61557 can specify additional requirements or deviations.

This document does not cover functional safety or cybersecurity.

2 Normative references

The following documents are referred to in the text in such a way that some or all of their content constitutes requirements of this document. For dated references, only the edition cited applies. For undated references, the latest edition of the referenced document (including any amendments) applies.

IEC 60038:2009, *IEC standard voltages*

IEC 60529:1989, *Degrees of protection provided by enclosures (IP code)*

IEC 60529:1989/AMD1:1999

IEC 60529:1989/AMD2:2013¹

IEC 61010-1:2010, *Safety requirements for electrical equipment for measurement, control and laboratory use – Part 1: General requirements*

IEC 61010-1:2010/AMD1:2016²

IEC 61010-031, *Safety requirements for electrical equipment for measurement, control and laboratory use – Part 031: Safety requirements for hand-held and hand-manipulated assemblies for electrical test and measurement*

¹ A consolidated version of this publication exists, comprising IEC 60529:1989, IEC 60529:1989/AMD1:1999 and IEC 60529:1989/AMD2:2013.

² A consolidated version of this publication exists, comprising IEC 61010-1:2010 and IEC 61010-1:2010/AMD 1:2016.

IEC 61010-2-030:2017, *Safety requirements for electrical equipment for measurement, control, and laboratory use – Part 2-030: Particular requirements for equipment having testing or measuring circuits*

IEC 61010-2-032, *Safety requirements for electrical equipment for measurement, control, and laboratory use – Part 2-032: Particular requirements for hand-held and hand-manipulated current sensors for electrical test and measurement*

IEC 61010-2-034:2017, *Safety requirements for electrical equipment for measurement, control, and laboratory use – Part 2-034: Particular requirements for measurement equipment for insulation resistance and test equipment for electric strength*

IEC 61326-1:2012, *Electrical equipment for measurement, control and laboratory use – EMC requirements – Part 1: General requirements*

IEC 61326-2-4, *Electrical equipment for measurement, control and laboratory use – EMC requirements – Part 2-4: Particular requirements – Test configurations, operational conditions and performance criteria for insulation monitoring devices according to IEC 61557-8 and for equipment for insulation fault location according to IEC 61557-9*

IEC 61557-8:2014, *Electrical safety in low voltage distribution systems up to 1 000 V AC and 1 500 V DC – Equipment for testing, measuring or monitoring of protective measures – Part 8: Insulation monitoring devices for IT systems*

IEC 61557-9:2014, *Electrical safety in low voltage distribution systems up to 1 000 V AC and 1 500 V DC – Equipment for testing, measuring or monitoring of protective measures – Part 9: Equipment for insulation fault location in IT systems*

CONTENTS

FOREWORD.....	4
INTRODUCTION.....	6
1 Scope.....	7
2 Normative references	7
3 Terms and definitions	8
4 Requirements	12
4.1 General requirements	12
4.2 Influence quantities – Operating uncertainty (B), percentage operating uncertainty (B [%])	12
4.3 Rated operating conditions	13
4.4 Battery test facility	14
4.5 Safety	14
4.6 Electromagnetic compatibility.....	14
4.6.1 Immunity.....	14
4.6.2 Emission.....	14
4.7 Mechanical strength against vibration	15
5 Marking and operating instructions	15
5.1 General.....	15
5.2 Marking.....	15
5.3 Operating instructions	15
5.3.1 Performance requirements.....	15
5.3.2 Other information.....	15
6 Tests	16
6.1 General.....	16
6.2 Operating uncertainty.....	16
6.2.1 General	16
6.2.2 Influence of changing position	16
6.2.3 Influence of temperature.....	16
6.2.4 Influence of the supply voltage	16
6.3 Battery test facility	16
6.4 Safety tests.....	16
6.5 EMC tests	17
6.6 Mechanical requirements	17
6.7 Marking and operating instructions.....	17
6.8 Records	17
Annex A (informative) Explanation of the application of GUM in series IEC 61557	18
A.1 Overview.....	18
A.2 Basic model of evaluation of results under operational conditions	18
A.2.1 General	18
A.2.2 Standard uncertainty of a result	18
A.2.3 Expanded uncertainty	19
A.2.4 Relative operating uncertainty	19
A.2.5 Calibration uncertainty.....	19
A.3 Operating uncertainty calculations as basis for 4.1	20
A.3.1 Standard uncertainty	20
A.3.2 Operating uncertainty in accordance with 4.1.....	20

Annex B (informative) Environmental aspects	21
B.1 Overview.....	21
B.2 Guidelines to establish a material declaration and end-of-life information	21
B.2.1 General	21
B.2.2 Guidelines for material declaration	22
B.2.3 Guidelines for end-of-life (EoL).....	22
B.2.4 Example of a material declaration and end-of-life information	22
Bibliography.....	25
Figure B.1 – Components listed for EoL of a product	24
Table B.1 – Material content according to IEC 62474 material classes.....	23

INTERNATIONAL ELECTROTECHNICAL COMMISSION

ELECTRICAL SAFETY IN LOW VOLTAGE DISTRIBUTION SYSTEMS UP TO 1 000 V AC AND 1 500 V DC – EQUIPMENT FOR TESTING, MEASURING OR MONITORING OF PROTECTIVE MEASURES

Part 1: General requirements

FOREWORD

- 1) The International Electrotechnical Commission (IEC) is a worldwide organization for standardization comprising all national electrotechnical committees (IEC National Committees). The object of IEC is to promote international co-operation on all questions concerning standardization in the electrical and electronic fields. To this end and in addition to other activities, IEC publishes International Standards, Technical Specifications, Technical Reports, Publicly Available Specifications (PAS) and Guides (hereafter referred to as "IEC Publication(s)"). Their preparation is entrusted to technical committees; any IEC National Committee interested in the subject dealt with may participate in this preparatory work. International, governmental and non-governmental organizations liaising with the IEC also participate in this preparation. IEC collaborates closely with the International Organization for Standardization (ISO) in accordance with conditions determined by agreement between the two organizations.
- 2) The formal decisions or agreements of IEC on technical matters express, as nearly as possible, an international consensus of opinion on the relevant subjects since each technical committee has representation from all interested IEC National Committees.
- 3) IEC Publications have the form of recommendations for international use and are accepted by IEC National Committees in that sense. While all reasonable efforts are made to ensure that the technical content of IEC Publications is accurate, IEC cannot be held responsible for the way in which they are used or for any misinterpretation by any end user.
- 4) In order to promote international uniformity, IEC National Committees undertake to apply IEC Publications transparently to the maximum extent possible in their national and regional publications. Any divergence between any IEC Publication and the corresponding national or regional publication shall be clearly indicated in the latter.
- 5) IEC itself does not provide any attestation of conformity. Independent certification bodies provide conformity assessment services and, in some areas, access to IEC marks of conformity. IEC is not responsible for any services carried out by independent certification bodies.
- 6) All users should ensure that they have the latest edition of this publication.
- 7) No liability shall attach to IEC or its directors, employees, servants or agents including individual experts and members of its technical committees and IEC National Committees for any personal injury, property damage or other damage of any nature whatsoever, whether direct or indirect, or for costs (including legal fees) and expenses arising out of the publication, use of, or reliance upon, this IEC Publication or any other IEC Publications.
- 8) Attention is drawn to the Normative references cited in this publication. Use of the referenced publications is indispensable for the correct application of this publication.
- 9) IEC draws attention to the possibility that the implementation of this document may involve the use of (a) patent(s). IEC takes no position concerning the evidence, validity or applicability of any claimed patent rights in respect thereof. As of the date of publication of this document, IEC had not received notice of (a) patent(s), which may be required to implement this document. However, implementers are cautioned that this may not represent the latest information, which may be obtained from the patent database available at <https://patents.iec.ch>. IEC shall not be held responsible for identifying any or all such patent rights.

This consolidated version of the official IEC Standard and its amendment has been prepared for user convenience.

IEC 61557-1 edition 3.1 contains the third edition (2019-07) [documents 85/689/FDIS and 85/692/RVD] and its amendment 1 (2024-10) [documents 85/900/CDV and 85/926/RVC].

This Final version does not show where the technical content is modified by amendment 1. A separate Redline version with all changes highlighted is available in this publication.

International Standard IEC 61557-1 has been prepared by technical committee 85: Measuring equipment for electrical and electromagnetic quantities.

This third edition cancels and replaces the second edition published in 2007. This edition constitutes a technical revision.

This third edition includes the following significant technical changes with respect to the previous edition:

- a) terms aligned with IEC 60050;
- b) measurement of uncertainty revised according to the equations in 4.2 of ISO/IEC Guide 98-3:2008 (GUM);
- c) updated references for safety and EMC requirements;
- d) updated references for marking and operating instructions;
- e) updated references for testing safety and EMC;
- f) Annex A contains an explanation of GUM;
- g) Annex B addresses environmental aspects.

This document has been drafted in accordance with the ISO/IEC Directives, Part 2.

A list of all parts in the IEC 61557 series, published under the general title *Electrical safety in low voltage distribution systems up to 1 000 V AC and 1 500 V DC – Equipment for testing, measuring or monitoring of protective measures*, can be found on the IEC website.

The committee has decided that the contents of this document and its amendment will remain unchanged until the stability date indicated on the IEC website under webstore.iec.ch in the data related to the specific document. At this date, the document will be

- reconfirmed,
- withdrawn, or
- revised.

INTRODUCTION

IEC 60364-6 stipulates standardized conditions for the initial test of power installations in TN, TT or IT systems for continuous monitoring and for testing these installations after modifications. In addition to general references for the performance of the tests, IEC 60364-6 contains requirements that have to be verified by measurements. Only in a few instances, for example when measuring the insulation resistance, does IEC 60364-6 contain details of the characteristics of the measuring device to be used. Circuits which are given as examples in IEC 60364-6, and referred to within the text of that document, are generally not suitable for practical use.

The tests are carried out in installations where hazardous voltages can occur and where careless use or a defect in the equipment can easily cause an accident. Therefore, the technician has to rely on measuring devices which ensure safe test methods, in addition to simplifying the measurements.

The application of the general safety regulations for electrical and electronic measuring devices (IEC 61010-1) for testing the protective measures is not sufficient in itself. The performance of measurements in the installation can cause hazards not only to the technician, but also to third persons, depending on the measuring method used.

Likewise, reliable and comparable results of measurement with measuring devices from different manufacturers are an important precondition in order to obtain an objective assessment about the installation, for example when the installation is handed over for periodic tests, for continuous insulation monitoring or in the case of performance warranty.

The IEC 61557 series has been established with the aim of stipulating common principles for measuring and monitoring equipment for testing electrical safety and measuring performances in systems with nominal voltages up to 1 000 V AC and 1 500 V DC which correspond to the above-mentioned characteristics.

For that reason, the following common requirements have been stipulated in IEC 61557-1 (other parts of IEC 61557 can specify additional requirements or deviations):

- protection against extraneous voltages;
- class II protection (except insulation monitoring devices and insulation fault location systems);
- requirements and safety precautions against hazardous touch voltages at the measuring device;
- requirements for the assessment of connection configurations with respect to wiring errors in the tested equipment;
- special mechanical requirements;
- measuring methods;
- measured quantity;
- specification of the maximum operating uncertainty;
- requirements for testing the influencing quantity and the calculation of the operating uncertainty;
- uncertainties of the measuring device at the thresholds specified in the respective standards;
- specification of the nature of type and routine tests and the required conditions for testing.

Contrary to the usual convention, terms and definitions that occur more than once in another part of the series are listed in IEC 61557-1:2019, Clause 3. Only terms and definitions specific to the respective part of IEC 61557 are listed in Clause 3 of that part.

ELECTRICAL SAFETY IN LOW VOLTAGE DISTRIBUTION SYSTEMS UP TO 1 000 V AC AND 1 500 V DC – EQUIPMENT FOR TESTING, MEASURING OR MONITORING OF PROTECTIVE MEASURES

Part 1: General requirements

1 Scope

This part of IEC 61557 specifies the general requirements applicable to measuring and monitoring equipment for testing the electrical safety in low-voltage distribution systems with nominal voltages up to 1 000 V AC and 1 500 V DC.

When measuring equipment or measuring installations involve measurement tasks of various measuring equipment covered by this series of standards, then the part of this series relevant to each of the measurement tasks is applicable.

NOTE The term "measuring equipment" will hereafter be used to designate "testing, measuring and monitoring equipment".

Other parts of IEC 61557 can specify additional requirements or deviations.

This document does not cover functional safety or cybersecurity.

2 Normative references

The following documents are referred to in the text in such a way that some or all of their content constitutes requirements of this document. For dated references, only the edition cited applies. For undated references, the latest edition of the referenced document (including any amendments) applies.

IEC 60038:2009, *IEC standard voltages*

IEC 60529:1989, *Degrees of protection provided by enclosures (IP code)*

IEC 60529:1989/AMD1:1999

IEC 60529:1989/AMD2:2013¹

IEC 61010-1:2010, *Safety requirements for electrical equipment for measurement, control and laboratory use – Part 1: General requirements*

IEC 61010-1:2010/AMD1:2016²

IEC 61010-031, *Safety requirements for electrical equipment for measurement, control and laboratory use – Part 031: Safety requirements for hand-held and hand-manipulated assemblies for electrical test and measurement*

¹ A consolidated version of this publication exists, comprising IEC 60529:1989, IEC 60529:1989/AMD1:1999 and IEC 60529:1989/AMD2:2013.

² A consolidated version of this publication exists, comprising IEC 61010-1:2010 and IEC 61010-1:2010/AMD 1:2016.

IEC 61010-2-030:2017, *Safety requirements for electrical equipment for measurement, control, and laboratory use – Part 2-030: Particular requirements for equipment having testing or measuring circuits*

IEC 61010-2-032, *Safety requirements for electrical equipment for measurement, control, and laboratory use – Part 2-032: Particular requirements for hand-held and hand-manipulated current sensors for electrical test and measurement*

IEC 61010-2-034:2017, *Safety requirements for electrical equipment for measurement, control, and laboratory use – Part 2-034: Particular requirements for measurement equipment for insulation resistance and test equipment for electric strength*

IEC 61326-1:2012, *Electrical equipment for measurement, control and laboratory use – EMC requirements – Part 1: General requirements*

IEC 61326-2-4, *Electrical equipment for measurement, control and laboratory use – EMC requirements – Part 2-4: Particular requirements – Test configurations, operational conditions and performance criteria for insulation monitoring devices according to IEC 61557-8 and for equipment for insulation fault location according to IEC 61557-9*

IEC 61557-8:2014, *Electrical safety in low voltage distribution systems up to 1 000 V AC and 1 500 V DC – Equipment for testing, measuring or monitoring of protective measures – Part 8: Insulation monitoring devices for IT systems*

IEC 61557-9:2014, *Electrical safety in low voltage distribution systems up to 1 000 V AC and 1 500 V DC – Equipment for testing, measuring or monitoring of protective measures – Part 9: Equipment for insulation fault location in IT systems*