

# TECHNICAL SPECIFICATION

# IEC TS 61850-2

First edition  
2003-08

---

---

## Communication networks and systems in substations –

### Part 2: Glossary

© IEC 2003 — Copyright - all rights reserved

No part of this publication may be reproduced or utilized in any form or by any means, electronic or mechanical, including photocopying and microfilm, without permission in writing from the publisher.

International Electrotechnical Commission, 3, rue de Varembé, PO Box 131, CH-1211 Geneva 20, Switzerland  
Telephone: +41 22 919 02 11 Telefax: +41 22 919 03 00 E-mail: [inmail@iec.ch](mailto:inmail@iec.ch) Web: [www.iec.ch](http://www.iec.ch)



Commission Electrotechnique Internationale  
International Electrotechnical Commission  
Международная Электротехническая Комиссия

PRICE CODE

X

*For price, see current catalogue*

## CONTENTS

FOREWORD .....	3
1 Scope .....	5
2 Terms and definitions.....	5
3 Abbreviations .....	28
Bibliography .....	40

## INTERNATIONAL ELECTROTECHNICAL COMMISSION

### COMMUNICATION NETWORKS AND SYSTEMS IN SUBSTATIONS –

#### Part 2: Glossary

#### FOREWORD

- 1) The International Electrotechnical Commission (IEC) is a worldwide organization for standardization comprising all national electrotechnical committees (IEC National Committees). The object of IEC is to promote international co-operation on all questions concerning standardization in the electrical and electronic fields. To this end and in addition to other activities, IEC publishes International Standards, Technical Specifications, Technical Reports, and Guides (hereafter referred to as "IEC Publication(s)"). Their preparation is entrusted to technical committees; any IEC National Committee interested in the subject dealt with may participate in this preparatory work. International, governmental and non-governmental organizations liaising with the IEC also participate in this preparation. IEC collaborates closely with the International Organization for Standardization (ISO) in accordance with conditions determined by agreement between the two organizations.
- 2) The formal decisions or agreements of IEC on technical matters express, as nearly as possible, an international consensus of opinion on the relevant subjects since each technical committee has representation from all interested IEC National Committees.
- 3) IEC Publications have the form of recommendations for international use and are accepted by IEC National Committees in that sense. While all reasonable efforts are made to ensure that the technical content of IEC Publications is accurate, IEC cannot be held responsible for the way in which they are used or for any misinterpretation by any end user.
- 4) In order to promote international uniformity, IEC National Committees undertake to apply IEC Publications transparently to the maximum extent possible in their national and regional publications. Any divergence between any IEC Publication and the corresponding national or regional publication shall be clearly indicated in the latter.
- 5) IEC provides no marking procedure to indicate its approval and cannot be rendered responsible for any equipment declared to be in conformity with an IEC Publication.
- 6) All users should ensure that they have the latest edition of this publication.
- 7) No liability shall attach to IEC or its directors, employees, servants or agents including individual experts and members of its technical committees and IEC National Committees for any personal injury, property damage or other damage of any nature whatsoever, whether direct or indirect, or for costs (including legal fees) and expenses arising out of the publication, use of, or reliance upon, this IEC Publication or any other IEC Publications.
- 8) Attention is drawn to the Normative references cited in this publication. Use of the referenced publications is indispensable for the correct application of this publication.
- 9) Attention is drawn to the possibility that some of the elements of this IEC Publication may be the subject of patent rights. IEC shall not be held responsible for identifying any or all such patent rights.

The main task of IEC technical committees is to prepare International Standards. In exceptional circumstances, a technical committee may propose the publication of a technical specification when

- the required support cannot be obtained for the publication of an International Standard, despite repeated efforts, or
- the subject is still under technical development or where, for any other reason, there is the future but no immediate possibility of an agreement on an International Standard.

Technical specifications are subject to review within three years of publication to decide whether they can be transformed into International Standards.

IEC 61850-2, which is a technical specification, has been prepared by IEC technical committee 57: Power system control and associated communications.

The text of this technical specification is based on the following documents:

Enquiry draft	Report on voting
57/615/DTS	57/645/RVC

Full information on the voting for the approval of this technical specification can be found in the report on voting indicated in the above table.

This publication has been drafted in accordance with the ISO/IEC Directives, Part 2.

IEC 61850 consists of the following parts, under the general title *Communication networks and systems in substations*.

- Part 1: Introduction and overview
- Part 2: Glossary
- Part 3: General requirements
- Part 4: System and project management
- Part 5: Communication requirements for functions and device models
- Part 6: Configuration description language for communication in electrical substations related to IEDs <sup>1</sup>
- Part 7-1: Basic communication structure for substation and feeder equipment – Principles and models
- Part 7-2: Basic communication structure for substation and feeder equipment – Abstract communication service interface (ACSI)
- Part 7-3: Basic communication structure for substation and feeder equipment – Common data classes
- Part 7-4: Basic communication structure for substation and feeder equipment – Compatible logical node classes and data classes
- Part 8-1: Specific communication service mapping (SCSM) – Mappings to MMS (ISO/IEC 9506-1 and ISO/IEC 9506-2) over ISO/IEC 8802-3 <sup>1</sup>
- Part 9-1: Specific communication service mapping (SCSM) – Sampled values over serial unidirectional multidrop point to point link
- Part 9-2: Specific communication service mapping (SCSM) – Sampled values over ISO/IEC 8802-3 <sup>1</sup>
- Part 10: Conformance testing <sup>1</sup>

The committee has decided that the contents of this publication will remain unchanged until 2005. At this date, the publication will be either

- reconfirmed;
- withdrawn;
- replaced by a revised edition, or
- amended.

---

<sup>1</sup> Under consideration.

## COMMUNICATION NETWORKS AND SYSTEMS IN SUBSTATIONS -

### Part 2: Glossary

#### 1 Scope

This part of the IEC 61850 series applies to Substation Automation Systems (SAS). It defines the communication between intelligent electronic devices (IEDs) in the substation and the related system requirements.

This part of the IEC 61850 series contains the glossary of specific terminology and definitions used in the context of Substation Automation Systems within the various parts of the standard.

#### 2 Terms and definitions

The following terms and definitions apply to all parts of the IEC 61850 series<sup>2</sup>.

##### 2.1

##### **abstract communication service interface**

virtual interface to an IED providing abstract information modelling methods for logical devices, logical nodes, data, and data attributes, and communication services for example connection, variable access, unsolicited data transfer, device control and file transfer services, independent of the actual communication stack and profiles used

[IEC 61850-1]

##### 2.2

##### **access point**

communication access point to an IED. This may be a serial port, an Ethernet connection, or a client or server address dependent on the stack being used. Each access point of an IED to a communication bus is uniquely identified. Each server has only one, logical, access point

[IEC 61850-6]

##### 2.3

##### **application layer**

layer 7 in the OSI reference model for Open Systems Interconnection comprising the interface between the OSI environment and the IED's or user's application

[ISO/IEC 7498-1]

##### 2.4

##### **association**

conveyance path established between a client and a server for the exchange of messages

[IEC 61850-7-1]

---

<sup>2</sup> References to other standards given below certain definitions indicate that the term is either described or used in the cited standard. All references are listed in the bibliography.