

TECHNICAL REPORT



**Communication networks and systems for power utility automation –
Part 90-7: Object models for power converters in distributed energy resources
(DER) systems**

INTERNATIONAL
ELECTROTECHNICAL
COMMISSION

ICS 33.200

ISBN 978-2-83220-647-8

Warning! Make sure that you obtained this publication from an authorized distributor.

CONTENTS

FOREWORD.....	7
1 Scope.....	9
2 Normative references	9
3 Terms, definitions and acronyms	10
3.1 Terms and definitions	10
3.2 Acronyms	13
4 Abbreviated terms	14
5 Overview of power converter-based DER functions	15
5.1 General.....	15
5.2 Power converter configurations and interactions.....	16
5.3 Power converter methods.....	18
5.4 Power converter functions	19
5.5 Differing DER architectures	20
5.5.1 Conceptual architecture: electrical coupling point (ECP).....	20
5.5.2 Conceptual architecture: point of common coupling (PCC).....	20
5.5.3 Utility interactions directly with power converters or indirectly via a customer EMS	21
5.5.4 Communication profiles	21
5.6 General Sequence of information exchange interactions	22
6 Concepts and constructs for managing power converter functions	23
6.1 Basic settings of power converters	23
6.1.1 Nameplate values versus basic settings	23
6.1.2 Power factor and power converter quadrants	23
6.1.3 Maximum watts, vars, and volt-amp settings	25
6.1.4 Active power ramp rate settings.....	27
6.1.5 Voltage phase and correction settings	27
6.1.6 Charging settings	28
6.1.7 Example of basic settings	28
6.1.8 Basic setting process.....	29
6.2 Modes for managing autonomous behaviour.....	29
6.2.1 Benefits of modes to manage DER at ECPs.....	29
6.2.2 Modes using curves to describe behaviour	30
6.2.3 Paired arrays to describe mode curves	31
6.2.4 Percentages as size-neutral parameters: voltage and var calculations.....	32
6.2.5 Hysteresis as values cycle within mode curves	32
6.2.6 Low pass exponential time rate.....	33
6.2.7 Ramp rates.....	34
6.2.8 Randomized response times.....	34
6.2.9 Timeout period	35
6.2.10 Multiple curves for a mode.....	35
6.2.11 Multiple modes	35
6.2.12 Use of modes for loosely coupled, autonomous actions	35
6.3 Schedules for establishing time-based behaviour	35
6.3.1 Purpose of schedules	35
6.3.2 Schedule components	36
7 DER management functions for power converters.....	37

7.1	Immediate control functions for power converters	37
7.1.1	General	37
7.1.2	Function INV1: connect / disconnect from grid	38
7.1.3	Function INV2: adjust maximum generation level up/down.....	38
7.1.4	Function INV3: adjust power factor	39
7.1.5	Function INV4: request active power (charge or discharge storage).....	39
7.1.6	Function INV5: pricing signal for charge/discharge action	40
7.2	Modes for volt-var management	41
7.2.1	VAr management modes using volt-var arrays	41
7.2.2	Example setting volt-var mode VV11: available var support mode with no impact on watts	42
7.2.3	Example setting volt-var mode VV12: maximum var support mode based on <i>WMax</i>	44
7.2.4	Example setting volt-var mode VV13: static power converter mode based on settings	45
7.2.5	Example setting volt-var mode VV14: passive mode with no var support	46
7.3	Modes for frequency-related behaviours	47
7.3.1	Frequency management modes	47
7.3.2	Frequency-watt mode FW21: high frequency reduces active power	48
7.3.3	Frequency-watt mode FW22: constraining generating/charging by frequency	50
7.4	Dynamic reactive current support during abnormally high or low voltage levels	53
7.4.1	Purpose of dynamic reactive current support	53
7.4.2	Dynamic reactive current support mode TV31: support during abnormally high or low voltage levels	54
7.5	Low/high voltage ride-through curves for “must disconnect” and “must remain connected” zones	57
7.5.1	Purpose of L/HVRT.....	57
7.5.2	“Must disconnect” (MD) and “must remain connected” (MRC) curves	57
7.6	Modes for watt-triggered behaviours.....	59
7.6.1	Watt-power factor mode WP41: feed-in power controls power factor.....	59
7.6.2	Alternative watt-power factor mode WP42: feed-in power controls power factor	59
7.7	Modes for voltage-watt management	60
7.7.1	Voltage-watt mode VW51: voltage-watt management: generating by voltage	60
7.7.2	Voltage-watt mode VW52: voltage-watt management: charging by voltage	60
7.8	Modes for behaviours triggered by non-power parameters.....	61
7.8.1	Temperature mode TMP	61
7.8.2	Pricing signal mode PS.....	61
7.9	Setting and reporting functions	62
7.9.1	Purpose of setting and reporting functions	62
7.9.2	Establishing settings DS91: modify power converter-based DER settings	62
7.9.3	Event logging DS92: log alarms and events, retrieve logs.....	62
7.9.4	Reporting status DS93: selecting status points, establishing reporting mechanisms	66
7.9.5	Time synchronization DS94: time synchronization requirements	68
8	IEC 61850 information models for power converter-based functions	68

8.1	Overall structure of IEC 61850	68
8.2	IEC 61850 system logical nodes	69
8.3	Key components of IEC 61850 information modelling of power converter-based functions	71
8.3.1	Subsets of 61850 models for power converter-based DER functions	71
8.3.2	Types of interactions for settings, functions, and modes	72
8.3.3	Key common data classes (CDCs)	73
8.3.4	Messaging services	77
8.3.5	Message errors	78
8.4	Basic settings in IEC 61850	78
8.4.1	Logical nodes for basic settings	78
8.4.2	IEC 61850 models for basic settings	79
8.5	Mode settings in IEC 61850	80
8.5.1	Logical nodes for establishing and managing modes	80
8.5.2	IEC 61850 models for modes	81
8.6	Schedules in IEC 61850	83
8.6.1	Scheduling structures	83
8.6.2	IEC 61850 models for schedules	84
8.7	Immediate control functions in IEC 61850	84
8.7.1	IEC 61850 models for INV1: connect/disconnect	84
8.7.2	IEC 61850 models for INV2: adjust maximum generation level up/down	85
8.7.3	IEC 61850 models for INV3: adjust power factor	86
8.7.4	IEC 61850 models for INV4: charge/discharge storage	86
8.7.5	IEC 61850 models for INV5: pricing signal for charge/discharge of storage	87
8.8	Volt-var management modes in IEC 61850	88
8.8.1	IEC 61850 models for VV11 – VV12: volt-var curve settings	88
8.8.2	IEC 61850 models for VV13 – VV14: volt-var parameter settings	88
8.9	Frequency-related modes in IEC 61850	89
8.9.1	IEC 61850 for FW21: frequency-driven active power modification	89
8.9.2	IEC 61850 for FW22: Frequency-watt mode FW22: generating/charging by frequency	90
8.10	Voltage management modes in IEC 61850	91
8.10.1	IEC 61850 for TV31: dynamic reactive current support	91
8.10.2	IEC 61850 for “must disconnect”	92
8.10.3	IEC 61850 for “must remain connected”	92
8.11	Watt-triggered behaviour modes in IEC 61850	93
8.11.1	IEC 61850 for WP41 and WP42: feed-in watts control of power factor	93
8.12	Voltage-watt management modes in IEC 61850	94
8.12.1	IEC 61850 for VW51: voltage-watt management in generation and charging	94
8.13	Non-power mode behaviours in IEC 61850	95
8.13.1	IEC 61850 models for temperature mode TMP	95
8.13.2	IEC 61850 models for pricing signal mode PS	95
8.14	IEC 61850 reporting commands	96
8.14.1	IEC 61850 models for DS91: modify DER settings	96
8.14.2	IEC 61850 models for DS92: event/history logging	96
8.14.3	IEC 61850 models for DS93: status reporting	97
	Bibliography	102

Figure 1 – DER management hierarchical interactions: autonomous, loosely-coupled, broadcast/multicast 18

Figure 2 – Electrical Connection Points (ECP) and Point of Common Coupling (PCC) 21

Figure 3 – Producer and Consumer Reference Frame conventions 24

Figure 4 – EEI Power Factor sign convention 25

Figure 5 – Working areas for different modes 26

Figure 6 – Example of voltage offsets (*VRefOfs*) with respect to the reference voltage (*VRef*) 28

Figure 7 – Example of modes associated with different ECPs 30

Figure 8 – Example of a volt-var mode curve 31

Figure 9 – Example of hysteresis in volt-var curves 33

Figure 10 – Example of deadband in volt-var curves 33

Figure 11 – Local function block diagram 34

Figure 12 – Time domain response of first order low pass filter 34

Figure 13 – Interrelationships of schedule controllers, schedules, and schedule references 37

Figure 14 – Volt-var mode VV11 – available vars mode 43

Figure 15 – Power converter mode VV12 – Maximum var support mode based on *WMax* 44

Figure 16 – Power converter mode VV13 – Example: static var support mode based on *VArMax* 46

Figure 17 – Frequency-watt mode curves 48

Figure 18 – Frequency-based active power reduction 49

Figure 19 – Frequency-based active power modification with the use of an array 50

Figure 20 – Example of a basic frequency-watt mode configuration 51

Figure 21 – Example array settings with hysteresis 52

Figure 22 – Example of an asymmetrical hysteresis configuration 52

Figure 23 – Example array configuration for absorbed watts vs. frequency 53

Figure 24 – Basic concepts of the dynamic reactive current support function 54

Figure 25 – Calculation of delta voltage over the filter time window 55

Figure 26 – Activation zones for dynamic reactive current support 55

Figure 27 – Alternative gradient behaviour, selected by *ArGraMod* 56

Figure 28 – Settings to define a blocking zone 57

Figure 29 – Must disconnect and must remain connected zones 58

Figure 30 – Examples of “must remain connected” requirements for different regions 58

Figure 31 – Power factor controlled by feed-in power 59

Figure 32 – Example configuration curve for maximum watts vs. voltage 60

Figure 33 – Example configuration curve for maximum watts absorbed vs. voltage 61

Figure 34 – Structure of the IEC 61850 Parts 69

Figure 35 – Interrelationships of schedule controllers, schedules, and schedule references 84

Table 1 – Producer Reference Frame (PRF) conventions 24

Table 2 – Example basic settings for a storage DER unit 28

Table 3 – Events.....	64
Table 4 – Examples of status points.....	66
Table 5 – Interpretation of logical node tables.....	70
Table 6 – LPHD class	70
Table 7 – Common LN class	71
Table 8 – LLN0 class	71
Table 9 – CDC SPS	73
Table 10 – CDC SPC	73
Table 11 – CDC DPC	74
Table 12 – CDC INC	74
Table 13 – CDC ING	75
Table 14 – CDC ASG	75
Table 15 – CDC ORG	76
Table 16 – CDC CSG.....	76
Table 17 – Schedule (SCR) common data class specification	77
Table 18 – Service error type definitions	78
Table 19 – LN DRCT – DER controller characteristics.....	79
Table 20 – LN FMAR – set mode array	81
Table 21 – LN DGSM – issue mode command	83
Table 22 – LN DOPM – operations.....	85
Table 23 – INV1 – LN CSWI – issue and respond to control.....	85
Table 24 – LN FWHZ – set power levels by frequency for FW21	90
Table 25 – LN RDGS – dynamic reactive current support for TV31	92
Table 26 – LN PPFW – set power factor by feed-in power for WP41	94
Table 27 – DS92 – IEC 61850 log structure	97
Table 28 – LN DRCS – DER state for DS93.....	99
Table 29 – DS93 – Status, settings, and measurement points	99

INTERNATIONAL ELECTROTECHNICAL COMMISSION

**COMMUNICATION NETWORKS AND SYSTEMS
FOR POWER UTILITY AUTOMATION –****Part 90-7: Object models for power converters
in distributed energy resources (DER) systems**

FOREWORD

- 1) The International Electrotechnical Commission (IEC) is a worldwide organization for standardization comprising all national electrotechnical committees (IEC National Committees). The object of IEC is to promote international co-operation on all questions concerning standardization in the electrical and electronic fields. To this end and in addition to other activities, IEC publishes International Standards, Technical Specifications, Technical Reports, Publicly Available Specifications (PAS) and Guides (hereafter referred to as "IEC Publication(s)"). Their preparation is entrusted to technical committees; any IEC National Committee interested in the subject dealt with may participate in this preparatory work. International, governmental and non-governmental organizations liaising with the IEC also participate in this preparation. IEC collaborates closely with the International Organization for Standardization (ISO) in accordance with conditions determined by agreement between the two organizations.
- 2) The formal decisions or agreements of IEC on technical matters express, as nearly as possible, an international consensus of opinion on the relevant subjects since each technical committee has representation from all interested IEC National Committees.
- 3) IEC Publications have the form of recommendations for international use and are accepted by IEC National Committees in that sense. While all reasonable efforts are made to ensure that the technical content of IEC Publications is accurate, IEC cannot be held responsible for the way in which they are used or for any misinterpretation by any end user.
- 4) In order to promote international uniformity, IEC National Committees undertake to apply IEC Publications transparently to the maximum extent possible in their national and regional publications. Any divergence between any IEC Publication and the corresponding national or regional publication shall be clearly indicated in the latter.
- 5) IEC itself does not provide any attestation of conformity. Independent certification bodies provide conformity assessment services and, in some areas, access to IEC marks of conformity. IEC is not responsible for any services carried out by independent certification bodies.
- 6) All users should ensure that they have the latest edition of this publication.
- 7) No liability shall attach to IEC or its directors, employees, servants or agents including individual experts and members of its technical committees and IEC National Committees for any personal injury, property damage or other damage of any nature whatsoever, whether direct or indirect, or for costs (including legal fees) and expenses arising out of the publication, use of, or reliance upon, this IEC Publication or any other IEC Publications.
- 8) Attention is drawn to the Normative references cited in this publication. Use of the referenced publications is indispensable for the correct application of this publication.
- 9) Attention is drawn to the possibility that some of the elements of this IEC Publication may be the subject of patent rights. IEC shall not be held responsible for identifying any or all such patent rights.

The main task of IEC technical committees is to prepare International Standards. However, a technical committee may propose the publication of a technical report when it has collected data of a different kind from that which is normally published as an International Standard, for example "state of the art".

IEC 61850-90-7, which is a technical report, has been prepared by IEC technical committee 57: Power systems management and associated information exchange.

The text of this technical report is based on the following documents:

Enquiry draft	Report on voting
57/1239/DTR	57/1281/RVC

Full information on the voting for the approval of this technical report can be found in the report on voting indicated in the above table.

This publication has been drafted in accordance with the ISO/IEC Directives, Part 2.

A list of all parts of the IEC 61850 series, under the general title *Communication networks and systems for power utility automation*, can be found on the IEC website.

Only the new data objects and CDCs which are represented in ***bold-italic*** will be tagged with the namespace name of this document. The others should still refer to the namespace where they are primarily defined.

The committee has decided that the contents of this publication will remain unchanged until the stability date indicated on the IEC web site under "<http://webstore.iec.ch>" in the data related to the specific publication. At this date, the publication will be

- reconfirmed,
- withdrawn,
- replaced by a revised edition, or
- amended.

A bilingual version of this publication may be issued at a later date.

IMPORTANT – The 'colour inside' logo on the cover page of this publication indicates that it contains colours which are considered to be useful for the correct understanding of its contents. Users should therefore print this document using a colour printer.

COMMUNICATION NETWORKS AND SYSTEMS FOR POWER UTILITY AUTOMATION –

Part 90-7: Object models for power converters in distributed energy resources (DER) systems

1 Scope

This part of IEC 61850 describes the functions for power converter-based distributed energy resources (DER) systems, focused on DC-to-AC and AC-to-AC conversions and including photovoltaic systems (PV), battery storage systems, electric vehicle (EV) charging systems, and any other DER systems with a controllable power converter. It defines the IEC 61850 information models to be used in the exchange of information between these power converter-based DER systems and the utilities, energy service providers (ESPs), or other entities which are tasked with managing the volt, var, and watt capabilities of these power converter-based systems.

These power converter-based DER systems can range from very small grid-connected systems at residential customer sites, to medium-sized systems configured as microgrids on campuses or communities, to very large systems in utility-operated power plants, and to many other configurations and ownership models. They may or may not combine different types of DER systems behind the power converter, such as an power converter-based DER system and a battery that are connected at the DC level.

The namespace of this document is:

“(Tr) IEC 61850-90-7:2012”

The namespace "IEC 61850-90-7" is considered as "transitional" since the models are expected to be included in IEC 61850-7-420. Potential extensions/modifications may happen if/when the models are moved to International Standard status.

Only the new data objects and CDCs which are represented in ***bold-italic font*** will be tagged with this namespace name. The others should still refer to the namespace where they are primarily defined.

NOTE The term power converter is being used in place of “inverter” since it covers more types of conversion from input to output power:

- AC to DC (rectifier)
- DC to AC (inverter)
- DC to DC (DC-to-DC converter)
- AC to AC (AC-to-AC converter)

2 Normative references

The following documents, in whole or in part, are normatively referenced in this document and are indispensable for its application. For dated references, only the edition cited applies. For undated references, the latest edition of the referenced document (including any amendments) applies.

IEC 61850-7-2, *Communication networks and systems for power utility automation – Part 7-2: Basic communication structure – Abstract communication service interface (ACSI)*

IEC 61850-7-3, *Communication networks and systems for power utility automation – Part 7-3: Basic communication structure – Common data classes*

IEC 61850-7-4, *Communication networks and systems for power utility automation – Part 7-4: Basic communication structure – Compatible logical node classes and data object classes*

IEC 61850-7-410, *Communication networks and systems for power utility automation – Part 7-410: Hydroelectric power plants – Communication for monitoring and control*

IEC 61850-7-420, *Communication networks and systems for power utility automation – Part 7-420: Basic communication structure – Distributed energy resources logical nodes*

IEC 61850-8-1, *Communication networks and systems for power utility automation – Part 8-1: Specific communication service mapping (SCSM) – Mappings to MMS (ISO 9506-1 and ISO 9506-2) and to ISO/IEC 8802-3*

ISO 4217, *Codes for the representation of currencies and funds*

EI Handbook for Electricity Metering, 10th Edition (2002), Edison Electric Institute, Washington, D.C.