This is a preview of IEC 62271-200 Ed. 3.1 en:2024. Click here to purchase the full version from the ANSI store.

Edition 3.1 2024-06
CONSOLIDATED VERSION

INTERNATIONAL STANDARD

colour inside

High-voltage switchgear and controlgear – Part 200: AC metal-enclosed switchgear and controlgear for rated voltages above 1 kV and up to and including 52 kV

INTERNATIONAL
ELECTROTECHNICAL
COMMISSION

ICS 29.130.10

ISBN 978-2-8322-9349-2

Warning! Make sure that you obtained this publication from an authorized distributor.

® Registered trademark of the International Electrotechnical Commission

This is a preview of IEC 62271-200 Ed. 3.1 en:2024. Click here to purchase the full version from the ANSI store.

CONTENTS

FOREWORD 9
INTRODUCTION 12
1 Scope 13
2 Normative references 13
3 Terms and definitions 14
3.1 General terms and definitions 15
3.2 Assemblies of switchgear and controlgear 16
3.3 Parts of assemblies 16
3.4 Switching devices 16
3.5 Parts of switchgear and controlgear 16
3.6 Operational characteristics of switchgear and controlgear 19
3.7 Characteristic quantities 22
3.8 Index of definitions 22
4 Normal and special service conditions 24
5 Ratings 24
5.1 General 24
5.2 Rated voltage (U_r) 24
5.3 Rated insulation level (U_d, U_p, U_s) 24
5.4 Rated frequency (f_r) 24
5.5 Rated continuous current (I_r) 24
5.6 Rated short-time withstand currents (I_k, I_{ke}) 25
5.6.101 Rated short-time withstand current (I_k) 25
5.6.102 Rated short-time phase-to-earth withstand current (I_{ke}) 25
5.7 Rated peak withstand currents (I_p, I_{pe}) 25
5.7.101 Rated peak withstand current (I_p) 25
5.7.102 Rated peak phase-to-earth withstand current (I_{pe}) 25
5.8 Rated durations of short-circuit (t_k, t_{ke}) 25
5.8.101 Rated duration of short-circuit (t_k) 26
5.8.102 Rated duration of phase-to-earth short-circuit (t_{ke}) 26
5.9 Rated supply voltage of auxiliary and control circuits (U_a) 26
5.10 Rated supply frequency of auxiliary and control circuits 26
5.11 Rated pressure of compressed gas supply for controlled pressure systems 26
5.101 Classification of earthing function through main switching device 26
5.102 Rated cable test voltages ($U_{ct\ (AC)}$, $U_{ct\ (DC)}$) 26
5.102.1 General 26
5.102.2 Rated power-frequency cable test voltage $U_{ct\ (AC)}$ 26
5.102.3 Rated DC cable test voltage $U_{ct\ (DC)}$ with rated duration $t_{ct\ (DC)}$ 26
5.103 Ratings of the internal arc classification (IAC) 27
5.103.1 General 27
5.103.2 Types of accessibility 27
5.103.3 Classified sides 27
5.103.4 Rated arc fault currents (I_A, I_{Ae}) 27

This is a preview of IEC 62271-200 Ed. 3.1 en:2024. Click here to purchase the full version from the ANSI store.

5.103.5 Rated arc fault duration (t_A, t_{Ae}) 28
6 Design and construction 28
6.1 Requirements for liquids in switchgear and controlgear 28
6.2 Requirements for gases in switchgear and controlgear 28
6.3 Earthing of switchgear and controlgear 28
6.3.101 Earthing of the high-voltage conductive parts 28
6.3.102 Earthing of enclosure(s) 28
6.3.103 Earthing of withdrawable and removable parts 29
6.3.104 Earthing circuit 29
6.4 Auxiliary and control equipment and circuits 29
6.5 Dependent power operation 29
6.6 Stored energy operation 29
6.7 Independent unlatched operation (independent manual or power operation) 30
6.8 Manually operated actuators 30
6.9 Operation of releases 30
6.10 Pressure/level indication 30
6.11 Nameplates 30
6.12 Locking devices 32
6.13 Position indication 33
6.14 Degrees of protection provided by enclosures 33
6.14.1 General 33
6.14.2 Protection of persons against access to hazardous parts and protection of the equipment against ingress of solid foreign objects (IP coding) 33
6.14.3 Protection against ingress of water (IP coding) 33
6.14.4 Protection of equipment against mechanical impact under normal operating conditions (IK coding) 33
6.15 Creepage distances for outdoor insulators 33
6.16 Gas and vacuum tightness 33
6.17 Tightness for liquid systems 34
6.18 Fire hazard (flammability) 34
6.19 Electromagnetic compatibility (EMC) 34
6.20 X-ray emission 34
6.21 Corrosion 34
6.22 Filling levels for insulation, switching and/or operation 34
6.101 General requirements for assemblies 34
6.102 Metal enclosure 35
6.102.1 General 35
6.102.2 Covers and doors 35
6.102.3 Partition or shutter being part of the enclosure 36
6.102.4 Inspection windows 37
6.102.5 Ventilating openings, vent outlets 37
6.103 High-voltage compartments 37
6.103.1 General 37
6.103.2 Fluid-filled compartments (gas or liquid) 38
6.103.3 Partitions and shutters 39
6.104 Removable parts 41
6.105 Provisions for dielectric tests on cables 41
6.106 Internal arc fault 41
7 Type tests 42

This is a preview of IEC 62271-200 Ed. 3.1 en:2024. Click here to purchase the full version from the ANSI store.

7.1 General 42
7.1.1 Basics 42
7.1.2 Information for identification of test objects 43
7.1.3 Information to be included in type-test reports 43
7.2 Dielectric tests 43
7.2.1 General 43
7.2.2 Ambient air conditions during tests 43
7.2.3 Wet test procedure 43
7.2.4 Arrangement of the equipment 43
7.2.5 Criteria to pass the test 43
7.2.6 Application of the test voltage and test conditions 43
7.2.7 Tests of switchgear and controlgear of U_r ≤ 245 kV 45
7.2.8 Tests of switchgear and controlgear of U_r > 245 kV 46
7.2.9 Artificial pollution tests for outdoor insulators 46
7.2.10 Partial discharge tests 46
7.2.11 Dielectric tests on auxiliary and control circuits 46
7.2.12 Voltage test as condition check 46
7.2.101 Dielectric tests on cable testing circuits 46
7.3 Radio interference voltage (RIV) test 46
7.4 Resistance measurement 47
7.4.1 Measurement of the resistance of auxiliary contacts class 1 and class 2 47
7.4.2 Measurement of the resistance of auxiliary contacts class 3 47
7.4.3 Electrical continuity of earthed metallic parts test 47
7.4.4 Resistance measurement of contacts and connections in the main circuit as a condition check 47
7.5 Continuous current tests 47
7.5.1 Condition of the test object 47
7.5.2 Arrangement of the equipment 47
7.5.3 Test current and duration 47
7.5.4 Temperature measurement during test 48
7.5.5 Resistance of the main circuit 48
7.5.6 Criteria to pass test 48
7.5.101 Test report 48
7.6 Short-time withstand current and peak withstand current tests 49
7.6.1 General 49
7.6.2 Arrangement of the equipment and of the test circuit 50
7.6.3 Test current and duration 50
7.6.4 Conditions of the test object after test 51
7.7 Verification of the protection 51
7.7.1 Verification of the IP coding 51
7.7.2 Verification of the IK coding 51
7.8 Tightness tests 51
7.9 Electromagnetic compatibility tests (EMC) 51
7.10 Additional tests on auxiliary and control circuits 52
7.10.1 General 52
7.10.2 Functional tests 52
7.10.3 Verification of the operational characteristics of auxiliary contacts 52
7.10.4 Environmental tests 52

This is a preview of IEC 62271-200 Ed. 3.1 en:2024. Click here to purchase the full version from the ANSI store.

7.10.5 Dielectric test 52
7.11 X-radiation test for vacuum interrupters 52
7.101 Verification of making and breaking capacities 52
7.101.1 General 52
7.101.2 Test requirements for main switching devices 53
7.101.3 Test requirements for earthing function 53
7.102 Mechanical operation tests 53
7.102.1 Switching devices and removable parts 53
7.102.2 Mechanical and electromechanical interlocks and locking devices 54
7.103 Pressure withstand test for gas-filled compartments 55
7.103.1 Pressure withstand test for gas-filled compartments with pressure relief devices 55
7.103.2 Pressure withstand test for gas-filled compartments without pressure-relief devices 57
7.104 Tests to verify the protection of persons against dangerous electrical effects 57
7.104.1 General 57
7.104.2 Dielectric tests 58
7.104.3 Measurements of leakage currents 58
7.105 Internal arc test 58
7.105.1 General 58
7.105.2 Test conditions 58
7.105.3 Arrangement of the equipment 60
7.105.4 Test procedure 60
7.105.5 Criteria to pass the test 60
7.105.6 Test report 61
7.105.7 Extension of validity of test results 62
8 Routine tests 62
8.1 General 62
8.2 Dielectric test on the main circuit 63
8.3 Tests on auxiliary and control circuits 63
8.3.1 Inspection of auxiliary and control circuits, and verification of conformity to the circuit diagrams and wiring diagrams 63
8.3.2 Functional tests 63
8.3.3 Verification of protection against electrical shock 63
8.3.4 Dielectric tests 63
8.4 Measurement of the resistance of the main circuit 63
8.5 Tightness test 64
8.6 Design and visual checks 64
8.101 Partial discharge measurement 64
8.102 Mechanical operation tests 64
8.103 Pressure tests of gas-filled compartments 64
8.104 Tests after erection on site 65
8.105 Measurement of fluid condition after filling on site 65
9 Guide to the selection of switchgear and controlgear (informative) 65
9.1 General 65
9.2 Selection of rated values 66
9.3 Cable-interface considerations 66
9.4 Continuous or temporary overload due to changed service conditions 66
9.5 Environmental aspects 66

This is a preview of IEC 62271-200 Ed. 3.1 en:2024. Click here to purchase the full version from the ANSI store.

9.101 Selection of design and construction 66
9.101.1 General 66
9.101.2 Architecture and accessibility to high-voltage compartments 67
9.101.3 Service continuity of the switchgear 68
9.101.4 Partition classes 70
9.102 Ratings related to earthing circuits 71
9.103 Internal arc fault 71
9.103.1 General 71
9.103.2 Causes and preventive measures 71
9.103.3 Supplementary protective measures 72
9.103.4 Considerations for the selection and installation 73
9.103.5 Internal arc test 74
9.104 Summary of technical requirements, ratings and optional tests 77
10 Information to be given with enquiries, tenders and orders (informative) 79
10.1 General 79
10.2 Information with enquiries and orders 79
10.3 Information with tenders 80
11 Transport, storage, installation, operating instructions and maintenance 81
11.1 General 81
11.2 Conditions during transport, storage and installation 81
11.3 Installation 81
11.4 Operating instructions 81
11.5 Maintenance 82
12 Safety 82
12.101 Procedures 82
12.102 Internal arc aspects 82
13 Influence of the product on the environment 83
Annex A (normative) Internal arc fault – Method to verify the internal arc classification (IAC) 84
A.1 Room simulation 84
A.1.1 Room simulation for indoor assemblies 84
A.1.2 Room simulation for outdoor assemblies 86
A.2 Indicators (for assessing the thermal effects of the gases) 86
A.2.1 General 86
A.2.2 Arrangement of indicators 86
A.3 Tolerances for geometrical dimensions of test arrangements 88
A.4 Test parameters 88
A.4.1 General 88
A.4.2 Voltage 88
A.4.3 Current 88
A.4.4 Frequency 89
A.5 Test procedure 89
A.5.1 Supply circuit 89
A.5.2 Arc initiation 90
Annex B (normative) Partial discharge measurement 101
B.1 General 101
B.2 Application 101
B.3 Test circuits and measuring instruments 101

This is a preview of IEC 62271-200 Ed. 3.1 en:2024. Click here to purchase the full version from the ANSI store.

B.4 Test procedure 102
B.5 Maximum permissible partial discharge quantity 103
Annex C (informative) List of notes concerning certain countries 107
Annex D (normative) Flowchart categorization procedure for LSC for a given functional unit FU1 with connection compartment 108
Annex E (informative) Pressure coordination chart for gas-filled compartments 109
Bibliography 110

Figure 1 – LSC1 70
Figure 2 – LSC2 70
Figure 3 – LSC2 70
Figure 4 – LSC2 70
Figure 5 – LSC2A 70
Figure 6 – LSC2B 70
Figure 7 – LSC2B 70
Figure 8 – ~~LSC1~~ No LSC assigned 70
Figure 9 – No LSC assigned 70
Figure A.1 – Mounting frame for vertical indicators 92
Figure A.2 – Horizontal indicator 92
Figure A.3 – Position of the indicators 93
Figure A.4 – Room simulation and indicator positioning for accessibility type A, classified rear side, ceiling above 2 000 mm, functional unit of any height 94
Figure A.5 – Room simulation and indicator positioning for accessibility type A, non-accessible rear side, ceiling at 2 000 mm, so functional unit ≤ 1 800 mm high 95
Figure A.6 – Room simulation and indicator positioning for accessibility type B, classified rear side, functional unit ≥ 1 900 mm high 96
Figure A.7 – Room simulation and indicator positioning for accessibility type B, classified rear side, functional unit < 1 900 mm high 97
Figure A.8 – Ceiling height stated from the floor or false floor level where the assembly is actually placed 98
Figure A.9 – Indicator positioning in case of protrusion at < 2 000 mm height, at classified side 99
Figure A.10 – Indicator positioning in case a bottom exhaust duct belonging to the assembly is defined as a walkable integrated part of the false floor 100
Figure B.1 – Partial discharge test circuit (three-phase arrangement) 105
Figure B.2 – Partial-discharge test circuit (system without earthed neutral) 106
Figure D.1 – Flowchart categorization procedure for LSC for a given functional unit FU1 with connection compartment 108
Figure E.1 – Example of pressure coordination chart 109

Table 1 – Nameplate information 30
Table 2 – Locations, causes and examples of measures to decrease the probability of internal arc faults 73
Table 3 – Single-phase-to-earth arc fault current depending on the network neutral earthing 75
Table 4 – Summary of technical requirements, ratings and optional tests for assemblies 77

This is a preview of IEC 62271-200 Ed. 3.1 en:2024. Click here to purchase the full version from the ANSI store.

Table A.1 – Parameters for internal arc test according to compartment construction 91
Table B.1 – Test circuits and procedures 104

This is a preview of IEC 62271-200 Ed. 3.1 en:2024. Click here to purchase the full version from the ANSI store.

INTERNATIONAL ELECTROTECHNICAL COMMISSION

_____

HIGH-VOLTAGE SWITCHGEAR AND CONTROLGEAR –

Part 200: AC metal-enclosed switchgear and controlgear for rated voltages above 1 kV and up to and including 52 kV

FOREWORD

1) The International Electrotechnical Commission (IEC) is a worldwide organization for standardization comprising all national electrotechnical committees (IEC National Committees). The object of IEC is to promote international co-operation on all questions concerning standardization in the electrical and electronic fields. To this end and in addition to other activities, IEC publishes International Standards, Technical Specifications, Technical Reports, Publicly Available Specifications (PAS) and Guides (hereafter referred to as "IEC Publication(s)"). Their preparation is entrusted to technical committees; any IEC National Committee interested in the subject dealt with may participate in this preparatory work. International, governmental and non-governmental organizations liaising with the IEC also participate in this preparation. IEC collaborates closely with the International Organization for Standardization (ISO) in accordance with conditions determined by agreement between the two organizations.
2) The formal decisions or agreements of IEC on technical matters express, as nearly as possible, an international consensus of opinion on the relevant subjects since each technical committee has representation from all interested IEC National Committees.
3) IEC Publications have the form of recommendations for international use and are accepted by IEC National Committees in that sense. While all reasonable efforts are made to ensure that the technical content of IEC Publications is accurate, IEC cannot be held responsible for the way in which they are used or for any misinterpretation by any end user.
4) In order to promote international uniformity, IEC National Committees undertake to apply IEC Publications transparently to the maximum extent possible in their national and regional publications. Any divergence between any IEC Publication and the corresponding national or regional publication shall be clearly indicated in the latter.
5) IEC itself does not provide any attestation of conformity. Independent certification bodies provide conformity assessment services and, in some areas, access to IEC marks of conformity. IEC is not responsible for any services carried out by independent certification bodies.
6) All users should ensure that they have the latest edition of this publication.
7) No liability shall attach to IEC or its directors, employees, servants or agents including individual experts and members of its technical committees and IEC National Committees for any personal injury, property damage or other damage of any nature whatsoever, whether direct or indirect, or for costs (including legal fees) and expenses arising out of the publication, use of, or reliance upon, this IEC Publication or any other IEC Publications.
8) Attention is drawn to the Normative references cited in this publication. Use of the referenced publications is indispensable for the correct application of this publication.
9) IEC draws attention to the possibility that the implementation of this document may involve the use of (a) patent(s). IEC takes no position concerning the evidence, validity or applicability of any claimed patent rights in respect thereof. As of the date of publication of this document, IEC had not received notice of (a) patent(s), which may be required to implement this document. However, implementers are cautioned that this may not represent the latest information, which may be obtained from the patent database available at https://patents.iec.ch. IEC shall not be held responsible for identifying any or all such patent rights.

This consolidated version of the official IEC Standard and its amendment has been prepared for user convenience.

IEC 62271-200 edition 3.1 contains the third edition (2021-05) [documents 17C/782/FDIS and 17C/792/RVD] and its amendment 1 (2024-06) [documents 17C/933/FDIS and 17C/938/RVD].

In this Redline version, a vertical line in the margin shows where the technical content is modified by amendment 1. Additions are in green text, deletions are in strikethrough red text. A separate Final version with all changes accepted is available in this publication.

This is a preview of IEC 62271-200 Ed. 3.1 en:2024. Click here to purchase the full version from the ANSI store.

IEC 62271-200 has been prepared by subcommittee 17C: Assemblies, of IEC technical committee 17: High-voltage switchgear and controlgear. It is an International Standard.

This third edition cancels and replaces the second edition published in 2011. This edition constitutes a technical revision.

This edition includes the following significant technical changes with respect to the previous edition:

a) clause numbering aligned with IEC 62271-1:2017, including the adoption of the subclause names of Clause 3;

b) in Clause 3 specific definitions are added for "in service", "normal operating condition" and "normal use";

c) internal arc testing on pole-mounted switchgear is taken out of this document, as it is now covered by the specific standard IEC 62271-214:2019;

d) a more precise description of earthing circuit is given with the inclusion of ratings and test requirements;

e) number of mechanical tests on interlocks is reduced for type testing; a more precise description of forces to apply during type testing is given (refer to 7.102);

f) resistance measuring on main circuit is only needed before continuous current tests (as reference for routine tests) and no longer needed after this continuous current test. Rationale for this deletion is that this measured resistance does not mean anything; as the temperature rise test was just finished, a new temperature rise test will not give new information;

g) IEC 62271-100:2021, IEC 62271-103:2021, IEC 62271-105:2021 and IEC 62271-106:2021 are referred to in the document;

h) IEC 62271-107:2019 and IEC IEEE 62271-37-013:2015 are also considered in 7.101.2;

i) a more precise description of LSC category is given with the inclusion of an explanatory flowchart (Annex D);

j) examples not covered by the IAC test are transferred from Clause 6 to 9.103;

k) the term "assembly" is defined in Clause 3 and used as synonym for "metal-enclosed switchgear and controlgear" in this document;

l) "metallic" is replaced by "metal" where applicable;

m) 6.105 is now covered by 7.7;

n) a 1 s rule was introduced for Criterion 4 during IAC tests regarding hot gases versus glowing particles as cause of ignition;

o) a more precise description of internal arc tests for switchgear with protrusions is given in Annex A.

The language used for the development of this International Standard is English.

This document was drafted in accordance with ISO/IEC Directives, Part 2, and developed in accordance with ISO/IEC Directives, Part 1 and ISO/IEC Directives, IEC Supplement, available at www.iec.ch/members_experts/refdocs. The main document types developed by IEC are described in greater detail at www.iec.ch/standardsdev/publications.

This document should be read in conjunction with IEC 62271-1:2017, to which it refers and which is applicable unless otherwise specified. In order to simplify the indication of corresponding requirements, the same numbering of clauses and subclauses is used as in IEC 62271-1:2017. Amendments to these clauses and subclauses are given under the same numbering, whilst additional subclauses, are numbered from 101.

The reader's attention is drawn to the fact that Annex C lists all of the "in-some-country" clauses on differing practices of a less permanent nature relating to the subject of this document.

This is a preview of IEC 62271-200 Ed. 3.1 en:2024. Click here to purchase the full version from the ANSI store.

A list of all parts in the IEC 62271 series, published under the general title *High-voltage switchgear and controlgear*, can be found on the IEC website.

The committee has decided that the contents of this document and its amendment will remain unchanged until the stability date indicated on the IEC website under webstore.iec.ch in the data related to the specific document. At this date, the document will be

- reconfirmed,
- withdrawn, or
- revised.

IMPORTANT – The *'colour inside'* logo on the cover page of this publication indicates that it contains colours which are considered to be useful for the correct understanding of its contents. Users should therefore print this document using a colour printer.

This is a preview of IEC 62271-200 Ed. 3.1 en:2024. Click here to purchase the full version from the ANSI store.

INTRODUCTION

High-voltage (IEC 60050-601:1985, 601-01-27) switchgear refers to rated voltages above 1 kV. However, medium-voltage is commonly used for distribution systems with rated voltages above 1 kV and generally applied up to and including 52 kV; refer to IEC 60050-601:1985, 601-01-28 [1][1].

Although primarily dedicated to three-phase systems, this document can also be applied to single-phase and two-phase systems.

Switchgear and controlgear assemblies having a solid-insulation enclosure are covered by IEC 62271-201.

Generally, gas-filled medium-voltage designs have design pressures below 500 kPa, as mentioned for example in the introduction of EN 50187.

[1] Numbers in square brackets refer to the Bibliography.

This is a preview of IEC 62271-200 Ed. 3.1 en:2024. Click here to purchase the full version from the ANSI store.

HIGH-VOLTAGE SWITCHGEAR AND CONTROLGEAR –

Part 200: AC metal-enclosed switchgear and controlgear for rated voltages above 1 kV and up to and including 52 kV

1 Scope

This part of IEC 62271 is applicable to prefabricated metal-enclosed switchgear and controlgear assemblies designed for:

– alternating current;
– rated voltages above 1 kV and up to and including 52 kV;
– service frequencies up to and including 60 Hz;
– indoor and outdoor installation.

The assembly can include air-insulated and/or fluid-filled compartments.

For components installed in a metal-enclosed switchgear and controlgear, this document supplements or even replaces in some cases, the requirements as stated by the individual product standards.

The list of components which can be inside the metal-enclosed switchgear and controlgear is not limited to the ones explicitly cited in this document.

2 Normative references

The following documents are referred to in the text in such a way that some or all of their content constitutes requirements of this document. For dated references, only the edition cited applies. For undated references, the latest edition of the referenced document (including any amendments) applies.

IEC 60050-151, *International Electrotechnical Vocabulary (IEV) – Part 151: Electrical and magnetic devices* (available at http://www.electropedia.org)

IEC 60050-441, *International Electrotechnical Vocabulary (IEV) – Part 441: Switchgear, controlgear and fuses* (available at http://www.electropedia.org)

IEC 60060-1:2010, *High-voltage test techniques – Part 1: General definitions and test requirements*

IEC 60270:2000, *High-voltage test techniques – Partial discharge measurements*
IEC 60270:2000/AMD1:2015

IEC 60529:1989, *Degrees of protection provided by enclosures (IP Code)*
IEC 60529:1989/AMD1:1999
IEC 60529:1989/AMD2:2013

IEC 62262:2002, *Degrees of protection provided by enclosures for electrical equipment against external mechanical impacts (IK code)*

IEC 62271-1:2017, *High-voltage switchgear and controlgear – Part 1: Common specifications for alternating current switchgear and controlgear*

This is a preview of IEC 62271-200 Ed. 3.1 en:2024. Click here to purchase the full version from the ANSI store.

IEC 62271-100:2021, *High-voltage switchgear and controlgear – Part 100: Alternating-current circuit-breakers*

IEC 62271-102:2018, *High-voltage switchgear and controlgear – Part 102: Alternating current disconnectors and earthing switches*

IEC 62271-103:2021, *High-voltage switchgear and controlgear – Part 103: Switches for rated voltages above 1 kV up to and including 52 kV*

IEC 62271-105:2021, *High-voltage switchgear and controlgear – Part 105: Alternating current switch-fuse combinations for rated voltages above 1 kV up to and including 52 kV*

IEC 62271-106:2021, *High-voltage switchgear and controlgear – Part 106: Alternating current contactors, contactor-based controllers and motor-starters*

IEC 62271-107:2019, *High-voltage switchgear and controlgear – Part 107: Alternating current fused circuit-switchers for rated voltages above 1 kV up to and including 52 kV*

IEC 62271-201:2014, *High-voltage switchgear and controlgear – Part 201: AC solid-insulation enclosed switchgear and controlgear for rated voltages above 1 kV and up to and including 52 kV*

~~IEC 62271-203:2011, *High-voltage switchgear and controlgear – Part 203: Gas-insulated metal-enclosed switchgear for rated voltages above 52 kV*~~

IEC 62271-213:2021, *High-voltage switchgear and controlgear – Part 213: Voltage detecting and indicating system*

IEC 62271-215:2021, *High-voltage switchgear and controlgear – Part 215: Phase comparator used with VDIS*

IEC IEEE 62271-37-013:2015, *High-voltage switchgear and controlgear – Part 37-013: Alternating-current generator circuit-breakers*

ISO 4126-2, *Safety devices for protection against excessive pressure – Part 2: Bursting disc safety devices*

This is a preview of IEC 62271-200 Ed. 3.1 en:2024. Click here to purchase the full version from the ANSI store.

CONTENTS

FOREWORD 9
INTRODUCTION 12
1 Scope 13
2 Normative references 13
3 Terms and definitions 14
3.1 General terms and definitions 14
3.2 Assemblies of switchgear and controlgear 16
3.3 Parts of assemblies 16
3.4 Switching devices 16
3.5 Parts of switchgear and controlgear 16
3.6 Operational characteristics of switchgear and controlgear 19
3.7 Characteristic quantities 22
3.8 Index of definitions 22
4 Normal and special service conditions 23
5 Ratings 24
5.1 General 24
5.2 Rated voltage (U_r) 24
5.3 Rated insulation level (U_d, U_p, U_s) 24
5.4 Rated frequency (f_r) 24
5.5 Rated continuous current (I_r) 24
5.6 Rated short-time withstand currents (I_k, I_{ke}) 24
5.6.101 Rated short-time withstand current (I_k) 24
5.6.102 Rated short-time phase-to-earth withstand current (I_{ke}) 25
5.7 Rated peak withstand currents (I_p, I_{pe}) 25
5.7.101 Rated peak withstand current (I_p) 25
5.7.102 Rated peak phase-to-earth withstand current (I_{pe}) 25
5.8 Rated durations of short-circuit (t_k, t_{ke}) 25
5.8.101 Rated duration of short-circuit (t_k) 25
5.8.102 Rated duration of phase-to-earth short-circuit (t_{ke}) 25
5.9 Rated supply voltage of auxiliary and control circuits (U_a) 26
5.10 Rated supply frequency of auxiliary and control circuits 26
5.11 Rated pressure of compressed gas supply for controlled pressure systems 26
5.101 Classification of earthing function through main switching device 26
5.102 Rated cable test voltages ($U_{ct\ (AC)}$, $U_{ct\ (DC)}$) 26
5.102.1 General 26
5.102.2 Rated power-frequency cable test voltage $U_{ct\ (AC)}$ 26
5.102.3 Rated DC cable test voltage $U_{ct\ (DC)}$ with rated duration $t_{ct\ (DC)}$ 26
5.103 Ratings of the internal arc classification (IAC) 26
5.103.1 General 26
5.103.2 Types of accessibility 27
5.103.3 Classified sides 27
5.103.4 Rated arc fault currents (I_A, I_{Ae}) 27

This is a preview of IEC 62271-200 Ed. 3.1 en:2024. Click here to purchase the full version from the ANSI store.

5.103.5 Rated arc fault duration (t_A, t_{Ae}) 27
6 Design and construction 28
6.1 Requirements for liquids in switchgear and controlgear 28
6.2 Requirements for gases in switchgear and controlgear 28
6.3 Earthing of switchgear and controlgear 28
6.3.101 Earthing of the high-voltage conductive parts 28
6.3.102 Earthing of enclosure(s) 28
6.3.103 Earthing of withdrawable and removable parts 28
6.3.104 Earthing circuit 29
6.4 Auxiliary and control equipment and circuits 29
6.5 Dependent power operation 29
6.6 Stored energy operation 29
6.7 Independent unlatched operation (independent manual or power operation) 29
6.8 Manually operated actuators 29
6.9 Operation of releases 29
6.10 Pressure/level indication 30
6.11 Nameplates 30
6.12 Locking devices 32
6.13 Position indication 33
6.14 Degrees of protection provided by enclosures 33
6.14.1 General 33
6.14.2 Protection of persons against access to hazardous parts and protection of the equipment against ingress of solid foreign objects (IP coding) 33
6.14.3 Protection against ingress of water (IP coding) 33
6.14.4 Protection of equipment against mechanical impact under normal operating conditions (IK coding) 33
6.15 Creepage distances for outdoor insulators 33
6.16 Gas and vacuum tightness 33
6.17 Tightness for liquid systems 33
6.18 Fire hazard (flammability) 33
6.19 Electromagnetic compatibility (EMC) 33
6.20 X-ray emission 33
6.21 Corrosion 34
6.22 Filling levels for insulation, switching and/or operation 34
6.101 General requirements for assemblies 34
6.102 Metal enclosure 35
6.102.1 General 35
6.102.2 Covers and doors 35
6.102.3 Partition or shutter being part of the enclosure 36
6.102.4 Inspection windows 36
6.102.5 Ventilating openings, vent outlets 37
6.103 High-voltage compartments 37
6.103.1 General 37
6.103.2 Fluid-filled compartments (gas or liquid) 38
6.103.3 Partitions and shutters 39
6.104 Removable parts 40
6.105 Provisions for dielectric tests on cables 41
6.106 Internal arc fault 41
7 Type tests 41

This is a preview of IEC 62271-200 Ed. 3.1 en:2024. Click here to purchase the full version from the ANSI store.

7.1 General 41
7.1.1 Basics 41
7.1.2 Information for identification of test objects 42
7.1.3 Information to be included in type-test reports 42
7.2 Dielectric tests 42
7.2.1 General 42
7.2.2 Ambient air conditions during tests 43
7.2.3 Wet test procedure 43
7.2.4 Arrangement of the equipment 43
7.2.5 Criteria to pass the test 43
7.2.6 Application of the test voltage and test conditions 43
7.2.7 Tests of switchgear and controlgear of U_r ≤ 245 kV 44
7.2.8 Tests of switchgear and controlgear of U_r > 245 kV 45
7.2.9 Artificial pollution tests for outdoor insulators 45
7.2.10 Partial discharge tests 45
7.2.11 Dielectric tests on auxiliary and control circuits 45
7.2.12 Voltage test as condition check 46
7.2.101 Dielectric tests on cable testing circuits 46
7.3 Radio interference voltage (RIV) test 46
7.4 Resistance measurement 46
7.4.1 Measurement of the resistance of auxiliary contacts class 1 and class 2 46
7.4.2 Measurement of the resistance of auxiliary contacts class 3 46
7.4.3 Electrical continuity of earthed metallic parts test 46
7.4.4 Resistance measurement of contacts and connections in the main circuit as a condition check 46
7.5 Continuous current tests 47
7.5.1 Condition of the test object 47
7.5.2 Arrangement of the equipment 47
7.5.3 Test current and duration 47
7.5.4 Temperature measurement during test 47
7.5.5 Resistance of the main circuit 48
7.5.6 Criteria to pass test 48
7.5.101 Test report 48
7.6 Short-time withstand current and peak withstand current tests 48
7.6.1 General 48
7.6.2 Arrangement of the equipment and of the test circuit 49
7.6.3 Test current and duration 50
7.6.4 Conditions of the test object after test 50
7.7 Verification of the protection 51
7.7.1 Verification of the IP coding 51
7.7.2 Verification of the IK coding 51
7.8 Tightness tests 51
7.9 Electromagnetic compatibility tests (EMC) 51
7.10 Additional tests on auxiliary and control circuits 51
7.10.1 General 51
7.10.2 Functional tests 51
7.10.3 Verification of the operational characteristics of auxiliary contacts 51
7.10.4 Environmental tests 52

This is a preview of IEC 62271-200 Ed. 3.1 en:2024. Click here to purchase the full version from the ANSI store.

7.10.5 Dielectric test 52
7.11 X-radiation test for vacuum interrupters 52
7.101 Verification of making and breaking capacities 52
7.101.1 General 52
7.101.2 Test requirements for main switching devices 52
7.101.3 Test requirements for earthing function 53
7.102 Mechanical operation tests 53
7.102.1 Switching devices and removable parts 53
7.102.2 Mechanical and electromechanical interlocks and locking devices 54
7.103 Pressure withstand test for gas-filled compartments 55
7.103.1 Pressure withstand test for gas-filled compartments with pressure relief devices 55
7.103.2 Pressure withstand test for gas-filled compartments without pressure relief devices 56
7.104 Tests to verify the protection of persons against dangerous electrical effects 56
7.104.1 General 56
7.104.2 Dielectric tests 57
7.104.3 Measurements of leakage currents 57
7.105 Internal arc test 57
7.105.1 General 57
7.105.2 Test conditions 58
7.105.3 Arrangement of the equipment 58
7.105.4 Test procedure 59
7.105.5 Criteria to pass the test 59
7.105.6 Test report 60
7.105.7 Extension of validity of test results 61
8 Routine tests 61
8.1 General 61
8.2 Dielectric test on the main circuit 61
8.3 Tests on auxiliary and control circuits 62
8.3.1 Inspection of auxiliary and control circuits, and verification of conformity to the circuit diagrams and wiring diagrams 62
8.3.2 Functional tests 62
8.3.3 Verification of protection against electrical shock 62
8.3.4 Dielectric tests 62
8.4 Measurement of the resistance of the main circuit 62
8.5 Tightness test 62
8.6 Design and visual checks 62
8.101 Partial discharge measurement 62
8.102 Mechanical operation tests 63
8.103 Pressure tests of gas-filled compartments 63
8.104 Tests after erection on site 63
8.105 Measurement of fluid condition after filling on site 64
9 Guide to the selection of switchgear and controlgear (informative) 64
9.1 General 64
9.2 Selection of rated values 64
9.3 Cable-interface considerations 64
9.4 Continuous or temporary overload due to changed service conditions 65
9.5 Environmental aspects 65

This is a preview of IEC 62271-200 Ed. 3.1 en:2024. Click here to purchase the full version from the ANSI store.

9.101 Selection of design and construction 65
9.101.1 General 65
9.101.2 Architecture and accessibility to high-voltage compartments 65
9.101.3 Service continuity of the switchgear 66
9.101.4 Partition classes 69
9.102 Ratings related to earthing circuits 69
9.103 Internal arc fault 70
9.103.1 General 70
9.103.2 Causes and preventive measures 70
9.103.3 Supplementary protective measures 70
9.103.4 Considerations for the selection and installation 72
9.103.5 Internal arc test 73
9.104 Summary of technical requirements, ratings and optional tests 76
10 Information to be given with enquiries, tenders and orders (informative) 78
10.1 General 78
10.2 Information with enquiries and orders 78
10.3 Information with tenders 79
11 Transport, storage, installation, operating instructions and maintenance 80
11.1 General 80
11.2 Conditions during transport, storage and installation 80
11.3 Installation 80
11.4 Operating instructions 80
11.5 Maintenance 81
12 Safety 81
12.101 Procedures 81
12.102 Internal arc aspects 81
13 Influence of the product on the environment 82
Annex A (normative) Internal arc fault – Method to verify the internal arc classification (IAC) 83
A.1 Room simulation 83
A.1.1 Room simulation for indoor assemblies 83
A.1.2 Room simulation for outdoor assemblies 85
A.2 Indicators (for assessing the thermal effects of the gases) 85
A.2.1 General 85
A.2.2 Arrangement of indicators 85
A.3 Tolerances for geometrical dimensions of test arrangements 87
A.4 Test parameters 87
A.4.1 General 87
A.4.2 Voltage 87
A.4.3 Current 87
A.4.4 Frequency 88
A.5 Test procedure 88
A.5.1 Supply circuit 88
A.5.2 Arc initiation 89
Annex B (normative) Partial discharge measurement 100
B.1 General 100
B.2 Application 100
B.3 Test circuits and measuring instruments 100

This is a preview of IEC 62271-200 Ed. 3.1 en:2024. Click here to purchase the full version from the ANSI store.

B.4 Test procedure 101
B.5 Maximum permissible partial discharge quantity 102
Annex C (informative) List of notes concerning certain countries 106
Annex D (normative) Flowchart categorization procedure for LSC for a given functional unit FU1 with connection compartment 107
Annex E (informative) Pressure coordination chart for gas-filled compartments 108
Bibliography 109

Figure 1 – LSC1 68
Figure 2 – LSC2 68
Figure 3 – LSC2 68
Figure 4 – LSC2 69
Figure 5 – LSC2A 69
Figure 6 – LSC2B 69
Figure 7 – LSC2B 69
Figure 8 – No LSC assigned 69
Figure 9 – No LSC assigned 69
Figure A.1 – Mounting frame for vertical indicators 91
Figure A.2 – Horizontal indicator 91
Figure A.3 – Position of the indicators 92
Figure A.4 – Room simulation and indicator positioning for accessibility type A, classified rear side, ceiling above 2 000 mm, functional unit of any height 93
Figure A.5 – Room simulation and indicator positioning for accessibility type A, non-accessible rear side, ceiling at 2 000 mm, so functional unit ≤ 1 800 mm high 94
Figure A.6 – Room simulation and indicator positioning for accessibility type B, classified rear side, functional unit ≥ 1 900 mm high 95
Figure A.7 – Room simulation and indicator positioning for accessibility type B, classified rear side, functional unit < 1 900 mm high 96
Figure A.8 – Ceiling height stated from the floor or false floor level where the assembly is actually placed 97
Figure A.9 – Indicator positioning in case of protrusion at < 2 000 mm height, at classified side 98
Figure A.10 – Indicator positioning in case a bottom exhaust duct belonging to the assembly is defined as a walkable integrated part of the false floor 99
Figure B.1 – Partial discharge test circuit (three-phase arrangement) 104
Figure B.2 – Partial-discharge test circuit (system without earthed neutral) 105
Figure D.1 – Flowchart categorization procedure for LSC for a given functional unit FU1 with connection compartment 107
Figure E.1 – Example of pressure coordination chart 108

Table 1 – Nameplate information 30
Table 2 – Locations, causes and examples of measures to decrease the probability of internal arc faults 72
Table 3 – Single-phase-to-earth arc fault current depending on the network neutral earthing 74
Table 4 – Summary of technical requirements, ratings and optional tests for assemblies 76

This is a preview of IEC 62271-200 Ed. 3.1 en:2024. Click here to purchase the full version from the ANSI store.

Table A.1 – Parameters for internal arc test according to compartment construction 90
Table B.1 – Test circuits and procedures 103

This is a preview of IEC 62271-200 Ed. 3.1 en:2024. Click here to purchase the full version from the ANSI store.

INTERNATIONAL ELECTROTECHNICAL COMMISSION

_____

HIGH-VOLTAGE SWITCHGEAR AND CONTROLGEAR –

Part 200: AC metal-enclosed switchgear and controlgear for rated voltages above 1 kV and up to and including 52 kV

FOREWORD

1) The International Electrotechnical Commission (IEC) is a worldwide organization for standardization comprising all national electrotechnical committees (IEC National Committees). The object of IEC is to promote international co-operation on all questions concerning standardization in the electrical and electronic fields. To this end and in addition to other activities, IEC publishes International Standards, Technical Specifications, Technical Reports, Publicly Available Specifications (PAS) and Guides (hereafter referred to as "IEC Publication(s)"). Their preparation is entrusted to technical committees; any IEC National Committee interested in the subject dealt with may participate in this preparatory work. International, governmental and non-governmental organizations liaising with the IEC also participate in this preparation. IEC collaborates closely with the International Organization for Standardization (ISO) in accordance with conditions determined by agreement between the two organizations.
2) The formal decisions or agreements of IEC on technical matters express, as nearly as possible, an international consensus of opinion on the relevant subjects since each technical committee has representation from all interested IEC National Committees.
3) IEC Publications have the form of recommendations for international use and are accepted by IEC National Committees in that sense. While all reasonable efforts are made to ensure that the technical content of IEC Publications is accurate, IEC cannot be held responsible for the way in which they are used or for any misinterpretation by any end user.
4) In order to promote international uniformity, IEC National Committees undertake to apply IEC Publications transparently to the maximum extent possible in their national and regional publications. Any divergence between any IEC Publication and the corresponding national or regional publication shall be clearly indicated in the latter.
5) IEC itself does not provide any attestation of conformity. Independent certification bodies provide conformity assessment services and, in some areas, access to IEC marks of conformity. IEC is not responsible for any services carried out by independent certification bodies.
6) All users should ensure that they have the latest edition of this publication.
7) No liability shall attach to IEC or its directors, employees, servants or agents including individual experts and members of its technical committees and IEC National Committees for any personal injury, property damage or other damage of any nature whatsoever, whether direct or indirect, or for costs (including legal fees) and expenses arising out of the publication, use of, or reliance upon, this IEC Publication or any other IEC Publications.
8) Attention is drawn to the Normative references cited in this publication. Use of the referenced publications is indispensable for the correct application of this publication.
9) IEC draws attention to the possibility that the implementation of this document may involve the use of (a) patent(s). IEC takes no position concerning the evidence, validity or applicability of any claimed patent rights in respect thereof. As of the date of publication of this document, IEC had not received notice of (a) patent(s), which may be required to implement this document. However, implementers are cautioned that this may not represent the latest information, which may be obtained from the patent database available at https://patents.iec.ch. IEC shall not be held responsible for identifying any or all such patent rights.

This consolidated version of the official IEC Standard and its amendment has been prepared for user convenience.

IEC 62271-200 edition 3.1 contains the third edition (2021-05) [documents 17C/782/FDIS and 17C/792/RVD] and its amendment 1 (2024-06) [documents 17C/933/FDIS and 17C/938/RVD].

This Final version does not show where the technical content is modified by amendment 1. A separate Redline version with all changes highlighted is available in this publication.

This is a preview of IEC 62271-200 Ed. 3.1 en:2024. Click here to purchase the full version from the ANSI store.

IEC 62271-200 has been prepared by subcommittee 17C: Assemblies, of IEC technical committee 17: High-voltage switchgear and controlgear. It is an International Standard.

This third edition cancels and replaces the second edition published in 2011. This edition constitutes a technical revision.

This edition includes the following significant technical changes with respect to the previous edition:

a) clause numbering aligned with IEC 62271-1:2017, including the adoption of the subclause names of Clause 3;

b) in Clause 3 specific definitions are added for "in service", "normal operating condition" and "normal use";

c) internal arc testing on pole-mounted switchgear is taken out of this document, as it is now covered by the specific standard IEC 62271-214:2019;

d) a more precise description of earthing circuit is given with the inclusion of ratings and test requirements;

e) number of mechanical tests on interlocks is reduced for type testing; a more precise description of forces to apply during type testing is given (refer to 7.102);

f) resistance measuring on main circuit is only needed before continuous current tests (as reference for routine tests) and no longer needed after this continuous current test. Rationale for this deletion is that this measured resistance does not mean anything; as the temperature rise test was just finished, a new temperature rise test will not give new information;

g) IEC 62271-100:2021, IEC 62271-103:2021, IEC 62271-105:2021 and IEC 62271-106:2021 are referred to in the document;

h) IEC 62271-107:2019 and IEC IEEE 62271-37-013:2015 are also considered in 7.101.2;

i) a more precise description of LSC category is given with the inclusion of an explanatory flowchart (Annex D);

j) examples not covered by the IAC test are transferred from Clause 6 to 9.103;

k) the term "assembly" is defined in Clause 3 and used as synonym for "metal-enclosed switchgear and controlgear" in this document;

l) "metallic" is replaced by "metal" where applicable;

m) 6.105 is now covered by 7.7;

n) a 1 s rule was introduced for Criterion 4 during IAC tests regarding hot gases versus glowing particles as cause of ignition;

o) a more precise description of internal arc tests for switchgear with protrusions is given in Annex A.

The language used for the development of this International Standard is English.

This document was drafted in accordance with ISO/IEC Directives, Part 2, and developed in accordance with ISO/IEC Directives, Part 1 and ISO/IEC Directives, IEC Supplement, available at www.iec.ch/members_experts/refdocs. The main document types developed by IEC are described in greater detail at www.iec.ch/standardsdev/publications.

This document should be read in conjunction with IEC 62271-1:2017, to which it refers and which is applicable unless otherwise specified. In order to simplify the indication of corresponding requirements, the same numbering of clauses and subclauses is used as in IEC 62271-1:2017. Amendments to these clauses and subclauses are given under the same numbering, whilst additional subclauses, are numbered from 101.

The reader's attention is drawn to the fact that Annex C lists all of the "in-some-country" clauses on differing practices of a less permanent nature relating to the subject of this document.

This is a preview of IEC 62271-200 Ed. 3.1 en:2024. Click here to purchase the full version from the ANSI store.

A list of all parts in the IEC 62271 series, published under the general title *High-voltage switchgear and controlgear*, can be found on the IEC website.

The committee has decided that the contents of this document and its amendment will remain unchanged until the stability date indicated on the IEC website under webstore.iec.ch in the data related to the specific document. At this date, the document will be

- reconfirmed,
- withdrawn, or
- revised.

IMPORTANT – The *'colour inside'* logo on the cover page of this publication indicates that it contains colours which are considered to be useful for the correct understanding of its contents. Users should therefore print this document using a colour printer.

This is a preview of IEC 62271-200 Ed. 3.1 en:2024. Click here to purchase the full version from the ANSI store.

INTRODUCTION

High-voltage (IEC 60050-601:1985, 601-01-27) switchgear refers to rated voltages above 1 kV. However, medium-voltage is commonly used for distribution systems with rated voltages above 1 kV and generally applied up to and including 52 kV; refer to IEC 60050-601:1985, 601-01-28 [1][1].

Although primarily dedicated to three-phase systems, this document can also be applied to single-phase and two-phase systems.

Switchgear and controlgear assemblies having a solid-insulation enclosure are covered by IEC 62271-201.

Generally, gas-filled medium-voltage designs have design pressures below 500 kPa, as mentioned for example in the introduction of EN 50187.

[1] Numbers in square brackets refer to the Bibliography.

This is a preview of IEC 62271-200 Ed. 3.1 en:2024. Click here to purchase the full version from the ANSI store.

HIGH-VOLTAGE SWITCHGEAR AND CONTROLGEAR –

Part 200: AC metal-enclosed switchgear and controlgear for rated voltages above 1 kV and up to and including 52 kV

1 Scope

This part of IEC 62271 is applicable to prefabricated metal-enclosed switchgear and controlgear assemblies designed for:

– alternating current;
– rated voltages above 1 kV and up to and including 52 kV;
– service frequencies up to and including 60 Hz;
– indoor and outdoor installation.

The assembly can include air-insulated and/or fluid-filled compartments.

For components installed in a metal-enclosed switchgear and controlgear, this document supplements or even replaces in some cases, the requirements as stated by the individual product standards.

The list of components which can be inside the metal-enclosed switchgear and controlgear is not limited to the ones explicitly cited in this document.

2 Normative references

The following documents are referred to in the text in such a way that some or all of their content constitutes requirements of this document. For dated references, only the edition cited applies. For undated references, the latest edition of the referenced document (including any amendments) applies.

IEC 60050-151, *International Electrotechnical Vocabulary (IEV) – Part 151: Electrical and magnetic devices* (available at http://www.electropedia.org)

IEC 60050-441, *International Electrotechnical Vocabulary (IEV) – Part 441: Switchgear, controlgear and fuses* (available at http://www.electropedia.org)

IEC 60060-1:2010, *High-voltage test techniques – Part 1: General definitions and test requirements*

IEC 60270:2000, *High-voltage test techniques – Partial discharge measurements*
IEC 60270:2000/AMD1:2015

IEC 60529:1989, *Degrees of protection provided by enclosures (IP Code)*
IEC 60529:1989/AMD1:1999
IEC 60529:1989/AMD2:2013

IEC 62262:2002, *Degrees of protection provided by enclosures for electrical equipment against external mechanical impacts (IK code)*

IEC 62271-1:2017, *High-voltage switchgear and controlgear – Part 1: Common specifications for alternating current switchgear and controlgear*

This is a preview of IEC 62271-200 Ed. 3.1 en:2024. Click here to purchase the full version from the ANSI store.

IEC 62271-100:2021, *High-voltage switchgear and controlgear – Part 100: Alternating-current circuit-breakers*

IEC 62271-102:2018, *High-voltage switchgear and controlgear – Part 102: Alternating current disconnectors and earthing switches*

IEC 62271-103:2021, *High-voltage switchgear and controlgear – Part 103: Switches for rated voltages above 1 kV up to and including 52 kV*

IEC 62271-105:2021, *High-voltage switchgear and controlgear – Part 105: Alternating current switch-fuse combinations for rated voltages above 1 kV up to and including 52 kV*

IEC 62271-106:2021, *High-voltage switchgear and controlgear – Part 106: Alternating current contactors, contactor-based controllers and motor-starters*

IEC 62271-107:2019, *High-voltage switchgear and controlgear – Part 107: Alternating current fused circuit-switchers for rated voltages above 1 kV up to and including 52 kV*

IEC 62271-201:2014, *High-voltage switchgear and controlgear – Part 201: AC solid-insulation enclosed switchgear and controlgear for rated voltages above 1 kV and up to and including 52 kV*

IEC 62271-213:2021, *High-voltage switchgear and controlgear – Part 213: Voltage detecting and indicating system*

IEC 62271-215:2021, *High-voltage switchgear and controlgear – Part 215: Phase comparator used with VDIS*

IEC IEEE 62271-37-013:2015, *High-voltage switchgear and controlgear – Part 37-013: Alternating-current generator circuit-breakers*

ISO 4126-2, *Safety devices for protection against excessive pressure – Part 2: Bursting disc safety devices*