



IEC 62439-6

Edition 1.0 2010-02

# INTERNATIONAL STANDARD



---

**Industrial communication networks – High availability automation networks –  
Part 6: Distributed Redundancy Protocol (DRP)**

INTERNATIONAL  
ELECTROTECHNICAL  
COMMISSION

PRICE CODE **XB**

---

ICS 25.040, 35.040

ISBN 978-2-88910-709-4

## CONTENTS

FOREWORD.....	5
INTRODUCTION.....	7
1 Scope.....	8
2 Normative references .....	8
3 Terms, definitions, abbreviations, acronyms, and conventions .....	8
3.1 Terms and definitions .....	8
3.2 Abbreviations and acronyms.....	9
3.3 Conventions .....	9
4 Overview .....	9
4.1 Principles .....	9
4.2 Ring ports .....	10
4.3 DRP switch node.....	10
4.4 Single ring topology redundancy.....	11
4.5 Double ring topology redundancy .....	11
4.6 Configuration.....	12
4.6.1 Overview .....	12
4.6.2 Manufacturer configuration .....	12
4.6.3 Communication configuration.....	12
4.6.4 Application configuration .....	13
4.7 Start up .....	13
5 DRP communications .....	13
5.1 Overview .....	13
5.2 Communication procedure .....	15
5.3 Fault detection and recovery .....	18
5.3.1 General .....	18
5.3.2 Handling in a single ring network .....	19
5.3.3 Handling in a double ring network.....	20
5.4 Repairing the inter-switch link fault.....	21
5.5 Repairing time synchronization fault.....	21
5.6 Inserting a repaired switch node.....	22
5.7 Inserting a new switch node .....	23
6 DRP class specification .....	23
7 DRP attributes .....	24
8 DRP services .....	27
8.1 Read .....	27
8.2 Write .....	30
9 DRP protocol specification.....	32
9.1 Basic types encoding .....	32
9.2 ErrorDescription encoding .....	32
9.3 Encoding of DRP Class .....	33
9.4 PDU description .....	34
9.4.1 Encoding of DRP DLPDU .....	34
9.4.2 Encoding of DLSDU.....	35
9.4.3 Encoding of VLAN .....	35
9.4.4 Ethertype.....	35

9.4.5	Encoding of DRP PDU .....	35
9.4.6	Encoding of DRP_DATA .....	36
9.4.7	Encoding of Read Service .....	40
9.4.8	Encoding of Write Service primitives.....	42
9.5	Protocol machine.....	44
9.5.1	Switch node states description .....	44
9.5.2	Protocol State Machine description.....	44
9.5.3	State transitions .....	45
9.5.4	Function descriptions.....	52
	Bibliography.....	64
Figure 1	– DRP communication model .....	10
Figure 2	– Single ring topology redundancy .....	11
Figure 3	– Double ring topology redundancy .....	12
Figure 4	– DRP communication procedure .....	14
Figure 5	– Inserting a new switch node into the DRP system .....	14
Figure 6	– Fault detection and recovery .....	15
Figure 7	– Fault detection and recovery of single ring topology redundancy.....	19
Figure 8	– Single inter-switch link fault detection and recovery of double ring topology redundancy.....	20
Figure 9	– Double inter-switch link fault detection and recovery of double ring topology redundancy.....	21
Figure 10	– Inserting a repaired switch node.....	22
Figure 11	– DRP protocol state machine .....	45
Table 1	– Relationship between required recovery time and the TargetTimeSyncClass.....	22
Table 2	– Parameters of Read service .....	27
Table 3	– Parameters of Write service .....	30
Table 4	– Error Type definition.....	32
Table 5	– Error Code definition .....	33
Table 6	– Definition of DRP Class .....	33
Table 7	– DRP OUI .....	34
Table 8	– DRP MulticastMACAddress .....	35
Table 9	– Encoding of DLSDU .....	35
Table 10	– Encoding of DRP PDU.....	35
Table 11	– DRP_Type definition .....	35
Table 12	– Encoding of RingCheck frame .....	36
Table 13	– Encoding of DeviceAnnunciation frame.....	37
Table 14	– Encoding of RingChange frame .....	39
Table 15	– Encoding of LinkCheck frame .....	39
Table 16	– Encoding of LinkAlarm frame.....	40
Table 17	– Encoding of LinkChange frame.....	40
Table 18	– Encoding of Read Request.....	41
Table 19	– Encoding of Read Service Positive Response .....	41
Table 20	– Encoding of Read Service Negative Response .....	42

Table 21 – Encoding of Write Request .....	43
Table 22 – Encoding of Write Service Positive Response.....	43
Table 23 – Encoding of Write Service Negative Response .....	43
Table 24 – DRP state transitions.....	46
Table 25 – SetRingPortState() descriptions .....	52
Table 26 – LoadRingPortState() descriptions .....	52
Table 27 – WriteSucceed() descriptions .....	52
Table 28 – SynchronizationFinished() descriptions .....	53
Table 29 – ActivePortLinkState() descriptions .....	53
Table 30 – StandbyPortLinkState() descriptions.....	53
Table 31 – ConfigureInfo() descriptions .....	53
Table 32 – DRPSendTimer() descriptions .....	54
Table 33 – SendRingChange() descriptions .....	54
Table 34 – ForwardingRingCheck() descriptions .....	54
Table 35 – AnnunciationBlockingPort() descriptions.....	54
Table 36 – LocalDRPSequenceIDSmaller() descriptions .....	55
Table 37 – RecvAnnunciationWithinTimeLimit() descriptions.....	55
Table 38 – RecvLinkCheckWithinTimeLimit() descriptions.....	55
Table 39 – NoLocalLinkFault() descriptions .....	55
Table 40 – RecvLinkAlarm() descriptions .....	56
Table 41 – Clear_FDB() descriptions .....	56
Table 42 – ChangeRingState() descriptions .....	56
Table 43 – BlockingPortSelect() descriptions .....	56
Table 44 – SendLinkChange() descriptions.....	57
Table 45 – DRPSequenceIDCompare() descriptions .....	57
Table 46 – ChangePortState() descriptions.....	57
Table 47 – ChangeDoublePortState() descriptions .....	57
Table 48 – LocalSendRingCheck() descriptions .....	58
Table 49 – DRPKeyParaConfigure() descriptions .....	58
Table 50 – CheckMACAddress() descriptions .....	58
Table 51 – SetDRPKeyPara() descriptions.....	58
Table 52 – SendDeviceAnnunciation() descriptions.....	59
Table 53 – FaultRecvRingCheck() descriptions.....	59
Table 54 – RecordDeviceState() descriptions .....	59
Table 55 – DrpRecvMsg() descriptions .....	59
Table 56 – SendLinkAlarm() descriptions.....	60
Table 57 – TimeUnsynchronization() descriptions .....	60
Table 58 – PassiveMasterState() descriptions .....	60
Table 59 – SearchDeviceState() descriptions.....	60
Table A.1 – An example of parameters setting for DRP Class .....	62
Table A.2 – Parameters for calculation of recovery time.....	63

## INTERNATIONAL ELECTROTECHNICAL COMMISSION

**INDUSTRIAL COMMUNICATION NETWORKS –  
HIGH AVAILABILITY AUTOMATION NETWORKS –****Part 6: Distributed Redundancy Protocol (DRP)**

## FOREWORD

- 1) The International Electrotechnical Commission (IEC) is a worldwide organization for standardization comprising all national electrotechnical committees (IEC National Committees). The object of IEC is to promote international co-operation on all questions concerning standardization in the electrical and electronic fields. To this end and in addition to other activities, IEC publishes International Standards, Technical Specifications, Technical Reports, Publicly Available Specifications (PAS) and Guides (hereafter referred to as "IEC Publication(s)"). Their preparation is entrusted to technical committees; any IEC National Committee interested in the subject dealt with may participate in this preparatory work. International, governmental and non-governmental organizations liaising with the IEC also participate in this preparation. IEC collaborates closely with the International Organization for Standardization (ISO) in accordance with conditions determined by agreement between the two organizations.
- 2) The formal decisions or agreements of IEC on technical matters express, as nearly as possible, an international consensus of opinion on the relevant subjects since each technical committee has representation from all interested IEC National Committees.
- 3) IEC Publications have the form of recommendations for international use and are accepted by IEC National Committees in that sense. While all reasonable efforts are made to ensure that the technical content of IEC Publications is accurate, IEC cannot be held responsible for the way in which they are used or for any misinterpretation by any end user.
- 4) In order to promote international uniformity, IEC National Committees undertake to apply IEC Publications transparently to the maximum extent possible in their national and regional publications. Any divergence between any IEC Publication and the corresponding national or regional publication shall be clearly indicated in the latter.
- 5) IEC itself does not provide any attestation of conformity. Independent certification bodies provide conformity assessment services and, in some areas, access to IEC marks of conformity. IEC is not responsible for any services carried out by independent certification bodies.
- 6) All users should ensure that they have the latest edition of this publication.
- 7) No liability shall attach to IEC or its directors, employees, servants or agents including individual experts and members of its technical committees and IEC National Committees for any personal injury, property damage or other damage of any nature whatsoever, whether direct or indirect, or for costs (including legal fees) and expenses arising out of the publication, use of, or reliance upon, this IEC Publication or any other IEC Publications.
- 8) Attention is drawn to the Normative references cited in this publication. Use of the referenced publications is indispensable for the correct application of this publication.

International Standard 62439-6 has been prepared by subcommittee 65C: Industrial Networks, of IEC technical committee 65: Industrial-process measurement, control and automation.

This standard cancels and replaces IEC 62439 published in 2008. This first edition constitutes a technical revision.

This edition includes the following significant technical changes with respect to IEC 62439 (2008):

- adding a calculation method for RSTP (rapid spanning tree protocol, IEEE 802.1Q),
- adding two new redundancy protocols: HSR (High-availability Seamless Redundancy) and DRP (Distributed Redundancy Protocol),
- moving former Clauses 1 to 4 (introduction, definitions, general aspects) and the Annexes (taxonomy, availability calculation) to IEC 62439-1, which serves now as a base for the other documents,
- moving Clause 5 (MRP) to IEC 62439-2 with minor editorial changes,
- moving Clause 6 (PRP) was to IEC 62439-3 with minor editorial changes,

- moving Clause 7 (CRP) was to IEC 62439-4 with minor editorial changes, and
- moving Clause 8 (BRP) was to IEC 62439-5 with minor editorial changes,
- adding a method to calculate the maximum recovery time of RSTP in a restricted configuration (ring) to IEC 62439-1 as Clause 8,
- adding specifications of the HSR (High-availability Seamless Redundancy) protocol, which shares the principles of PRP to IEC 62439-3 as Clause 5, and
- introducing the DRP protocol as IEC 62439-6.

The text of this standard is based on the following documents:

FDIS	Report on voting
65C/583/FDIS	65C/589/RVD

Full information on the voting for the approval of this standard can be found in the report on voting indicated in the above table.

This International Standard is to be read in conjunction with IEC 62439-1:2010, *Industrial communication networks – High availability automation networks – Part 1: General concepts and calculation methods*.

A list of the IEC 62439 series can be found, under the general title *Industrial communication networks – High availability automation networks*, on the IEC website.

This publication has been drafted in accordance with ISO/IEC Directives, Part 2.

The committee has decided that the contents of this amendment and the base publication will remain unchanged until the stability date indicated on the IEC web site under "<http://webstore.iec.ch>" in the data related to the specific publication. At this date, the publication will be

- reconfirmed,
- withdrawn,
- replaced by a revised edition, or
- amended.

A bilingual version of this standard may be issued at a later date.

**IMPORTANT – The “colour inside” logo on the cover page of this publication indicates that it contains colours which are considered to be useful for the correct understanding of its contents. Users should therefore print this publication using a colour printer.**

## INTRODUCTION

The IEC 62439 series specifies relevant principles for high availability networks that meet the requirements for industrial automation networks.

In the fault-free state of the network, the protocols of the IEC 62439 series provide ISO/IEC 8802-3 (IEEE 802.3) compatible, reliable data communication, and preserve determinism of real-time data communication. In cases of fault, removal, and insertion of a component, they provide deterministic recovery times.

These protocols retain fully the typical Ethernet communication capabilities as used in the office world, so that the software involved remains applicable.

The market is in need of several network solutions, each with different performance characteristics and functional capabilities, matching diverse application requirements. These solutions support different redundancy topologies and mechanisms which are introduced in IEC 62439-1 and specified in the other Parts of the IEC 62439 series. IEC 62439-1 also distinguishes between the different solutions, giving guidance to the user.

The IEC 62439 series follows the general structure and terms of IEC 61158 series.

The International Electrotechnical Commission (IEC) draws attention to the fact that it is claimed that compliance with this document may involve the use of a patent concerning about the communication procedure and fault detection and recovery for DRP given in 5.2 and 5.3.

IEC takes no position concerning the evidence, validity and scope of this patent right.

The holder of this patent right has assured the IEC that he/she is willing to negotiate licences either free of charge or under reasonable and non-discriminatory terms and conditions with applicants throughout the world. In this respect, the statement of the holder of this patent right is registered with IEC. Information may be obtained from:

SUPCON Group Co., Ltd & Zhejiang University  
Hangzhou  
China

Beijing Kyland Technology Co. LTD  
No 95 Building  
Southeast Corner of Xisanqi Bridge  
Haidian  
Beijing  
China

Attention is drawn to the possibility that some of the elements of this document may be the subject of patent rights other than those identified above. IEC shall not be held responsible for identifying any or all such patent rights.

ISO ([www.iso.org/patents](http://www.iso.org/patents)) and IEC ([http://www.iec.ch/tctools/patent\\_decl.htm](http://www.iec.ch/tctools/patent_decl.htm)) maintain on-line data bases of patents relevant to their standards. Users are encouraged to consult the data bases for the most up to date information concerning patents.

# INDUSTRIAL COMMUNICATION NETWORKS – HIGH AVAILABILITY AUTOMATION NETWORKS –

## Part 6: Distributed Redundancy Protocol (DRP)

### 1 Scope

The IEC 62439 series is applicable to high-availability automation networks based on the ISO/IEC 8802-3 (IEEE 802.3) (Ethernet) technology.

This part of the IEC 62439 series specifies a recovery protocol based on a ring topology, designed to react deterministically on a single failure of an inter-switch link or switch in the network. Each switch has equal management role in the network. Double rings are supported.

### 2 Normative references

The following referenced documents are indispensable for the application of this document. For dated references, only the edition cited applies. For undated references, the latest edition of the referenced document (including any amendments) applies.

IEC 60050-191, *International Electrotechnical Vocabulary – Chapter 191: Dependability and quality of service*

IEC 61158 (all parts), *Industrial communication networks – Fieldbus specifications*

IEC 61588:2009, *Precision clock synchronization protocol for networked measurement and control systems* (IEEE 1588)

IEC 62439-1:2010, *Industrial communication networks – High availability automation networks – Part 1: General concepts and calculation methods*

ISO/IEC/TR 8802-1, *Information technology – Telecommunications and information exchange between systems – Local and metropolitan area networks – Specific requirements – Part 1: Overview of Local Area Network Standards Technologies de* (IEEE 802.1)

ISO/IEC 8802-3:2000, *Information technology – Telecommunications and information exchange between systems – Local and metropolitan area networks – Specific requirements – Part 3: Carrier sense multiple access with collision detection (CSMA/CD) access method and physical layer specifications*

IEEE 802.1D:2004, *IEEE standard for local Local and metropolitan area networks Media Access Control (MAC) Bridges*

IEEE 802.1Q, *IEEE standards for local and metropolitan area network. Virtual bridged local area networks*