

This is a preview of "IEC/TR 62543 Ed. 1.1...". [Click here to purchase the full version from the ANSI store.](#)



Edition 1.1 2013-07

# CONSOLIDATED VERSION



---

**High-voltage direct current (HVDC) power transmission using voltage sourced converters (VSC)**

INTERNATIONAL  
ELECTROTECHNICAL  
COMMISSION

---

ICS 29.200; 29.240.99

ISBN 978-2-8322-1031-4

**Warning! Make sure that you obtained this publication from an authorized distributor.**



# REDLINE VERSION



---

## High-voltage direct current (HVDC) power transmission using voltage sourced converters (VSC)



## CONTENTS

FOREWORD.....	6
1 Scope.....	8
2 Normative references .....	8
3 Terms and definitions .....	8
3.1 General.....	8
3.2 Letter symbols.....	9
3.3 Power semiconductor terms .....	9
3.4 VSC topologies .....	10
3.5 VSC transmission.....	13
3.6 Operating states.....	14
3.7 Type tests .....	16
3.8 Production tests .....	17
3.9 Sample tests .....	17
3.10 Insulation co-ordination terms .....	17
3.11 Power losses.....	17
4 VSC transmission overview .....	18
4.1 Basic operating principles of VSC transmission .....	18
4.1.1 The voltage sourced converter as a black box .....	18
4.1.2 The principles of active and reactive power control.....	19
4.1.3 Operating principles of a VSC transmission scheme .....	21
4.1.4 Applications of VSC transmission .....	21
4.2 Design life.....	22
4.3 VSC transmission configurations .....	22
4.3.1 General .....	22
4.3.2 D.C. circuit configurations.....	22
4.3.3 Monopole configuration .....	22
4.3.4 Bipolar configuration.....	23
4.3.5 Parallel connection of two converters .....	24
4.3.6 Series connection of two converters .....	24
4.3.7 Parallel and series connection of more than two converters.....	25
4.4 Semiconductors for VSC transmission.....	25
5 VSC transmission converter topologies .....	26
5.1 General.....	26
5.2 Converter topologies with VSC valves of “switch” type .....	27
5.2.1 General .....	27
5.2.2 Operating principle .....	27
5.2.3 Topologies.....	28
5.3 Converter topologies with VSC valves of the “controllable voltage source” type.....	31
5.3.1 General .....	31
5.3.2 MMC topology with VSC levels in half-bridge topology.....	33
5.3.3 MMC topology with VSC levels in full-bridge topology.....	35
5.3.4 CTL topology with VSC cells in half-bridge topology .....	33
5.3.5 CTL topology with VSC cells in full-bridge topology .....	33
5.4 VSC valve design considerations .....	37
5.4.1 Reliability and failure mode .....	37
5.4.2 Current rating .....	37

5.4.3	Transient current and voltage requirements .....	37
5.4.4	Diode requirements .....	38
5.4.5	Additional design details .....	38
5.5	Other converter topologies .....	39
5.6	Other equipment for VSC transmission schemes .....	39
5.6.1	General .....	39
5.6.2	Power components of a VSC transmission scheme .....	39
5.6.3	VSC substation circuit breaker .....	40
5.6.4	A.C. system side harmonic filters .....	40
5.6.5	Radio frequency interference filters .....	40
5.6.6	Interface transformers and phase reactors .....	40
5.6.7	Valve reactor .....	41
5.6.8	D.C. capacitors .....	41
5.6.9	D.C. reactor .....	43
5.6.10	Common mode blocking reactor .....	43
5.6.11	D.C. filter .....	44
5.6.12	Dynamic braking system .....	44
6	Overview of VSC controls .....	44
6.1	General .....	44
6.2	Operational modes and operational options .....	45
6.3	Power transfer .....	46
6.3.1	General .....	46
6.3.2	Telecommunication between converter stations .....	47
6.4	Reactive power and a.c. voltage control .....	47
6.4.1	A.C. voltage control .....	47
6.4.2	Reactive power control .....	47
6.5	Black start capability .....	48
6.6	Supply from a wind farm .....	48
7	Steady state operation .....	48
7.1	Steady state capability .....	48
7.2	Converter power losses .....	50
8	Dynamic performance .....	50
8.1	A.C. system disturbances .....	50
8.2	D.C. system disturbances .....	51
8.2.1	D.C. cable fault .....	51
8.2.2	D.C. overhead line fault .....	51
8.3	Internal faults .....	51
9	HVDC performance requirements .....	52
9.1	Harmonic performance .....	52
9.2	Wave distortion .....	53
9.3	Fundamental and harmonics .....	53
9.3.1	Three-phase 2-level VSC .....	53
9.3.2	Selective harmonic elimination modulation .....	55
9.3.3	Multi-pulse and multi-level converters .....	56
9.4	Harmonic voltages on power systems due to VSC operation .....	56
9.5	Design considerations for harmonic filters (a.c. side) .....	57
9.6	D.C. side filtering .....	57

10	Environmental impact .....	57
10.1	General .....	57
10.2	Audible noise .....	57
10.3	Electric and magnetic fields (EMF) .....	58
10.4	Electromagnetic compatibility (EMC) .....	58
11	Testing and commissioning .....	59
11.1	General .....	59
11.2	Factory tests .....	59
11.2.1	Component tests .....	59
11.2.2	Control system tests .....	59
11.3	Commissioning tests / System tests .....	60
11.3.1	General .....	60
11.3.2	Precommissioning tests .....	60
11.3.3	Subsystem tests .....	60
11.3.4	System tests.....	61
	Annex A (informative) Functional specification requirements for VSC transmission systems .....	65
	Annex B (informative) Determination of VSC valve power losses .....	73
	Bibliography.....	82
	Figure 1 – Major components that may be found in a VSC substation .....	9
	Figure 2 – Diagram of a generic voltage source converter (a.c. filters not shown) .....	18
	Figure 3 – The principle of active power control .....	19
	Figure 4 – The principle of reactive power control .....	20
	Figure 5 – A point-to-point VSC transmission scheme.....	21
	Figure 6 – VSC transmission with a symmetrical monopole.....	23
	Figure 7 – VSC transmission with an asymmetrical monopole with metallic return.....	23
	Figure 8 – VSC transmission with an asymmetrical monopole with earth return.....	23
	Figure 9 – VSC transmission in bipolar configuration .....	24
	Figure 10 – Parallel connection of two converter units .....	24
	Figure 11 – Symbol of a <del>controllable switch</del> turn-off semi-conductor device and associated free-wheeling diode.....	25
	Figure 12 – Symbol of an IGBT and associated free-wheeling diode .....	26
	Figure 13 – Diagram of a three-phase 2-level converter and associated a.c. waveform for one phase.....	28
	Figure 14 – Single-phase a.c. output for 2-level converter with PWM switching at 21 times fundamental frequency .....	29
	Figure 15 – Diagram of a three-phase 3-level NPC converter and associated a.c. waveform for one phase.....	30
	Figure 16 – Single-phase a.c. output for 3-level NPC converter with PWM switching at 21 times fundamental frequency .....	31
	Figure 17 – Electrical equivalent for a converter with VSC valves acting like a controllable voltage source .....	32
	Figure 18 – VSC valve level arrangement and equivalent circuit in MMC topology in half-bridge topology .....	33
	Figure 19 – Converter block arrangement with MMC topology in half-bridge topology .....	35

Figure 20 – VSC valve level arrangement and equivalent circuit in MMC topology with full-bridge topology .....	36
Figure 21 – Typical SSOA for the IGBT .....	37
Figure 22 – A 2-level VSC bridge with the IGBTs turned off .....	38
Figure 23 – Representing a VSC unit as an a.c. voltage of magnitude $U$ and phase angle $\delta$ behind reactance.....	45
Figure 24 – Concept of vector control .....	46
Figure 25 – VSC power controller .....	46
Figure 26 – A.C. voltage controller.....	47
Figure 27 – A typical simplified PQ diagram.....	49
Figure 28 – Protection concept of a VSC substation.....	52
Figure 29 – Waveforms for three-phase 2-level VSC.....	54
Figure 30 – Voltage harmonics spectra of a 2-level VSC with carrier frequency at 21st harmonic.....	55
Figure 31 – Phase output voltage for selective harmonic elimination modulation (SHEM).....	55
Figure 32 – Equivalent circuit at the PCC of the VSC.....	56
Figure B.1 – On state voltage of an IGBT or free-wheeling diode .....	74
Figure B.2 – Piecewise-linear representation of IGBT or FWD on-state voltage .....	75
Figure B.3 – IGBT switching losses as a function of collector current.....	78
Figure B.4 – Free-wheeling diode recovery loss as a function of current .....	79

## INTERNATIONAL ELECTROTECHNICAL COMMISSION

---

### HIGH-VOLTAGE DIRECT CURRENT (HVDC) POWER TRANSMISSION USING VOLTAGE SOURCED CONVERTERS (VSC)

#### FOREWORD

- 1) The International Electrotechnical Commission (IEC) is a worldwide organization for standardization comprising all national electrotechnical committees (IEC National Committees). The object of IEC is to promote international co-operation on all questions concerning standardization in the electrical and electronic fields. To this end and in addition to other activities, IEC publishes International Standards, Technical Specifications, Technical Reports, Publicly Available Specifications (PAS) and Guides (hereafter referred to as "IEC Publication(s)"). Their preparation is entrusted to technical committees; any IEC National Committee interested in the subject dealt with may participate in this preparatory work. International, governmental and non-governmental organizations liaising with the IEC also participate in this preparation. IEC collaborates closely with the International Organization for Standardization (ISO) in accordance with conditions determined by agreement between the two organizations.
- 2) The formal decisions or agreements of IEC on technical matters express, as nearly as possible, an international consensus of opinion on the relevant subjects since each technical committee has representation from all interested IEC National Committees.
- 3) IEC Publications have the form of recommendations for international use and are accepted by IEC National Committees in that sense. While all reasonable efforts are made to ensure that the technical content of IEC Publications is accurate, IEC cannot be held responsible for the way in which they are used or for any misinterpretation by any end user.
- 4) In order to promote international uniformity, IEC National Committees undertake to apply IEC Publications transparently to the maximum extent possible in their national and regional publications. Any divergence between any IEC Publication and the corresponding national or regional publication shall be clearly indicated in the latter.
- 5) IEC itself does not provide any attestation of conformity. Independent certification bodies provide conformity assessment services and, in some areas, access to IEC marks of conformity. IEC is not responsible for any services carried out by independent certification bodies.
- 6) All users should ensure that they have the latest edition of this publication.
- 7) No liability shall attach to IEC or its directors, employees, servants or agents including individual experts and members of its technical committees and IEC National Committees for any personal injury, property damage or other damage of any nature whatsoever, whether direct or indirect, or for costs (including legal fees) and expenses arising out of the publication, use of, or reliance upon, this IEC Publication or any other IEC Publications.
- 8) Attention is drawn to the Normative references cited in this publication. Use of the referenced publications is indispensable for the correct application of this publication.
- 9) Attention is drawn to the possibility that some of the elements of this IEC Publication may be the subject of patent rights. IEC shall not be held responsible for identifying any or all such patent rights.

**This Consolidated version of IEC/TR 62543 bears the edition number 1.1. It consists of the first edition (2011) [documents 22F/230/DTR and 22F/239A/RVC] and its amendment 1 (2013) [documents 22F/300A/DTR and 22F/307/RVC]. The technical content is identical to the base edition and its amendment.**

**In this Redline version, a vertical line in the margin shows where the technical content is modified by amendment 1. Additions and deletions are displayed in red, with deletions being struck through. A separate Final version with all changes accepted is available in this publication.**

**This publication has been prepared for user convenience.**

This is a preview of "IEC/TR 62543 Ed. 1.1...". [Click here to purchase the full version from the ANSI store.](#)

The main task of IEC technical committees is to prepare International Standards. However, a technical committee may propose the publication of a technical report when it has collected data of a different kind from that which is normally published as an International Standard, for example "state of the art".

IEC/TR 62543, which is a technical report, has been prepared by subcommittee 22F: Power electronics for electrical transmission and distribution systems, of IEC technical committee 22: Power electronic systems and equipment.

This publication has been drafted in accordance with the ISO/IEC Directives, Part 2.

The committee has decided that the contents of the base publication and its amendment will remain unchanged until the stability date indicated on the IEC web site under "<http://webstore.iec.ch>" in the data related to the specific publication. At this date, the publication will be

- reconfirmed,
- withdrawn,
- replaced by a revised edition, or
- amended.

A bilingual version of this publication may be issued at a later date.

**IMPORTANT – The “colour inside” logo on the cover page of this publication indicates that it contains colours which are considered to be useful for the correct understanding of its contents. Users should therefore print this publication using a colour printer.**



## **HIGH-VOLTAGE DIRECT CURRENT (HVDC) POWER TRANSMISSION USING VOLTAGE SOURCED CONVERTERS (VSC)**

### **1 Scope**

This technical report gives general guidance on the subject of voltage-sourced converters used for transmission of power by high voltage direct current (HVDC). It describes converters that are not only voltage-sourced (containing a capacitive energy storage medium and where the polarity of d.c. voltage remains fixed) but also self-commutated, using semiconductor devices which can both be turned on and turned off by control action. The scope includes 2-level and 3-level converters with pulse-width modulation (PWM), along with multi-level converters, **modular multi-level converters and cascaded two-level converters**, but excludes 2-level and 3-level converters operated without PWM, in square-wave output mode.

HVDC power transmission using voltage sourced converters is known as "VSC transmission".

The various types of circuit that can be used for VSC transmission are described in the report, along with their principal operational characteristics and typical applications. The overall aim is to provide a guide for purchasers to assist with the task of specifying a VSC transmission scheme.

Line-commutated and current-sourced converters are specifically excluded from this report.

### **2 Normative references**

The following referenced documents are indispensable for the application of this document. For dated references, only the edition cited applies. For undated references, the latest edition of the referenced document (including any amendments) applies.

IEC 60633, *Terminology for high-voltage direct-current (HVDC) transmission*

IEC 61975, *High-voltage direct current (HVDC) installations – System tests*

This is a preview of "IEC/TR 62543 Ed. 1.1...". [Click here to purchase the full version from the ANSI store.](#)



Edition 1.1 2013-07

# FINAL VERSION



**High-voltage direct current (HVDC) power transmission using voltage sourced converters (VSC)**



## CONTENTS

FOREWORD.....	6
1 Scope.....	8
2 Normative references .....	8
3 Terms and definitions .....	8
3.1 General.....	8
3.2 Letter symbols.....	9
3.3 Power semiconductor terms .....	9
3.4 VSC topologies .....	10
3.5 VSC transmission.....	13
3.6 Operating states.....	14
3.7 Type tests .....	16
3.8 Production tests .....	16
3.9 Sample tests .....	16
3.10 Insulation co-ordination terms .....	16
3.11 Power losses.....	17
4 VSC transmission overview .....	17
4.1 Basic operating principles of VSC transmission .....	17
4.1.1 The voltage sourced converter as a black box .....	17
4.1.2 The principles of active and reactive power control.....	18
4.1.3 Operating principles of a VSC transmission scheme .....	20
4.1.4 Applications of VSC transmission .....	21
4.2 Design life.....	21
4.3 VSC transmission configurations .....	21
4.3.1 General .....	21
4.3.2 D.C. circuit configurations.....	22
4.3.3 Monopole configuration .....	22
4.3.4 Bipolar configuration.....	23
4.3.5 Parallel connection of two converters .....	23
4.3.6 Series connection of two converters .....	24
4.3.7 Parallel and series connection of more than two converters.....	24
4.4 Semiconductors for VSC transmission.....	24
5 VSC transmission converter topologies .....	26
5.1 General.....	26
5.2 Converter topologies with VSC valves of “switch” type .....	26
5.2.1 General .....	26
5.2.2 Operating principle .....	27
5.2.3 Topologies.....	27
5.3 Converter topologies with VSC valves of the “controllable voltage source” type.....	30
5.3.1 General .....	30
5.3.2 MMC topology with VSC levels in half-bridge topology.....	31
5.3.3 MMC topology with VSC levels in full-bridge topology.....	33
5.3.4 CTL topology with VSC cells in half-bridge topology .....	33
5.3.5 CTL topology with VSC cells in full-bridge topology .....	33
5.4 VSC valve design considerations .....	34
5.4.1 Reliability and failure mode .....	34
5.4.2 Current rating .....	34

5.4.3	Transient current and voltage requirements .....	34
5.4.4	Diode requirements .....	35
5.4.5	Additional design details .....	35
5.5	Other converter topologies .....	36
5.6	Other equipment for VSC transmission schemes .....	36
5.6.1	General .....	36
5.6.2	Power components of a VSC transmission scheme .....	36
5.6.3	VSC substation circuit breaker .....	37
5.6.4	A.C. system side harmonic filters .....	37
5.6.5	Radio frequency interference filters .....	37
5.6.6	Interface transformers and phase reactors .....	37
5.6.7	Valve reactor .....	38
5.6.8	D.C. capacitors .....	38
5.6.9	D.C. reactor .....	40
5.6.10	Common mode blocking reactor .....	40
5.6.11	D.C. filter .....	41
5.6.12	Dynamic braking system .....	41
6	Overview of VSC controls .....	41
6.1	General .....	41
6.2	Operational modes and operational options .....	42
6.3	Power transfer .....	43
6.3.1	General .....	43
6.3.2	Telecommunication between converter stations .....	44
6.4	Reactive power and a.c. voltage control .....	44
6.4.1	A.C. voltage control .....	44
6.4.2	Reactive power control .....	44
6.5	Black start capability .....	45
6.6	Supply from a wind farm .....	45
7	Steady state operation .....	45
7.1	Steady state capability .....	45
7.2	Converter power losses .....	47
8	Dynamic performance .....	47
8.1	A.C. system disturbances .....	47
8.2	D.C. system disturbances .....	48
8.2.1	D.C. cable fault .....	48
8.2.2	D.C. overhead line fault .....	48
8.3	Internal faults .....	48
9	HVDC performance requirements .....	49
9.1	Harmonic performance .....	49
9.2	Wave distortion .....	50
9.3	Fundamental and harmonics .....	50
9.3.1	Three-phase 2-level VSC .....	50
9.3.2	Selective harmonic elimination modulation .....	52
9.3.3	Multi-pulse and multi-level converters .....	53
9.4	Harmonic voltages on power systems due to VSC operation .....	53
9.5	Design considerations for harmonic filters (a.c. side) .....	54
9.6	D.C. side filtering .....	54

10	Environmental impact .....	54
10.1	General .....	54
10.2	Audible noise .....	54
10.3	Electric and magnetic fields (EMF) .....	55
10.4	Electromagnetic compatibility (EMC) .....	55
11	Testing and commissioning .....	56
11.1	General .....	56
11.2	Factory tests .....	56
11.2.1	Component tests .....	56
11.2.2	Control system tests .....	56
11.3	Commissioning tests / System tests .....	57
11.3.1	General .....	57
11.3.2	Precommissioning tests .....	57
11.3.3	Subsystem tests .....	57
11.3.4	System tests.....	58
	Annex A (informative) Functional specification requirements for VSC transmission systems .....	62
	Annex B (informative) Determination of VSC valve power losses .....	70
	Bibliography.....	79
	Figure 1 – Major components that may be found in a VSC substation .....	9
	Figure 2 – Diagram of a generic voltage source converter (a.c. filters not shown) .....	18
	Figure 3 – The principle of active power control .....	19
	Figure 4 – The principle of reactive power control .....	20
	Figure 5 – A point-to-point VSC transmission scheme.....	20
	Figure 6 – VSC transmission with a symmetrical monopole.....	22
	Figure 7 – VSC transmission with an asymmetrical monopole with metallic return.....	22
	Figure 8 – VSC transmission with an asymmetrical monopole with earth return.....	23
	Figure 9 – VSC transmission in bipolar configuration .....	23
	Figure 10 – Parallel connection of two converter units .....	24
	Figure 11 – Symbol of a turn-off semi-conductor device and associated free-wheeling diode .....	25
	Figure 12 – Symbol of an IGBT and associated free-wheeling diode .....	25
	Figure 13 – Diagram of a three-phase 2-level converter and associated a.c. waveform for one phase.....	28
	Figure 14 – Single-phase a.c. output for 2-level converter with PWM switching at 21 times fundamental frequency .....	28
	Figure 15 – Diagram of a three-phase 3-level NPC converter and associated a.c. waveform for one phase.....	29
	Figure 16 – Single-phase a.c. output for 3-level NPC converter with PWM switching at 21 times fundamental frequency .....	30
	Figure 17 – Electrical equivalent for a converter with VSC valves acting like a controllable voltage source .....	31
	Figure 18 – VSC valve level arrangement and equivalent circuit in MMC topology in half-bridge topology .....	32
	Figure 19 – Converter block arrangement with MMC topology in half-bridge topology .....	32

Figure 20 – VSC valve level arrangement and equivalent circuit in MMC topology with full-bridge topology .....	33
Figure 21 – Typical SSOA for the IGBT .....	34
Figure 22 – A 2-level VSC bridge with the IGBTs turned off .....	35
Figure 23 – Representing a VSC unit as an a.c. voltage of magnitude $U$ and phase angle $\delta$ behind reactance.....	42
Figure 24 – Concept of vector control .....	43
Figure 25 – VSC power controller .....	43
Figure 26 – A.C. voltage controller.....	44
Figure 27 – A typical simplified PQ diagram.....	46
Figure 28 – Protection concept of a VSC substation.....	49
Figure 29 – Waveforms for three-phase 2-level VSC.....	51
Figure 30 – Voltage harmonics spectra of a 2-level VSC with carrier frequency at 21st harmonic.....	52
Figure 31 – Phase output voltage for selective harmonic elimination modulation (SHEM).....	52
Figure 32 – Equivalent circuit at the PCC of the VSC.....	53
Figure B.1 – On state voltage of an IGBT or free-wheeling diode .....	71
Figure B.2 – Piecewise-linear representation of IGBT or FWD on-state voltage .....	72
Figure B.3 – IGBT switching losses as a function of collector current.....	75
Figure B.4 – Free-wheeling diode recovery loss as a function of current .....	76

## INTERNATIONAL ELECTROTECHNICAL COMMISSION

---

### **HIGH-VOLTAGE DIRECT CURRENT (HVDC) POWER TRANSMISSION USING VOLTAGE SOURCED CONVERTERS (VSC)**

#### FOREWORD

- 1) The International Electrotechnical Commission (IEC) is a worldwide organization for standardization comprising all national electrotechnical committees (IEC National Committees). The object of IEC is to promote international co-operation on all questions concerning standardization in the electrical and electronic fields. To this end and in addition to other activities, IEC publishes International Standards, Technical Specifications, Technical Reports, Publicly Available Specifications (PAS) and Guides (hereafter referred to as "IEC Publication(s)"). Their preparation is entrusted to technical committees; any IEC National Committee interested in the subject dealt with may participate in this preparatory work. International, governmental and non-governmental organizations liaising with the IEC also participate in this preparation. IEC collaborates closely with the International Organization for Standardization (ISO) in accordance with conditions determined by agreement between the two organizations.
- 2) The formal decisions or agreements of IEC on technical matters express, as nearly as possible, an international consensus of opinion on the relevant subjects since each technical committee has representation from all interested IEC National Committees.
- 3) IEC Publications have the form of recommendations for international use and are accepted by IEC National Committees in that sense. While all reasonable efforts are made to ensure that the technical content of IEC Publications is accurate, IEC cannot be held responsible for the way in which they are used or for any misinterpretation by any end user.
- 4) In order to promote international uniformity, IEC National Committees undertake to apply IEC Publications transparently to the maximum extent possible in their national and regional publications. Any divergence between any IEC Publication and the corresponding national or regional publication shall be clearly indicated in the latter.
- 5) IEC itself does not provide any attestation of conformity. Independent certification bodies provide conformity assessment services and, in some areas, access to IEC marks of conformity. IEC is not responsible for any services carried out by independent certification bodies.
- 6) All users should ensure that they have the latest edition of this publication.
- 7) No liability shall attach to IEC or its directors, employees, servants or agents including individual experts and members of its technical committees and IEC National Committees for any personal injury, property damage or other damage of any nature whatsoever, whether direct or indirect, or for costs (including legal fees) and expenses arising out of the publication, use of, or reliance upon, this IEC Publication or any other IEC Publications.
- 8) Attention is drawn to the Normative references cited in this publication. Use of the referenced publications is indispensable for the correct application of this publication.
- 9) Attention is drawn to the possibility that some of the elements of this IEC Publication may be the subject of patent rights. IEC shall not be held responsible for identifying any or all such patent rights.

**This Consolidated version of IEC/TR 62543 bears the edition number 1.1. It consists of the first edition (2011) [documents 22F/230/DTR and 22F/239A/RVC] and its amendment 1 (2013) [documents 22F/300A/DTR and 22F/307/RVC]. The technical content is identical to the base edition and its amendment.**

**This Final version does not show where the technical content is modified by amendment 1. A separate Redline version with all changes highlighted is available in this publication.**

**This publication has been prepared for user convenience.**

This is a preview of "IEC/TR 62543 Ed. 1.1...". [Click here to purchase the full version from the ANSI store.](#)

The main task of IEC technical committees is to prepare International Standards. However, a technical committee may propose the publication of a technical report when it has collected data of a different kind from that which is normally published as an International Standard, for example "state of the art".

IEC/TR 62543, which is a technical report, has been prepared by subcommittee 22F: Power electronics for electrical transmission and distribution systems, of IEC technical committee 22: Power electronic systems and equipment.

This publication has been drafted in accordance with the ISO/IEC Directives, Part 2.

The committee has decided that the contents of the base publication and its amendment will remain unchanged until the stability date indicated on the IEC web site under "<http://webstore.iec.ch>" in the data related to the specific publication. At this date, the publication will be

- reconfirmed,
- withdrawn,
- replaced by a revised edition, or
- amended.

A bilingual version of this publication may be issued at a later date.

**IMPORTANT – The “colour inside” logo on the cover page of this publication indicates that it contains colours which are considered to be useful for the correct understanding of its contents. Users should therefore print this publication using a colour printer.**



## **HIGH-VOLTAGE DIRECT CURRENT (HVDC) POWER TRANSMISSION USING VOLTAGE SOURCED CONVERTERS (VSC)**

### **1 Scope**

This technical report gives general guidance on the subject of voltage-sourced converters used for transmission of power by high voltage direct current (HVDC). It describes converters that are not only voltage-sourced (containing a capacitive energy storage medium and where the polarity of d.c. voltage remains fixed) but also self-commutated, using semiconductor devices which can both be turned on and turned off by control action. The scope includes 2-level and 3-level converters with pulse-width modulation (PWM), along with multi-level converters, modular multi-level converters and cascaded two-level converters, but excludes 2-level and 3-level converters operated without PWM, in square-wave output mode.

HVDC power transmission using voltage sourced converters is known as "VSC transmission".

The various types of circuit that can be used for VSC transmission are described in the report, along with their principal operational characteristics and typical applications. The overall aim is to provide a guide for purchasers to assist with the task of specifying a VSC transmission scheme.

Line-commutated and current-sourced converters are specifically excluded from this report.

### **2 Normative references**

The following referenced documents are indispensable for the application of this document. For dated references, only the edition cited applies. For undated references, the latest edition of the referenced document (including any amendments) applies.

IEC 60633, *Terminology for high-voltage direct-current (HVDC) transmission*

IEC 61975, *High-voltage direct current (HVDC) installations – System tests*