



Edition 1.0 2025-03
EXTENDED VERSION

TECHNICAL SPECIFICATION

This full version of IEC TS 62271-313:2025 includes the content of the references made to IEC TS 62271-5:2024

High-voltage switchgear and controlgear – Part 313: Direct current circuit-breakers

INTERNATIONAL
ELECTROTECHNICAL
COMMISSION

ICS 29.130.10

ISBN 978-2-8327-0334-2

Warning! Make sure that you obtained this publication from an authorized distributor.

CONTENTS

FOREWORD	11
INTRODUCTION to IEC TS 62271-5:2024	13
INTRODUCTION to IEC TS 62271-313:2025.....	13
1 Scope	14
2 Normative references	14
3 Terms and definitions	17
3.1 General terms and definitions	17
3.2 Assemblies of switchgear and controlgear	23
3.3 Parts of assemblies	23
3.4 Switching devices	23
3.5 Parts of switchgear and controlgear	29
3.6 Operational characteristics of switchgear and controlgear.....	36
3.7 Characteristic quantities	42
3.8 Index of definitions.....	48
4 Normal and special service conditions	53
4.1 Normal service conditions	53
4.1.1 General	53
4.1.2 Indoor switchgear and controlgear	53
4.1.3 Outdoor switchgear and controlgear	53
4.2 Special service conditions.....	54
4.2.1 General	54
4.2.2 Altitude	54
4.2.3 Exposure to pollution	54
4.2.4 Temperature and humidity	55
4.2.5 Exposure to abnormal vibrations, shock or tilting	55
4.2.6 Wind speed	55
4.2.7 Other parameters	55
5 Ratings.....	55
5.1 General.....	55
5.2 Rated direct voltage (U_{rd}).....	56
5.2.1 General	56
5.2.2 Rated voltages	56
5.3 Rated insulation level (U_{dd} , U_p , U_s).....	57
5.4 Rated continuous current (I_{rd})	60
5.5 Rated values of short-time withstand current.....	60
5.5.1 Typical waveform of short-circuit current.....	60
5.5.2 Rated short-time withstand direct current (I_{kd})	63
5.5.3 Rated peak withstand current (I_{pd})	63
5.5.4 Rated duration of short-circuit (t_{kd}).....	63
5.6 Rated supply voltage of auxiliary and control circuits (U_a)	63
5.6.1 General	63
5.6.2 Rated supply voltage (U_a)	64
5.7 Rated supply frequency of auxiliary and control circuits	64
5.101 Rated operating sequence	65

5.102	Rated short-circuit breaking current (I_{scd})	65
5.103	Rated short-circuit making current	65
5.104	Rated dissipated energy during breaking operation	65
6	Design and construction	65
6.1	Requirements for liquids in switchgear and controlgear	65
6.2	Requirements for gases in switchgear and controlgear	66
6.3	Earthing of switchgear and controlgear	66
6.4	Auxiliary and control equipment and circuits	66
6.4.1	General	66
6.4.2	Protection against electric shock	67
6.4.3	Components installed in enclosures	67
6.5	Dependent power operation	70
6.6	Stored energy operation	70
6.6.1	General	70
6.6.2	Energy storage in gas receivers or hydraulic accumulators	71
6.6.3	Energy storage in springs (or weights)	71
6.6.4	Manual charging	71
6.6.5	Motor charging	71
6.6.6	Energy storage in capacitors	71
6.7	Independent unlatched operation (independent manual or power operation)	71
6.8	Manually operated actuators	72
6.9	Operation of releases	72
6.9.1	General	72
6.9.2	Shunt closing release	72
6.9.3	Shunt opening release	72
6.9.4	Capacitor operation of shunt releases	72
6.9.5	Under-voltage release	73
6.10	Pressure/level indication	73
6.10.1	Gas pressure	73
6.10.2	Liquid level	73
6.11	Nameplates	73
6.11.1	General	74
6.11.2	Application	74
6.12	Locking devices	76
6.13	Position indication	77
6.14	Degrees of protection provided by enclosures	77
6.14.1	General	77
6.14.2	Protection of persons against access to hazardous parts and protection of the equipment against ingress of solid foreign objects (IP coding)	77
6.14.3	Protection against ingress of water (IP coding)	77
6.14.4	Protection against mechanical impact under normal service conditions (IK coding)	78
6.15	Creepage distances for outdoor insulators	78
6.16	Gas and vacuum tightness	78
6.16.1	General	78
6.16.2	Controlled pressure systems for gas	78
6.16.3	Closed pressure systems for gas	78
6.16.4	Sealed pressure systems	79
6.17	Tightness for liquid systems	79

6.17.1	General	79
6.17.2	Leakage rates.....	79
6.18	Fire hazard (flammability)	79
6.19	Electromagnetic compatibility (EMC).....	80
6.20	X-ray emission	80
6.21	Corrosion	80
6.22	Filling levels for insulation, switching and/or operation	80
6.101	Static mechanical load	80
6.102	Metal oxide surge arrester (MOSA)	80
6.103	Power to potential device (if applicable).....	80
6.104	Liquid cooling system (if applicable).....	81
6.105	Power electronic devices (if applicable)	81
6.106	Other components (if applicable)	81
7	Type tests	81
7.1	General.....	81
7.1.1	Basics	81
7.1.2	Information for identification of test objects.....	82
7.1.3	Information to be included in type-test reports	83
7.1.4	Invalid tests	83
7.2	Dielectric tests	84
7.2.1	General	84
7.2.2	Ambient air conditions during tests	84
7.2.3	Wet test procedure	84
7.2.4	Arrangement of the equipment.....	84
7.2.5	Criteria to pass the test	85
7.2.6	Application of the test voltage and test conditions.....	86
7.2.7	Tests of switchgear and controlgear	88
7.2.8	Artificial pollution tests for outdoor insulators.....	90
7.2.9	Partial discharge tests	90
7.2.10	Dielectric tests on auxiliary and control circuits.....	90
7.2.11	Voltage test as condition check	90
7.3	Resistance measurement.....	91
7.3.1	Measurement of the resistance of auxiliary contacts class 1 and class 2.....	91
7.3.2	Measurement of the resistance of auxiliary contacts class 3	91
7.3.3	Electrical continuity of earthed metallic parts test	91
7.3.4	Resistance measurement of contacts and connections in the main circuit as a condition check.....	91
7.4	Continuous current tests	92
7.4.1	Condition of the test object	92
7.4.2	Arrangement of the equipment.....	93
7.4.3	Test current and duration.....	93
7.4.4	Temperature measurement during test	94
7.4.5	Resistance of the main circuit.....	95
7.4.6	Criteria to pass test	95
7.5	Short-time withstand current and peak withstand current tests	99
7.5.1	General	99
7.5.2	Arrangement of the equipment and of the test circuit	99
7.5.3	Test current and duration.....	100
7.5.4	Conditions of the test object after test.....	101

7.6	Verification of the protection	101
7.6.1	Verification of the IP coding	101
7.6.2	Verification of the IK coding	101
7.7	Tightness tests	102
7.7.1	General	102
7.7.2	Controlled pressure systems for gas	103
7.7.3	Closed pressure systems for gas	103
7.7.4	Sealed pressure systems	104
7.7.5	Liquid tightness tests	104
7.8	Electromagnetic compatibility tests (EMC)	104
7.8.1	Emission tests	105
7.8.2	Immunity tests on auxiliary and control circuits	107
7.8.3	Additional EMC tests on auxiliary and control circuits	110
7.9	Additional tests on auxiliary and control circuits	110
7.9.1	General	111
7.9.2	Functional tests	111
7.9.3	Verification of the operational characteristics of auxiliary contacts	111
7.9.4	Environmental tests	112
7.9.5	Dielectric test	113
7.10	X-radiation test for vacuum interrupters	113
7.10.1	General requirements	113
7.10.2	Test voltage and measurement procedure	115
7.10.3	Acceptance criteria	115
7.101	Mechanical and environmental test	116
7.101.1	Miscellaneous provisions for mechanical and environmental tests	116
7.101.2	Mechanical operation test at ambient air temperature	118
7.101.3	Low and high-temperature test	120
7.102	Short-circuit making and breaking tests	121
7.102.1	General	121
7.102.2	Making tests	122
7.102.3	Breaking tests	122
7.102.4	Unit testing	124
7.102.5	Multi-part testing	127
7.103	Seismic qualification tests	128
7.104	Communication conformance tests	128
7.105	Cooling equipment tests	128
8	Routine tests	128
8.1	General	128
8.2	Dielectric test on the main circuit	128
8.3	Tests on auxiliary and control circuits	128
8.3.1	Inspection of auxiliary and control circuits, and verification of conformity to the circuit diagrams and wiring diagrams	128
8.3.2	Functional tests	129
8.3.3	Verification of protection against electrical shock	129
8.3.4	Dielectric tests	129
8.4	Measurement of the resistance of the main circuit	129
8.5	Tightness test	130
8.5.1	General	130
8.5.2	Controlled pressure systems for gas	130

8.5.3	Closed pressure systems for gas	130
8.5.4	Sealed pressure systems	130
8.5.5	Liquid tightness tests	130
8.6	Design and visual checks	131
8.101	Connection inspection	131
8.102	Voltage-grading circuit inspection	131
8.103	Voltage withstand test	131
8.104	Mechanical operating tests	131
8.105	MOSA current distribution test	131
8.106	Verification of other components	131
9	Guide to the selection of switchgear and controlgear (informative)	132
9.1	General	132
9.2	Selection of rated values	132
9.2.101	Selection of the rated direct voltage	132
9.2.102	Insulation coordination	132
9.2.103	Selection of the rated continuous current	133
9.2.104	Local service conditions	133
9.2.105	Selection of the rated short-circuit breaking current	133
9.2.106	Operating sequence in service	133
9.3	Cable-interface considerations	133
9.4	Continuous or temporary overload due to changed service conditions	133
9.5	Environmental aspects	133
9.5.1	Service conditions	133
9.5.2	Clearances affected by service conditions	133
9.5.3	High humidity	134
9.5.4	Solar radiation	134
10	Information to be given with enquiries, tenders and orders (informative)	134
10.1	General	134
10.2	Information with enquiries and orders	134
10.3	Information with tenders	136
11	Transport, storage, installation, operating instructions and maintenance	138
11.1	General	138
11.2	Conditions during transport, storage and installation	138
11.3	Installation	139
11.3.1	General	139
11.3.2	Unpacking and lifting	139
11.3.3	Assembly	139
11.3.4	Mounting	139
11.3.5	Connections	139
11.3.6	Information about gas and gas mixtures for controlled and closed pressure systems	140
11.3.7	Final installation inspection	140
11.3.8	Basic input data by the user	140
11.3.9	Basic input data by the manufacturer	141
11.4	Operating instructions	141
11.5	Maintenance	141
11.5.1	General	141
11.5.2	Information about fluids and gas to be included in maintenance manual	141
11.5.3	Recommendations for the manufacturer	142

11.5.4	Recommendations for the user	143
11.5.5	Failure report.....	144
12	Safety.....	145
12.1	General.....	145
12.2	Precautions by manufacturers.....	146
12.3	Precautions by users	146
12.101	High energy capacitor	147
12.102	High-voltage switchgear.....	147
12.103	High power laser.....	147
12.104	MOSA.....	147
12.105	Cooling system	147
12.106	Power electronic devices	147
13	Influence of the product on the environment	147
Annex A (informative)	Examples of HVDC side switchgear arrangement for one pole in an HVDC substation	148
Annex B (informative)	Exposure to pollution.....	150
B.1	General.....	150
B.2	Minimum requirements for switchgear in normal service condition.....	150
B.3	Minimum requirements for switchgear in special service condition	150
Annex C (informative)	Preferred insulation levels for rated voltages lower than 105 kV.....	151
Annex D (informative)	Short-circuit current in HVDC systems	152
D.1	VSC HVDC	152
D.2	LCC HVDC	153
D.3	Special case of LCC HVDC DC faults – LCC as diode bridge.....	153
D.4	HVDC systems with DC circuit-breakers.....	155
D.5	Calculation of the rated short-time withstand direct current	156
D.6	Calculation of Joule integral value (E_j).....	157
Annex E (informative)	References for auxiliary and control circuit components	158
Annex F (informative)	List of symbols	160
Annex G (normative)	Method for the weatherproofing test for outdoor switchgear and controlgear	162
Annex H (normative)	Tolerances on test quantities during tests	165
Annex I (informative)	Extension of validity of type tests.....	168
I.1	General.....	168
I.2	Dielectric tests	168
I.3	Short-time withstand current and peak withstand current tests	168
I.4	Electromagnetic immunity test on auxiliary and control circuits	168
I.5	Environmental tests on auxiliary and control circuits	168
Annex J (normative)	Identification of test objects	170
J.1	General.....	170
J.2	Data.....	170
J.3	Drawings.....	170
Annex K (informative)	Test circuit for superimposed impulse voltage tests.....	172
K.1	General.....	172
K.2	Test circuit using blocking capacitor.....	172
K.3	Test circuit using sphere gap	172
Annex L (informative)	Information and technical requirements to be given with enquiries, tenders and orders	174

L.1	General.....	174
L.2	Normal and special service conditions (refer to Clause 4)	174
L.3	Ratings (refer to Clause 5).....	175
L.4	Design and construction (refer to Clause 6)	175
L.5	System information	176
L.6	Documentation for enquiries and tenders	176
Annex M	(informative) Electromagnetic compatibility on site	177
Annex N	(informative) Standardization activities of HVDC	178
Annex A	(informative) Calculation of the duration of the transient interruption voltage (TIV) and the dissipated energy in type tests	179
A.1	General.....	179
A.2	Stresses during fault current suppression	179
A.2.1	Test circuit with negligible resistance.....	179
A.2.2	Test circuit with appreciable resistance	180
A.3	Direct recovery voltage after current interruption.....	182
Annex B	(informative) Test-circuits for testing the breaking capability of DC circuit-breakers	183
Annex C	(informative) Layout examples of a test object for unit testing.....	188
C.1	General.....	188
C.2	Example of a unit testing layout using one of the common units of a mechanical DC circuit-breaker with current injection composed of multiple vacuum interrupters in series in the case of a modular design.....	188
C.3	Example of a concept of unit testing layout using a partial unit for a mechanical DC circuit-breaker with current injection composed of multiple vacuum interrupters in series in the case of the combined design	188
Annex D	(normative) Tolerances on test quantities during type tests.....	191
Bibliography	192
Figure 1	– Schematic of two-branch DC circuit-breaker.....	25
Figure 2	– Schematic of three-branch DC circuit-breaker	26
Figure 3	– Schematic of power electronic DC circuit-breaker	26
Figure 4	– Schematic of mechanical DC circuit-breaker	27
Figure 5	– Schematic of hybrid DC circuit-breaker	28
Figure 6	– Schematic of DC circuit-breaker electronic valve, section, and level.....	36
Figure 7	– Schematic of a fault interruption process.....	43
Figure 1	– Schematic representation of superimposed impulse voltage tests	60
Figure 2	– Typical waveform of a short-circuit current in an HVDC system	62
Figure 3	– Examples of classes of contacts.....	70
Figure 4	– Diagram of connections of a switching device	86
Figure 5	– Test sequence for polarity reversal tests	90
Figure 6	– Diagram of a test circuit for the radio interference voltage test	106
Figure 7	– Test location of radiation survey instrument	115
Figure A.1	– Example of HVDC side switchgear arrangement for one pole in an HVDC substation	149
Figure D.1	– VSC HVDC under worst-case, pole-pole DC fault	152
Figure D.2	– LCC HVDC under worst-case, pole-pole DC fault.....	153
Figure D.3	– Special case LCC HVDC under worst-case, pole-pole DC fault.....	154

Figure D.4 – HVDC system with DC circuit-breaker under worst-case, pole-pole DC fault.....	155
Figure D.5 – DC circuit-breaker simple model.....	155
Figure D.6 – Equivalent fault current for calculation of rated short time withstand direct current.....	156
Figure G.1 – Arrangement for weatherproofing test.....	163
Figure G.2 – Nozzle for weatherproofing test.....	164
Figure K.1 – Test circuit for superimposed impulse tests using blocking capacitor.....	172
Figure K.2 – Test circuit for superimposed impulse tests using sphere gap.....	173
Figure A.1 – Schematic diagram of current interruption process.....	179
Figure A.2 – Schematic of DC circuit when the current has been commutated into the DC circuit-breaker's energy dissipation branch.....	181
Figure A.3 – Schematic diagram of current interruption process in a slightly resistive circuit.....	181
Figure B.1 – Schematic diagrams of test-circuits for DC circuit-breakers.....	183
Figure B.2 – Current for breaking test.....	184
Figure B.3 – Example of test oscillogram with test-circuit type C.....	185
Figure B.4 – Example of generator supplied test-circuit (type C).....	186
Figure B.5 – Simulation of a direct current interruption with test-circuit type B.....	186
Figure B.6 – Example of test oscillogram with test-circuit type B.....	187
Figure B.7 – Example of pre-charged capacitor supplied test-circuit (type B).....	187
Figure C.1 – Layout of unit for unit testing for a series-connected module design.....	188
Figure C.2 – Example of a unit for unit testing of the combined design to take out the necessary components.....	189
Table 1 – Preferred rated insulation levels.....	58
Table 2 – Direct voltage of auxiliary and control circuits.....	64
Table 3 – Alternating voltage of auxiliary and control circuits.....	64
Table 4 – Auxiliary contact classes.....	69
Table 1 – Nameplate information.....	74
Table 5 – Nameplate information.....	76
Table 2 – Type test items.....	82
Table 3 – Invalid tests.....	83
Table 6 – Test conditions in general case.....	87
Table 7 – Test conditions in case of impulse voltage tests across the isolating distance (or open switching device).....	87
Table 8 – Test conditions in case of superimposed impulse voltage tests.....	87
Table 9 – Test conditions for polarity reversal tests.....	90
Table 10 – Limits of temperature and temperature rise for various parts, materials and dielectrics of high-voltage switchgear and controlgear.....	96
Table 11 – Permissible leakage rates for gas systems.....	103
Table 12 – Application of voltages at the fast transient/burst test.....	108
Table 13 – Application of voltage at the damped oscillatory wave test.....	109
Table 14 – Assessment criteria for transient disturbance immunity.....	110
Table 4 – Number of operating sequences.....	119

Table 5 – Making and breaking test duties	122
Table 6 – Minimum number of DC-CB electronic valve levels per DC-CB electronic valve to be operational type tested.....	127
Table C.1 – Preferred insulation levels for rated voltages lower than 105 kV.....	151
Table E.1 – List of reference documents for auxiliary and control circuit components.....	158
Table H.1 – Tolerances on test quantities for type test.....	165
Table J.1 Drawing list and contents	170
Table A.1 – Examples of DC circuit-breaker parameters and related interruption parameters	182
Table C.1 – Calculation example of a unit for unit testing.....	190
Table D.1 – Tolerances on test quantities during type tests	191

INTERNATIONAL ELECTROTECHNICAL COMMISSION

HIGH-VOLTAGE SWITCHGEAR AND CONTROLGEAR –

Part 313: Direct current circuit-breakers

FOREWORD

- 1) The International Electrotechnical Commission (IEC) is a worldwide organization for standardization comprising all national electrotechnical committees (IEC National Committees). The object of IEC is to promote international co-operation on all questions concerning standardization in the electrical and electronic fields. To this end and in addition to other activities, IEC publishes International Standards, Technical Specifications, Technical Reports, Publicly Available Specifications (PAS) and Guides (hereafter referred to as "IEC Publication(s)"). Their preparation is entrusted to technical committees; any IEC National Committee interested in the subject dealt with may participate in this preparatory work. International, governmental and non-governmental organizations liaising with the IEC also participate in this preparation. IEC collaborates closely with the International Organization for Standardization (ISO) in accordance with conditions determined by agreement between the two organizations.
- 2) The formal decisions or agreements of IEC on technical matters express, as nearly as possible, an international consensus of opinion on the relevant subjects since each technical committee has representation from all interested IEC National Committees.
- 3) IEC Publications have the form of recommendations for international use and are accepted by IEC National Committees in that sense. While all reasonable efforts are made to ensure that the technical content of IEC Publications is accurate, IEC cannot be held responsible for the way in which they are used or for any misinterpretation by any end user.
- 4) In order to promote international uniformity, IEC National Committees undertake to apply IEC Publications transparently to the maximum extent possible in their national and regional publications. Any divergence between any IEC Publication and the corresponding national or regional publication shall be clearly indicated in the latter.
- 5) IEC itself does not provide any attestation of conformity. Independent certification bodies provide conformity assessment services and, in some areas, access to IEC marks of conformity. IEC is not responsible for any services carried out by independent certification bodies.
- 6) All users should ensure that they have the latest edition of this publication.
- 7) No liability shall attach to IEC or its directors, employees, servants or agents including individual experts and members of its technical committees and IEC National Committees for any personal injury, property damage or other damage of any nature whatsoever, whether direct or indirect, or for costs (including legal fees) and expenses arising out of the publication, use of, or reliance upon, this IEC Publication or any other IEC Publications.
- 8) Attention is drawn to the Normative references cited in this publication. Use of the referenced publications is indispensable for the correct application of this publication.
- 9) IEC draws attention to the possibility that the implementation of this document may involve the use of (a) patent(s). IEC takes no position concerning the evidence, validity or applicability of any claimed patent rights in respect thereof. As of the date of publication of this document, IEC had not received notice of a patent, which may be required to implement this document. However, implementers are cautioned that this may not represent the latest information, which may be obtained from the patent database available at <https://patents.iec.ch>. IEC shall not be held responsible for identifying any or all such patent rights.

This extended version (EXV) of the official IEC Standard provides the user with the full content of the Standard.

IEC TS 62271-313:2025 EXV includes the content of IEC TS 62271-313:2025, and the references made to IEC TS 62271-5:2024.

The specific content of IEC TS 62271-313:2025 is displayed on a [blue background](#).

IEC TS 62271-313 has been prepared by subcommittee 17A: Switching devices, of IEC technical committee 17: High-voltage switchgear and controlgear. It is a Technical Specification.

The text of this Technical Specification is based on the following documents:

Draft	Report on voting
17A/1413/DTS	17A/1416/RVDTS

Full information on the voting for its approval can be found in the report on voting indicated in the above table.

The language used for the development of this Technical Specification is English.

This document was drafted in accordance with ISO/IEC Directives, Part 2, and developed in accordance with ISO/IEC Directives, Part 1 and ISO/IEC Directives, IEC Supplement, available at www.iec.ch/members_experts/refdocs. The main document types developed by IEC are described in greater detail at www.iec.ch/publications.

This document is to be read in conjunction with IEC TS 62271-5:2024, to which it refers and which is applicable unless otherwise specified in this document. In order to simplify the indication of corresponding requirements, the same numbering of clauses and subclauses is used as in IEC TS 62271-5 if applicable. Modifications to these clauses and subclauses are given under the same references whilst additional subclauses are numbered from 101.

A list of all parts in the IEC 62271 series, published under the general title *High-voltage switchgear and controlgear*, can be found on the IEC website.

The committee has decided that the contents of this document will remain unchanged until the stability date indicated on the IEC website under webstore.iec.ch in the data related to the specific document. At this date, the document will be

- reconfirmed,
- withdrawn, or
- revised.

INTRODUCTION to IEC TS 62271-5:2024

This Technical Specification has been prepared by TC 17 and it defines common specifications for high-voltage direct current (HVDC) switchgear and controlgear covering both types of air insulated (AIS) and gas insulated (GIS) equipment of HVDC substations. This document includes rules for service conditions, ratings, design and construction requirements. Test requirements and criteria to proof for passing type and routine tests are defined in this document for development and manufacturing of HVDC switchgear.

This specification is applicable for both LCC and VSC HVDC technology.

SC 17A is in the process of preparing documents for the following HVDC switching devices:

- circuit-breakers (IEC TS 62271-313 [1])¹;
- disconnectors and earthing switches (IEC TS 62271-314 [2]);
- transfer switches (IEC TS 62271-315 [3]);
- by-pass switches and paralleling switches (IEC TS 62271-316 [4]).

SC 17C is in the process of preparing a document for DC gas insulated switchgears (IEC TS 62271-318 [5]).

Standardization of direct voltages is the responsibility of TC 8 (System aspects of electrical energy supply).

TC 99 (Insulation co-ordination and system engineering of high voltage electrical power installations above 1,0 kV AC and 1,5 kV DC) defines requirements of DC substations for safety of insulation, equipment, installation and earthing (IEC 61936-2).

TC 115 (High Voltage Direct Current (HVDC) transmission for DC voltages above 100 kV) is responsible for DC transmission system aspects. It is the responsibility of TC 115 to define requirements for different equipment (e. g. switching devices) from system point of view. These definitions are implemented in documents from other TCs. Several Working Groups and Maintenance Teams are preparing documents on reliability, EMC, asset management, system design, DC harmonics, testing, HVDC grids, VSC and LCC converter and insulation coordination for HVDC systems.

INTRODUCTION to IEC TS 62271-313:2025

This document mainly refers to IEC TS 62271-5. In addition, some findings and considerations from CIGRE are referred to in this document [1],[2].

¹ Numbers in square brackets refer to the Bibliography.

HIGH-VOLTAGE SWITCHGEAR AND CONTROLGEAR –

Part 5: Common specifications for direct current switchgear and controlgear

1 Scope

This part of IEC 62271 is applicable to direct current circuit-breakers (hereafter termed DC circuit-breakers) for indoor or outdoor installation having direct voltages of 100 kV and above for operation on DC transmission and distribution systems.

This document includes the (mechanical) switching devices, including the residual current interruption devices, and their operating devices, power electronic switches, primary auxiliary circuits and energy dissipation systems, as well as their controls. Depending on design and system needs, operation can be for one current direction only (unidirectional) or for both directions (bidirectional).

This document does not cover:

Series reactors described in IEC TS 63014-1 for reducing the rate-of-rise of fault current. Although these are often installed with the operation of DC circuit-breakers, they are typically and specifically system-dependent.

2 Normative references

The following documents are referred to in the text in such a way that some or all of their content constitutes requirements of this document. For dated references, only the edition cited applies. For undated references, the latest edition of the referenced document (including any amendments) applies.

IEC 60038:2009, *IEC standard voltages*

IEC 60050-441, *International Electrotechnical Vocabulary (IEV) – Part 441: Switchgear, controlgear and fuses*

IEC 60050-614:2016, *International Electrotechnical Vocabulary (IEV) – Part 614: Generation, transmission and distribution of electricity – Operation*

IEC 60050-811, *International Electrotechnical Vocabulary (IEV) – Part 811: Electric traction*

IEC 60050-826:2022, *International Electrotechnical Vocabulary (IEV) – Part 826: Electrical installations*

IEC 60059, *IEC standard current ratings*

IEC 60060-1, *High-voltage test techniques – Part 1: General definitions and test requirements*

IEC 60068-2-1:2007, *Environmental testing – Part 2-1: Tests – Test A: Cold*

IEC 60068-2-2:2007, *Environmental testing – Part 2-2: Tests – Test B: Dry heat*

IEC 60068-2-17:1994, *Basic environmental testing procedures – Part 2-17: Tests – Test Q: Sealing*

IEC 60068-2-30:2005, *Environmental testing – Part 2-30: Tests – Test Db: Damp heat, cyclic (12 h + 12 h cycle)*

IEC 60071-1:2019, *Insulation co-ordination – Part 1: Definitions, principles and rules*

IEC 60071-2:2018, *Insulation co-ordination – Part 2: Application guidelines*

IEC 60071-11:2022, *Insulation co-ordination – Part 11: Definitions, principles and rules for HVDC system*

IEC 60085:2007, *Electrical insulation – Thermal evaluation and designation*

IEC 60099-9:2014, *Surge arresters – Part 9: Metal-oxide surge arresters without gaps for HVDC converter stations*

IEC 60255-21-1:1988, *Electrical relays – Part 21: Vibration, shock, bump and seismic tests on measuring relays and protection equipment – Section One: Vibration tests (sinusoidal)*

IEC 60270, *High-voltage test techniques – Partial discharge measurements*

IEC 60296, *Fluids for electrotechnical applications – Mineral insulating oils for electrical equipment*

IEC 60376, *Specification of technical grade sulphur hexafluoride (SF₆) and complementary gases to be used in its mixtures for use in electrical equipment*

IEC 60417:2006, *Graphical symbols for use on equipment (available at <http://www.graphical-symbols.info/equipment>)*

IEC 60437, *Radio interference test on high-voltage insulators*

IEC 60480, *Specifications for the re-use of sulphur hexafluoride (SF₆) and its mixtures in electrical equipment*

IEC 60512-2-2, *Connectors for electronic equipment – Tests and measurements – Part 2-2: Electrical continuity and contact resistance tests – Test 2b: Contact resistance – Specified test current method*

IEC 60529:1989, *Degrees of protection provided by enclosures (IP Code)*

IEC 60529:1989/AMD1:1999

IEC 60529:1989/AMD2:2013

IEC 60700-1, *Thyristor valves for high voltage direct current (HVDC) power transmission – Part 1: Electrical testing*

IEC 60633:2019, *High-voltage direct current (HVDC) transmission – Vocabulary*

IEC TS 60815-4:2016, *Selection and dimensioning of high-voltage insulators intended for use in polluted conditions – Part 4: Insulators for DC systems*

IEC 60825-1, *Safety of laser products – Part 1: Equipment classification and requirements*

IEC 60825-2, *Safety of laser products –Part 2: Safety of optical fibre communication systems (OFCSs)*

IEC 61000-4-4, *Electromagnetic compatibility (EMC) – Part 4-4: Testing and measurement techniques – Electrical fast transient/burst immunity test*

IEC 61000-4-11, *Electromagnetic compatibility (EMC) – Part 4-11: Testing and measurement techniques – Voltage dips, short interruptions and voltage variations immunity tests for equipment with input current up to 16 A per phase*

IEC 61000-4-17:1999, *Electromagnetic compatibility (EMC) – Part 4-17: Testing and measurement techniques – Ripple on d.c. input power port immunity test*

IEC 61000-4-18, *Electromagnetic compatibility (EMC) – Part 4-18: Testing and measurement techniques – Damped oscillatory wave immunity test*

IEC 61000-4-29, *Electromagnetic compatibility (EMC) – Part 4-29: Testing and measurement techniques – Voltage dips, short interruptions and voltage variations on DC input power port immunity tests*

IEC 61000-6-2, *Electromagnetic compatibility (EMC) – Part 6-2: Generic standards – Immunity standard for industrial environments*

IEC 61000-6-5, *Electromagnetic compatibility (EMC) – Part 6-5: Generic standards – Immunity for equipment used in power station and substation environment*

IEC 61071:2017, *Capacitors for power electronics*

IEC 61180, *High-voltage test techniques for low-voltage equipment – Definitions, test and procedure requirements, test equipment*

IEC TS 61245, *Artificial pollution tests on high-voltage ceramic and glass insulators to be used on DC systems*

IEC 61810-7:2006, *Electromechanical elementary relays – Part 7: Test and measurement procedures*

IEC 61850-10, *Communication networks and systems for power utility automation – Part 10: Conformance testing*

IEC 62262:2002, *Degrees of protection provided by enclosures for electrical equipment against external mechanical impacts (IK code)*

IEC 62271-1:2017, *High-voltage switchgear and controlgear – Part 1: Common specifications for alternating current switchgear and controlgear*

IEC 62271-1:2017/AMD1:2021

IEC 62271-4, *High-voltage switchgear and controlgear – Part 4: Handling procedures for gases for insulation and/or switching*

IEC TS 62271-5:2024, *High-voltage switchgear and controlgear – Part 5: Common specifications for direct current switchgear*

IEC 62271-100:2021, *High-voltage switchgear and controlgear – Part 100: Alternating-current circuit-breakers*

IEC TR 62271-300, *High-voltage switchgear and controlgear – Part 300: Seismic qualification of alternating current circuit-breakers*

IEC 62501, *Voltage sourced converter (VSC) valves for high-voltage direct current (HVDC) power transmission – Electrical testing*

IEC 62751-1, *Power losses in voltage sourced converter (VSC) valves for high-voltage direct current (HVDC) systems – Part 1: General requirements*

IEC 62751-2, *Power losses in voltage sourced converter (VSC) valves for high-voltage direct current (HVDC) systems – Part 2: Modular multilevel converters*

IEC TR 63259:2022, *Water cooling systems for power electronics used in electrical transmission and distribution systems*

CISPR 11:2015, *Industrial, scientific and medical equipment – Radio-frequency disturbance characteristics – Limits and methods of measurement*

CISPR 16-1 (all parts), *Specification for radio disturbance and immunity measuring apparatus and methods – Part 1: Radio disturbance and immunity measuring apparatus*

CISPR TR 18-2, *Radio interference characteristics of overhead power lines and high-voltage equipment – Part 2: Methods of measurement and procedure for determining limits*



TECHNICAL SPECIFICATION

High-voltage switchgear and controlgear – Part 313: Direct current circuit-breakers



CONTENTS

FOREWORD.....	7
INTRODUCTION.....	9
1 Scope.....	10
2 Normative references	10
3 Terms and definitions	11
3.1 General terms and definitions	11
3.2 Assemblies of switchgear and controlgear	12
3.3 Parts of assemblies	12
3.4 Switching devices	12
3.5 Parts of switchgear and controlgear	16
3.6 Operational characteristics of DC circuit-breaker	20
3.7 Characteristic quantities	21
3.8 Index of definitions.....	26
4 Normal and special service conditions	28
5 Ratings.....	28
5.1 General.....	28
5.2 Rated direct voltage (U_{rd}).....	29
5.2.1 General	29
5.2.2 Rated voltages	29
5.3 Rated insulation level (U_{dd} , U_p , U_s)	29
5.4 Rated continuous current (I_{rd})	29
5.5 Rated values of short-time withstand current.....	29
5.5.1 Typical waveform of short-circuit current.....	29
5.5.2 Rated short-time withstand direct current (I_{kd})	29
5.5.3 Rated peak withstand current (I_{pd})	29
5.5.4 Rated duration of short circuit (t_{kd}).....	29
5.6 Rated supply voltage of auxiliary and control circuits (U_a)	29
5.6.1 General	29
5.6.2 Rated supply voltage (U_a)	29
5.7 Rated supply frequency of auxiliary and control circuits	29
5.101 Rated operating sequence	30
5.102 Rated short-circuit breaking current (I_{scd})	30
5.103 Rated short-circuit making current	30
5.104 Rated dissipated energy during breaking operation.....	30
6 Design and construction	30
6.1 Requirements for liquids in DC circuit-breaker	30
6.2 Requirements for gases in DC circuit-breaker	30
6.3 Earthing of DC circuit-breaker.....	30
6.4 Auxiliary and control equipment and circuits	31
6.5 Dependent power operation	31
6.6 Stored energy operation.....	31
6.7 Independent unlatched operation (independent manual or power operation)	31
6.8 Manually operated actuators	31
6.9 Operation of releases.....	31

6.10	Pressure/level indication	31
6.11	Nameplates.....	31
6.12	Locking devices	32
6.13	Position indication.....	33
6.14	Degrees of protection provided by enclosures.....	33
6.15	Creepage distances for outdoor insulators	33
6.16	Gas and vacuum tightness	33
6.17	Tightness for liquid systems.....	33
6.18	Fire hazard (flammability)	33
6.19	Electromagnetic compatibility (EMC).....	33
6.20	X-ray emission	33
6.21	Corrosion	33
6.22	Filling levels for insulation, switching and/or operation.....	33
6.101	Static mechanical load	33
6.102	Metal oxide surge arrester (MOSA).....	34
6.103	Power to potential device (if applicable).....	34
6.104	Liquid cooling system (if applicable).....	34
6.105	Power electronic devices (if applicable)	34
6.106	Other components (if applicable)	35
7	Type tests	35
7.1	General.....	35
7.1.1	Basics	35
7.1.2	Information for identification of test objects.....	36
7.1.3	Information to be included in type-test reports	36
7.1.4	Invalid tests	36
7.2	Dielectric tests	36
7.2.1	General	36
7.2.2	Ambient air conditions during tests	36
7.2.3	Wet test procedure	36
7.2.4	Arrangement of the equipment.....	36
7.2.5	Criteria to pass the tests.....	36
7.2.6	Application of the test voltage and test conditions.....	36
7.2.7	Tests of switchgear and controlgear	36
7.2.8	Artificial pollution tests for outdoor insulators.....	37
7.2.9	Partial discharge tests	37
7.2.10	Dielectric tests on auxiliary and control circuits.....	37
7.2.11	Voltage test as condition check	38
7.3	Resistance measurement.....	38
7.4	Continuous current tests	38
7.5	Short-time withstand current and peak withstand current tests	38
7.6	Verification of the protection	38
7.7	Tightness tests	38
7.8	Electromagnetic compatibility (EMC) tests	38
7.9	Additional tests on auxiliary and control circuits	38
7.10	X-radiation test for vacuum interrupters	38
7.101	Mechanical and environmental test.....	39
7.101.1	Miscellaneous provisions for mechanical and environmental tests	39
7.101.2	Mechanical operation test at ambient air temperature.....	41
7.101.3	Low and high-temperature test	43

7.102	Short-circuit making and breaking tests.....	44
7.102.1	General	44
7.102.2	Making tests	45
7.102.3	Breaking tests.....	45
7.102.4	Unit testing	47
7.102.5	Multi-part testing.....	50
7.103	Seismic qualification tests.....	51
7.104	Communication conformance tests.....	51
7.105	Cooling equipment tests.....	51
8	Routine tests	51
8.1	General.....	51
8.2	Dielectric test on the main circuit	51
8.3	Tests on auxiliary and control circuits	51
8.4	Measurement of the resistance of the main circuit.....	51
8.5	Tightness test	51
8.6	Design and visual checks.....	51
8.101	Connection inspection.....	51
8.102	Voltage-grading circuit inspection	51
8.103	Voltage withstand test.....	52
8.104	Mechanical operating tests	52
8.105	MOSA current distribution test	52
8.106	Verification of other components.....	52
9	Guide to the selection of DC circuit-breakers (informative)	52
9.1	General.....	52
9.2	Selection of rated values.....	53
9.2.101	Selection of the rated direct voltage.....	53
9.2.102	Insulation coordination.....	53
9.2.103	Selection of the rated continuous current.....	53
9.2.104	Local service conditions.....	53
9.2.105	Selection of the rated short-circuit breaking current	53
9.2.106	Operating sequence in service.....	53
9.3	Cable-interface considerations.....	54
9.4	Continuous or temporary overload due to changed service conditions.....	54
9.5	Environmental aspects.....	54
10	Information to be given with enquiries, tenders and orders (informative).....	54
10.1	General.....	54
10.2	Information with enquiries and orders	54
10.3	Information with tenders.....	55
11	Transport, storage, installation, operation instructions and maintenance.....	56
11.1	General.....	56
11.2	Conditions during transport, storage and installation	56
11.3	Installation	57
11.4	Operating instructions	57
11.5	Maintenance	57
11.5.1	General	57
11.5.2	Information about fluids and gas to be included in maintenance manual	57
11.5.3	Recommendations for the manufacturer.....	57
11.5.4	Recommendations for the user	57

11.5.5	Failure report.....	58
12	Safety.....	58
12.1	General.....	58
12.2	Precautions by manufacturers.....	58
12.3	Precautions by users.....	58
12.101	High energy capacitor.....	58
12.102	High-voltage switchgear.....	58
12.103	High power laser.....	58
12.104	MOSA.....	58
12.105	Cooling system.....	58
12.106	Power electronic devices.....	59
13	Influence of the product on the environment.....	59
Annex A (informative) Calculation of the duration of the transient interruption voltage (TIV) and the dissipated energy in type tests.....		60
A.1	General.....	60
A.2	Stresses during fault current suppression.....	60
A.2.1	Test circuit with negligible resistance.....	60
A.2.2	Test circuit with appreciable resistance.....	61
A.3	Direct recovery voltage after current interruption.....	63
Annex B (informative) Test-circuits for testing the breaking capability of DC circuit-breakers.....		64
Annex C (informative) Layout examples of a test object for unit testing.....		69
C.1	General.....	69
C.2	Example of a unit testing layout using one of the common units of a mechanical DC circuit-breaker with current injection composed of multiple vacuum interrupters in series in the case of a modular design.....	69
C.3	Example of a concept of unit testing layout using a partial unit for a mechanical DC circuit-breaker with current injection composed of multiple vacuum interrupters in series in the case of the combined design.....	69
Annex D (normative) Tolerances on test quantities during type tests.....		72
Bibliography.....		73
Figure 1 – Schematic of two-branch DC circuit-breaker.....		12
Figure 2 – Schematic of three-branch DC circuit-breaker.....		13
Figure 3 – Schematic of power electronic DC circuit-breaker.....		14
Figure 4 – Schematic of mechanical DC circuit-breaker.....		14
Figure 5 – Schematic of hybrid DC circuit-breaker.....		15
Figure 6 – Schematic of DC circuit-breaker electronic valve, section, and level.....		19
Figure 7 – Schematic of a fault interruption process.....		22
Figure A.1 – Schematic diagram of current interruption process.....		60
Figure A.2 – Schematic of DC circuit when the current has been commutated into the DC circuit-breaker's energy dissipation branch.....		62
Figure A.3 – Schematic diagram of current interruption process in a slightly resistive circuit.....		62
Figure B.1 – Schematic diagrams of test-circuits for DC circuit-breakers.....		64
Figure B.2 – Current for breaking test.....		65
Figure B.3 – Example of test oscillogram with test-circuit type C.....		66
Figure B.4 – Example of generator supplied test-circuit (type C).....		67

Figure B.5 – Simulation of a direct current interruption with test-circuit type B	67
Figure B.6 – Example of test oscillogram with test-circuit type B	68
Figure B.7 – Example of pre-charged capacitor supplied test-circuit (type B)	68
Figure C.1 – Layout of unit for unit testing for a series-connected module design	69
Figure C.2 – Example of a unit for unit testing of the combined design to take out the necessary components	70
Table 1 – Nameplate information	32
Table 2 – Type test items	35
Table 3 – Invalid tests	36
Table 4 – Number of operating sequences	42
Table 5 – Making and breaking test duties	45
Table 6 – Minimum number of DC-CB electronic valve levels per DC-CB electronic valve to be operational type tested	50
Table A.1 – Examples of DC circuit-breaker parameters and related interruption parameters	63
Table C.1 – Calculation example of a unit for unit testing	71
Table D.1 – Tolerances on test quantities during type tests	72

INTERNATIONAL ELECTROTECHNICAL COMMISSION

HIGH-VOLTAGE SWITCHGEAR AND CONTROLGEAR –

Part 313: Direct current circuit-breakers

FOREWORD

- 1) The International Electrotechnical Commission (IEC) is a worldwide organization for standardization comprising all national electrotechnical committees (IEC National Committees). The object of IEC is to promote international co-operation on all questions concerning standardization in the electrical and electronic fields. To this end and in addition to other activities, IEC publishes International Standards, Technical Specifications, Technical Reports, Publicly Available Specifications (PAS) and Guides (hereafter referred to as "IEC Publication(s)"). Their preparation is entrusted to technical committees; any IEC National Committee interested in the subject dealt with may participate in this preparatory work. International, governmental and non-governmental organizations liaising with the IEC also participate in this preparation. IEC collaborates closely with the International Organization for Standardization (ISO) in accordance with conditions determined by agreement between the two organizations.
- 2) The formal decisions or agreements of IEC on technical matters express, as nearly as possible, an international consensus of opinion on the relevant subjects since each technical committee has representation from all interested IEC National Committees.
- 3) IEC Publications have the form of recommendations for international use and are accepted by IEC National Committees in that sense. While all reasonable efforts are made to ensure that the technical content of IEC Publications is accurate, IEC cannot be held responsible for the way in which they are used or for any misinterpretation by any end user.
- 4) In order to promote international uniformity, IEC National Committees undertake to apply IEC Publications transparently to the maximum extent possible in their national and regional publications. Any divergence between any IEC Publication and the corresponding national or regional publication shall be clearly indicated in the latter.
- 5) IEC itself does not provide any attestation of conformity. Independent certification bodies provide conformity assessment services and, in some areas, access to IEC marks of conformity. IEC is not responsible for any services carried out by independent certification bodies.
- 6) All users should ensure that they have the latest edition of this publication.
- 7) No liability shall attach to IEC or its directors, employees, servants or agents including individual experts and members of its technical committees and IEC National Committees for any personal injury, property damage or other damage of any nature whatsoever, whether direct or indirect, or for costs (including legal fees) and expenses arising out of the publication, use of, or reliance upon, this IEC Publication or any other IEC Publications.
- 8) Attention is drawn to the Normative references cited in this publication. Use of the referenced publications is indispensable for the correct application of this publication.
- 9) IEC draws attention to the possibility that the implementation of this document may involve the use of (a) patent(s). IEC takes no position concerning the evidence, validity or applicability of any claimed patent rights in respect thereof. As of the date of publication of this document, IEC had not received notice of a patent, which may be required to implement this document. However, implementers are cautioned that this may not represent the latest information, which may be obtained from the patent database available at <https://patents.iec.ch>. IEC shall not be held responsible for identifying any or all such patent rights.

IEC TS 62271-313 has been prepared by subcommittee 17A: Switching devices, of IEC technical committee 17: High-voltage switchgear and controlgear. It is a Technical Specification.

The text of this Technical Specification is based on the following documents:

Draft	Report on voting
17A/1413/DTS	17A/1416/RVDTS

Full information on the voting for its approval can be found in the report on voting indicated in the above table.

The language used for the development of this Technical Specification is English.

This document was drafted in accordance with ISO/IEC Directives, Part 2, and developed in accordance with ISO/IEC Directives, Part 1 and ISO/IEC Directives, IEC Supplement, available at www.iec.ch/members_experts/refdocs. The main document types developed by IEC are described in greater detail at www.iec.ch/publications.

This document is to be read in conjunction with IEC TS 62271-5:2024, to which it refers and which is applicable unless otherwise specified in this document. In order to simplify the indication of corresponding requirements, the same numbering of clauses and subclauses is used as in IEC TS 62271-5 if applicable. Modifications to these clauses and subclauses are given under the same references whilst additional subclauses are numbered from 101.

A list of all parts in the IEC 62271 series, published under the general title *High-voltage switchgear and controlgear*, can be found on the IEC website.

The committee has decided that the contents of this document will remain unchanged until the stability date indicated on the IEC website under webstore.iec.ch in the data related to the specific document. At this date, the document will be

- reconfirmed,
- withdrawn, or
- revised.

INTRODUCTION

This document mainly refers to IEC TS 62271-5. In addition, some findings and considerations from CIGRE are referred to in this document [1],[2]¹.

¹ Numbers in square brackets refer to the Bibliography.

HIGH-VOLTAGE SWITCHGEAR AND CONTROLGEAR –

Part 313: Direct current circuit-breakers

1 Scope

This part of IEC 62271 is applicable to direct current circuit-breakers (hereafter termed DC circuit-breakers) for indoor or outdoor installation having direct voltages of 100 kV and above for operation on DC transmission and distribution systems.

This document includes the (mechanical) switching devices, including the residual current interruption devices, and their operating devices, power electronic switches, primary auxiliary circuits and energy dissipation systems, as well as their controls. Depending on design and system needs, operation can be for one current direction only (unidirectional) or for both directions (bidirectional).

This document does not cover:

Series reactors described in IEC TS 63014-1 for reducing the rate-of-rise of fault current. Although these are often installed with the operation of DC circuit-breakers, they are typically and specifically system-dependent.

2 Normative references

The following documents are referred to in the text in such a way that some or all of their content constitutes requirements of this document. For dated references, only the edition cited applies. For undated references, the latest edition of the referenced document (including any amendments) applies.

IEC 60050-441, *International Electrotechnical Vocabulary (IEV) – Part 441: Switchgear, controlgear and fuses*

IEC 60059, *IEC standard current ratings*

IEC 60099-9:2014, *Surge arresters – Part 9: Metal-oxide surge arresters without gaps for HVDC converter stations*

IEC 60700-1, *Thyristor valves for high voltage direct current (HVDC) power transmission – Part 1: Electrical testing*

IEC 60825-1, *Safety of laser products – Part 1: Equipment classification and requirements*

IEC 60825-2, *Safety of laser products –Part 2: Safety of optical fibre communication systems (OFCs)*

IEC 61071:2017, *Capacitors for power electronics*

IEC 61850-10, *Communication networks and systems for power utility automation – Part 10: Conformance testing*

IEC TS 62271-5:2024, *High-voltage switchgear and controlgear – Part 5: Common specifications for direct current switchgear*

IEC 62271-100:2021, *High-voltage switchgear and controlgear – Part 100: Alternating-current circuit-breakers*

IEC TR 62271-300, *High-voltage switchgear and controlgear – Part 300: Seismic qualification of alternating current circuit-breakers*

IEC 62501, *Voltage sourced converter (VSC) valves for high-voltage direct current (HVDC) power transmission – Electrical testing*

IEC 62751-1, *Power losses in voltage sourced converter (VSC) valves for high-voltage direct current (HVDC) systems – Part 1: General requirements*

IEC 62751-2, *Power losses in voltage sourced converter (VSC) valves for high-voltage direct current (HVDC) systems – Part 2: Modular multilevel converters*

IEC TR 63259:2022, *Water cooling systems for power electronics used in electrical transmission and distribution systems*