

Institute of Environmental Sciences and Technology

IEST-RP-CC034.3

Contamination Control Division
Recommended Practice 034.3

HEPA and ULPA Filter Leak Tests



Arlington Place One
2340 S. Arlington Heights Road, Suite 100
Arlington Heights, IL 60005-4516
Phone: (847) 981-0100 • Fax: (847) 981-4130
E-mail: iest@iest.org • Web: www.iest.org

This Recommended Practice is published by the Institute of Environmental Sciences and Technology (IEST) to advance the technical and engineering sciences. Use of this document is entirely voluntary, and determination of its applicability and suitability for any particular use is solely the responsibility of the user. Use of this Recommended Practice does not imply any warranty or endorsement by IEST.

This Recommended Practice was prepared by and is under the jurisdiction of Working Group 034 of the IEST Contamination Control Division.

Copyright © 2009 by the Institute of Environmental Sciences and Technology

First printing, October 2009

ISBN 978-0-9841330-0-0

PROPOSAL FOR IMPROVEMENT: The Working Groups of the Institute of Environmental Sciences and Technology are continually working on improvements to their Recommended Practices and Reference Documents. Suggestions from users of these documents are welcome. If you have a suggestion regarding this document, please use the online Proposal for Improvement form found on the IEST website at www.iest.org.

Institute of Environmental Sciences and Technology
Arlington Place One
2340 S. Arlington Heights Road, Suite 100
Arlington Heights, IL 60005-4516
Phone: (847) 981-0100 • Fax: (847) 981-4130
E-mail: iest@iest.org • Web: www.iest.org

HEPA and ULPA Filter Leak Tests

IEST-RP-CC034.3

CONTENTS

SECTION

1	SCOPE AND LIMITATIONS	4
2	REFERENCES	4
3	TERMS AND DEFINITIONS	5
4	BACKGROUND AND PURPOSE.....	7
5	CHOICE OF TESTS	8
6	RECOMMENDED TEST PROCEDURES	8

FIGURE

1	EXAMPLE OF A SAMPLING PROBE	15
E1	EXAMPLE OF A SAMPLING PROBE.....	28
E2	EFFECT OF THE NUMBER OF PARTICLES USED TO CHARACTERIZE A DESIGNATED LEAK....	30
I1	EFFECT OF MEDIA VARIABILITY ON LEAK DETECTION.....	36

TABLE

1	GUIDE FOR SELECTING APPROPRIATE LEAK-TESTING STRATEGIES.....	9
2	DESIGNATED-LEAK SIZES FOR VARIOUS EFFICIENCIES OF FILTERS.....	13
E1	PROBABILITIES OF MISSING LEAKS AND FALSE INDICATIONS.....	30

APPENDIX

A	CONSIDERATIONS IN LEAK-TESTING.....	21
B	CALCULATION OF AEROSOL CHALLENGE	24
C	EXAMPLE CALCULATION OF SPATIAL AND TEMPORAL CHALLENGE UNIFORMITY.....	25
D	EXAMPLE CONDITIONS FOR FILTER LEAK SCAN TEST: AEROSOL PHOTOMETER METHOD....	27
E	METHODS OF CALCULATION AND EXAMPLE CONDITIONS FOR FILTER LEAK SCAN TEST: DISCRETE-PARTICLE-COUNTER TEST METHOD.....	28
F	DILUTION OF AEROSOL FOR PARTICLE COUNTERS.....	31
G	EXAMPLE CONDITIONS FOR FILTER LEAK SCAN TEST: DISCRETE-PARTICLE-COUNTER METHOD.....	32
H	MEASURING THE RESPONSE TIME OF PHOTOMETERS.....	34
I	EXCESSIVE WIDESPREAD NON-SITE-SPECIFIC PENETRATION IN LEAK-TESTING	36
J	AEROSOL PHOTOMETER IN-SITU (FIELD) FILTER SCAN TEST METHOD.....	37
K	BIBLIOGRAPHY	39

Institute of Environmental Sciences and Technology
Contamination Control Division
Recommended Practice 034.3

HEPA and ULPA Filter Leak Tests

IEST-RP-CC034.3

1 SCOPE AND LIMITATIONS

1.1 Scope

This Recommended Practice (RP) covers definitions, equipment, and procedures for leak-testing high-efficiency particulate air (HEPA) filters and ultralow-penetration air (ULPA) filters in the factory as they are produced, at the job site before they are installed, and after they are installed in cleanrooms and in unidirectional-flow, clean-air devices. When used in conjunction with other RPs, including IEST-RP-CC001, IEST-RP-CC002, IEST-RP-CC006, IEST-RP-CC007, IEST-RP-CC021, and IEST-RP-CC028, this RP may be used to define the basis of an agreement between customer and supplier in the specification and procurement of HEPA and ULPA filters, and in the testing of unidirectional-flow, clean-air devices and cleanrooms.

This RP also includes procedures for measuring the uniformity of the aerosol challenge approaching the filter under test.

1.2 Limitations

This document does not cover in-place testing of banks of filters in nuclear power or nuclear research applications, nor does it cover biological safety or containment cabinets except for scanning of the filters for leaks. This document does not cover leak-testing of filters in high-temperature environments. This document provides values of acceptance limits for guidance; however, it is the responsibility of the customer and supplier to specify which leak-test method is used and the acceptance criteria for each application. A brief guideline on *in situ* leak-testing based on the procedures recommended in this RP is provided in Appendix J.

CAUTION: Testing in accordance with this RP may involve hazardous materials, operations, and equipment. This RP does not purport to address all of the

safety problems associated with its use. It is the responsibility of the user to establish appropriate safety and health practices and to determine the applicability of regulatory limitations prior to use of this RP.

2 REFERENCES

The following documents are incorporated into this Recommended Practice to the extent specified herein. If no specific edition is cited, the most recent edition should be used. Where specific editions are cited, subsequent revisions of these publications do not automatically supersede the cited editions and users should investigate the applicability of revised editions.

2.1 Reference documents

IEST-RP-CC001: HEPA and ULPA Filters

IEST-RP-CC002: Unidirectional-Flow, Clean-Air Devices

IEST-RP-CC006: Testing Cleanrooms

IEST-RP-CC007: Testing ULPA Filters

IEST-RP-CC013: Calibration Procedures and Guidelines for Select Equipment Used in Testing Cleanrooms and Other Controlled Environments.

IEST-RP-CC021: Testing HEPA and ULPA Filter Media

IEST-RP-CC028: Minienvironments

ISO 14644-1:1999 Cleanrooms and associated controlled environments—Part 1: Classification of air cleanliness

MIL-STD-282: Filter Units, Protective Clothing, Gas-Mask Components, and Related Products: Performance Test Methods

NSF/ANSI 49: Biosafety Cabinetry: Design, Construction, Performance, and Field Certification