

**AMERICAN NATIONAL STANDARD**

**ANSI/ISA-12.12.01-2010**

**Nonincendive Electrical Equipment for  
Use in Class I and II, Division 2 and  
Class III, Divisions 1 and 2 Hazardous  
(Classified) Locations**

**Approved 28 January 2011**

ANSI/ISA-12.12.01-2010

Nonincendive Electrical Equipment for Use in Class I and II, Division 2 and Class III, Divisions 1 and 2 Hazardous (Classified) Locations

ISBN: 978-1-936007-78-3

Copyright © 2010 by ISA. All rights reserved. Not for resale. Printed in the United States of America. No part of this publication may be reproduced, stored in a retrieval system, or transmitted, in any form or by any means (electronic, mechanical, photocopying, recording, or otherwise), without the prior written permission of the Publisher.

ISA  
67 Alexander Drive  
P. O. Box 12277  
Research Triangle Park, North Carolina 27709

## Preface

This preface, as well as all footnotes and annexes, is included for information purposes and is not part of ANSI/ISA-12.12.01-2010.

This Standard has been prepared as part of the service of ISA toward a goal of uniformity in the field of instrumentation. To be of real value, this document should not be static but should be subject to periodic review. Toward this end, the Society welcomes all comments and criticisms and asks that they be addressed to the Secretary, Standards and Practices Board; ISA; 67 Alexander Drive; P. O. Box 12277; Research Triangle Park, NC 27709; Telephone (919) 549-8411; Fax (919) 549-8288; E-mail: standards@isa.org.

The ISA Standards and Practices Department is aware of the growing need for attention to the metric system of units in general, and the International System of Units (SI) in particular, in the preparation of instrumentation standards. The Department is further aware of the benefits to USA users of ISA standards of incorporating suitable references to the SI (and the metric system) in their business and professional dealings with other countries. Toward this end, this Department will endeavor to introduce SI-acceptable metric units in all new and revised standards, recommended practices, and technical reports to the greatest extent possible. *Standard for Use of the International System of Units (SI): The Modern Metric System*, published by the American Society for Testing & Materials as IEEE/ASTM SI 10-97, and future revisions, will be the reference guide for definitions, symbols, abbreviations, and conversion factors.

It is the policy of ISA to encourage and welcome the participation of all concerned individuals and interests in the development of ISA standards, recommended practices, and technical reports. Participation in the ISA standards-making process by an individual in no way constitutes endorsement by the employer of that individual, of ISA, or of any of the standards, recommended practices, and technical reports that ISA develops.

**CAUTION — ISA DOES NOT TAKE ANY POSITION WITH RESPECT TO THE EXISTENCE OR VALIDITY OF ANY PATENT RIGHTS ASSERTED IN CONNECTION WITH THIS DOCUMENT, AND ISA DISCLAIMS LIABILITY FOR THE INFRINGEMENT OF ANY PATENT RESULTING FROM THE USE OF THIS DOCUMENT. USERS ARE ADVISED THAT DETERMINATION OF THE VALIDITY OF ANY PATENT RIGHTS, AND THE RISK OF INFRINGEMENT OF SUCH RIGHTS, IS ENTIRELY THEIR OWN RESPONSIBILITY.**

**PURSUANT TO ISA'S PATENT POLICY, ONE OR MORE PATENT HOLDERS OR PATENT APPLICANTS MAY HAVE DISCLOSED PATENTS THAT COULD BE INFRINGED BY USE OF THIS DOCUMENT AND EXECUTED A LETTER OF ASSURANCE COMMITTING TO THE GRANTING OF A LICENSE ON A WORLDWIDE, NON-DISCRIMINATORY BASIS, WITH A FAIR AND REASONABLE ROYALTY RATE AND FAIR AND REASONABLE TERMS AND CONDITIONS. FOR MORE INFORMATION ON SUCH DISCLOSURES AND LETTERS OF ASSURANCE, CONTACT ISA OR VISIT WWW.ISA.ORG/STANDARDSPATENTS.**

**OTHER PATENTS OR PATENT CLAIMS MAY EXIST FOR WHICH A DISCLOSURE OR LETTER OF ASSURANCE HAS NOT BEEN RECEIVED. ISA IS NOT RESPONSIBLE FOR IDENTIFYING PATENTS OR PATENT APPLICATIONS FOR WHICH A LICENSE MAY BE REQUIRED, FOR CONDUCTING INQUIRIES INTO THE LEGAL VALIDITY OR SCOPE OF PATENTS, OR DETERMINING WHETHER ANY LICENSING TERMS OR CONDITIONS PROVIDED IN CONNECTION WITH SUBMISSION OF A LETTER OF ASSURANCE, IF ANY, OR IN ANY LICENSING AGREEMENTS ARE REASONABLE OR NON-DISCRIMINATORY.**

**ISA REQUESTS THAT ANYONE REVIEWING THIS DOCUMENT WHO IS AWARE OF ANY PATENTS THAT MAY IMPACT IMPLEMENTATION OF THE DOCUMENT NOTIFY THE ISA STANDARDS AND PRACTICES DEPARTMENT OF THE PATENT AND ITS OWNER.**

**ADDITIONALLY, THE USE OF THIS DOCUMENT MAY INVOLVE HAZARDOUS MATERIALS, OPERATIONS OR EQUIPMENT. THE DOCUMENT CANNOT ANTICIPATE ALL POSSIBLE APPLICATIONS OR ADDRESS ALL POSSIBLE SAFETY ISSUES ASSOCIATED WITH USE IN HAZARDOUS CONDITIONS. THE USER OF THIS DOCUMENT MUST EXERCISE SOUND PROFESSIONAL JUDGMENT CONCERNING ITS USE AND APPLICABILITY UNDER THE USER'S PARTICULAR CIRCUMSTANCES. THE USER MUST ALSO CONSIDER THE APPLICABILITY OF ANY GOVERNMENTAL REGULATORY LIMITATIONS AND ESTABLISHED SAFETY AND HEALTH PRACTICES BEFORE IMPLEMENTING THIS DOCUMENT.**

**THE USER OF THIS DOCUMENT SHOULD BE AWARE THAT THIS DOCUMENT MAY BE IMPACTED BY ELECTRONIC SECURITY ISSUES. THE COMMITTEE HAS NOT YET ADDRESSED THE POTENTIAL ISSUES IN THIS VERSION.**

The following people served as members of ISA Subcommittee ISA12.12:

<b>NAME</b>	<b>COMPANY</b>
R. Masek, Chair	CSA International
M. Coppler, Managing Director	Ametek Inc.
N. Abbatiello	Speer Equipment Inc.
R. Allen	Honeywell Inc.
S. Arnold	Ametek Drexelbrook
A. Ballard	Consultant
W. Bennett	Mine Safety Appliances Co.
W. Berner	R Stahl Inc.
D. Bishop	David N. Bishop Consultant
S. Blais	EGS Electrical Group
K. Boegli	Phoenix Contact
J. Bossert	Consultant
E. Briesch	Underwriters Laboratories Inc.
S. Czaniecki	Intrinsic Safety Concepts Inc.
J. Dolphin	PSC Solutions
A. Engler	Det Norske Veritas DNV
G. Garcha	GE Energy
P. Hamer	Chevron Energy Tech. Co.
D. Hohenstein	Pepperl+Fuchs Inc.
G. Kozinski	GE Infrastructure Sensing
J. Kuczka	Killark
C. Kurtzman	Rosemount Inc.
B. Larson	Turck Inc.
W. Lawrence	FM Approvals LLC
E. Legenski	WorleyParsons
E. Leubner	Cooper Crouse-Hinds
N. Ludlam	FM Approvals Ltd.
K. Mansoor	Siemens Industry Inc.
E. Massey	Baldor Electric Company
J. McCormick	Bently Nevada LLC
J. Miller	Detector Electronics Corporation
J. Neagle	Intertek ETL SEMKO
C. Oudar	ExLoc Corporation
D. Wechsler	Dow Chemical Company
R. Wigg	E-x Solutions International Pty. Ltd.

The following people served as members of ISA Committee ISA12:

<b>NAME</b>	<b>COMPANY</b>
T. Schnaare, Chair	Rosemount Inc.
W. Lawrence, Vice Chair	FM Approvals LLC
M. Coppler, Managing Director	Ametek Inc.
N. Akhtar	Pakistan Refinery Ltd.
D. Ankele	Underwriters Laboratories Inc.
A. Ballard	Consultant
R. Batra	Chevron Corporation
K. Boegli	Phoenix Contact
D. Burns	Shell P&T – Innovation / R&D
C. Casso	Nabors Industries
S. Czaniecki	Intrinsic Safety Concepts Inc.
J. Dolphin	PSC Solutions
M. Dona	Santos Ltd.
T. Dubaniewicz	NIOSH
A. Engler	Det Norske Veritas DNV
W. Fiske	Intertek
G. Garcha	GE Energy
C. Huntley	MSHA A&CC
D. Jagger	Bifold-Fluid Power
F. Kent	Honeywell Inc.
P. Kovscek	Industrial Scientific Corporation
J. Kuczka	Killark
E. Leubner	Cooper Crouse-Hinds
S. Leverington	Zone Safe Solutions
N. Ludlam	FM Approvals Ltd.
K. Mansoor	Siemens Industry Inc.
R. Masek	CSA International
E. Massey	Baldor Electric Company
J. Miller	Detector Electronics Corporation
A. Page	Consultant
R. Seitz	Artech Engineering
R. Sierra	USCG
M. Spencer	Columbia Gas Transmission
J. Thomas	Schlumberger
D. Wechsler	Dow Chemical Company
R. Wigg	E-x Solutions International Pty. Ltd.

This standard was approved for publication by the ISA Standards and Practices Board on 16 November 2010.

**NAME**

**COMPANY**

J. Tatera	Tatera & Associates Inc.
P. Brett	Honeywell Inc.
M. Coppler	Ametek Inc.
E. Cosman	The Dow Chemical Company
B. Dumortier	Schneider Electric
D. Dunn	Aramco Services Co.
R. Dunn	DuPont Engineering
J. Gilsinn	NIST/MEL
E. Icyan	ACES Inc.
J. Jamison	EnCana Corporation Ltd.
D. Kaufman	Honeywell International Inc.
K. P. Lindner	Endress + Hauser Process Solutions AG
V. Maggioli	Feltronics Corp.
T. McAviney	Jacobs Engineering
A. McCauley	Chagrin Valley Controls Inc.
R. Reimer	Rockwell Automation
N. Sands	DuPont
H. Sasajima	Yamatake Corp.
T. Schnaare	Rosemount Inc.
I. Verhappen	Industrial Automation Networks Inc.
R. Webb	ICS Secure LLC
W. Weidman	Consultant
J. Weiss	Applied Control Solutions LLC
M. Widmeyer	Kahler EngineeringInc.
M. Wilkins	Yokogawa IA Global Marketing (USMK)
M. Zielinski	Emerson Process Management

## Contents

1	Purpose .....	9
2	Scope .....	9
3	Definitions .....	10
4	General requirements.....	14
5	Requirements for Class I, Division 2 equipment .....	14
6	Requirements for Class II, Division 2, Class III, Divisions 1 and 2 equipment .....	14
7	Nonincendive circuits and nonincendive field wiring.....	15
8	Normally nonarcing components.....	25
9	Marking.....	25
10	Surface temperature requirements .....	28
11	Evaluation of nonincendive circuits.....	30
12	Evaluation of nonincendive components .....	33
13	Evaluation of sealed device.....	34
14	Evaluation of enclosures for Class II and III.....	35
15	Drop tests and impact tests .....	37
16	Manufacturer's instructional manual .....	38
	Annex A — Normative references .....	41
	Annex B — Common standards – safety requirements for electrical equipment (informative) .....	43

This page intentionally left blank.



## 1 Purpose

The purpose of this standard is to provide minimum requirements for the design, construction, and marking of electrical equipment or parts of such equipment for use in Class I and Class II, Division 2 and Class III, Divisions 1 and 2 hazardous (classified) locations. This equipment, in normal operation, is not capable of causing ignition of the surrounding atmosphere under the conditions prescribed in this standard, although the equipment may contain electronic components that operate at incandive levels and may also have field wiring that is incandive. In addition, it is the intent of this document to establish uniformity in test methods for determining the suitability of the equipment and associated circuits and components as they relate to potential ignition of a specific flammable gas or vapour-in-air mixture, combustible dust, easily ignitable fibers, or flyings.

## 2 Scope

**2.1** This standard applies only to equipment, circuits, and components designed specifically for use in Class I and II, Division 2 and Class III, Divisions 1 and 2 hazardous (classified) locations as defined in the National Electrical Code<sup>®</sup> (NEC<sup>®</sup>) ANSI/NFPA 70.

NOTE Some equipment designed for use in unclassified locations is permitted by the NEC<sup>®</sup> for installing in Division 2 locations. The judgment of acceptability for the installation would be determined by the authority having jurisdiction. Such equipment would not have the hazardous location marking or documentation described in this standard. It is anticipated that such equipment would comply with the other requirements in this standard and that the determination of compliance is elementary (e.g., a nonarcing instrument inside a NEMA Type 4 or 12 enclosure used in a Class II, Division 2 location).

**2.2** This standard also applies to certain unclassified location equipment specifically designed to directly connect to nonincandive field wiring in Class I and II, Division 2 and Class III, Divisions 1 and 2 hazardous (classified) locations as defined in the NEC<sup>®</sup>.

**2.3** This standard is primarily intended to provide requirements for electrical and electronic test, measuring, and controlling equipment.

**2.4** This standard is concerned only with equipment construction and test criteria related to electrical or thermal ignition of specified flammable gases, vapors, combustible dusts, fibers, and flyings in air.

**2.5** This standard is not intended to cover equipment for use in Class I and Class II, Division 1 locations, such as equipment constructed to be intrinsically safe, dust ignition-proof, or explosion-proof. Such equipment is, however, suitable for use in Class I and Class II, Division 2 locations in the same group and temperature class for which it is suitable in Division 1.

**2.6** This standard does not cover mechanisms of ignition from external sources, such as static electricity or lightning, that are not related to the electrical characteristics of the equipment.

**2.7** This standard is not intended as an instructional manual for untrained persons. It is intended to promote uniformity of practice among those skilled in the area of design, construction, and application of equipment suitable for Class I and Class II, Division 2 and Class III, Divisions 1 and 2 locations.

**2.8** The requirements of this standard are based on consideration of ignition in locations made hazardous by the presence of flammable gases, vapors, combustible dusts, fibers, and flyings under the following ambient conditions: