

AMERICAN NATIONAL STANDARD

ANSI/ISA-12.13.04-2007 (R2014)

**Performance Requirements for
Open Path Combustible Gas Detectors**

Approved 26 February 2014

Commitment for Amendments

This standard is issued jointly by ISA and FM Approvals (FM). Comments or proposals for revisions on any part of the standard may be submitted to ISA or FM at any time. Revisions to this standard will be made only after processing according to the standards development procedures of ISA and FM. ***ISA and FM will issue revisions to this standard by means of a new edition or revised or additional pages bearing their date of issue.***

ISBN 978-0-876640-68-5

Copyright © 2014

By ISA

These materials are subject to copyright claims of ANSI and ISA. All rights reserved. Not for resale. Printed in the United States of America. No part of this publication may be reproduced in any form, including an electronic retrieval system, without the prior written permission of ISA. All requests pertaining to this standard should be submitted to ISA.

© 2014 FM Approvals LLC. All rights reserved.

ISA
ANSI/ISA-12.13.04
First Edition

FM Approvals
ANSI/FM 6325
First Edition



Member of the FM Global Group

Performance Requirements for Open Path Combustible Gas Detectors

This is a preview of "ANSI/ISA 12.13.04-20...". [Click here to purchase the full version from the ANSI store.](#)

This page intentionally left blank.

General Notes

This is the common ISA and FM standard for *Performance Requirements for Open Path Combustible Gas Detectors*. It is the first edition of ANSI/ISA-12.13.04 and the first edition of ANSI/FM 6325.

ANSI/ISA-12.13.04 and ANSI/FM 6325 contain identical requirements and identical publication dates. The presentation and format of the standards material may differ between the two published standards.

This common standard was prepared by ISA and FM Approvals.

Effective Date

The effective date for ISA and FM Approvals is the date of publication.

This is a preview of "ANSI/ISA 12.13.04-20...". [Click here to purchase the full version from the ANSI store.](#)

This page intentionally left blank.

Preface (ISA)

This preface, as well as all footnotes and annexes, is included for information purposes and is not part of ANSI/ISA-12.13.04.

This document has been prepared as part of the service of ISA towards a goal of uniformity in the field of instrumentation. To be of real value, this document should not be static but should be subject to periodic review. Toward this end, the Society welcomes all comments and criticisms and asks that they be addressed to the Secretary, Standards and Practices Board; ISA; 67 Alexander Drive; P. O. Box 12277; Research Triangle Park, NC 27709; Telephone (919) 549-8411; Fax (919) 549-8288; E-mail: standards@isa.org.

The ISA Standards and Practices Department is aware of the growing need for attention to the metric system of units in general, and the International System of Units (SI) in particular, in the preparation of instrumentation standards. The Department is further aware of the benefits to USA users of ISA standards of incorporating suitable references to the SI (and the metric system) in their business and professional dealings with other countries. Toward this end, this Department will endeavor to introduce SI-acceptable metric units in all new and revised standards, recommended practices, and technical reports to the greatest extent possible. *Standard for Use of the International System of Units (SI): The Modern Metric System*, published by the American Society for Testing & Materials as IEEE/ASTM SI 10-97, and future revisions, will be the reference guide for definitions, symbols, abbreviations, and conversion factors.

It is the policy of ISA to encourage and welcome the participation of all concerned individuals and interests in the development of ISA standards, recommended practices, and technical reports. Participation in the ISA standards-making process by an individual in no way constitutes endorsement by the employer of that individual, of ISA, or of any of the standards, recommended practices, and technical reports that ISA develops.

CAUTION — ISA DOES NOT TAKE ANY POSITION WITH RESPECT TO THE EXISTENCE OR VALIDITY OF ANY PATENT RIGHTS ASSERTED IN CONNECTION WITH THIS DOCUMENT, AND ISA DISCLAIMS LIABILITY FOR THE INFRINGEMENT OF ANY PATENT RESULTING FROM THE USE OF THIS DOCUMENT. USERS ARE ADVISED THAT DETERMINATION OF THE VALIDITY OF ANY PATENT RIGHTS, AND THE RISK OF INFRINGEMENT OF SUCH RIGHTS, IS ENTIRELY THEIR OWN RESPONSIBILITY.

PURSUANT TO ISA'S PATENT POLICY, ONE OR MORE PATENT HOLDERS OR PATENT APPLICANTS MAY HAVE DISCLOSED PATENTS THAT COULD BE INFRINGED BY USE OF THIS DOCUMENT AND EXECUTED A LETTER OF ASSURANCE COMMITTING TO THE GRANTING OF A LICENSE ON A WORLDWIDE, NON-DISCRIMINATORY BASIS, WITH A FAIR AND REASONABLE ROYALTY RATE AND FAIR AND REASONABLE TERMS AND CONDITIONS. FOR MORE INFORMATION ON SUCH DISCLOSURES AND LETTERS OF ASSURANCE, CONTACT ISA OR VISIT WWW.ISA.ORG/STANDARDSPATENTS.

OTHER PATENTS OR PATENT CLAIMS MAY EXIST FOR WHICH A DISCLOSURE OR LETTER OF ASSURANCE HAS NOT BEEN RECEIVED. ISA IS NOT RESPONSIBLE FOR IDENTIFYING PATENTS OR PATENT APPLICATIONS FOR WHICH A LICENSE MAY BE REQUIRED, FOR CONDUCTING INQUIRIES INTO THE LEGAL VALIDITY OR SCOPE OF PATENTS, OR DETERMINING WHETHER ANY LICENSING TERMS OR CONDITIONS PROVIDED IN CONNECTION WITH SUBMISSION OF A LETTER OF ASSURANCE, IF ANY, OR IN ANY LICENSING AGREEMENTS ARE REASONABLE OR NON-DISCRIMINATORY.

ISA REQUESTS THAT ANYONE REVIEWING THIS DOCUMENT WHO IS AWARE OF ANY PATENTS THAT MAY IMPACT IMPLEMENTATION OF THE DOCUMENT NOTIFY THE ISA STANDARDS AND PRACTICES DEPARTMENT OF THE PATENT AND ITS OWNER.

ADDITIONALLY, THE USE OF THIS DOCUMENT MAY INVOLVE HAZARDOUS MATERIALS, OPERATIONS OR EQUIPMENT. THE DOCUMENT CANNOT ANTICIPATE ALL POSSIBLE APPLICATIONS OR ADDRESS ALL POSSIBLE SAFETY ISSUES ASSOCIATED WITH USE IN HAZARDOUS CONDITIONS. THE USER OF THIS DOCUMENT MUST EXERCISE SOUND PROFESSIONAL JUDGMENT CONCERNING ITS USE AND APPLICABILITY UNDER THE USER'S PARTICULAR CIRCUMSTANCES. THE USER MUST ALSO CONSIDER THE APPLICABILITY OF ANY GOVERNMENTAL REGULATORY LIMITATIONS AND ESTABLISHED SAFETY AND HEALTH PRACTICES BEFORE IMPLEMENTING THIS DOCUMENT.

THE USER OF THIS DOCUMENT SHOULD BE AWARE THAT THIS DOCUMENT MAY BE IMPACTED BY ELECTRONIC SECURITY ISSUES. THE COMMITTEE HAS NOT YET ADDRESSED THE POTENTIAL ISSUES IN THIS VERSION.

The following people served as members of ISA Subcommittee ISA12.13:

NAME	COMPANY
J. Miller, Chair	Detector Electronics Corporation
R. Seitz, Co-Chair	Artech Engineering
M. Coppler, Managing Director	Det Norske Veritas Certification Inc.
S. Baliga	General Monitors
W. Bennett	Mine Safety Appliances Co.
S. Bihler	Zone Safe Solutions Inc.
S. Bruce	Delphian Corp.
T. Crawford	Intertek Testing Services
D. El Tawy	Solar Turbines, Inc.
G. Garcha	GE Power & Water
I. Gilstrap	GE Oil & Gas
K. Hedrick	MSHA Approval and Certification Center
S. Henney	FM Approvals
C. Lucarino	Senscient
R. Masek	CSA Group
D. Mills	UL LLC
L. Owen	Dooley Tackaberry Inc.
M. Phadke	Lanxess India Private Ltd.
R. Poling	Armstrong World Industries
P. Sallaway	Consultant
M. Schaeffer	Control Instruments Corporation
A. Skinner	GMI Gas Measurement Instruments LLC
M. Spencer	Columbia Gas Transmission
J. Stratman	Honeywell Analytics Inc.
A. Vial	Shell Exploration & Production Co.
D. Wechsler	American Chemistry Council

The following people served as members of ISA Committee ISA12:

NAME	COMPANY
T. Schnaare, Chair	Rosemount Inc.
W. Lawrence, Vice Chair	FM Approvals LLC
M. Coppler, Managing Director	Det Norske Veritas Certification Inc.
R. Allen	Honeywell Inc.
D. Ankele	UL LLC
K. Boegli	Phoenix Contact
D. Burns	Shell P&T – Innovation / R&D
C. Casso	Nabors Industries
M. Dona	Santos Ltd.
T. Dubaniewicz	NIOSH
D. El Tawy	Solar Turbines Inc.
W. Fiske	Intertek
G. Garcha	GE Power & Water
R. Holub	The DuPont Company Inc.
P. Kovscek	Industrial Scientific Corp.
J. Kuczka	Killark
E. Leubner	Eaton's Crouse-Hinds Business
N. Ludlam	FM Approvals Ltd.
E. Massey	Baldor Electric Co.
J. Miller	Detector Electronics Corp.
A. Page	Consultant
R. Seitz	Artech Engineering
R. Sierra	USCG
M. Spencer	Columbia Gas Transmission
R. Wigg	E-x Solutions International Pty. Ltd.

This standard was approved for publication by the ISA Standards and Practices Board on 17 February 2014.

NAME	COMPANY
E. Cosman, Vice President	The Dow Chemical Co.
D. Bartusiak	ExxonMobil Research & Engineering
P. Brett	Honeywell Inc.
J. Campbell	Consultant
M. Coppler	Det Norske Veritas Certification Inc.
B. Dumortier	Schneider Electric
D. Dunn	Aramco Services Co.
J. Federlein	Federlein & Assoc. Inc.
J. Gilsinn	Kenexis Consulting
E. Icayan	Atkins
J. Jamison	Spectra Energy Ltd.
K. Lindner	Endress+Hauser Process Solutions AG
V. Maggioli	Feltronics Corp.
T. McAviney	Instrumentation and Control Engineering LLC
V. Mezzano	Fluor Corp.
C. Monchinski	Automated Control Concepts Inc.
R. Reimer	Rockwell Automation
S. Russell	Valero Energy Corp.
N. Sands	DuPont
H. Sasajima	Azbil Corp.
T. Schnaare	Rosemount Inc.

J. Tatera
I. Verhappen
W. Weidman
J. Weiss
M. Wilkins
D. Zetterberg

Tatera & Associates Inc.
Industrial Automation Networks Inc.
WCW Consulting
Applied Control Solutions LLC
Yokogawa IA Global Marketing (USMK)
Chevron Energy Technology Company

Contents

1	Scope	13
2	Definitions	13
3	General requirements	17
3.1	Introduction	17
3.2	Markings	17
3.3	Manufacturer's installation and operation manual	18
3.4	Construction and functions	20
3.5	Test equipment calibration	22
4	Performance requirements	22
4.1	General	22
4.2	Samples and sequence	23
4.3	Preparation of apparatus	23
4.4	Conditions for test and test area	23
4.5	Un-powered preconditioning storage	27
4.6	Vibration	27
4.7	Calibration	28
4.8	Accuracy	28
4.9	Trouble signals	28
4.10	Temperature	28
4.11	Time of response	30
4.12	Solar radiation	30
4.13	Power supply variations	31
4.14	Power supply interruptions and transients	31
4.15	Recovery from power supply interruption	32
4.16	Electromagnetic interference (EMI)	32
4.17	Partial obscuration	32

4.18	Simulated fog/mist	32
4.19	Water vapor interference	33
4.20	Beam blockage fault	33
4.21	Long range operation.....	34
4.22	Environmental ratings	34
4.23	Long term stability.....	34
Annex A	— Open path monitor measurement.....	35
Annex B	— Fog machine for open path gas detection testing (informative)	37
Annex C	— Water vapor test fixture for open path gas detection test (informative).....	39

1 Scope

1.1 This standard provides minimum requirements for fixed and transportable open path gas detection apparatus.

1.2 This standard specifies the construction, performance and testing of open path (line-of-sight) gas monitors that sense the presence of combustible gas or vapor concentrations in air.

1.3 For apparatus used for sensing the presence of multiple gases, this document applies only to the portion sensing the flammable gas or vapor. Sensing of toxic gases is outside the scope of this document.

1.4 This standard addresses combustible gas monitors intended to provide a broad indication or alarm, the purpose of which is to give warning of possible presence of a potential flammable concentration of gas or vapor.

1.5 Conformance to this standard does not imply suitability for gas monitoring or monitoring apparatus of the laboratory or scientific type used for analysis or measurement, apparatus used for process control and process monitoring purposes, or apparatus used for residential purposes.

1.6 This standard specifies the requirements for gas detection apparatus that are intended to monitor gases or vapors in ambient air by measuring the spectral absorption by the gases or vapors over an extended optical path. The units of measurement and range of the gas detection apparatus are a mathematical integral of the gas concentration along the optical path. The units of measurement are expressed as full concentration of the lower flammable limit (100%LFL or 1LFL) multiplied by the distance, in meters, at that concentration (e.g. LFL·meter, %LFL(Avg)).

1.7 This standard only specifies the requirements for instrument applications where calibration is performed using either the gas to be monitored or another gas for which response conversion data appears in the instruction manual.

2 Definitions

For purposes of this standard, the following terms apply:

2.1 alarm:

an audible, visual or physical presentation designed to alert the apparatus user that a specific measurement level has been reached or exceeded.

2.1.1 alarm set point:

a fixed or adjustable setting of the system that is intended to pre-set the value of integral concentration at which the apparatus will automatically initiate an indication, alarm, or other output function for the selected gas concentration level(s) at which an indication, alarm, or other output function is initiated.

2.1.2 alarm signal:

an audible, visual, electronic or other signal generated by the apparatus when an integral concentration of gas in excess of a preset value is detected.

2.1.3 latching alarm:

an alarm which, once activated, requires a deliberate action to deactivate it.

2.2 alarm only apparatus:

an apparatus having an alarm but not having a meter or other indicating device that would allow measurement of the deviations permitted by the requirements of this standard.