

**AMERICAN NATIONAL STANDARD**

**ANSI/ISA-75.01.01 (IEC 60534-2-1 Mod)-2007**

**Flow Equations for  
Sizing Control Valves**

**Approved 7 November 2007**

ANSI/ISA-75.01.01 (IEC 60534-2-1 Mod)-2007  
Flow Equations for Sizing Control Valves

ISBN: 978-1-934394-39-7

Copyright © 2007 by ISA. All rights reserved. Not for resale. Printed in the United States of America.  
No part of this publication may be reproduced, stored in a retrieval system, or transmitted, in any form or  
by any means (electronic, mechanical, photocopying, recording, or otherwise), without the prior written  
permission of the Publisher.

ISA  
67 Alexander Drive  
P. O. Box 12277  
Research Triangle Park, North Carolina 27709  
USA

## Preface

This preface, as well as all footnotes and annexes, is included for information purposes and is not part of ANSI/ISA-75.01.01 (IEC 60534-2-1 Mod)-2007.

The standards referenced within this document may contain provisions which, through reference in this text, constitute requirements of this document. At the time of publication, the editions indicated were valid. All standards are subject to revision, and parties to agreements based on this document are encouraged to investigate the possibility of applying the most recent editions of the standards indicated within this document. Members of IEC and ISO maintain registers of currently valid International Standards. ANSI maintains registers of currently valid U.S. National Standards.

This document has been prepared as part of the service of ISA toward a goal of uniformity in the field of instrumentation. To be of real value, this document should not be static but should be subject to periodic review. Toward this end, the Society welcomes all comments and criticisms and asks that they be addressed to the Secretary, Standards and Practices Board; ISA; 67 Alexander Drive; P. O. Box 12277; Research Triangle Park, NC 27709; Telephone (919) 549-8411; Fax (919) 549-8288; E-mail: standards@isa.org.

The ISA Standards and Practices Department is aware of the growing need for attention to the metric system of units in general, and the International System of Units (SI) in particular, in the preparation of instrumentation standards. The Department is further aware of the benefits to USA users of ISA standards of incorporating suitable references to the SI (and the metric system) in their business and professional dealings with other countries. Toward this end, this Department will endeavor to introduce SI-acceptable metric units in all new and revised standards, recommended practices, and technical reports to the greatest extent possible. *Standard for Use of the International System of Units (SI): The Modern Metric System*, published by the American Society for Testing & Materials as IEEE/ASTM SI 10-97, and future revisions, will be the reference guide for definitions, symbols, abbreviations, and conversion factors.

It is the policy of ISA to encourage and welcome the participation of all concerned individuals and interests in the development of ISA standards, recommended practices, and technical reports. Participation in the ISA standards-making process by an individual in no way constitutes endorsement by the employer of that individual, of ISA, or of any of the standards, recommended practices, and technical reports that ISA develops.

**CAUTION — ISA ADHERES TO THE POLICY OF THE AMERICAN NATIONAL STANDARDS INSTITUTE WITH REGARD TO PATENTS. IF ISA IS INFORMED OF AN EXISTING PATENT THAT IS REQUIRED FOR USE OF THE STANDARD, IT WILL REQUIRE THE OWNER OF THE PATENT TO EITHER GRANT A ROYALTY-FREE LICENSE FOR USE OF THE PATENT BY USERS COMPLYING WITH THE STANDARD OR A LICENSE ON REASONABLE TERMS AND CONDITIONS THAT ARE FREE FROM UNFAIR DISCRIMINATION.**

**EVEN IF ISA IS UNAWARE OF ANY PATENT COVERING THIS STANDARD, THE USER IS CAUTIONED THAT IMPLEMENTATION OF THE STANDARD MAY REQUIRE USE OF TECHNIQUES, PROCESSES, OR MATERIALS COVERED BY PATENT RIGHTS. ISA TAKES NO POSITION ON THE EXISTENCE OR VALIDITY OF ANY PATENT RIGHTS THAT MAY BE INVOLVED IN IMPLEMENTING THE STANDARD. ISA IS NOT RESPONSIBLE FOR IDENTIFYING ALL PATENTS THAT MAY REQUIRE A LICENSE BEFORE IMPLEMENTATION OF THE STANDARD OR FOR INVESTIGATING THE VALIDITY OR SCOPE OF ANY PATENTS BROUGHT TO ITS ATTENTION. THE USER SHOULD CAREFULLY INVESTIGATE RELEVANT PATENTS BEFORE USING THE STANDARD FOR THE USER'S INTENDED APPLICATION.**

**HOWEVER, ISA ASKS THAT ANYONE REVIEWING THIS STANDARD WHO IS AWARE OF ANY PATENTS THAT MAY IMPACT IMPLEMENTATION OF THE STANDARD NOTIFY THE ISA STANDARDS AND PRACTICES DEPARTMENT OF THE PATENT AND ITS OWNER.**

**ADDITIONALLY, THE USE OF THIS STANDARD MAY INVOLVE HAZARDOUS MATERIALS, OPERATIONS OR EQUIPMENT. THE STANDARD CANNOT ANTICIPATE ALL POSSIBLE APPLICATIONS OR ADDRESS ALL POSSIBLE SAFETY ISSUES ASSOCIATED WITH USE IN HAZARDOUS CONDITIONS. THE USER OF THIS STANDARD MUST EXERCISE SOUND PROFESSIONAL JUDGMENT CONCERNING ITS USE AND APPLICABILITY UNDER THE USER'S PARTICULAR CIRCUMSTANCES. THE USER MUST ALSO CONSIDER THE APPLICABILITY OF ANY GOVERNMENTAL REGULATORY LIMITATIONS AND ESTABLISHED SAFETY AND HEALTH PRACTICES BEFORE IMPLEMENTING THIS STANDARD.**

The following people served as members of ISA Subcommittee SP75.01:

<b>NAME</b>	<b>COMPANY</b>
J. George, Chair	Richards Industries
W. Weidman, Managing Director	Worley Parsons
H. Baumann	Consultant
H. Boger*	Masoneilan Dresser
G. Borden	Consultant
S. Boyle	Metso Automation USA Inc.
C. Crawford	Consultant
A. Glenn	Flowserve Corporation
M. Hanusa*	Fisher Controls International Inc.
H. Hoffmann	Samson AG
J. McCaskill	Power Chokes
A. McCauley	Chagrin Valley Controls Inc.
J. Reed	Consultant
J. Reid	Cashco Inc.
M. Riveland*	Fisher Controls International Inc.
K. Schoonover	Con-Tek Valves Inc.
E. Skovgaard	Control Valve Solutions
F. Volpe*	Masoneilan Dresser
J. Young	The Dow Chemical Company

\* One vote per company.

The following people served as members of ISA Committee SP75:

<b>NAME</b>	<b>COMPANY</b>
J. Young, Chair	The Dow Chemical Company
W. Weidman, Managing Director	Worley Parsons
H. Baumann	Consultant
J. Beall	Emerson Process Management
M. Bober	Copes-Vulcan
H. Boger	Masoneilan Dresser
G. Borden	Consultant
S. Boyle	Metso Automation USA Inc.
J. Broyles	Enbridge Pipelines Inc.
F. Cain	Flowserve Corporation
W. Cohen	KBR
R. Duimstra	Fisher Controls International Inc.
J. Faramarzi	Control Components Inc.
J. George	Richards Industries
H. Hoffmann	Samson AG
J. Jamison	Jamison & Associated Ltd.
C. Langford	Cullen G. Langford, Inc.
A. Libke	DeZurik Water Controls
G. Liu	Syncrude Canada Ltd.
H. Maxwell	Bechtel Power Corporation
G. McAdoo	McAdoo Flow Systems Ltd.
J. McCaskill	Power Chokes
A. McCauley	Chagrin Valley Controls, Inc.
R. McEver	Consultant
V. Mezzano	Fluor Corporation
H. Miller	Consultant
T. Molloy	CMES Inc.
L. Ormanoski	York Process Systems
J. Reed	Consultant
E. Skovgaard	Control Valve Solutions

This standard was approved for publication by the ISA Standards and Practices Board on 24 October 2007.

**NAME**

**COMPANY**

T. McAviney, Vice President	Jacobs Engineering Group
M. Coppler	Ametek Inc.
E. Cosman	The Dow Chemical Company
B. Dumortier	Schneider Electric
D. Dunn	Aramco Services Company
J. Gilsinn	NIST/MEL
W. Holland	Consultant
E. Icyan	ACES Inc.
J. Jamison	Jamison & Associated Ltd.
K. Lindner	Endress+Hauser Process Solutions AG
V. Maggioli	Feltronics Corporation
A. McCauley	Chagrin Valley Controls Inc.
G. McFarland	Emerson Process Mgmt Power & Water Solutions
R. Reimer	Rockwell Automation
N. Sands	E I du Pont
H. Sasajima	Yamatake Corporation
T. Schnaare	Rosemount Inc.
J. Tatera	Tatera & Associates Inc.
I. Verhappen	MTL Instrument Group
R. Webb	Robert C Webb PE
W. Weidman	Worley Parsons
J. Weiss	Applied Control Solutions LLC
M. Widmeyer	Consultant
M. Zielinski	Emerson Process Management

## Contents

1	Scope.....	11
2	Normative references .....	11
3	Definitions .....	11
4	Installation.....	12
5	Symbols .....	13
6	Sizing equations for incompressible fluids.....	14
6.1	Turbulent flow .....	14
6.2	Non-turbulent (laminar and transitional) flow .....	15
7	Sizing equations for compressible fluids .....	16
7.1	Turbulent flow .....	16
7.2	Non-turbulent (laminar and transitional) flow .....	18
8	Determination of correction factors.....	19
8.1	Piping geometry factor $F_P$ .....	19
8.2	Reynolds number factor $F_R$ .....	20
8.3	Liquid pressure recovery factors $F_L$ or $F_{LP}$ .....	21
8.4	Liquid critical pressure ratio factor $F_F$ .....	21
8.5	Expansion factor $Y$ .....	22
8.6	Pressure differential ratio factor $x_T$ or $x_{TP}$ .....	22
8.7	Specific heat ratio factor $F_\gamma$ .....	23
8.8	Compressibility factor $Z$ .....	23
	Annex A (informative) — Derivation of valve style modifier $F_d$ .....	35
	Annex B (informative) — Control valve sizing flow charts .....	41
	Annex C (informative) — Physical constants .....	45
	Annex D (informative) — Alternate non-turbulent flow calculation method .....	47
	Annex E (informative) — Examples of sizing calculations.....	51

Annex F (informative) — Equations for Reynolds number factor, $F_R$ .....	67
Annex G (informative) — Bibliography.....	69



## FOREWORD

1) The IEC (International Electrotechnical Commission) is a worldwide organization for standardization comprising all national electrotechnical committees (IEC National Committees). The object of the IEC is to promote international co-operation on all questions concerning standardization in the electrical and electronic fields. To this end and in addition to other activities, the IEC publishes International Standards. Their preparation is entrusted to technical committees; any IEC National Committee interested in the subject dealt with may participate in this preparatory work. International, governmental and non-governmental organizations liaising with the IEC also participate in this preparation. The IEC collaborates closely with the International Organization for Standardization (ISO) in accordance with conditions determined by agreement between the two organizations.

2) The formal decisions or agreements of the IEC on technical matters express, as nearly as possible, an international consensus of opinion on the relevant subjects since each technical committee has representation from all interested National Committees.

3) The documents produced have the form of recommendations for international use and are published in the form of standards, technical reports or guides and they are accepted by the National Committees in that sense.

4) In order to promote international unification, IEC National Committees undertake to apply IEC International Standards transparently to the maximum extent possible in their national and regional standards. Any divergence between the IEC Standard and the corresponding national or regional standard shall be clearly indicated in the latter.

5) The IEC provides no marking procedure to indicate its approval and cannot be rendered responsible for any equipment declared to be in conformity with one of its standards.

6) Attention is drawn to the possibility that some of the elements of this International Standard may be the subject of patent rights. The IEC shall not be held responsible for identifying any or all such patent rights.

International Standard IEC 60534-2-1 has been prepared by subcommittee 65B: Devices, of IEC technical committee 65: Industrial-process measurement and control.

The text of this standard is based on the following documents:

FDIS	Report on voting
65B/347/FDIS	65B/357/RVD

Full information on the voting for the approval of this standard can be found in the report on voting indicated in the above table.

The current edition of IEC 60534-2-1 cancels and replaces the first edition of both IEC 60534-2 published in 1978, and IEC 60534-2-2 published in 1980, which cover incompressible and compressible fluid flow, respectively.

IEC 60534-2-1 covers sizing equations for both incompressible and compressible fluid flow.

Annexes A, B, C, D, E, F, and G are for information only.

A bilingual version of this standard may be issued at a later date.

## 1 Scope

ANSI/ISA-75.01.01 (IEC 60534-2-1 Mod)-2007 includes equations for predicting the flow coefficient of compressible and incompressible fluids through control valves.

The equations for incompressible flow are based on standard hydrodynamic equations for Newtonian incompressible fluids. They are not intended for use when non-Newtonian fluids, fluid mixtures, slurries, or liquid-solid conveyance systems are encountered.

At very low ratios of pressure differential to absolute inlet pressure ( $\Delta P/P_1$ ), compressible fluids behave similarly to incompressible fluids. Under such conditions, the sizing equations for compressible flow can be traced to the standard hydrodynamic equations for Newtonian incompressible fluids. However, increasing values of  $\Delta P/P_1$  result in compressibility effects that require that the basic equations be modified by appropriate correction factors. The equations for compressible fluids are for use with gas or vapor and are not intended for use with multiphase streams such as gas-liquid, vapor-liquid or gas-solid mixtures.

For compressible fluid applications, this part of ISA-75.01.01-2007 is valid for all valves. However, manufacturers of some valves with  $x_T \geq 0.84$  have reported minor inaccuracies (see Annex G). Caution must also be exercised when applying the equations for compressible fluids to gaseous mixtures of compounds, particularly near phase boundaries.

The accuracy of results computed with the equations in this standard will be governed by the accuracy of the constituent coefficients and the process data supplied. Methods of evaluating the coefficients used in the equations presented herein are given in ANSI/ISA-75.02-1996. The stated accuracy associated with the coefficients in that document is  $\pm 5\%$  when  $C_v/d^2 < 0.047 N_{18}$ . Reasonable accuracy can only be maintained for control valves if  $C_v/d^2 < 0.047 N_{18}$ .

## 2 Normative references

The following normative documents contain provisions which, through reference in this text, constitute provisions of this part of ISA-75.01.01-2007. At the time of publication, the editions indicated were valid. All normative documents are subject to revision, and parties to agreements based on this part of ISA-75.01.01-2007 are encouraged to investigate the possibility of applying the most recent editions of the normative documents indicated below. Members of IEC and ISO maintain registers of currently valid International Standards.

IEC 60534-1:2005, *Industrial-process control valves – Part 1: Control valve terminology and general considerations*

IEC 60534-2-3:1997, *Industrial-process control valves – Part 2-3: Flow capacity – Test procedures*

ANSI/ISA-75.02-1996, Control Valve Capacity Test Procedures

ANSI/ISA-75.05.01-2000 (R2005), Control Valve Terminology

## 3 Definitions

For the purpose of ANSI/ISA-75.01.01 (IEC 60534-2-1 Mod)-2007, definitions given in IEC 60534-2-1 apply with the addition of the following: