

AMERICAN NATIONAL STANDARD
ANSI/ISA-75.05.01-2000 (R2005)

Control Valve Terminology

Reaffirmed 17 February 2005

ANSI/ISA-75.05.01-2000 (R2005)
Control Valve Terminology

ISBN: 978-1-55617-741-5

Copyright © 2005 by ISA — The Instrumentation, Systems, and Automation Society. All rights reserved.
Not for resale. Printed in the United States of America. No part of this publication may be reproduced,
stored in a retrieval system, or transmitted in any form or by any means (electronic mechanical,
photocopying, recording, or otherwise), without the prior written permission of the Publisher.

ISA
67 Alexander Drive
P.O. Box 12277
Research Triangle Park, North Carolina 27709

Preface

This preface, as well as all footnotes and annexes, is included for information purposes and is not part of ANSI/ISA-75.05.01-2000 (R2005).

This document has been prepared as part of the service of ISA—The Instrumentation, Systems, and Automation Society—toward a goal of uniformity in the field of instrumentation. To be of real value, this document should not be static but should be subject to periodic review. Toward this end, the Society welcomes all comments and criticisms and asks that they be addressed to the Secretary, Standards and Practices Board; ISA; 67 Alexander Drive; P. O. Box 12277; Research Triangle Park, NC 27709; Telephone (919) 549-8411; Fax (919) 549-8288; E-mail: standards@isa.org.

The ISA Standards and Practices Department is aware of the growing need for attention to the metric system of units in general, and the International System of Units (SI) in particular, in the preparation of instrumentation standards. The Department is further aware of the benefits to USA users of ISA standards of incorporating suitable references to the SI (and the metric system) in their business and professional dealings with other countries. Toward this end, this Department will endeavor to introduce SI-acceptable metric units in all new and revised standards, recommended practices, and technical reports to the greatest extent possible. *Standard for Use of the International System of Units (SI): The Modern Metric System*, published by the American Society for Testing & Materials as IEEE/ASTM SI 10-97, and future revisions, will be the reference guide for definitions, symbols, abbreviations, and conversion factors.

It is the policy of ISA to encourage and welcome the participation of all concerned individuals and interests in the development of ISA standards, recommended practices, and technical reports. Participation in the ISA standards-making process by an individual in no way constitutes endorsement by the employer of that individual, of ISA, or of any of the standards, recommended practices, and technical reports that ISA develops.

CAUTION — ISA ADHERES TO THE POLICY OF THE AMERICAN NATIONAL STANDARDS INSTITUTE WITH REGARD TO PATENTS. IF ISA IS INFORMED OF AN EXISTING PATENT THAT IS REQUIRED FOR USE OF THE DOCUMENT, IT WILL REQUIRE THE OWNER OF THE PATENT TO EITHER GRANT A ROYALTY-FREE LICENSE FOR USE OF THE PATENT BY USERS COMPLYING WITH THE DOCUMENT OR A LICENSE ON REASONABLE TERMS AND CONDITIONS THAT ARE FREE FROM UNFAIR DISCRIMINATION.

EVEN IF ISA IS UNAWARE OF ANY PATENT COVERING THIS DOCUMENT, THE USER IS CAUTIONED THAT IMPLEMENTATION OF THE DOCUMENT MAY REQUIRE USE OF TECHNIQUES, PROCESSES, OR MATERIALS COVERED BY PATENT RIGHTS. ISA TAKES NO POSITION ON THE EXISTENCE OR VALIDITY OF ANY PATENT RIGHTS THAT MAY BE INVOLVED IN IMPLEMENTING THE DOCUMENT. ISA IS NOT RESPONSIBLE FOR IDENTIFYING ALL PATENTS THAT MAY REQUIRE A LICENSE BEFORE IMPLEMENTATION OF THE DOCUMENT OR FOR INVESTIGATING THE VALIDITY OR SCOPE OF ANY PATENTS BROUGHT TO ITS ATTENTION. THE USER SHOULD CAREFULLY INVESTIGATE RELEVANT PATENTS BEFORE USING THE DOCUMENT FOR THE USER'S INTENDED APPLICATION.

HOWEVER, ISA ASKS THAT ANYONE REVIEWING THIS DOCUMENT WHO IS AWARE OF ANY PATENTS THAT MAY IMPACT IMPLEMENTATION OF THE DOCUMENT NOTIFY THE ISA STANDARDS AND PRACTICES DEPARTMENT OF THE PATENT AND ITS OWNER.

ADDITIONALLY, THE USE OF THIS DOCUMENT MAY INVOLVE HAZARDOUS MATERIALS, OPERATIONS OR EQUIPMENT. THE DOCUMENT CANNOT ANTICIPATE ALL POSSIBLE APPLICATIONS OR ADDRESS ALL POSSIBLE SAFETY ISSUES ASSOCIATED WITH USE IN HAZARDOUS CONDITIONS. THE USER OF THIS DOCUMENT MUST EXERCISE SOUND

PROFESSIONAL JUDGMENT CONCERNING ITS USE AND APPLICABILITY UNDER THE USER'S PARTICULAR CIRCUMSTANCES. THE USER MUST ALSO CONSIDER THE APPLICABILITY OF ANY GOVERNMENTAL REGULATORY LIMITATIONS AND ESTABLISHED SAFETY AND HEALTH PRACTICES BEFORE IMPLEMENTING THIS DOCUMENT.

THE USER OF THIS DOCUMENT SHOULD BE AWARE THAT THIS DOCUMENT MAY BE IMPACTED BY ELECTRONIC SECURITY ISSUES. THE COMMITTEE HAS NOT YET ADDRESSED THE POTENTIAL ISSUES IN THIS VERSION.

The following people served as members of ISA Subcommittee SP75.05 and approved ANSI/ISA-75.05.01-2000:

NAME	COMPANY
J. Reed, Chairman	Norriseal
W. Weidman, Managing Director	Parsons Energy and Chemicals Group, Inc.
T. Abromaitis	Red Valve Company, Inc.
G. Barb	Consultant
H. Baumann	H B Services Partners LLC
H. Boger	Masoneilan/Dresser
J. Brett*	Con-Tek Valves, Inc.
R. Brodin	Fisher Controls International, Inc.
D. Buchanan	Union Carbide Corporation
F. Cain	Flowserve-FCD
C. Corson	Fluor Daniel, Inc.
M. Glavin	Grinnell Corporation
F. Harthun	Consultant
C. Koloboff	Consultant
G. Kovecses	Yarway Company
G. Richards	Richards Industries, Inc.
K. Schoonover*	Con-Tek Valves, Inc.
L. Stratton	Control Components, Inc.
F. Sullivan	Consultant
R. Terhune	Consultant

* One vote per company.

The following people served as members of ISA Committee SP75 and approved ANSI/ISA-75.05.01-2000:

NAME	COMPANY
D. Buchanan, Chairman	Union Carbide Corporation
W. Weidman, Managing Director	Parsons Energy & Chemicals Group
A. Abromaitis	Red Valve Company, Inc.
H. Backinger	J. F. Kraus & Company
G. Barb	Retired
H. Baumann	H B Services Partners LLC
H. Boger	Masoneilan Dresser
G. Borden	Consultant
S. Boyle	Neles Automation
R. Brodin	Fisher Controls International, Inc.
F. Cain	Flowserve Corporation
C. Corson	Fluor Daniel Inc.
M. Coughran	Fisher Controls
A. Engels	Praxair, Inc.

H. Fuller	Valvcon Corporation
J. George	Richards Industries
A. Glenn	Flowserve Corp.
L. Griffith	Consultant/Retired
B. Guinon	Shell Chemical
F. Harthun	Retired
B. Hatton	DeZurik Division Unit
J. Jamison	Bantrel, Inc.
R. Jeanes	TXU Electric
J. Kersh	M. W. Kellogg Company
C. Langford	Cullen G. Langford, Inc.
A. Libke	DeZurik Valve Company
R. Louviere	Creole Engineering Sales Company
O. Lovett	Consultant/Retired
A. McCauley	Chagrin Valley Controls, Inc.
R. McEver	Bettis Corporation
H. Miller	Control Components, Inc.
T. Molloy	CMES Inc.
L. Ormanoski	Frick Company
J. Ozol	Commonwealth Edison
W. Rahmeyer	Utah State University
J. Reed	Norriseal
K. Schoonover	Con-Tek Valves, Inc.
A. Shea	Copes-Vulcan, Inc.
E. Skovgaard	Leslie Controls, Inc.
H. Sonderegger	Tyco Flow Control
R. Terhune	Retired

* One vote per company.

The following ISA Standards and Practices Board members approved ANSI/ISA-75.05.01-2000 for publication on 30 December 2000.

NAME	COMPANY
M. Zielinski, Chair	Fisher-Rosemount Systems, Inc.
D. Bishop	Consultant
P. Brett	Honeywell, Inc.
M. Cohen	Senior Flexonics, Inc.
M. Coppler	Ametek, Inc.
B. Dumortier	Schneider Electric SA
W. Holland	Southern Company
A. Iverson	Ivy Optiks
R. Jones	Dow Chemical Company
V. Maggioli	Feltronics Corporation
T. McAviney	Bateman Engineering, Inc.
A. McCauley, Jr.	Chagrin Valley Controls, Inc.
G. McFarland	Westinghouse Process Control Inc.
D. Rapley	Rapley Consulting Inc.
R. Reimer	Rockwell Automation
J. Rennie	Factory Mutual Research Corporation
H. Sasajima	Yamatake Corporation
R. Webb	Altran Corporation
W. Weidman	Parsons Energy & Chemicals Group
J. Weiss	EPRI
J. Whetstone	National Institute of Standards & Technology

M. Widmeyer
R. Wiegler
C. Williams
G. Wood

EG&G Defense Materials
CANUS Corporation
Eastman Kodak Company
Graeme Wood Consulting

The following people served as members of ISA Subcommittee SP75.05 and reaffirmed ANSI/ISA-75.05.01-2000 (R2005):

NAME

COMPANY

J. Reed, Chair
W. Weidman, Managing Director
A. Abromaitis
H. Baumann
J. Brett
F. Cain
C. Corson
J. McCaskill
L. Stratton
J. Young

Consultant
Parsons E&C
Red Valve c/o S&T Design
H B Services Partners LLC
Con-Tek
Flowserve Corporation
Damiano Long Company
Power Chokes LP
Control Components Inc.
Dow Chemical Company Texas

* One vote per company.

The following people served as members of ISA Committee SP75 and reaffirmed ANSI/ISA-75.05.01-2000 (R2005):

NAME

COMPANY

J. Young, Chair
W. Weidman, Managing Director
H. Backinger
H. Baumann
J. Beall
W. Black
H. Boger*
G. Borden
S. Boyle
J. Broyles
F. Cain
W. Cohen
R. Duimstra
A. Engels
J. George
H. Hoffmann
J. Jamison
R. Jeanes
C. Langford
W. Lestan*
A. Libke*
J. McCaskill
A. McCauley
R. McEver
V. Mezzano
H. Miller
T. Molloy

Dow Chemical Company Texas
Parsons E&C
Consultant
H B Services Partners LLC
Emerson Process Management
Curtiss-Wright Flow Control Corporation
Masoneilan Dresser
Consultant
Metso Automation USA Inc.
Enbridge Pipelines Inc.
Flowserve Corporation
KBR
Fisher Controls International Inc.
Praxair Inc.
Richards Industries
Samson AG
OPTI Canada Inc.
TXU Electric
Cullen G Langford Inc.
Masoneilan Dresser
SPX Valves & Controls DeZurik Products
Power Chokes LP
Chagrin Valley Controls Inc.
Consultant
Fluor Corporation
Control Components Inc.
CMES Inc.

L. Ormanoski	Frick Company
J. Ozol	NMC Prairie Island Nuclear Plant
W. Rahmeyer	Utah State University
J. Reed	Consultant
A. Shea*	SPX Valves & Controls
E. Skovgaard	Consultant
H. Sonderegger	Consultant

* One vote per company.

ANSI/ISA-75.05.01-2000 (R2005) was reaffirmed by the following ISA Standards and Practices Board on 7 February 2005.

NAME	COMPANY
I. Verhappen, Chair	Syncrude Canada Ltd.
F. Amir	E I Du Pont Company
D. Bishop	David N Bishop, Consultant
M. Coppler	Ametek, Inc.
B. Dumortier	Schneider Electric
W. Holland	Consultant
E. Icyan	ACES Inc
A. Iverson	Ivy Optiks
R. Jones	Consultant
V. Maggioli	Feltronics Corporation
T. McAviney	Jacobs Engineering Group
A. McCauley	Chagrin Valley Controls, Inc.
G. McFarland	Emerson Process Management
R. Reimer	Rockwell Automation
J. Rennie	Consultant
N. Sands	E I du Pont
H. Sasajima	Yamatake Corporation
T. Schnaare	Rosemount Inc.
A. Summers	SIS-TECH Solutions LLC
R. Webb	Consultant
W. Weidman	Parsons Energy & Chemicals Group
J. Weiss	KEMA Inc.
M. Widmeyer	Stanford Linear Accelerator Center
C. Williams	Eastman Kodak Company
M. Zielinski	Emerson Process Management

This is a preview of "ANSI/ISA 75.05.01-20...". [Click here to purchase the full version from the ANSI store.](#)

This page intentionally left blank.

Contents

1	Scope	11
2	Purpose	11
3	Definitions.....	11

This is a preview of "ANSI/ISA 75.05.01-20...". [Click here to purchase the full version from the ANSI store.](#)

This page intentionally left blank.

1 Scope

This document contains terminology for control valves.

2 Purpose

To provide a glossary of definitions commonly used in the control valve industry.

3 Definitions

3.1 accuracy:

the degree of conformity of an indicated value to a recognized accepted standard value or ideal value.

3.2 accessories:

devices usually attached to the actuator for various control functions such as positioners, relays, solenoid valves, airsets, handwheels, and limit switches.

3.3 actuator:

a pneumatic, hydraulic, or electrically powered device that supplies force and motion to position a valve's closure member at or between the open or closed position.

3.3.1 bellows actuator:

a fluid powered device in which the fluid acts upon a flexible convoluted component, the bellows.

3.3.2 diaphragm actuator:

a fluid powered device in which the fluid acts upon a flexible component, the diaphragm. (See Figure 1.)

3.3.3 double-acting actuator:

a device in which power is supplied in either direction. (See Figure 2.)

3.3.4 electrohydraulic actuator:

a device that converts electrical energy to hydraulic pressure and into motion.

3.3.5 electromechanical actuator:

a device that converts electrical energy into motion.

3.3.6 hydraulic actuator:

a fluid device that converts the energy of an incompressible fluid into motion.

3.3.7 piston actuator:

a fluid powered device in which the fluid acts upon a movable piston to provide motion to the actuator stem. (See Figure 2.)