

**AMERICAN NATIONAL STANDARD**

**ANSI/ISA-75.08.06-2002 (R2013)**

Formerly ANSI/ISA-75.16-1993

**Face-to-Face Dimensions for  
Flanged Globe-Style Control Valve  
Bodies (Classes 900, 1500, and 2500)**

Approved 31 January 2013

ANSI/ISA-75.08.06-2002 (R2013)  
Face-to-Face Dimensions for Flanged Globe-Style Control Valve Bodies  
(Classes 900, 1500, and 2500)

ISBN: 978-1-937560-99-7

Copyright © 2013 by ISA. All rights reserved. Not for resale. Printed in the United States of America. No part of this publication may be reproduced, stored in a retrieval system, or transmitted in any form or by any means (electronic mechanical, photocopying, recording, or otherwise), without the prior written permission of the Publisher.

ISA  
67 Alexander Drive  
P.O. Box 12277  
Research Triangle Park, North Carolina 27709

## Preface

This preface, as well as all footnotes and annexes, is included for information purposes and is not part of ANSI/ISA-75.08.06-2002 (R2013).

The standards referenced within this document may contain provisions which, through reference in this text, constitute requirements of this document. At the time of publication, the editions indicated were valid. All standards are subject to revision, and parties to agreements based on this document are encouraged to investigate the possibility of applying the most recent editions of the standards indicated within this document. Members of IEC and ISO maintain registers of currently valid International Standards. ANSI maintain registers of currently valid U.S. National Standards.

This document has been prepared as part of the service of ISA toward a goal of uniformity in the field of instrumentation. To be of real value, this document should not be static but should be subject to periodic review. Toward this end, the Society welcomes all comments and criticisms and asks that they be addressed to the Secretary, Standards and Practices Board; ISA; 67 Alexander Drive; P. O. Box 12277; Research Triangle Park, NC 27709; Telephone (919) 549-8411; Fax (919) 549-8288; E-mail: standards@isa.org.

The ISA Standards and Practices Department is aware of the growing need for attention to the metric system of units in general, and the International System of Units (SI) in particular, in the preparation of instrumentation standards. The Department is further aware of the benefits to USA users of ISA standards of incorporating suitable references to the SI (and the metric system) in their business and professional dealings with other countries. Toward this end, this Department will endeavor to introduce SI-acceptable metric units in all new and revised standards, recommended practices, and technical reports to the greatest extent possible. IEEE/ASTM SI 10, *American National Standard for Metric Practice*, and future revisions, will be the reference guide for definitions, symbols, abbreviations, and conversion factors.

It is the policy of ISA to encourage and welcome the participation of all concerned individuals and interests in the development of ISA standards, recommended practices, and technical reports. Participation in the ISA standards-making process by an individual in no way constitutes endorsement by the employer of that individual, of ISA, or of any of the standards, recommended practices, and technical reports that ISA develops.

**CAUTION — ISA DOES NOT TAKE ANY POSITION WITH RESPECT TO THE EXISTENCE OR VALIDITY OF ANY PATENT RIGHTS ASSERTED IN CONNECTION WITH THIS DOCUMENT, AND ISA DISCLAIMS LIABILITY FOR THE INFRINGEMENT OF ANY PATENT RESULTING FROM THE USE OF THIS DOCUMENT. USERS ARE ADVISED THAT DETERMINATION OF THE VALIDITY OF ANY PATENT RIGHTS, AND THE RISK OF INFRINGEMENT OF SUCH RIGHTS, IS ENTIRELY THEIR OWN RESPONSIBILITY.**

**PURSUANT TO ISA'S PATENT POLICY, ONE OR MORE PATENT HOLDERS OR PATENT APPLICANTS MAY HAVE DISCLOSED PATENTS THAT COULD BE INFRINGED BY USE OF THIS DOCUMENT AND EXECUTED A LETTER OF ASSURANCE COMMITTING TO THE GRANTING OF A LICENSE ON A WORLDWIDE, NON-DISCRIMINATORY BASIS, WITH A FAIR AND REASONABLE ROYALTY RATE AND FAIR AND REASONABLE TERMS AND CONDITIONS. FOR MORE INFORMATION ON SUCH DISCLOSURES AND LETTERS OF ASSURANCE, CONTACT ISA OR VISIT WWW.ISA.ORG/STANDARDSPATENTS.**

**OTHER PATENTS OR PATENT CLAIMS MAY EXIST FOR WHICH A DISCLOSURE OR LETTER OF ASSURANCE HAS NOT BEEN RECEIVED. ISA IS NOT RESPONSIBLE FOR IDENTIFYING PATENTS OR PATENT APPLICATIONS FOR WHICH A LICENSE MAY BE REQUIRED, FOR CONDUCTING INQUIRIES INTO THE LEGAL VALIDITY OR SCOPE OF PATENTS, OR DETERMINING WHETHER**

**ANY LICENSING TERMS OR CONDITIONS PROVIDED IN CONNECTION WITH SUBMISSION OF A LETTER OF ASSURANCE, IF ANY, OR IN ANY LICENSING AGREEMENTS ARE REASONABLE OR NON-DISCRIMINATORY.**

**ISA REQUESTS THAT ANYONE REVIEWING THIS DOCUMENT WHO IS AWARE OF ANY PATENTS THAT MAY IMPACT IMPLEMENTATION OF THE DOCUMENT NOTIFY THE ISA STANDARDS AND PRACTICES DEPARTMENT OF THE PATENT AND ITS OWNER.**

**ADDITIONALLY, THE USE OF THIS DOCUMENT MAY INVOLVE HAZARDOUS MATERIALS, OPERATIONS OR EQUIPMENT. THE DOCUMENT CANNOT ANTICIPATE ALL POSSIBLE APPLICATIONS OR ADDRESS ALL POSSIBLE SAFETY ISSUES ASSOCIATED WITH USE IN HAZARDOUS CONDITIONS. THE USER OF THIS DOCUMENT MUST EXERCISE SOUND PROFESSIONAL JUDGMENT CONCERNING ITS USE AND APPLICABILITY UNDER THE USER'S PARTICULAR CIRCUMSTANCES. THE USER MUST ALSO CONSIDER THE APPLICABILITY OF ANY GOVERNMENTAL REGULATORY LIMITATIONS AND ESTABLISHED SAFETY AND HEALTH PRACTICES BEFORE IMPLEMENTING THIS DOCUMENT.**

**THE USER OF THIS DOCUMENT SHOULD BE AWARE THAT THIS DOCUMENT MAY BE IMPACTED BY ELECTRONIC SECURITY ISSUES. THE COMMITTEE HAS NOT YET ADDRESSED THE POTENTIAL ISSUES IN THIS VERSION.**

The following people served as members of ISA Committee SP75.08 and approved ANSI/ISA-75.08.06-2002:

| <b>NAME</b>          | <b>COMPANY</b>                   |
|----------------------|----------------------------------|
| W. Weidman, Chairman | Parsons Energy & Chemicals Group |
| H. Baumann           | HB Services Partners LLC         |
| G. Borden            | Consultant                       |
| R. Brodin            | Emerson Process Management       |
| F. Cain              | Flowserve Corporation            |
| R. Chown             | OTEC Process Systems Inc.        |
| B. Hatton            | Dezurik                          |
| J. Reed              | Norriseal                        |
| H. Sonderegger       | Anvil International Inc.         |

The following people served as members of ISA Committee SP75 and approved ANSI/ISA-75.08.06-2002:

| <b>NAME</b>                   | <b>COMPANY</b>                          |
|-------------------------------|---|
| D. Buchanan, Chairman         | Consultant                              |
| W. Weidman, Managing Director | Parsons Energy & Chemicals Group        |
| K. Schoonover, Secretary      | Con-Tek Valves Inc.                     |
| A. Abromaitis                 | Red Valve Co Inc.                       |
| H. Backinger                  | Consultant                              |
| G. Barb                       | Consultant                              |
| H. Baumann                    | HB Services Partners LLC                |
| J. Beall*                     | Emerson Process Management              |
| W. Black                      | Curtiss-Wright Flow Control Corporation |
| G. Blackwell                  | Industrial Valve                        |
| H. Boger*                     | Masoneilan Dresser                      |
| G. Borden                     | Consultant                              |
| S. Boyle                      | Metso Automation USA Inc.               |
| R. Brodin*                    | Emerson Process Management              |

F. Cain  
A. Engels  
H. Fuller  
J. George  
L. Griffith  
J. Jamison  
R. Jeanes  
J. Kersh  
C. Langford  
W. Lestan\*  
A. Libke\*  
R. Louviere  
J. McCaskill  
A. McCauley  
R. McEver\*  
H. Miller  
T. Molloy  
L. Ormanoski  
J. Ozol  
W. Rahmeyer  
J. Reed  
A. Shea\*  
E. Skovgaard  
H. Sonderegger

Flowserve Corporation  
Praxair Inc.  
Valvcon Corporation  
Richards Industries  
Consultant  
Bantrel Inc.  
TXU Electric  
M W Kellogg Company  
Cullen G. Langford Inc.  
Masoneilan Dresser  
SPX Valves & Controls DeZurik Products  
Services Unlimited  
Power Chokes  
Chagrin Valley Controls Inc.  
Emerson Valve Automation  
Control Components Inc.  
CMES Inc.  
Frick Company  
Northern States Power  
Utah State University  
Norriseal  
SPX Valves & Controls DeZurik Products  
Leslie Controls Inc.  
Anvil International Inc.

\* One vote per company.

ANSI/ISA-75.08.06-2002 was approved for publication by the ISA Standards and Practices Board on 26 September 2002.

**NAME**

**COMPANY**

M. Zielinski  
D. Bishop  
D. Bouchard  
M. Cohen  
M. Coppler  
B. Dumortier  
W. Holland  
E. Iccayan  
A. Iverson  
R. Jones  
V. Maggioli  
T. McAviney  
A. McCauley, Jr.  
G. McFarland  
R. Reimer  
J. Rennie  
H. Sasajima  
I. Verhappen  
R. Webb  
W. Weidman  
J. Weiss  
M. Widmeyer  
R. Wiegler  
C. Williams  
G. Wood

Emerson Process Management  
David N Bishop, Consultant  
Paprican  
Consultant  
Ametek, Inc.  
Schneider Electric  
Southern Company  
ACES Inc  
Ivy Optiks  
Dow Chemical Company  
Feltronics Corporation  
I&C Engineering, LLC  
Chagrin Valley Controls, Inc.  
Westinghouse Process Control Inc.  
Rockwell Automation  
Factory Mutual Research Corporation  
Yamatake Corporation  
Syncrude Canada Ltd.  
POWER Engineers  
Parsons Energy & Chemicals Group  
KEMA Consulting  
Stanford Linear Accelerator Center  
CANUS Corporation  
Eastman Kodak Company  
Graeme Wood Consulting

The following people served as members of ISA Subcommittee ISA75.08 and reaffirmed ANSI/ISA-75.08.06-2002 (R2013):

| <b>NAME</b>       | <b>COMPANY</b>                     |
|-------------------|------------------------------------|
| W. Weidman, Chair | WCW Consulting                     |
| H. Baumann        | H B Services Partners LLC          |
| G. Borden         | Consultant                         |
| F. Cain           | Flowserve Corporation              |
| R. Chown          | Madawaska Mechanical Inc.          |
| R. Duimstra       | Fisher Controls International Inc. |
| V. Mezzano        | Fluor Corporation                  |
| J. Reed           | Consultant                         |
| J. Young          | The Dow Chemical Company           |

The following people served as members of ISA Committee ISA75 and reaffirmed ANSI/ISA-75.08.06-2002 (R2013):

| <b>NAME</b>                   | <b>COMPANY</b>                     |
|-------------------------------|------------------------------------|
| J. Young, Chair               | The Dow Chemical Company           |
| W. Weidman, Managing Director | WCW Consulting                     |
| L. Al-Awami                   | Saudi Aramco                       |
| H. Baumann                    | H B Services Partners LLC          |
| J. Beall                      | Emerson Process Management         |
| M. Bober                      | Copes-Vulcan                       |
| H. Boger                      | GE Oil & Gas                       |
| G. Borden                     | Consultant                         |
| S. Boyle                      | Metso Automation USA Inc.          |
| J. Broyles                    | Enbridge Pipelines Inc.            |
| F. Cain                       | Flowserve Corporation              |
| W. Cohen                      | KBR                                |
| R. Duimstra                   | Fisher Controls International Inc. |
| J. Faramarzi                  | Control Components Inc.            |
| J. George                     | Richards Industries                |
| C. Hergert                    | Kellogg Brown & Root               |
| H. Hoffmann                   | Consultant                         |
| J. Jamison                    | Spectra Energy Ltd.                |
| J. Kiesbauer                  | Samson Aktiengesellschaft          |
| C. Langford                   | Cullen G Langford Inc.             |
| A. Libke                      | DeZurik                            |
| G. Liu                        | Consultant                         |
| T. Loudin                     | Flowrox Inc.                       |
| H. Maxwell                    | Bechtel Power Corp.                |
| J. McCaskill                  | Expro Group                        |
| A. McCauley                   | Chagrin Valley Controls Inc.       |
| R. McEver                     | Consultant                         |
| V. Mezzano                    | Fluor Corporation                  |
| H. Miller                     | Consultant                         |
| T. Molloy                     | CMES Inc.                          |
| L. Ormanoski                  | Consultant                         |
| J. Reed                       | Consultant                         |
| E. Skovgaard                  | Control Valve Solutions            |

This standard was approved for reaffirmation by the ISA Standards and Practices Board on 14 January 2013:

**NAME**

**COMPANY**

|                         |   |
|-------------------------|---|
| D. Dunn, Vice President | Aramco Services Co.                         |
| R. Bartusiak            | ExxonMobil Chemical Company                 |
| P. Brett                | Honeywell Inc.                              |
| J. Campbell             | Consultant                                  |
| M. Coppler              | Det Norske Veritas Certification Inc.       |
| E. Cosman               | The Dow Chemical Co.                        |
| B. Dumortier            | Schneider Electric                          |
| J. Federlein            | Federlein & Assoc. Inc.                     |
| J. Gilsinn              | Kenexis Consulting                          |
| E. Icyan                | ACES Inc.                                   |
| J. Jamison              | Spectra Energy Ltd.                         |
| K. Lindner              | Endress+Hauser Process Solutions AG         |
| V. Maggioli             | Feltronics Corp.                            |
| T. McAviney             | Instrumentation and Control Engineering LLC |
| R. Reimer               | Rockwell Automation                         |
| S. Russell              | Valero Energy Corp.                         |
| N. Sands                | DuPont                                      |
| H. Sasajima             | Azbil Corp.                                 |
| T. Schnaare             | Rosemount Inc.                              |
| J. Tatera               | Tatera & Associates Inc.                    |
| I. Verhappen            | Industrial Automation Networks Inc.         |
| W. Weidman              | WCW Consulting                              |
| J. Weiss                | Applied Control Solutions LLC               |
| M. Wilkins              | Yokogawa IA Global Marketing (USMK)         |
| D. Zetterberg           | Chevron Energy Technology Company           |

This is a preview of "ANSI/ISA 75.08.06-20...". [Click here to purchase the full version from the ANSI store.](#)

This page intentionally left blank.

## Contents

|   |  |    |
|---|--|----|
| 1 | Scope .....  | 11 |
| 2 | Purpose.....   | 11 |
| 3 | Definitions .....                                      | 11 |
| 4 | Dimensional data .....                                 | 11 |
| 5 | References.....  | 13 |
|   | Annex A — Dimensions for metrically sized valves ..... | 15 |

This is a preview of "ANSI/ISA 75.08.06-20...". [Click here to purchase the full version from the ANSI store.](#)

This page intentionally left blank.

## 1 Scope

This standard applies to flanged globe-style control valves, sizes 15 mm (1/2 inch) through 450 mm (18 inches), having top, top and bottom, port, or cage guiding.

## 2 Purpose

2.1 The purpose of this standard is to aid users in their piping design by providing Classes 900, 1500, and 2500, flanged globe-style control valve dimensions, without giving special consideration to the equipment manufacturer to be used.

2.2 The short-long dimensions provided in Table 1 clarify 2.1 by consolidating the diversity of existing manufacturers' lengths into two sets of dimensions for each valve size. Before using either the short or long dimension, the piping designer should confirm with the selected valve manufacturer which dimension is correct for the valve(s) being supplied.

## 3 Definitions

For definitions of terms used in this standard, see ANSI/ISA-75.05.01-2000 (R2005), Control Valve Terminology.

## 4 Dimensional data

4.1 For face-to-face dimensions for flanged globe-style control valves, see Table 1.

4.2 For end-to-end dimensions of flanged with ring joint ends, Dimension "A" shall be adjusted according to ASME B16.10-2000 (R2003), paragraph 3.3.