

AMERICAN NATIONAL STANDARD

ANSI/ISA-75.19.01-2013

**Hydrostatic Testing
of Control Valves**

Approved 6 August 2013

ANSI/ISA-75.19.01-2013, Hydrostatic Testing of Control Valves

ISBN: 978-0-876640-36-4

Copyright © 2013 by ISA. All rights reserved. Not for resale. Printed in the United States of America. No part of this publication may be reproduced, stored in a retrieval system, or transmitted, in any form or by any means (electronic, mechanical, photocopying, recording, or otherwise), without the prior written permission of the Publisher.

ISA
67 Alexander Drive
P. O. Box 12277
Research Triangle Park, North Carolina 27709

Preface

ANSI/ISA-75.19.01-2007 was revised in 2013 to include the changes in ASME B16.34-2009, Valves-Flanged, Threaded, and Welding End. All pressure-temperature ratings in ASME B16.34 were recalculated using data from the latest edition of the ASME Boiler and Pressure Vessel Code, Section II, Part D. As a result, new materials have been added, some materials have been shifted to other material groups and pressure-temperature ratings have changed within some material groups. The 2013 edition of ANSI/ISA-75.19.01 uses metric units as the primary reference units while maintaining U.S. customary units in reference tables. This follows the lead of ASME B16.34-2009 that states their goal is to delete the U.S. customary units in future revisions.

This preface, as well as all footnotes and annexes, is included for informational purposes and is not part of ANSI/ISA-75.19.01-2013.

This standard has been prepared as part of the service of ISA toward a goal of uniformity in the field of instrumentation. To be of real value, this document should not be static, but should be subject to periodic review. Toward this end, the Society welcomes all comments and criticisms, and asks that they be addressed to the Secretary, Standards and Practices Board; ISA; 67 Alexander Drive; P. O. Box 12277; Research Triangle Park, NC 27709; Telephone (919) 990-9227; Fax: (919) 549-8288; e-mail: standards@isa.org.

The ISA Standards and Practices Department is aware of the growing need for attention to the metric system of units in general and the International System of Units (SI) in particular, in the preparation of instrumentation standards, recommended practices, or technical reports. The Department is further aware of the benefits to U.S.A. users of ISA standards of incorporating suitable references to the SI (and the metric system) in their business and professional dealings with other countries. Toward this end, this Department will endeavor to introduce SI-acceptable metric units in all new and revised standards to the greatest extent possible. *The Metric Practice Guide*, which has been published by the Institute of Electrical and Electronics Engineers as ANSI/IEEE Std. 268-1992, and future revisions, will be the reference guide for definitions, symbols, abbreviations, and conversion factors. Certain metric units that are part of the SI system are in common accepted pressure measurement that is convertible to kilopascals by multiplying by 100.

It is the policy of ISA to encourage and welcome the participation of all concerned individuals and interests in the development of ISA standards. Participation in the ISA standards-making process by an individual in no way constitutes endorsement by the employer of that individual, of ISA, or of any of the standards that ISA develops.

CAUTION — ISA DOES NOT TAKE ANY POSITION WITH RESPECT TO THE EXISTENCE OR VALIDITY OF ANY PATENT RIGHTS ASSERTED IN CONNECTION WITH THIS DOCUMENT, AND ISA DISCLAIMS LIABILITY FOR THE INFRINGEMENT OF ANY PATENT RESULTING FROM THE USE OF THIS DOCUMENT. USERS ARE ADVISED THAT DETERMINATION OF THE VALIDITY OF ANY PATENT RIGHTS, AND THE RISK OF INFRINGEMENT OF SUCH RIGHTS, IS ENTIRELY THEIR OWN RESPONSIBILITY.

PURSUANT TO ISA'S PATENT POLICY, ONE OR MORE PATENT HOLDERS OR PATENT APPLICANTS MAY HAVE DISCLOSED PATENTS THAT COULD BE INFRINGED BY USE OF THIS DOCUMENT AND EXECUTED A LETTER OF ASSURANCE COMMITTING TO THE GRANTING OF A LICENSE ON A WORLDWIDE, NON-DISCRIMINATORY BASIS, WITH A FAIR AND REASONABLE ROYALTY RATE AND FAIR AND REASONABLE TERMS AND CONDITIONS. FOR MORE INFORMATION ON SUCH DISCLOSURES AND LETTERS OF ASSURANCE, CONTACT ISA OR VISIT WWW.ISA.ORG/STANDARDSPATENTS.

OTHER PATENTS OR PATENT CLAIMS MAY EXIST FOR WHICH A DISCLOSURE OR LETTER OF ASSURANCE HAS NOT BEEN RECEIVED. ISA IS NOT RESPONSIBLE FOR IDENTIFYING PATENTS OR PATENT APPLICATIONS FOR WHICH A LICENSE MAY BE REQUIRED, FOR CONDUCTING INQUIRIES INTO THE LEGAL VALIDITY OR SCOPE OF PATENTS, OR DETERMINING WHETHER ANY LICENSING TERMS OR CONDITIONS PROVIDED IN CONNECTION WITH SUBMISSION OF A LETTER OF ASSURANCE, IF ANY, OR IN ANY LICENSING AGREEMENTS ARE REASONABLE OR NON-DISCRIMINATORY.

ISA REQUESTS THAT ANYONE REVIEWING THIS DOCUMENT WHO IS AWARE OF ANY PATENTS THAT MAY IMPACT IMPLEMENTATION OF THE DOCUMENT NOTIFY THE ISA STANDARDS AND PRACTICES DEPARTMENT OF THE PATENT AND ITS OWNER.

ADDITIONALLY, THE USE OF THIS DOCUMENT MAY INVOLVE HAZARDOUS MATERIALS, OPERATIONS OR EQUIPMENT. THE DOCUMENT CANNOT ANTICIPATE ALL POSSIBLE APPLICATIONS OR ADDRESS ALL POSSIBLE SAFETY ISSUES ASSOCIATED WITH USE IN HAZARDOUS CONDITIONS. THE USER OF THIS DOCUMENT MUST EXERCISE SOUND PROFESSIONAL JUDGMENT CONCERNING ITS USE AND APPLICABILITY UNDER THE USER'S PARTICULAR CIRCUMSTANCES. THE USER MUST ALSO CONSIDER THE APPLICABILITY OF ANY GOVERNMENTAL REGULATORY LIMITATIONS AND ESTABLISHED SAFETY AND HEALTH PRACTICES BEFORE IMPLEMENTING THIS DOCUMENT.

THE USER OF THIS DOCUMENT SHOULD BE AWARE THAT THIS DOCUMENT MAY BE IMPACTED BY ELECTRONIC SECURITY ISSUES. THE COMMITTEE HAS NOT YET ADDRESSED THE POTENTIAL ISSUES IN THIS VERSION.

The following people served as members of ISA Subcommittee ISA75.19:

NAME	COMPANY
M. Bober, Chairman	Copes-Vulcan
W. Weidman, Managing Director	WCW Consulting
G. Borden	Consultant
R. Duimstra	Fisher Controls International LLC
J. McCaskill	Expro Group
J. Reed	Consultant
L. Winkel	Flowserve
J. Young	The Dow Chemical Company

The following people served as members of ISA Committee ISA75:

NAME	COMPANY
J. Young, Chair	The Dow Chemical Company
W. Weidman, Managing Director	WCW Consulting
L. Al-Awami	Saudi Aramco
H. Baumann	HB Services Partners LLC
J. Beall	Emerson Process Management
M. Bober	Copes-Vulcan
H. Boger	GE Oil & Gas
G. Borden	Consultant
S. Boyle	Metso Automation USA Inc.
J. Broyles	Enbridge Pipelines Inc.
F. Cain	Flowserve Corporation
R. Duimstra	Fisher Controls International LLC
J. Faramarzi*	Control Components Inc.

J. George	Richards Industries
C. Hergert	Kellogg Brown & Root
H. Hoffmann	Consultant
J. Jamison	Spectra Energy Ltd.
J. Kiesbauer	Samson Aktiengesellschaft
A. Libke	DeZurik
G. Liu	Consultant
T. Loudin	Flowrox Inc.
H. Maxwell	Bechtel Power Corporation
J. McCaskill	Expro Group
A. McCauley	Chagrin Valley Controls Inc.
R. McEver	Consultant
V. Mezzano	Fluor Corporation
H. Miller*	Control Components Inc.
T. Molloy	CMES Inc.
L. Ormanoski	Consultant
J. Reed	Consultant
E. Skovgaard	Control Valve Solutions

* One vote per company.

This standard was approved for publication by the ISA Standards and Practices Board on 23 July 2013.

NAME	COMPANY
E. Cosman, Vice President	The Dow Chemical Company
D. Bartusiak	ExxonMobil Chemical Company
P. Brett	Honeywell Inc.
J. Campbell	Consultant
M. Coppler	Det Norske Veritas Certification Inc.
B. Dumortier	Schneider Electric
D. Dunn	Aramco Services Co.
J. Federlein	Federlein & Assoc. Inc.
J. Gilsinn	Kenexis Consulting
E. Icyan	Atkins
J. Jamison	Spectra Energy Ltd.
K. P. Lindner	Endress + Hauser Process Solutions AG
V. Maggioli	Feltronics Corp.
T. McAviney	Instrumentation and Control Engineering, LLC
V. Mezzano	Fluor Corp.
C. Monchinski	Automated Control Concepts Inc.
R. Reimer	Rockwell Automation
S. Russell	Valero Energy Corp.
N. Sands	DuPont
H. Sasajima	Azbil Corp.
T. Schnaare	Rosemount Inc.
J. Tatera	Tatera & Associates Inc.
I. Verhappen	Industrial Automation Networks Inc.
W. Weidman	WCW Consulting
J. Weiss	Applied Control Solutions LLC
M. Wilkins	Yokogawa IA Global Marketing (USMK)
D. Zetterberg	Chevron Energy Technology Company

This is a preview of "ANSI/ISA 75.19.01-20...". [Click here to purchase the full version from the ANSI store.](#)

This page intentionally left blank.

Contents

1	Scope	9
2	Definitions	9
3	Test fixture and instrumentation.....	9
4	Test requirements.....	9
5	Test procedures	11
6	Acceptance standards	11
7	Test pressures	12
	Annex A — Test pressures (psig)	23
	Annex B — References.....	27

This is a preview of "ANSI/ISA 75.19.01-20...". [Click here to purchase the full version from the ANSI store.](#)

This page intentionally left blank.

1 Scope

1.1 This standard applies to control valves having bodies, bonnets, cover plates, and bottom flanges made of carbon steel, low alloy and high alloy (stainless) steel, nickel-base alloy, cast iron, and ductile iron.

1.2 This standard establishes requirements and definitions for standard hydrostatic shell testing of control valves by the valve manufacturer to prove the structural integrity and leak tightness of the valves' pressure retaining parts, including any closure parts such as the valve body to bonnet joint, but excluding packings, bellows or other moving seals, and packing leakoff/purge/vent port connections. Bellows or similar moving stem seals may be pressure tested after assembly at a pressure to be agreed upon by the valve manufacturer and the purchaser. The requirements of this standard do not cover pneumatic and hydraulic actuators and regulators.

1.3 This standard describes and specifies the specific circumstances of hydrostatic shell testing of control valves and is in accordance with the hydrostatic testing requirements of ASME B16.1, ASME B16.34 and ASME B16.42 with the exception that the test requirements of paragraph 4.8 are not allowed by ASME B16.34.

1.4 WARNING – SERIOUS BODILY HARM CAN BE CAUSED BY HIGH VELOCITY LEAKS THROUGH THE SHELL OR SEALS, RESULTING FROM THE ENERGY STORED IN THE PRESSURIZED FLUID AND CONTAINMENT EQUIPMENT. CARE SHOULD BE EXERCISED TO ENSURE THE SAFETY OF TEST AND INSPECTION PERSONNEL. SPECIFIC SAFETY REQUIREMENTS FOR CONDUCTING HYDROSTATIC TESTING AND INSPECTION ARE NOT WITHIN THE SCOPE OF THIS STANDARD.

2 Definitions

2.1 control valve:
refer to ANSI/ISA-75.05.01, *Control Valve Terminology*.

2.2 test fixture:
a test fixture is a device to close off the end connections and/or stem seal areas of the control valve to allow pressurization for hydrostatic shell testing.

3 Test fixture and instrumentation

3.1 Test fixtures include, but are not limited to, the following: plugs with tie-bars and tie-rods, hydraulic presses, plugs or flanges attached to the pipe connections, bosses or lugs on the valve, and expandable rubber plugs. For butt welding end valves when end plugs are used, the seal point shall be as close to the weld end as practical without overstressing the weld preparation.

3.2 The analog or digital pressure measuring instruments used in testing shall be of the indicating or recording type.

3.3 The valve manufacturer shall be responsible for maintaining the accuracy of the pressure measuring instruments.

3.4 Pressure measuring instruments shall be accurate within 3% at test pressure, and analog-type shall be used between 20% and 80% of their scale range.

4 Test requirements

4.1 The control valve, with or without its actuator, must be complete before hydrostatic shell testing, except as permitted in 4.2, 4.3, 4.4, and 4.8.