


ANSI/ISA-77.44.02-2001



Fossil Fuel Power Plant Steam Temperature Control System — Once-Through Type



**ISA—The Instrumentation,
Systems, and
Automation Society**

Approved 23 January 2001

ANSI/ISA-77.44.02-2001
Fossil Fuel Power Plant Steam Temperature Control System —
Once-Through Type

ISBN: 1-55617-744-5

Copyright © 2001 by the Instrument Society of America. All rights reserved. Not for resale. Printed in the United States of America. No part of this publication may be reproduced, stored in a retrieval system, or transmitted, in any form or by any means (electronic, mechanical, photocopying, recording, or otherwise), without the prior written permission of the Publisher.

ISA
67 Alexander Drive
P.O. Box 12277
Research Triangle Park, North Carolina 27709
USA

Preface

This preface, as well as all footnotes and annexes, is included for information purposes and is not part of ANSI/ISA-77.44.02-2001.

The standards referenced within this document may contain provisions which, through reference in this text, constitute requirements of this document. At the time of publication, the editions indicated were valid. All standards are subject to revision, and parties to agreements based on this document are encouraged to investigate the possibility of applying the most recent editions of the standards indicated within this document. Members of IEC and ISO maintain registers of currently valid International Standards. ANSI maintain registers of currently valid U.S. National Standards.

This document has been prepared as part of the service of ISA—The Instrumentation, Systems, and Automation Society, toward a goal of uniformity in the field of instrumentation. To be of real value, this document should not be static but should be subject to periodic review. Toward this end, the Society welcomes all comments and criticisms and asks that they be addressed to the Secretary, Standards and Practices Board; ISA; 67 Alexander Drive; P. O. Box 12277; Research Triangle Park, NC 27709; Telephone (919) 549-8411; Fax (919) 549-8288; E-mail: standards@isa.org.

The ISA Standards and Practices Department is aware of the growing need for attention to the metric system of units in general, and the International System of Units (SI) in particular, in the preparation of instrumentation standards. The Department is further aware of the benefits to USA users of ISA standards of incorporating suitable references to the SI (and the metric system) in their business and professional dealings with other countries. Toward this end, this Department will endeavor to introduce SI-acceptable metric units in all new and revised standards, recommended practices, and technical reports to the greatest extent possible. *Standard for Use of the International System of Units (SI): The Modern Metric System*, published by the American Society for Testing & Materials as IEEE/ASTM SI 10-97, and future revisions, will be the reference guide for definitions, symbols, abbreviations, and conversion factors.

It is the policy of ISA to encourage and welcome the participation of all concerned individuals and interests in the development of ISA standards, recommended practices, and technical reports. Participation in the ISA standards-making process by an individual in no way constitutes endorsement by the employer of that individual, of ISA, or of any of the standards, recommended practices, and technical reports that ISA develops.

CAUTION — ISA ADHERES TO THE POLICY OF THE AMERICAN NATIONAL STANDARDS INSTITUTE WITH REGARD TO PATENTS. IF ISA IS INFORMED OF AN EXISTING PATENT THAT IS REQUIRED FOR USE OF THE STANDARD, IT WILL REQUIRE THE OWNER OF THE PATENT TO EITHER GRANT A ROYALTY-FREE LICENSE FOR USE OF THE PATENT BY USERS COMPLYING WITH THE STANDARD OR A LICENSE ON REASONABLE TERMS AND CONDITIONS THAT ARE FREE FROM UNFAIR DISCRIMINATION.

EVEN IF ISA IS UNAWARE OF ANY PATENT COVERING THIS STANDARD, THE USER IS CAUTIONED THAT IMPLEMENTATION OF THE STANDARD MAY REQUIRE USE OF TECHNIQUES, PROCESSES, OR MATERIALS COVERED BY PATENT RIGHTS. ISA TAKES NO POSITION ON THE EXISTENCE OR VALIDITY OF ANY PATENT RIGHTS THAT MAY BE INVOLVED IN IMPLEMENTING THE STANDARD. ISA IS NOT RESPONSIBLE FOR IDENTIFYING ALL PATENTS THAT MAY REQUIRE A LICENSE BEFORE IMPLEMENTATION OF THE STANDARD OR FOR INVESTIGATING THE VALIDITY OR SCOPE OF ANY PATENTS BROUGHT TO ITS ATTENTION. THE USER SHOULD CAREFULLY INVESTIGATE RELEVANT PATENTS BEFORE USING THE STANDARD FOR THE USER'S INTENDED APPLICATION.

HOWEVER, ISA ASKS THAT ANYONE REVIEWING THIS STANDARD WHO IS AWARE OF ANY PATENTS THAT MAY IMPACT IMPLEMENTATION OF THE STANDARD NOTIFY THE ISA STANDARDS AND PRACTICES DEPARTMENT OF THE PATENT AND ITS OWNER.

ADDITIONALLY, THE USE OF THIS STANDARD MAY INVOLVE HAZARDOUS MATERIALS, OPERATIONS OR EQUIPMENT. THE STANDARD CANNOT ANTICIPATE ALL POSSIBLE APPLICATIONS OR ADDRESS ALL POSSIBLE SAFETY ISSUES ASSOCIATED WITH USE IN HAZARDOUS CONDITIONS. THE USER OF THIS STANDARD MUST EXERCISE SOUND PROFESSIONAL JUDGMENT CONCERNING ITS USE AND APPLICABILITY UNDER THE USER'S PARTICULAR CIRCUMSTANCES. THE USER MUST ALSO CONSIDER THE APPLICABILITY OF ANY GOVERNMENTAL REGULATORY LIMITATIONS AND ESTABLISHED SAFETY AND HEALTH PRACTICES BEFORE IMPLEMENTING THIS STANDARD.

The following people served as members of ISA Subcommittee SP77.44:

NAME	COMPANY
D. Lee, Chairman	ABB Automation Inc.
W. Holland, Managing Director	Southern Company
L. Altcheh	Israel Electric Corporation
D. Christopher	Reliant Energy
D. Crow*	TXU
D. Fitzgerald	Foster Wheeler Energy Corporation
J. Glegg	Central & South West
R. Hubby	Consultant
G. Kumar	Fichtner Consulting Engineers
J. Lee	Korea Electric Power Company
G. McFarland	Honeywell Inc.
R. McSpadden	Vision Controls Company
R. Papilla	Southern California Edison Company
L. Rawlings	Babcock & Wilcox
D. Roney	Raytheon Engineers & Constructors
M. Skoncey	Duquesne Light Company
C. Taft	Electric Power Research Institute
J. Vavrek	Sargent & Lundy Inc.
D. Wade*	TXU

The following served as members of the ISA SP77 Committee:

NAME	COMPANY
W. Holland, Managing Director	Southern Company
E. Adamson	Stone & Webster, Inc.
L. Altcheh	Israel Electric Corporation
S. Alvarez	Compania Inspeccion Mexicana
J. Batug	Pennsylvania Power & Light Company
L. Broeker	PSI Energy
Q. Chou	Consultant
D. Christopher	Reliant Energy

* One vote per company.

D. Crow	TXU
F. Cunningham	Swagelock Company
G. Davis	Duke Power Company
D. Foreman	Brown & Root Energy Services
W. Fryman	Illinois Power Company
K. Gabel	Centerior Energy
A. Gile	Potomac Electric Power Company
R. Hicks*	Black & Veatch
R. Hubby	Consultant
R. Johnson	Sargent & Lundy Engineers
J. Kennard	Ontario Hydro
J. Kling*	Black & Veatch
G. Kumar	Fichtner Consulting Engineers
D. Lee	ABB Automation Inc.
W. Matz	Foxboro Company
G. McFarland*	Honeywell Inc.
R. McSpadden	Vision Controls Company
G. Mookerjee	Detroit Edison Company
N. Obleton*	Honeywell Inc.
R. Papilla	Southern California Edison Company
G. Ramachandran	Cytec Industries Inc.
L. Rawlings	Babcock & Wilcox
D. Roney	Raytheon Engineers & Constructors
R. Roop	Hoosier Energy Inc.
A. Schager	Vitec Inc.
T. Stevenson	Baltimore Gas & Electric Company
C. Taft*	Electric Power Research Institute
D. Tennant	International Applied Engineering
B. Traylor	Instrument Control Service
J. Weiss*	Electric Power Research Institute
D. Younie*	Woodward Global Services
F. Zikas	Parker Hannifin Corporation
T. Zuvlis*	Woodward Global Services

This standard was approved for publication by the ISA Standards and Practices Board on 11 January 2001.

NAME

COMPANY

H. Dammeyer	The Ohio State University
H. Baumann	H. D. Baumann, Inc.
D. Bishop	Chevron Petroleum Technology Co.
P. Brett	Honeywell, Inc.
M. Cohen	Senior Flexonics, Inc.
M. Coppler	Ametek, Inc.
W. Holland	Southern Company
A. Iverson	Ivy Optiks
R. Jones	Dow Chemical Co.
V. Maggioli	Feltronics Corp.
T. McAviney	Instrumentation & Control Engineering LLC

* One vote per company.

A. McCauley, Jr.
G. McFarland
R. Reimer
J. Rennie
R. Webb
W. Weidman
J. Weiss
J. Whetstone
M. Widmeyer
R. Wiegler
C. Williams
G. Wood
M. Zielinski

Chagrin Valley Controls, Inc.
Honeywell, Inc.
Rockwell Automation
Factory Mutual Research Corp.
Altran Corp.
Parsons Energy & Chemicals Group
EPRI
National Inst. of Standards & Technology
EG&G
CANUS Corp.
Eastman Kodak Co.
Graeme Wood Consulting
Fisher-Rosemount Systems, Inc.

Contents

1 Purpose	9
2 Scope	9
3 Definitions.....	9
4 Minimum design requirements for a superheat steam temperature control system.....	11
4.1 Process measurement requirements	11
4.2 Control and logic requirements	13
4.3 Final control element requirements.....	16
4.4 System reliability and availability.....	17
4.5 Minimum alarm requirements.....	17
4.6 Operator interface	17
5 Minimum design requirements for a reheat steam temperature.....	18
5.1 Process measurement requirement.....	18
5.2 Control and logic requirements	18
5.3 Final control element requirements.....	21
5.4 System reliability and availability.....	21
5.5 Minimum alarm requirements.....	21
5.6 Operator interface	22
Annex A — References	23
Annex B — Steam Temperature Control.....	25
Annex C — Figures	31

This page intentionally left blank.

1 Purpose

The purpose of this standard is to establish the minimum requirements for the functional design specification of steam temperature control systems for once-through type fossil fuel power plant boilers.

2 Scope

The scope of this standard addresses the major steam temperature control subsystems in once-through boilers with steaming capacities of 200,000 lb/hr (25 kg/s) or greater. These subsystems include, but are not limited to, superheat temperature control and reheat temperature control. Specifically excluded from consideration are turbine bypass control, motor control logic, combustion control, sootblower control, and controls associated with fluidized bed- and stoker-fired furnace combustion units.

3 Definitions

The following definitions are provided to clarify their use in this standard and may not be relevant to the user of the words in other texts. For other definitions, please refer to ANSI/ISA-S51.1-1979 (R1993) Process Instrumentation Terminology.

3.1 attemperator:

mechanical device used for maintaining and controlling the temperature of superheated steam.

3.2 attemperator (direct contact type):

mechanical device in which the steam and the cooling medium (water) are mixed.

3.3 boiler:

the entire vessel in which steam or other vapor is generated for use external to the vessel. This includes the furnace, consisting of waterwall tubes; the firebox area, including burners and dampers; the convection area, consisting of any superheater, reheater, economizer sections or any combination thereof, as well as drums and headers.

3.4 cascade control system:

a control system in which the output of one controller (the outer loop) is the setpoint for another controller (the inner loop). The outer loop is normally a slow responding process as compared to the inner loop.

3.5 control:

maintaining a desired setpoint of steam temperature during operation.

3.6 control loop:

a combination of field devices and control functions arranged so that a control variable is compared to a setpoint and returns to the process in the form of a manipulated variable.

3.7 controller:

a manual or automatic device or system of devices used to regulate the boiler steam temperatures within defined parameters as set forth by a turbine/boiler manufacturer.

3.8 desuperheater:

see 3.2 attemperator (direct contact type).

3.9 deviation:

the difference between the loop setpoint and the process variable.

3.10 error:

see 3.9 deviation.