


**ANSI/ISA–S77.42.01–1999**



**Fossil Fuel Power Plant  
Feedwater Control System —  
Drum Type**



**Approved 15 March 2000**

ISA-S77.42.01-1999  
Fossil Fuel Power Plant Feedwater Control System — Drum Type

ISBN: 1-55617-717-8

Copyright © 1999 by the Instrument Society of America. All rights reserved. Not for resale. Printed in the United States of America. No part of this publication may be reproduced, stored in a retrieval system, or transmitted, in any form or by any means (electronic, mechanical, photocopying, recording, or otherwise), without the prior written permission of the Publisher.

ISA  
67 Alexander Drive  
P.O. Box 12277  
Research Triangle Park, North Carolina 27709

## Preface

This preface, as well as all footnotes and annexes, is included for information purposes and is not part of ISA-S77.42.01.

This document has been prepared as part of the service of ISA, the international society for measurement and control, toward a goal of uniformity in the field of instrumentation. To be of real value, this document should not be static but should be subject to periodic review. Toward this end, the Society welcomes all comments and criticisms and asks that they be addressed to the Secretary, Standards and Practices Board; ISA; 67 Alexander Drive; P. O. Box 12277; Research Triangle Park, NC 27709; Telephone (919) 549-8411; Fax (919) 549-8288; E-mail: standards@isa.org.

The ISA Standards and Practices Department is aware of the growing need for attention to the metric system of units in general, and the International System of Units (SI) in particular, in the preparation of instrumentation standards. The Department is further aware of the benefits to USA users of ISA standards of incorporating suitable references to the SI (and the metric system) in their business and professional dealings with other countries. Toward this end, this Department will endeavor to introduce SI-acceptable metric units in all new and revised standards, recommended practices, and technical reports to the greatest extent possible. *Standard for Use of the International System of Units (SI): The Modern Metric System*, published by the American Society for Testing & Materials as IEEE/ASTM SI 10-97, and future revisions, will be the reference guide for definitions, symbols, abbreviations, and conversion factors.

Certain metric units that are not a part of the SI system are in common accepted use. This document uses *bar* as a pressure measurement that is convertible to kilopascals by multiplying by 100. Functional drawings in the annex are provided using established power industry conventions.

It is the policy of ISA to encourage and welcome the participation of all concerned individuals and interests in the development of ISA standards, recommended practices, and technical reports. Participation in the ISA standards-making process by an individual in no way constitutes endorsement by the employer of that individual, of ISA, or of any of the standards, recommended practices, and technical reports that ISA develops.

This document is part of a series of standards developed by ISA's SP77.40 Committee, Boiler Controls, under the direction of the SP77 Committee, Fossil Power Plant Standards. It should be used in conjunction with the other SP77 series of standards for safe, reliable, and efficient design, construction, operation, and maintenance of fossil-fired power plants. It is not intended that this document establish any procedures or practices that are contrary to any other standard in this series.

A variety of feedwater control systems have been developed and used over the years to maintain drum level within limits and at the required setpoint. This document is intended to establish minimum requirements for steam temperature control.

**CAUTION — ISA ADHERES TO THE POLICY OF THE AMERICAN NATIONAL STANDARDS INSTITUTE WITH REGARD TO PATENTS. IF ISA IS INFORMED OF AN EXISTING PATENT THAT IS REQUIRED FOR USE OF THE STANDARD, IT WILL REQUIRE THE OWNER OF THE PATENT TO EITHER GRANT A ROYALTY-FREE LICENSE FOR USE OF THE PATENT BY USERS COMPLYING WITH THE STANDARD OR A LICENSE ON REASONABLE TERMS AND CONDITIONS THAT ARE FREE FROM UNFAIR DISCRIMINATION.**

**EVEN IF ISA IS UNAWARE OF ANY PATENT COVERING THIS STANDARD, THE USER IS CAUTIONED THAT IMPLEMENTATION OF THE STANDARD MAY REQUIRE USE OF TECHNIQUES, PROCESSES, OR MATERIALS COVERED BY PATENT RIGHTS. ISA TAKES NO POSITION ON THE EXISTENCE OR VALIDITY OF ANY PATENT RIGHTS THAT MAY BE INVOLVED IN IMPLEMENTING**

**THE STANDARD. ISA IS NOT RESPONSIBLE FOR IDENTIFYING ALL PATENTS THAT MAY REQUIRE A LICENSE BEFORE IMPLEMENTATION OF THE STANDARD OR FOR INVESTIGATING THE VALIDITY OR SCOPE OF ANY PATENTS BROUGHT TO ITS ATTENTION. THE USER SHOULD CAREFULLY INVESTIGATE RELEVANT PATENTS BEFORE USING THE STANDARD FOR THE USER'S INTENDED APPLICATION.**

**HOWEVER, ISA ASKS THAT ANYONE REVIEWING THIS STANDARD WHO IS AWARE OF ANY PATENTS THAT MAY IMPACT IMPLEMENTATION OF THE STANDARD NOTIFY THE ISA STANDARDS AND PRACTICES DEPARTMENT OF THE PATENT AND ITS OWNER.**

**ADDITIONALLY, THE USE OF THIS STANDARD MAY INVOLVE HAZARDOUS MATERIALS, OPERATIONS OR EQUIPMENT. THE STANDARD CANNOT ANTICIPATE ALL POSSIBLE APPLICATIONS OR ADDRESS ALL POSSIBLE SAFETY ISSUES ASSOCIATED WITH USE IN HAZARDOUS CONDITIONS. THE USER OF THIS STANDARD MUST EXERCISE SOUND PROFESSIONAL JUDGMENT CONCERNING ITS USE AND APPLICABILITY UNDER THE USER'S PARTICULAR CIRCUMSTANCES. THE USER MUST ALSO CONSIDER THE APPLICABILITY OF ANY GOVERNMENTAL REGULATORY LIMITATIONS AND ESTABLISHED SAFETY AND HEALTH PRACTICES BEFORE IMPLEMENTING THIS STANDARD.**

The following people served as members of ISA Subcommittee SP77.42:

<b>NAME</b>	<b>COMPANY</b>
G. McFarland, Chairman*	Honeywell Industrial Inc.
W. Holland, Managing Director	Southern Company
S. Alvarez	Compania Inspeccion Mexicana
D. Crow	TXU
G. Davis	Duke Power Company
R. Eng	Foster Wheeler Energy Corporation
H. Foreman	Brown & Root Energy Services
R. Hubby	Consultant
D. Lee	ABB Automation Inc.
R. McSpadden	Vision Controls Company
G. Mockerjee	U.S. Department of Energy
T. New	Leeds & Northrup
R. Roop	Hoosier Energy Inc.
J. Rovnak	Stone & Webster Engineering Corporation
T. Russell*	Honeywell, Inc.
C. Skidmore	Consultant
R. Spellman	Westinghouse Electric Corporation
T. Toms	Carolina Power & Light Company
B. Traylor	GE ICS

The following served as members of ISA Subcommittee SP77.40:

<b>NAME</b>	<b>COMPANY</b>
G. McFarland, Chairman	Honeywell Inc.
W. Holland, Managing Director	Southern Company
E. Adamson	The Foxboro Company

\* One vote per company.

S. Alvarez	Compania de Inspeccion Mexicana
D. Crow	TXU
R. Eng	Foster Wheeler Energy Corporation
H. Foreman	Brown & Root Energy Services
R. Hubby	Consultant
D. Lee	ABB Automation Inc.
R. McSpadden	Vision Controls Company
G. Mookerjee	U.S. Department of Energy
C. Taft	EPRI
B. Traylor	GE ICS

The following served as members of the ISA SP77 Committee:

<b>NAME</b>	<b>COMPANY</b>
W. Holland, Managing Director	Southern Company
L. Altcheh	Israel Electric Corporation
S. Alvarez	Compania Inspeccion Mexicana
J. Batug	Pennsylvania Power & Light Inc.
L. Broeker	PSI Energy
Q. Chou	Consultant
D. Christopher	Reliant Energy
D. Crow	TXU
F. Cunningham	Swagelok Company
G. Davis	Duke Power Company
H. Foreman	Brown & Root Energy Services
W. Fryman	Illinois Power Company
A. Gile	Potomac Electric Power Company
R. Hicks	Black & Veatch
R. Hubby	Consultant
R. Johnson	Sargent & Lundy Engineers
J. Kennard	Ontario Hydro
D. Lee	ABB Automation Inc.
W. Matz	The Foxboro Company
G. McFarland*	Honeywell Inc.
G. Mookerjee	U.S. Department of Energy
N. Obleton*	Honeywell, Inc.
R. Papilla	Southern California Edison Company
G. Ramachandran	Cytec Industries, Inc.
L. Rawlings	Babcock & Wilcox
D. Roney	Raytheon Engineers & Constructors, Inc.
R. Roop	Hoosier Energy, Inc.
T. Russell*	Honeywell, Inc.
A. Schager	Vitec Inc.
C. Skidmore	Consultant
T. Stevenson	Baltimore Gas & Electric Company
C. Taft*	EPRI
D. Tennant	International Applied Engineering
B. Traylor	GE ICS

\* One vote per company.

J. Weiss*	EPRI
D. Younnie*	Woodward Global Services
T. Zuvlis*	Woodward Governor Company

This standard was approved for publication by the ISA Standards and Practices Board on 15 December 1999.

**NAME**

**COMPANY**

H. Dammeyer	The Ohio State University
H. Baumann	H. D. Baumann, Inc.
D. Bishop	Vastar Resources Inc.
P. Brett	Honeywell, Inc.
M. Cohen	Senior Flexonics, Inc.
M. Coppler	Ametek, Inc.
W. Holland	Southern Company
A. Iverson	Ivy Optiks
R. Jones	Dow Chemical Co.
V. Maggioli	Feltronics Corp.
T. McAviney	Instrumentation & Control Engineering LLC
A. McCauley, Jr.	Chagrin Valley Controls, Inc.
G. McFarland	Honeywell, Inc.
R. Reimer	Rockwell Automation
J. Rennie	Factory Mutual Research Corp.
R. Webb	Altran Corp.
W. Weidman	Parsons Energy & Chemicals Group
J. Weiss	EPRI
J. Whetstone	National Institute of Standards & Technology
M. Widmeyer	EG&G
R. Wiegler	CANUS Corp.
C. Williams	Eastman Kodak Co.
G. Wood	Graeme Wood Consulting
M. Zielinski	Fisher-Rosemount Systems, Inc.

---

\* One vote per company.

## CONTENTS

1 Scope .....	9
2 Purpose .....	9
3 Definitions.....	9
4 Minimum design requirements for a feedwater control system .....	11
4.1 Process measurement requirements .....	11
4.2 Control and logic requirements .....	12
4.3 Final control device requirements .....	17
4.4 System reliability and availability.....	17
4.5 Minimum alarm requirements.....	17
4.6 Operator interface .....	17
Annex A — References .....	19
Annex B — Feedwater control.....	21

This is a preview of "ANSI/ISA S77.42.01-1...". [Click here to purchase the full version from the ANSI store.](#)

This page intentionally left blank.

## 1 Scope

The standard is intended to assist in the development of design specifications covering the measurement and control of feedwater systems in boilers with steaming capacities of 200,000 lb/h (25 kg/s) or greater. The safe physical containment of the feedwater shall be in accordance with applicable piping codes and standards and is beyond the scope of this standard.

## 2 Purpose

The purpose of this standard is to establish the minimum criteria for the control of levels, pressures, and flow for the safe and reliable operation of drum-type feedwater systems in fossil power plants.

## 3 Definitions

### 3.1 boiler:

the entire vessel in which steam or other vapor is generated for use external to itself, including the furnace, consisting of the following: water wall tubes; the firebox area, including burners and dampers; and the convection area, consisting of any superheater, reheater, and/or economizer sections, as well as drums and headers.

### 3.2 cascade control:

a control action in which the output of one controller is the setpoint for another controller.

### 3.3 controller:

any manual or automatic device or system of devices for the regulation of boiler systems to keep the boiler at normal operation. If automatic, the device or system is motivated by variations in temperature, pressure, water level, time, flow, or other influences.

### 3.4 drum (steam):

a closed vessel designed to withstand internal pressure. A device for collecting and separating the steam/water mixture circulated through the boiler.

### 3.5 feedwater flow control system:

a control system that uses input signals derived from the process for the purpose of regulating feedwater flow to the boiler to maintain adequate drum level according to the manufacturer's recommendations.

### 3.6 mass feedwater flow rate:

the mass flow rate of all water delivered to the boiler; it is derived either from direct process measurements and/or calculations from other parameters. When volumetric feedwater flow rate measurement techniques are employed and the feedwater temperature at the flow-measuring element varies 100°F (37.8°C), the measured (indicated) flow shall be compensated for flowing feedwater density to determine the true mass feedwater flow rate.

### 3.7 mass steam flow rate:

the mass flow rate of steam from the boiler, derived either from direct process measurements and/or calculations from other parameters. If volumetric steam flow-rate measuring techniques are employed, the measured (indicated) flow shall be compensated for flowing steam density to determine the true mass steam flow rate.

### 3.8 primary/secondary control loop controller:

the controller that adjusts the setpoint for the secondary control loop controller in the cascade control action scheme.