

**ANSI/ISA-TR12.12.04-2011
(formerly ISA-TR12.06.01-1999)
ANSI Technical Report prepared by ISA**

**Electrical Equipment in a Class I,
Division 2/Zone 2 Hazardous Location**

Approved 20 June 2011

ANSI/ISA-TR12.12.04-2011 (formerly ISA-TR12.06.01-1999), Electrical Equipment in a Class I, Division 2/Zone 2 Hazardous Location

ISBN: 978-1-936007-95-0

Copyright ©.2011 by the International Society of Automation. All rights reserved. Printed in the United States of America. No part of this publication may be reproduced, stored in a retrieval system, or transmitted, in any form or by any means (electronic, mechanical, photocopying, recording, or otherwise), without the prior written permission of the Publisher.

ISA
67 Alexander Drive
P.O. Box 12277
Research Triangle Park, North Carolina 27709

Preface

This preface, as well as all footnotes and annexes, is included for information purposes and is not part of ANSI/ISA-TR12.12.04-2011.

This document has been prepared as part of the service of ISA toward a goal of uniformity in the field of instrumentation. To be of real value, this document should not be static but should be subject to periodic review. Toward this end, the Society welcomes all comments and criticisms and asks that they be addressed to the Secretary, Standards and Practices Board; ISA; 67 Alexander Drive; P. O. Box 12277; Research Triangle Park, NC 27709; Telephone (919) 549-8411; Fax (919) 549-8288; E-mail: standards@isa.org.

The ISA Standards and Practices Department is aware of the growing need for attention to the metric system of units in general, and the International System of Units (SI) in particular, in the preparation of instrumentation standards. The Department is further aware of the benefits to USA users of ISA standards of incorporating suitable references to the SI (and the metric system) in their business and professional dealings with other countries. Toward this end, this Department will endeavor to introduce SI-acceptable metric units in all new and revised standards, recommended practices, and technical reports to the greatest extent possible. *Standard for Use of the International System of Units (SI): The Modern Metric System*, published by the American Society for Testing & Materials as IEEE/ASTM SI 10-97, and future revisions, will be the reference guide for definitions, symbols, abbreviations, and conversion factors.

It is the policy of ISA to encourage and welcome the participation of all concerned individuals and interests in the development of ISA standards, recommended practices, and technical reports. Participation in the ISA standards-making process by an individual in no way constitutes endorsement by the employer of that individual, of ISA, or of any of the standards, recommended practices, and technical reports that ISA develops.

CAUTION — ISA DOES NOT TAKE ANY POSITION WITH RESPECT TO THE EXISTENCE OR VALIDITY OF ANY PATENT RIGHTS ASSERTED IN CONNECTION WITH THIS DOCUMENT, AND ISA DISCLAIMS LIABILITY FOR THE INFRINGEMENT OF ANY PATENT RESULTING FROM THE USE OF THIS DOCUMENT. USERS ARE ADVISED THAT DETERMINATION OF THE VALIDITY OF ANY PATENT RIGHTS, AND THE RISK OF INFRINGEMENT OF SUCH RIGHTS, IS ENTIRELY THEIR OWN RESPONSIBILITY.

PURSUANT TO ISA'S PATENT POLICY, ONE OR MORE PATENT HOLDERS OR PATENT APPLICANTS MAY HAVE DISCLOSED PATENTS THAT COULD BE INFRINGED BY USE OF THIS DOCUMENT AND EXECUTED A LETTER OF ASSURANCE COMMITTING TO THE GRANTING OF A LICENSE ON A WORLDWIDE, NON-DISCRIMINATORY BASIS, WITH A FAIR AND REASONABLE ROYALTY RATE AND FAIR AND REASONABLE TERMS AND CONDITIONS. FOR MORE INFORMATION ON SUCH DISCLOSURES AND LETTERS OF ASSURANCE, CONTACT ISA OR VISIT WWW.ISA.ORG/STANDARDSPATENTS.

OTHER PATENTS OR PATENT CLAIMS MAY EXIST FOR WHICH A DISCLOSURE OR LETTER OF ASSURANCE HAS NOT BEEN RECEIVED. ISA IS NOT RESPONSIBLE FOR IDENTIFYING PATENTS OR PATENT APPLICATIONS FOR WHICH A LICENSE MAY BE REQUIRED, FOR CONDUCTING INQUIRIES INTO THE LEGAL VALIDITY OR SCOPE OF PATENTS, OR DETERMINING WHETHER ANY LICENSING TERMS OR CONDITIONS PROVIDED IN CONNECTION WITH SUBMISSION OF A LETTER OF ASSURANCE, IF ANY, OR IN ANY LICENSING AGREEMENTS ARE REASONABLE OR NON-DISCRIMINATORY.

ISA REQUESTS THAT ANYONE REVIEWING THIS DOCUMENT WHO IS AWARE OF ANY PATENTS THAT MAY IMPACT IMPLEMENTATION OF THE DOCUMENT NOTIFY THE ISA STANDARDS AND PRACTICES DEPARTMENT OF THE PATENT AND ITS OWNER.

ADDITIONALLY, THE USE OF THIS DOCUMENT MAY INVOLVE HAZARDOUS MATERIALS, OPERATIONS OR EQUIPMENT. THE DOCUMENT CANNOT ANTICIPATE ALL POSSIBLE APPLICATIONS OR ADDRESS ALL POSSIBLE SAFETY ISSUES ASSOCIATED WITH USE IN HAZARDOUS CONDITIONS. THE USER OF THIS DOCUMENT MUST EXERCISE SOUND PROFESSIONAL JUDGMENT CONCERNING ITS USE AND APPLICABILITY UNDER THE USER'S PARTICULAR CIRCUMSTANCES. THE USER MUST ALSO CONSIDER THE APPLICABILITY OF ANY GOVERNMENTAL REGULATORY LIMITATIONS AND ESTABLISHED SAFETY AND HEALTH PRACTICES BEFORE IMPLEMENTING THIS DOCUMENT.

THE USER OF THIS DOCUMENT SHOULD BE AWARE THAT THIS DOCUMENT MAY BE IMPACTED BY ELECTRONIC SECURITY ISSUES. THE COMMITTEE HAS NOT YET ADDRESSED THE POTENTIAL ISSUES IN THIS VERSION.

The following people served as members of ISA Subcommittee ISA12.12:

NAME	COMPANY
R. Masek, Chair	CSA International
M. Coppler, Managing Director	Ametek Inc.
N. Abbatiello	Speer Equipment Inc.
R. Allen	Honeywell Inc.
S. Arnold	Ametek Drexelbrook
A. Ballard	Cooper Crouse-Hinds
W. Bennett	Mine Safety Appliances Co.
W. Berner	R Stahl Inc.
S. Blais	EGS Electrical Group
K. Boegli	Phoenix Contact
J. Bossert	Hazloc Inc.
S. Czaniecki	Intrinsic Safety Concepts Inc.
J. Dolphin	PSC Solutions
A. Engler	Det Norske Veritas DNV
G. Garcha	GE Energy
P. Hamer	Chevron Energy Tech. Co.
D. Hohenstein	Pepperl+Fuchs Inc.
P. Kelly	Underwriters Laboratories
G. Kozinski	GE Infrastructure Sensing
J. Kuczka	Killark
C. Kurtzman	Rosemount Inc.
B. Larson	Turck Inc.
W. Lawrence	FM Approvals LLC
E. Leubner	Cooper Crouse-Hinds
N. Ludlam	FM Approvals Ltd.
K. Mansoor	Siemens Industry Inc.
E. Massey	Baldor Electric Company
J. McCormick	Bently Nevada LLC
J. Miller	Detector Electronics Corporation
J. Oudar	ExLoc Corporation
D. Wechsler	Dow Chemical Company
R. Wigg	E-x Solutions International Pty. Ltd.

The following people served as members of ISA Committee ISA12:

NAME	COMPANY
T. Schnaare, Chair	Rosemount Inc.
W. Lawrence, Vice Chair	FM Approvals LLC
M. Coppler, Managing Director	Ametek Inc.
N. Akhtar	AF Technologies Inc.
D. Ankele	Underwriters Laboratories Inc.
R. Batra	Chevron Corporation
K. Boegli	Phoenix Contact
D. Burns	Shell P&T – Innovation / R&D
C. Casso	Nabors Industries
J. Dolphin	PSC Solutions
M. Dona	Santos Ltd.
T. Dubaniewicz	NIOSH
A. Engler	Det Norske Veritas DNV
W. Fiske	Intertek
G. Garcha	GE Energy
D. Jagger	Bifold-Fluid Power
J. Jonscher	Adalet PLM
F. Kent	Honeywell Inc.
P. Kovscek	Industrial Scientific Corp.
J. Kuczka	Killark
E. Leubner	Cooper Crouse-Hinds
S. Leverington	Zone Safe Solutions
N. Ludlam	FM Approvals Ltd.
K. Mansoor	Siemens Industry Inc.
R. Masek	CSA International
E. Massey	Baldor Electric Co.
J. Miller	Detector Electronics Corp.
A. Page	Consultant
R. Seitz	Artech Engineering
R. Sierra	USCG
M. Spencer	Columbia Gas Transmission
J. Thomas	Schlumberger
D. Wechsler	Dow Chemical Co.
R. Wigg	E-x Solutions International Pty. Ltd.

This recommended practice was approved for publication by the ISA Standards and Practices Board on 12 April 2011.

NAME	COMPANY
D. Dunn, S&P Department VP	Aramco Services Co.
R. Bartusiak	ExxonMobil Research & Engineering
P. Brett	Honeywell Inc.
J. Campbell	ConocoPhillips
M. Coppler	Ametek Inc.
E. Cosman	The Dow Chemical Company
B. Dumortier	Schneider Electric
J. Federlein	Federlein & Associates Inc.
J. Gilsinn	NIST/MEL
E. Icyan	ACES Inc.
J. Jamison	EnCana Corporation Ltd.
K. P. Lindner	Endress + Hauser Process Solutions AG
V. Maggioli	Feltronics Corp.
T. McAvinew	Jacobs Engineering

R. Reimer
S. Russell
N. Sands
H. Sasajima
T. Schnaare
J. Tatera
I. Verhappen
R. Webb
W. Weidman
J. Weiss
M. Widmeyer
M. Wilkins
D. Zetterberg

Rockwell Automation
Valero Energy Corp.
DuPont
Yamatake Corp.
Rosemount Inc.
Tatera & Associates Inc.
Industrial Automation Networks Inc.
ICS Secure LLC
Consultant
Applied Control Solutions LLC
Kahler Engineering Inc.
Yokogawa IA Global Marketing
Chevron Energy Technology Company

CONTENTS

Foreword.....	9
1 Introduction.....	11
2 Hazardous locations.....	11
2.1 General.....	11
2.2 Class	11
2.3 Division.....	12
2.4 Group (Division system)	12
2.5 Zone	12
2.6 Group (Zone system).....	12
2.7 Temperature classification.....	13
3 The nonincendive equipment concept	13
3.1 General.....	13
4 Nonincendive and non-sparking terminology	14
4.1 Nonincendive	14
4.2 Type of protection "n"	15
5 Related terminology	17
6 General design requirements.....	18
7 Field wiring	19
8 Maintenance	20
9 References	20

This page intentionally left blank.

Foreword

Publication of this Registered Technical Report has been approved by ISA. This document is registered as a Technical Report series of publications according to the procedures for the Registration of Technical Reports with ANSI. This document is not an American National Standard and the material contained herein is not normative in nature. Comments on the content of this document should be sent to ISA; 67 Alexander Drive; P. O. Box 12277; Research Triangle Park, NC 27709.

This page intentionally left blank.

1 Introduction

When electrical equipment is used in locations in which fire or explosion hazards may exist due to flammable gases or vapours, flammable liquids, combustible dust, or ignitable fibers or flyings, the National Electrical Code[®] (NEC[®]), ANSI/NFPA 70 requires special precautions to be taken in equipment construction and installation to minimize risks of fire and explosions. There are several protection techniques in common use, each of which has its own set of advantages and disadvantages. Other countries, including Canada, utilize varying wiring methods, so the contents of this report may not be applicable to countries other than the United States.

A location in which the fire or explosion hazard exists infrequently and for short periods is designated as a Division 2 or Zone 2 location. Two of the primary protection techniques for Division 2 or Zone 2 locations are "Nonincendive equipment" or "Non-sparking equipment". This Technical Report is intended to explain these protection techniques and to clarify the associated terminology. This Technical Report also addresses field wiring for Division 2/Zone 2 locations.

Division 2 equipment is permitted to be marked and used in Zone 2 hazardous locations per the NEC[®], Section 505.9(C)(1).

Zone 2 equipment, in accordance with ANSI/ISA-60079-15, is permitted to be marked and used in Division 2 hazardous location per the NEC[®], Section 501.5.

The term "combustible material" will be used throughout this Technical Report to refer to materials mentioned above, i.e., flammable gases, flammable liquid produced vapours, or combustible liquid produced vapours. Similarly, the term "hazardous location" will be used in place of the phrase "hazardous (classified) location" used in the NEC[®] and in the product standards. Finally, although combustible materials pose a fire hazard, the primary concern is an explosion.

2 Hazardous locations

2.1 General

To understand this Technical Report, it is necessary to know the terminology associated with hazardous locations as defined in the NEC[®]. Although there are numerous hazards such as high voltages, carcinogens and moving objects, the term "hazardous locations" only refers to areas made hazardous by the presence of a combustible material that may create an explosion hazard when mixed with air.

A much fuller discussion of hazardous locations can be found in numerous publications, including ANSI/ISA-12.01.01, "Definitions and Information Pertaining to Electrical Apparatus in Hazardous (Classified) Locations." The following is provided as an overview. In some cases, terms have been defined in a simplified manner to ease understanding. There are four essential elements used to define a hazardous location in North America: Class, Division or Zone, Group, and Temperature Class.

2.2 Class

Hazardous locations are divided into three classes:

- Class I for flammable gases or vapours.