ANSI/ISA-84.00.01-2004 Part 3 (IEC 61511-3 Mod)

Functional Safety: Safety Instrumented Systems for the Process Industry Sector - Part 3: Guidance for the Determination of the Required Safety Integrity Levels - Informative



ISA–The Instrumentation, Systems, and Automation Society Approved 2 September 2004

ANSI/ISA-84.00.01-2004 Part 3 (IEC 61511-3 Mod) Functional safety: Safety Instrumented Systems for the process industry sector – Part 3: Guidance for the determination of the required safety integrity levels - informative

ISBN: 1-55617-921-9

Copyright © 2004 by ISA. All rights reserved. Not for resale. Printed in the United States of America. No part of this publication may be reproduced, stored in a retrieval system, or transmitted in any form or by any means (electronic, mechanical, photocopying, recording, or otherwise), without the prior written permission of the Publisher.

ISA 67 Alexander Drive P.O. Box 12277 Research Triangle Park, North Carolina 27709 USA

Preface

This preface, as well as all footnotes, is included for information purposes and is not part of ANSI/ISA-84.00.01-2004 Part 3 (IEC 61511-3 Mod).

This document has been prepared as part of the service of ISA – the Instrumentation, Systems, and Automation Society – toward a goal of uniformity in the field of instrumentation. To be of real value, this document should not be static but should be subject to periodic review. Toward this end, the Society welcomes all comments and criticisms and asks that they be addressed to the Secretary, Standards and Practices Board; ISA; 67 Alexander Drive; P. O. Box 12277; Research Triangle Park, NC 27709; Telephone (919) 549-8411; Fax (919) 549-8288; E-mail: standards@isa.org.

The ISA Standards and Practices Department is aware of the growing need for attention to the metric system of units in general, and the International System of Units (SI) in particular, in the preparation of instrumentation standards. The Department is further aware of the benefits to USA users of ISA standards of incorporating suitable references to the SI (and the metric system) in their business and professional dealings with other countries. Toward this end, this Department will endeavor to introduce SI-acceptable metric units in all new and revised standards, recommended practices, and technical reports to the greatest extent possible. *Standard for Use of the International System of Units (SI): The Modern Metric System*, published by the American Society for Testing & Materials as IEEE/ASTM SI 10-97, and future revisions, will be the reference guide for definitions, symbols, abbreviations, and conversion factors.

It is the policy of ISA to encourage and welcome the participation of all concerned individuals and interests in the development of ISA standards, recommended practices, and technical reports. Participation in the ISA standards-making process by an individual in no way constitutes endorsement by the employer of that individual, of ISA, or of any of the standards, recommended practices, and technical reports that ISA develops.

CAUTION — ISA ADHERES TO THE POLICY OF THE AMERICAN NATIONAL STANDARDS INSTITUTE WITH REGARD TO PATENTS. IF ISA IS INFORMED OF AN EXISTING PATENT THAT IS REQUIRED FOR USE OF THE STANDARD, IT WILL REQUIRE THE OWNER OF THE PATENT TO EITHER GRANT A ROYALTY-FREE LICENSE FOR USE OF THE PATENT BY USERS COMPLYING WITH THE STANDARD OR A LICENSE ON REASONABLE TERMS AND CONDITIONS THAT ARE FREE FROM UNFAIR DISCRIMINATION.

EVEN IF ISA IS UNAWARE OF ANY PATENT COVERING THIS STANDARD, THE USER IS CAUTIONED THAT IMPLEMENTATION OF THE STANDARD MAY REQUIRE USE OF TECHNIQUES, PROCESSES, OR MATERIALS COVERED BY PATENT RIGHTS. ISA TAKES NO POSITION ON THE EXISTENCE OR VALIDITY OF ANY PATENT RIGHTS THAT MAY BE INVOLVED IN IMPLEMENTING THE STANDARD. ISA IS NOT RESPONSIBLE FOR ALL PATENTS IDENTIFYING THAT MAY REQUIRE LICENSE BEFORE Α IMPLEMENTATION OF THE STANDARD OR FOR INVESTIGATING THE VALIDITY OR SCOPE OF ANY PATENTS BROUGHT TO ITS ATTENTION. THE USER SHOULD CAREFULLY INVESTIGATE RELEVANT PATENTS BEFORE USING THE STANDARD FOR THE USER'S INTENDED APPLICATION.

HOWEVER, ISA ASKS THAT ANYONE REVIEWING THIS STANDARD WHO IS AWARE OF ANY PATENTS THAT MAY IMPACT IMPLEMENTATION OF THE STANDARD NOTIFY THE ISA STANDARDS AND PRACTICES DEPARTMENT OF THE PATENT AND ITS OWNER. ADDITIONALLY, THE USE OF THIS STANDARD MAY INVOLVE HAZARDOUS MATERIALS, OPERATIONS OR EQUIPMENT. THE STANDARD CANNOT ANTICIPATE ALL POSSIBLE APPLICATIONS OR ADDRESS ALL POSSIBLE SAFETY ISSUES ASSOCIATED WITH USE IN -HAZARDOUS CONDITIONS. THE USER OF THIS STANDARD MUST EXERCISE SOUND PROFESSIONAL JUDGMENT CONCERNING ITS USE AND APPLICABILITY UNDER THE USER'S PARTICULAR CIRCUMSTANCES. THE USER MUST ALSO CONSIDER THE APPLICABILITY OF ANY GOVERNMENTAL REGULATORY

LIMITATIONS AND ESTABLISHED SAFETY AND HEALTH PRACTICES BEFORE IMPLEMENTING THIS STANDARD.

THE USER OF THIS DOCUMENT SHOULD BE AWARE THAT THIS DOCUMENT MAY BE IMPACTED BY ELECTRONIC SECURITY ISSUES. THE COMMITTEE HAS NOT YET ADDRESSED THE POTENTIAL ISSUES IN THIS VERSION.

The following people served as active members of ISA-SP84:

NAME

AFFILIATION

W. Johnson, Chair	E.I. DuPont
K. Bond, Managing Director	Consultant
R. Dunn, Recorder	DuPont Engineering
R. Adamski	Premier Consulting Services
B. Adler	AE Solutions
R. Bailliet	Syscon International Inc.
N. Battikha	BergoTech Inc.
L. Beckman	Safeplex Systems Inc.
J. Berge	SMAR Singapore Pte Ltd.
H. Bezecny	Dow Deutschland
D. Bolland	ExxonMobil Research & Engineering Co.
D. Brown	Emerson Process Management
S. Brown	E.I. DuPont
S. Brown	Health & Safety Executive
J. Campbell	ConocoPhillips
H. Cheddie	Bayer Inc.
W. Cohen	KBR
J. Cusimano	Siemens Energy & Automation, Inc.
K. Dejmek	Baker Engineering & Risk Consultants
A. Dowell	Rohm & Haas Co.
P. Early	Langdon Coffman Services
S. Gallagher	ConocoPhillips
L. Gamboa	Rockwell Automation Inc.
K. Gandhi	KBR
I. Gibson	Fluor Australia Pty Ltd
J. Gilman	JFG Technology Transfer LLC
W. Goble	Exida Com LLC
D. Green	Rohm & Haas Co.
R. Green	Green Associates
P. Gruhn	L&M Engineering
C. Hardin	CDH Consulting Inc.
J. Harris	UOP LLC
T. Hurst	Hurst Technologies Corp.
T. Jackson	Bechtel Corp.
J. Jamison	OPTI Canada Inc.
J. Jarvi	Automation Partners Oy
K. Klein	Solutia Inc.
R. Kotoski	Honeywell
L. Laskowski	Emerson Process Management
T. Layer	Emerson Process Management
V. Maggioli	Feltronics Corp.
E. Marszal	Kenexis
J. Martel	Invensys-Triconex
R. McCrea-Steele	Premier Consulting Services
N. McLeod	Atofina
M. Moderski	ABB Lummus Global Inc.
W. Mostia	WLM Engineering Company
R. Nelson	Celanese
D. Ogwude	Creative Systems International
L. Owen	Dooley Tackaberry, Inc.

R. Peterson	Lyondell Chemical Co.
G. Ramachandran	Systems Research International Inc.
G. Raney	Triconex Systems Inc.
G. Robertson	Oxy Information Technology
M. Scott	AE Solutions
R. Seitz	Artech Engineering
J. Siebert	Invista
B. Smith	Nova Chemicals
D. Sniezek	Lockheed Martin Federal Services
C. Sossman	WGI-W Safety Management Solutions
P. Stavrianidis	FM Approvals
R. Stevens	US Dept. of Energy
H. Storey	Shell Global Solutions
R. Strube	Intertek Testing Services NA, Inc.
A. Summers	SIS-Tech Solutions LLC
L. Suttinger	Westinghouse Savannah River Co.
W. Taggart	Waldemar S. Nelson & Co.
R. Taubert	BASF Corp.
H. Tausch	Honeywell Inc.
H. Thomas	Air Products & Chemicals Inc.
I. Verhappen	Syncrude Canada Ltd.
T. Walczak	GE Fanuc Automation
M. Weber	System Safety Inc.
L. Wells	Georgia-Pacific Corp.
J. Williamson	Bechtel Corp.
A. Woltman	Shell Global Solutions
P. Wright	BHP Engineering & Construction, Inc.
D. Zetterberg	ChevronTexaco Energy Technology Co.
5	57 · 57 · ·

This document was approved for publication by the ISA Standards and Practices Board on 2 August 2004.

AFFILIATION

NAME

V. Maggioli, Chair K. Bond D. Bishop D. Bouchard M. Cohen M. Coppler B. Dumortier W. Holland E. Icayan A. Iverson R. Jones T. McAvinew A. McCauley, Jr.	Feltronics Corp. Consultant David N. Bishop, Consultant Paprican Consultant Ametek, Inc. Schneider Electric Consultant ACES, Inc. Ivy Optiks Dow Chemical Co. I&C Engineering, LLC Chagrin Valley Controls, Inc.
G. McFarland	Emerson Process Management
D. Rapley	Rapley Consulting Inc.
R. Reimer	Rockwell Automation
J. Rennie	Factory Mutual Research Corp.
H. Sasajima	Yamatake Corp.
I. Verhappen	Syncrude Canada Ltd.
R. Webb	Consultant
W. Weidman	Parsons Energy & Chemicals Group
J. Weiss	KEMA Inc.
M. Widmeyer	Stanford Linear Accelerator Center
R. Wiegle C. Williams	CANUS Corp. Eastman Kodak Co.
M. Zielinski	Emerson Process Management

This page intentionally left blank.

CONTENTS

UN	ITED	STATES NATIONAL FOREWORD	11
IEC	FOR	EWORD	11
ΙΝΤ	ROD	UCTION	13
1	Scor	e	17
2	•	is, Definitions and abbreviations	
3		and safety integrity – general guidance	
3			
	3.1	General	
	3.2	Necessary risk reduction	
	3.3	Role of safety instrumented systems	
	3.4	Safety integrity	
	3.5	Risk and safety integrity	
	3.6	Allocation of safety requirements	
	3.7	Safety integrity levels	
۸	3.8	Selection of the method for determining the required safety integrity level	23
Ani		(informative) As Low As Reasonably Practicable (ALARP) and tolerable concepts	25
	A.1	General	
	A.1 A.2	ALARP model	
۸n		(informative) Semi-quantitative method	
Am			
	B.1		29
	B.2	Compliance to IEC 61511-1 ANSI/ISA-84.00.01-2004 Part 1 (IEC 61511-1 Mod)	20
	B.3	Example	
Δni		(informative) The safety layer matrix method	
	C.1	Introduction	
	C.1 C.2		
	-	Process safety target	
	C.3	Hazard analysis	
	C.4 C.5	Risk analysis technique	
	C.5 C.6	Safety layer matrix General procedure	
٨٣		•	41
Ani		(informative) Determination of the required safety integrity levels – a semi- tative method: calibrated risk graph	43
	D.1	Introduction	
	D.2	Risk graph synthesis	
	D.3	Calibration	
	D.4	Membership and organization of the team undertaking the SIL assessment	
	D.5	Documentation of results of SIL determination	
	D.6	Example calibration based on typical criteria	
	D.7	Using risk graphs where the consequences are environmental damage	
	D.8	Using risk graphs where the consequences are asset loss	
	D.9	Determining the integrity level of instrument protection function where the consequences of failure involve more than one type of loss	
۸۳		(informative) Determination of the required safety integrity levels – a	
AIII		tative method: risk graph	51
	E.1	General	
	E.2	Typical implementation of instrumented functions	
	_ .∠	. Jeser impromontation of motifunonted funotions	

E.3 Risk graph synthesis	
E.4 Risk graph implementation: personnel protection	53
E.5 Relevant issues to be considered during application of risk graphs	
Annex F (informative) Layer of protection analysis (LOPA)	57
F.1 Introduction	
F.2 Layer of protection analysis	57
F.3 Impact event	58
F.4 Severity Level	
F.5 Initiating cause	
F.6 Initiation likelihood	
F.7 Protection layers F.8 Additional mitigation	
F.9 Independent Protection Layers (IPL)	
F.10 Intermediate event likelihood	
F.11 SIF integrity level	
F.12 Mitigated event likelihood	
F.13 Total risk	
F.14 Example	
Figure 1 – Overall framework of this standard	15
Figure 2 – Typical risk reduction methods found in process plants	18
Figure 3 – Risk reduction: general concepts	21
Figure 4 – Risk and safety integrity concepts	21
Figure 5 – Allocation of safety requirements to the Safety Instrumented Systems,	00
non-SIS prevention/mitigation protection layers and other protection layers	
Figure A.1 – Tolerable risk and ALARP	26
	26
Figure A.1 – Tolerable risk and ALARP	26 30
Figure A.1 – Tolerable risk and ALARP Figure B.1 – Pressurized Vessel with Existing Safety Systems	26 30 33
Figure A.1 – Tolerable risk and ALARP Figure B.1 – Pressurized Vessel with Existing Safety Systems Figure B.2 – Fault Tree for Overpressure of the Vessel	26 30 33 34
Figure A.1 – Tolerable risk and ALARP Figure B.1 – Pressurized Vessel with Existing Safety Systems Figure B.2 – Fault Tree for Overpressure of the Vessel Figure B.3 – Hazardous Events with Existing Safety Systems	26 30 33 34 35
Figure A.1 – Tolerable risk and ALARP Figure B.1 – Pressurized Vessel with Existing Safety Systems Figure B.2 – Fault Tree for Overpressure of the Vessel Figure B.3 – Hazardous Events with Existing Safety Systems Figure B.4 – Hazardous Events with Redundant Protection Layer	26 30 33 34 35 36
Figure A.1 – Tolerable risk and ALARP Figure B.1 – Pressurized Vessel with Existing Safety Systems Figure B.2 – Fault Tree for Overpressure of the Vessel Figure B.3 – Hazardous Events with Existing Safety Systems Figure B.4 – Hazardous Events with Redundant Protection Layer Figure B.5 – Hazardous Events with SIL 2 SIS Safety Function	26 30 33 34 35 36 37
Figure A.1 – Tolerable risk and ALARP Figure B.1 – Pressurized Vessel with Existing Safety Systems Figure B.2 – Fault Tree for Overpressure of the Vessel Figure B.3 – Hazardous Events with Existing Safety Systems Figure B.4 – Hazardous Events with Redundant Protection Layer Figure B.5 – Hazardous Events with SIL 2 SIS Safety Function Figure C.1 – Protection Layers	26 30 34 35 36 37 41
 Figure A.1 – Tolerable risk and ALARP Figure B.1 – Pressurized Vessel with Existing Safety Systems Figure B.2 – Fault Tree for Overpressure of the Vessel Figure B.3 – Hazardous Events with Existing Safety Systems Figure B.4 – Hazardous Events with Redundant Protection Layer Figure B.5 – Hazardous Events with SIL 2 SIS Safety Function Figure C.1 – Protection Layers Figure C.2 – Example Safety Layer Matrix Figure D.1 – Risk graph: general scheme 	26 30 34 35 36 37 41 47
 Figure A.1 – Tolerable risk and ALARP Figure B.1 – Pressurized Vessel with Existing Safety Systems Figure B.2 – Fault Tree for Overpressure of the Vessel Figure B.3 – Hazardous Events with Existing Safety Systems Figure B.4 – Hazardous Events with Redundant Protection Layer Figure B.5 – Hazardous Events with SIL 2 SIS Safety Function Figure C.1 – Protection Layers Figure C.2 – Example Safety Layer Matrix Figure D.1 – Risk graph: general scheme Figure D.2 – Risk Graph: Environmental Loss 	26 30 34 35 36 37 41 47 49
Figure A.1 – Tolerable risk and ALARP Figure B.1 – Pressurized Vessel with Existing Safety Systems Figure B.2 – Fault Tree for Overpressure of the Vessel Figure B.3 – Hazardous Events with Existing Safety Systems Figure B.4 – Hazardous Events with Redundant Protection Layer Figure B.5 – Hazardous Events with SIL 2 SIS Safety Function Figure C.1 – Protection Layers Figure C.2 – Example Safety Layer Matrix Figure D.1 – Risk graph: general scheme Figure D.2 – Risk Graph: Environmental Loss Figure E.1 – DIN V 19250 Risk graph – personnel protection (see Table E.1) Figure E.2 – Relationship between IEC 61511 ANSI/ISA-84.00.01-2004 (IEC 61511	26 30 34 35 36 37 41 47 49 54
 Figure A.1 – Tolerable risk and ALARP Figure B.1 – Pressurized Vessel with Existing Safety Systems Figure B.2 – Fault Tree for Overpressure of the Vessel Figure B.3 – Hazardous Events with Existing Safety Systems Figure B.4 – Hazardous Events with Redundant Protection Layer Figure B.5 – Hazardous Events with SIL 2 SIS Safety Function Figure C.1 – Protection Layers Figure C.2 – Example Safety Layer Matrix Figure D.1 – Risk graph: general scheme Figure D.2 – Risk Graph: Environmental Loss Figure E.1 – DIN V 19250 Risk graph – personnel protection (see Table E.1) 	26
 Figure A.1 – Tolerable risk and ALARP Figure B.1 – Pressurized Vessel with Existing Safety Systems Figure B.2 – Fault Tree for Overpressure of the Vessel Figure B.3 – Hazardous Events with Existing Safety Systems Figure B.4 – Hazardous Events with Redundant Protection Layer Figure B.5 – Hazardous Events with SIL 2 SIS Safety Function Figure C.1 – Protection Layers Figure D.1 – Risk graph: general scheme Figure D.2 – Risk Graph: Environmental Loss Figure E.1 – DIN V 19250 Risk graph – personnel protection (see Table E.1) Figure E.2 – Relationship between IEC 61511 Mod) series, DIN 19250 and VDI/VDE 2180 Figure F.1 – Layer of Protection Analysis (LOPA) Report 	26 30 34 35 36 37 41 47 47 49 54 55 58
 Figure A.1 – Tolerable risk and ALARP Figure B.1 – Pressurized Vessel with Existing Safety Systems Figure B.2 – Fault Tree for Overpressure of the Vessel Figure B.3 – Hazardous Events with Existing Safety Systems Figure B.4 – Hazardous Events with Redundant Protection Layer Figure B.5 – Hazardous Events with SIL 2 SIS Safety Function Figure C.1 – Protection Layers Figure D.1 – Risk graph: general scheme Figure E.2 – Risk Graph: Environmental Loss Figure E.1 – DIN V 19250 Risk graph – personnel protection (see Table E.1) Figure E.2 – Relationship between IEC 61511 ANSI/ISA-84.00.01-2004 (IEC 61511 Mod) series, DIN 19250 and VDI/VDE 2180 Figure F.1 – Layer of Protection Analysis (LOPA) Report 	26
 Figure A.1 – Tolerable risk and ALARP Figure B.1 – Pressurized Vessel with Existing Safety Systems. Figure B.2 – Fault Tree for Overpressure of the Vessel. Figure B.3 – Hazardous Events with Existing Safety Systems Figure B.4 – Hazardous Events with Redundant Protection Layer Figure B.5 – Hazardous Events with SIL 2 SIS Safety Function. Figure C.1 – Protection Layers. Figure D.1 – Risk graph: general scheme Figure E.1 – DIN V 19250 Risk graph – personnel protection (see Table E.1). Figure E.2 – Relationship between IEC 61511 ANSI/ISA-84.00.01-2004 (IEC 61511 Mod) series, DIN 19250 and VDI/VDE 2180. Figure F.1 – Layer of Protection Analysis (LOPA) Report. Table A.1 – Example of risk classification of incidents Table A.2 – Interpretation of risk classes. 	26 30 33 34 35 36 37 41 47 49 54 55 58 58 58
 Figure A.1 – Tolerable risk and ALARP Figure B.1 – Pressurized Vessel with Existing Safety Systems. Figure B.2 – Fault Tree for Overpressure of the Vessel. Figure B.3 – Hazardous Events with Existing Safety Systems Figure B.4 – Hazardous Events with Redundant Protection Layer Figure B.5 – Hazardous Events with SIL 2 SIS Safety Function. Figure C.1 – Protection Layers. Figure D.1 – Risk graph: general scheme Figure E.1 – DIN V 19250 Risk graph – personnel protection (see Table E.1). Figure E.2 – Relationship between IEC 61511 ANSI/ISA-84.00.01-2004 (IEC 61511 Mod) series, DIN 19250 and VDI/VDE 2180. Figure F.1 – Layer of Protection Analysis (LOPA) Report. Table A.1 – Example of risk classification of incidents Table A.2 – Interpretation of risk classes. Table B.1 – HAZOP analysis results. 	26
 Figure A.1 – Tolerable risk and ALARP Figure B.1 – Pressurized Vessel with Existing Safety Systems. Figure B.2 – Fault Tree for Overpressure of the Vessel. Figure B.3 – Hazardous Events with Existing Safety Systems Figure B.4 – Hazardous Events with Redundant Protection Layer Figure B.5 – Hazardous Events with SIL 2 SIS Safety Function. Figure C.1 – Protection Layers. Figure D.1 – Risk graph: general scheme Figure E.1 – DIN V 19250 Risk graph – personnel protection (see Table E.1). Figure E.2 – Relationship between IEC 61511 ANSI/ISA-84.00.01-2004 (IEC 61511 Mod) series, DIN 19250 and VDI/VDE 2180. Figure F.1 – Layer of Protection Analysis (LOPA) Report. Table A.1 – Example of risk classification of incidents Table A.2 – Interpretation of risk classes. 	26 30 33 34 35 36 37 41 47 49 54 55 58 58 27 27 27 31 40

Copyright 2004 ISA. All rights reserved.

This is a preview of "ANSI/ISA-84.00.01-20". (Click here to purchase the full version from the ANSI store.
--	--

Table D.2 – Example calibration of the general purpose risk graph	47
Table D.3 – General environmental consequences	49
Table E.1 – Data relating to risk graph (see Figure E.1)	54
Table F.1 – HAZOP developed data for LOPA	58
Table F.2 – Impact event severity levels	59
Table F.3 – Typical protection layer (prevention and mitigation) PFDs	60
Table F.4 – Initiation Likelihood	59

This page intentionally left blank.

INTERNATIONAL ELECTROTECHNICAL COMMISSION

FUNCTIONAL SAFETY– SAFETY INSTRUMENTED SYSTEMS FOR THE PROCESS INDUSTRY SECTOR –

Part 3: Guidance for the determination of the required safety integrity levels

UNITED STATES NATIONAL FOREWORD

All text of IEC 61511-3 Ed. 1.0 (2003-03) is included. United States National Deviations are shown by strikeout through deleted text and <u>underline</u> under added text.

IEC FOREWORD

- 1) The IEC (International Electrotechnical Commission) is a worldwide organization for standardization comprising all national electrotechnical committees (IEC National Committees). The object of the IEC is to promote international co-operation on all questions concerning standardization in the electrical and electronic fields. To this end and in addition to other activities, the IEC publishes International Standards. Their preparation is entrusted to technical committees; any IEC National Committee interested in the subject dealt with may participate in this preparatory work. International, governmental and non-governmental organizations liaising with the IEC also participate in this preparation. The IEC collaborates closely with the International Organization for Standardization (ISO) in accordance with conditions determined by agreement between the two organizations.
- 2) The formal decisions or agreements of the IEC on technical matters express, as nearly as possible, an international consensus of opinion on the relevant subjects since each technical committee has representation from all interested National Committees.
- 3) The documents produced have the form of recommendations for international use and are published in the form of standards, technical specifications, technical reports or guides and they are accepted by the National Committees in that sense.
- 4) In order to promote international unification, IEC National Committees undertake to apply IEC International Standards transparently to the maximum extent possible in their national and regional standards. Any divergence between the IEC Standard and the corresponding national or regional standard shall be clearly indicated in the latter.
- 5) The IEC provides no marking procedure to indicate its approval and cannot be rendered responsible for any equipment declared to be in conformity with one of its standards.
- 6) Attention is drawn to the possibility that some of the elements of this International Standard may be the subject of patent rights. The IEC shall not be held responsible for identifying any or all such patent rights.

International Standard IEC 61511-3 has been prepared by subcommittee 65A: System aspects, of IEC technical committee 65: Industrial-process measurement and control.

The text of this standard is based on the following documents:

FDIS	Report on voting
65A/367/FDIS	65A/370/RVD

Full information on the voting for the approval of this standard can be found in the report on voting indicated in the above table.

This publication has been drafted in accordance with the ISO/IEC Directives, Part 2.

IEC 61511 series has been developed as a process sector implementation of IEC 61508 series.

IEC 61511 ANSI/ISA-84.00.01-2004 (IEC 61511 Mod) consists of the following parts, under the general title *Functional safety – Safety Instrumented Systems for the process industry sector* (see Figure 1):

Part 1: Framework, definitions, system, hardware and software requirements

Part 2: Guidelines for the application of IEC 61511-1 ANSI/ISA-84.00.01-2004 Part 1 (IEC 61511-1 Mod)

Part 3: Guidance for the determination of the required safety integrity levels

The committee has decided that the contents of this publication will remain unchanged until 2007. At this date, the publication will be

- reconfirmed;
- withdrawn;
- replaced by a revised edition, or
- amended.

INTRODUCTION

Safety instrumented systems have been used for many years to perform safety instrumented functions in the process industries. If instrumentation is to be effectively used for safety instrumented functions, it is essential that this instrumentation achieves certain minimum standards and performance levels.

This International Standard addresses the application of safety instrumented systems for the Process Industries. It also requires a process hazard and risk assessment to be carried out to enable the specification for safety instrumented systems to be derived. Other safety systems are only considered so that their contribution can be taken into account when considering the performance requirements for the safety instrumented systems. The safety instrumented system includes all components and subsystems necessary to carry out the safety instrumented function from sensor(s) to final element (s).

This International Standard has two concepts which are fundamental to its application; safety lifecycle and safety integrity levels.

This International Standard addresses safety instrumented systems which are based on the use of Electrical (E)/Electronic (E)/Programmable Electronic (PE) technology. Where other technologies are used for logic solvers, the basic principles of this standard should be applied. This standard also addresses the safety instrumented system sensors and final elements regardless of the technology used. This International Standard is process industry specific within the framework of IEC 61508 (see Annex A of IEC 61511-1 ANSI/ISA-84.00.01-2004 Part 1 (IEC 61511-1 Mod)).

This International Standard sets out an approach for safety lifecycle activities to achieve these minimum standards. This approach has been adopted in order that a rational and consistent technical policy be used.

In most situations, safety is best achieved by an inherently safe process design. If necessary, this may be combined with a protective system or systems to address any residual identified risk. Protective systems can rely on different technologies (chemical, mechanical, hydraulic, pneumatic, electrical, electronic, programmable electronic). Any safety strategy should consider each individual safety instrumented system in the context of the other protective systems. To facilitate this approach, this standard

- requires that a hazard and risk assessment is carried out to identify the overall safety requirements;
- requires that an allocation of the safety requirements to the safety instrumented system (s) is carried out;
- works within a framework which is applicable to all instrumented methods of achieving functional safety;
- details the use of certain activities, such as safety management, which may be applicable to all methods of achieving functional safety.

This International Standard on safety instrumented systems for the process industry:

- addresses all safety life cycle phases from initial concept, design, implementation, operation and maintenance through to decommissioning;
- enables existing or new country specific process industry standards to be harmonized with this standard.

This standard is intended to lead to a high level of consistency (for example, of underlying principles, terminology, information) within the process industries. This should have both safety and economic benefits.

In jurisdictions where the governing authorities (for example national, federal, state, province, county, city) have established process safety design, process safety management, or other requirements, these take precedence over the requirements defined in this standard.

This standard deals with guidance in the area of determining the required SIL in hazards and risk analysis (H & RA). The information herein is intended to provide a broad overview of the wide range of global methods used to implement H & RA. The information provided is not of sufficient detail to implement any of these approaches.

Before proceeding, the concept and determination of safety integrity level (s) (SIL) provided in IEC 61511-1 ANSI/ISA-84.00.01-2004 Part 1 (IEC 61511-1 Mod) should be reviewed. The annexes in this standard address the following:

- Annex A provides an overview of the concepts of tolerable risk and ALARP.
- Annex B provides an overview of a semi-quantitative method used to determine the required SIL.
- Annex C provides an overview of a safety matrix method to determine the required SIL.
- Annex D provides an overview of a method using a semi-qualitative risk graph approach to determine the required SIL.
- Annex E provides an overview of a method using a qualitative risk graph approach to determine the required SIL.
- Annex F provides an overview of a method using a layer of protection analysis (LOPA) approach to select the required SIL.




Figure 1 – Overall framework of this standard

This page intentionally left blank.

FUNCTIONAL SAFETY – SAFETY INSTRUMENTED SYSTEMS FOR THE PROCESS INDUSTRY SECTOR –

Part 3: Guidance for the determination of the required safety integrity levels

1 Scope

- 1.1 This part provides information on
- the underlying concepts of risk, the relationship of risk to safety integrity, see Clause 3;
- the determination of tolerable risk, see Annex A;
- a number of different methods that enable the safety integrity levels for the safety instrumented functions to be determined, see Annexes B, C, D, E, and F.

In particular, this part

- a) applies when functional safety is achieved using one or more safety instrumented functions for the protection of either personnel, the general public, or the environment;
- b) may be applied in non-safety applications such as asset protection;
- c) illustrates typical hazard and risk assessment methods that may be carried out to define the safety functional requirements and safety integrity levels of each safety instrumented function;
- d) illustrates techniques/measures available for determining the required safety integrity levels;
- e) provides a framework for establishing safety integrity levels but does not specify the safety integrity levels required for specific applications;
- f) does not give examples of determining the requirements for other methods of risk reduction.

1.2 Annexes B, C, D, E, and F illustrate quantitative and qualitative approaches and have been simplified in order to illustrate the underlying principles. These annexes have been included to illustrate the general principles of a number of methods but do not provide a definitive account.

NOTE Those intending to apply the methods indicated in these annexes should consult the source material referenced in each annex.

1.3 Figure 1 shows the overall framework for IEC 61511-1 ANSI/ISA-84.00.01-2004 Part 1 (IEC 61511-1 Mod), IEC 61511-2 ANSI/ISA-84.00.01-2004 Part 2 (IEC 61511-2 Mod), and IEC 61511-3 ANSI/ISA-84.00.01-2004 Part 3 (IEC 61511-3 Mod), and indicates the role that this standard plays in the achievement of functional safety for safety instrumented systems.

Figure 2 gives an overview of risk reduction methods.

For existing SIS designed and constructed in accordance with codes, standards, or practices prior to the issue of this standard (e.g., ANSI/ISA-84.01-1996), the owner/operator shall determine that the equipment is designed, maintained, inspected, tested, and operating in a safe manner.