

ISA-RP12.2.02-1996

Approved May 15, 1996

Recommended Practice

**Recommendations for the
Preparation, Content, and
Organization of Intrinsic Safety
Control Drawings**



ISA-RP12.2.02 — Recommendations for the Preparation, Content, and Organization of
Intrinsic Safety Control Drawings

ISBN: 1-55617-605-8

Copyright © 1996 by the Instrument Society of America. All rights reserved. Printed in the United States of America. No part of this publication may be reproduced, stored in a retrieval system, or transmitted in any form or by any means (electronic, mechanical, photocopying, recording, or otherwise), without the prior written permission of the publisher.

ISA
67 Alexander Drive
P.O. Box 12277
Research Triangle Park, North Carolina 27709

Preface

This preface, as well as all annexes and footnotes, is included for informational purposes and is not part of ISA-RP12.2.02.

This recommended practice has been prepared as part of the service of ISA, the international society for measurement and control, toward a goal of uniformity in the field of instrumentation. To be of real value, this document should not be static, but should be subject to periodic review. Toward this end, the Society welcomes all comments and criticisms, and asks that they be addressed to the Secretary, Standards and Practices Board; ISA; 67 Alexander Drive; P. O. Box 12277; Research Triangle Park, NC 27709; Telephone (919) 549-8411; Fax (919) 549-8288; E-mail: standards@isa.org.

The ISA Standards and Practices Department is aware of the growing need for attention to the metric system of units in general, and the International System of Units (SI) in particular, in the preparation of instrumentation standards, recommended practices, and technical reports. The Department is further aware of the benefits to USA users of ISA standards of incorporating suitable references to the SI (and the metric system) in their business and professional dealings with other countries. Toward this end, this Department will endeavor to introduce SI-acceptable metric units in all new and revised standards to the greatest extent possible. *The Metric Practice Guide*, which has been published by the Institute of Electrical and Electronics Engineers as ANSI/IEEE Std. 268-1992, and future revisions, will be the reference guide for definitions, symbols, abbreviations, and conversion factors.

It is the policy of ISA to encourage and welcome the participation of all concerned individuals and interests in the development of ISA standards. Participation in the ISA standards-making process by an individual in no way constitutes endorsement by the employer of that individual, of ISA, or of any of the standards, recommended practices, and technical reports that ISA develops.

The following members of ISA SP12.2 contributed to the development of this document:

NAME	COMPANY
A. Engler, Chairman	Applied Automation, Inc.
D. Bishop, Managing Director	Chevron USA Production Company
*N. Abbatiello	Eastman Kodak Company
R. Amin	Dow Corning, Inc.
P. Austen	Electronic Controls Design, Inc.
P. Babiarz	Crouse-Hinds Company
W. Calder III	Calder Enterprises
R. Cardinal	Bentley Nevada Corporation
M. Coppler	Bacharach Instruments, Inc.
U. Dugar	Mobil Chemical Company
T. Feindel	R. Stahl, Inc.
W. Fiske	Inchcape Testing Services
S. Florence	Motorola, Inc.

*One vote per company

NAME	COMPANY
D. Hohenstein	Pepperl + Fuchs
S. Jackson	Elcon Instruments, Inc.
*P. Kelly	Underwriters Laboratories, Inc.
B. Larson	Turck, Inc.
D. Li	Canadian Standards Association
E. Magison	Honeywell, Inc.
D. Martell	Dastech, Inc.
R. Masek	Bailey Controls Company
F. McGowan	Factory Mutual Research Corporation
J. Miller	Detector Electronics Corporation
*A. Mobley	3M Company
*S. Norako	Crouse-Hinds Company
*E. Olson	3M Company
C. Oudar	MTL, Inc.
A. Page III	MSHA Certification Center
M. Rains	Foxboro Company
R. Ring	Mine Safety Appliances Company
P. Schimmoeller	Weidmuller, Inc.
T. Schnaare	Rosemount, Inc.
*D. Styracula	Underwriters Laboratories, Inc.
L. Truscott	Motorola, Inc.
D. Wechsler	Union Carbide Corporation
*R. Weinzler	Eastman Kodak Company

The following members of ISA Committee SP12 contributed to the development of this document:

NAME	COMPANY
*F. McGowan, Chairman	Factory Mutual Research Corporation
D. Bishop, Managing Director	Chevron USA Production Company
*N. Abbatiello	Eastman Kodak Company
*W. Alexander	Mine Safety Appliances Company
S. Arnold	Drexelbrook Engineering Company
*P. Babiarz	Crouse-Hinds Company
*A. Ballard	Crouse-Hinds Company
G. Bentinck	Du Pont Engineering
*R. Berthold	Chevron USA Production Company
H. Bockle	Killark-Stahl, Inc.
J. Bossert	Hazloc, Inc.
R. Brodin	Fisher Controls International, Inc.
M. Buettner	Ralston Purina Company
R. Buschart	PC & E, Inc.
R. Cardinal	Bently Nevada Corporation
R. Castillo	Corpoven SA
H. Conner	Consultant

*One vote per company

NAME	COMPANY
M. Coppler	Bacharach Instruments, Inc.
J. Cospolich	Waldemar S. Nelson & Company, Inc.
J. Costello	Henkel Corporation
*E. Cranch	Drexelbrook Engineering Company
U. Dugar	Mobil Chemical Company
A. Engler	Applied Automation, Inc.
T. Feindel	R. Stahl, Inc.
W. Fiske	Inchcape Testing Services
G. Garcha	PCS Engineering
B. Gibson	ABB Kent-Taylor, Inc.
E. Henning	Fischer & Porter Company
D. Hohenstein	Pepperl + Fuchs
X. Jianping	Shanghai Institute of Process Automation Instrumentation
F. Kent	Honeywell, Inc.
J. Kuczka	Killark Electric Manufacturing Company
T. Lagana	BE&K, Inc.
R. Landman	International Marine Products, Inc.
B. Larson	Turck, Inc.
T. Lewis	Applied Automation
D. Li	Canadian Standards Association
E. Magison	Consultant
*F. Maltby	Drexelbrook Engineering Company
R. Masek	Bailey Controls Company
J. Miller	Detector Electronics Corporation
*A. Mobley	3M Company
*W. Mueller	Pepperl + Fuchs, Inc.
E. Nesvig	Erdco Engineering Corporation
*E. Olson	3M Company
A. Page III	MSHA Certification Center
*R. Ring	Mine Safety Appliances Company
C. Sandberg	Raychem Corporation
P. Schimmoeller	Weidmuller, Inc.
T. Schnaare	Rosemount, Inc.
A. Stafford	Foxboro Company
D. Stevens	Chevron USA Production Company
D. Styracula	Underwriters Laboratories, Inc.
J. Thomason	OMNI Industrial Systems, Inc.
L. Truscott	Motorola, Inc.
*P. Turner	3M Company
D. Wechsler	Union Carbide Corporation
*R. Weinzler	Eastman Kodak Company
Z. Zborovszky	U.S. Bureau of Mines

*One vote per company

This recommended practice was approved for publication by the ISA Standards and Practices Board on May 15, 1996.

NAME

COMPANY

M. Widmeyer, Vice President	Washington Public Power Supply System
H. Baumann	H. D. Baumann, Inc.
D. Bishop	Chevron USA Production Company
P. Brett	Honeywell Industrial Automation Controls
W. Calder III	Calder Enterprises
H. Dammeyer	Phoenix Industries, Inc.
R. Dieck	Pratt & Whitney
W. Holland	Southern Company Services, Inc.
A. Iverson	Lyondell Petrochemical Company
K. Lindner	Endress + Hauser GmbH + Company
T. McAviney	Metro Wastewater Reclamation District
A. McCauley, Jr.	Chagrin Valley Controls, Inc.
G. McFarland	Honeywell Industrial Automation Controls
E. Montgomery	Fluor Daniel, Inc.
D. Rapley	Rapley Engineering Services
R. Reimer	Rockwell Automation A-B
J. Rennie	Factory Mutual Research Corporation
R. Webb	Pacific Gas & Electric Company
W. Weidman	Consultant
J. Weiss	Electric Power Research Institute
J. Whetstone	National Inst. of Standards & Technology
H. Wiegler	Canus Corporation
C. Williams	Eastman Kodak Company
G. Wood	Graeme Wood Consulting
M. Zielinski	Fisher•Rosemount

Contents

1 Scope	9
2 Purpose	9
3 Definitions	9
4 General considerations	10
4.1 Types of control drawings.....	10
4.2 Availability.....	11
4.3 Drawing format	11
5 Drawing content	11
5.1 Wiring diagram	11
5.2 Equipment identification	11
5.3 Entity parameters	12
5.4 Hazardous location identification.....	12
5.5 Control drawing identification	12
5.6 Maximum voltage	12
5.7 Installation information.....	12
5.8 Other information	13
Figures	
1 — Intrinsically safe apparatus for connection to associated apparatus specified by entity parameters	13
2 — Associated apparatus identified by manufacturer and model number for connection to intrinsically safe apparatus specified by entity parameters.....	14
3 — Intrinsically safe apparatus and associated apparatus specified by manufacturer and model number	15

This is a preview of "ISA RP12.2.02-1996". [Click here to purchase the full version from the ANSI store.](#)

1 Scope

1.1 This recommended practice provides guidance in the preparation of control drawings for intrinsically safe apparatus, associated apparatus, and intrinsically safe systems.

1.2 This recommended practice is intended to be used in conjunction with ANSI/UL 913-1988, "Standard for Safety, Intrinsically Safe Apparatus and Associated Apparatus for Use in Class I, II, and III, Division 1, Hazardous (Classified) Locations."

1.3 This recommended practice is not intended to include guidance for the design or installation of intrinsically safe equipment or systems.

2 Purpose

2.1 This recommended practice has been formulated to provide guidance for and to promote the uniformity of manufacturers' control drawings for intrinsically safe apparatus, associated apparatus, and intrinsically safe systems.

2.2 Article 504 of the *National Electrical Code*[®] and Canadian Electrical Code, Part 1, Appendix F, requires that documentation for intrinsically safe apparatus and associated apparatus include a control drawing. This recommended practice is intended to provide guidance for the content of control drawings.

3 Definitions

3.1 control drawing: A drawing or other document provided by the manufacturer of the intrinsically safe or associated apparatus that details the allowed interconnections between the intrinsically safe and associated apparatus.

3.2 entity concept (also known as entity evaluation): A method used to determine acceptable combinations of intrinsically safe apparatus and connected associated apparatus that have not been previously investigated in such combination.

NOTE — ISA-TR12.2-1995 provides more information on the use of the entity concept.

3.3 entity parameters for intrinsically safe apparatus:

C_i : total equivalent internal capacitance that must be considered as appearing across the terminals of the intrinsically safe apparatus.