


ANSI/ISA-TR75.25.02-2000



Control Valve Response Measurement from Step Inputs



**ISA—The Instrumentation,
Systems, and
Automation Society**

Approved 11 March 2001

ANSI/ISA–TR75.25.02–2000
Control Valve Response Measurement from Step Inputs

ISBN: 1-55617-743-7

Copyright © 2000 by ISA–The Instrumentation, Systems, and Automation Society. All rights reserved. Not for resale. Printed in the United States of America. No part of this publication may be reproduced, stored in a retrieval system, or transmitted, in any form or by any means (electronic, mechanical, photocopying, recording, or otherwise), without the prior written permission of the Publisher.

ISA
67 Alexander Drive
P.O. Box 12277
Research Triangle Park, North Carolina 27709
USA

Preface

This preface, as well as all footnotes and annexes, is included for information purposes and is not part of ANSI/ISA-TR75.25.02-2000.

The standards referenced within this document may contain provisions which, through reference in this text, constitute requirements of this document. At the time of publication, the editions indicated were valid. All standards are subject to revision, and parties to agreements based on this document are encouraged to investigate the possibility of applying the most recent editions of the standards indicated within this document. Members of IEC and ISO maintain registers of currently valid International Standards. ANSI maintains registers of currently valid U.S. National Standards.

This document has been prepared as part of the service of ISA—The Instrumentation, Systems, and Automation Society, toward a goal of uniformity in the field of instrumentation. To be of real value, this document should not be static but should be subject to periodic review. Toward this end, the Society welcomes all comments and criticisms and asks that they be addressed to the Secretary, Standards and Practices Board; ISA; 67 Alexander Drive; P. O. Box 12277; Research Triangle Park, NC 27709; Telephone (919) 549-8411; Fax (919) 549-8288; E-mail: standards@isa.org.

The ISA Standards and Practices Department is aware of the growing need for attention to the metric system of units in general, and the International System of Units (SI) in particular, in the preparation of instrumentation standards. The Department is further aware of the benefits to USA users of ISA standards of incorporating suitable references to the SI (and the metric system) in their business and professional dealings with other countries. Toward this end, this Department will endeavor to introduce SI-acceptable metric units in all new and revised standards, recommended practices, and technical reports to the greatest extent possible. *Standard for Use of the International System of Units (SI): The Modern Metric System*, published by the American Society for Testing & Materials as IEEE/ASTM SI 10-97, and future revisions, will be the reference guide for definitions, symbols, abbreviations, and conversion factors.

It is the policy of ISA to encourage and welcome the participation of all concerned individuals and interests in the development of ISA standards, recommended practices, and technical reports. Participation in the ISA standards-making process by an individual in no way constitutes endorsement by the employer of that individual, of ISA, or of any of the standards, recommended practices, and technical reports that ISA develops.

CAUTION — ISA ADHERES TO THE POLICY OF THE AMERICAN NATIONAL STANDARDS INSTITUTE WITH REGARD TO PATENTS. IF ISA IS INFORMED OF AN EXISTING PATENT THAT IS REQUIRED FOR USE OF THE STANDARD, IT WILL REQUIRE THE OWNER OF THE PATENT TO EITHER GRANT A ROYALTY-FREE LICENSE FOR USE OF THE PATENT BY USERS COMPLYING WITH THE STANDARD OR A LICENSE ON REASONABLE TERMS AND CONDITIONS THAT ARE FREE FROM UNFAIR DISCRIMINATION.

EVEN IF ISA IS UNAWARE OF ANY PATENT COVERING THIS STANDARD, THE USER IS CAUTIONED THAT IMPLEMENTATION OF THE STANDARD MAY REQUIRE USE OF TECHNIQUES, PROCESSES, OR MATERIALS COVERED BY PATENT RIGHTS. ISA TAKES NO POSITION ON THE EXISTENCE OR VALIDITY OF ANY PATENT RIGHTS THAT MAY BE INVOLVED IN IMPLEMENTING THE STANDARD. ISA IS NOT RESPONSIBLE FOR IDENTIFYING ALL PATENTS THAT MAY REQUIRE A LICENSE BEFORE IMPLEMENTATION OF THE STANDARD OR FOR INVESTIGATING THE VALIDITY OR SCOPE OF ANY PATENTS BROUGHT TO ITS ATTENTION. THE USER SHOULD CAREFULLY INVESTIGATE RELEVANT PATENTS BEFORE USING THE STANDARD FOR THE USER'S INTENDED APPLICATION.

HOWEVER, ISA ASKS THAT ANYONE REVIEWING THIS STANDARD WHO IS AWARE OF ANY PATENTS THAT MAY IMPACT IMPLEMENTATION OF THE STANDARD NOTIFY THE ISA STANDARDS AND PRACTICES DEPARTMENT OF THE PATENT AND ITS OWNER.

ADDITIONALLY, THE USE OF THIS STANDARD MAY INVOLVE HAZARDOUS MATERIALS, OPERATIONS OR EQUIPMENT. THE STANDARD CANNOT ANTICIPATE ALL POSSIBLE APPLICATIONS OR ADDRESS ALL POSSIBLE SAFETY ISSUES ASSOCIATED WITH USE IN HAZARDOUS CONDITIONS. THE USER OF THIS STANDARD MUST EXERCISE SOUND PROFESSIONAL JUDGMENT CONCERNING ITS USE AND APPLICABILITY UNDER THE USER'S PARTICULAR CIRCUMSTANCES. THE USER MUST ALSO CONSIDER THE APPLICABILITY OF ANY GOVERNMENTAL REGULATORY LIMITATIONS AND ESTABLISHED SAFETY AND HEALTH PRACTICES BEFORE IMPLEMENTING THIS STANDARD.

The following people served as members of ISA Subcommittee SP75.25:

NAME	COMPANY
C. Langford, Chairman	Cullen G. Langford, Inc.
W. Weidman, Managing Director	Parsons Energy & Chemicals Group
J. Beall	Eastman Chemical Co.
D. Bennett	Sampson Controls, Inc.
W. Bialkowski	Entech Control Engineering, Inc.
W. Black	Cashco, Inc.
M. Boudreaux	Exxon Mobil Chemical
S. Boyle	Neles Automation
D. Buchanan	Union Carbide Corporation
F. Cain	Flowserve Corporation
N. Cammy	UOP LLC
J. Jamison	Bantrel Inc.
S. Kempf	Harold Beck & Sons, Inc.
P. Maurath	Procter & Gamble Company
R. McEver	Bettis Corporation
N. McLeod	Elf Atochem
G. McMillan	Solutia, Inc.
J. Reed	Norriseal

The following people served as members of ISA Committee SP75:

NAME	COMPANY
D. Buchanan, Chairman	Union Carbide Corporation
W. Weidman, Managing Director	Parsons Energy & Chemicals Group
A. Abromaitis	Red Valve Company, Inc.
H. Backinger	J. F. Kraus & Company
G. Barb	Retired
H. Baumann	H B Services Partners LLC
H. Boger	Masoneilan Dresser
G. Borden	Consultant
S. Boyle	Neles Automation
R. Brodin	Fisher Controls International, Inc.
F. Cain	Flowserve Corporation
C. Corson	Fluor Daniel Inc.
M. Coughran	Fisher Controls
A. Engels	Praxair, Inc.

H. Fuller	Valvcon Corporation
J. George	Richards Industries
A. Glenn	Flowserve Corp.
L. Griffith	Consultant/Retired
B. Guinon	Shell Chemical
F. Harthun	Retired
B. Hatton	DeZurik Division Unit
J. Jamison	Bantrel, Inc.
R. Jeanes	TXU Electric
J. Kersh	M. W. Kellogg Company
C. Langford	Cullen G. Langford, Inc.
A. Libke	DeZurik Valve Company
R. Louviere	Creole Engineering Sales Company
O. Lovett	Consultant/Retired
A. McCauley	Chagrin Valley Controls, Inc.
R. McEver	Bettis Corporation
H. Miller	Control Components, Inc.
T. Molloy	CMES Inc.
L. Ormanoski	Frick Company
J. Ozol	Commonwealth Edison
W. Rahmeyer	Utah State University
J. Reed	Norriseal
K. Schoonover	Con-Tek Valves, Inc.
A. Shea	Copes-Vulcan, Inc.
E. Skovgaard	Leslie Controls, Inc.
H. Sonderegger	Tyco Flow Control
R. Terhune	Retired

This standard was approved for publication by the ISA Standards and Practices Board on 30 December 2000:

NAME	COMPANY
M. Zielinski, Vice President	Fisher-Rosemount Systems, Inc.
D. Bishop	Consultant
P. Brett	Honeywell, Inc.
M. Cohen	Senior Flexonics, Inc.
M. Coppler	Ametek, Inc.
B. Dumortier	Schneider Electric
W. Holland	Southern Company
A. Iverson	Ivy Optiks
R. Jones	Dow Chemical Co.
V. Maggioli	Feltronics Corp.
T. McAviney	Bateman Engineering, Inc.
A. McCauley, Jr.	Chagrin Valley Controls, Inc.
G. McFarland	Westinghouse Process Control Inc.
D. Rapley	Rapley Consulting Inc.
R. Reimer	Rockwell Automation
J. Rennie	Factory Mutual Research Corp.
H. Sasajima	Yamatake Corp.
R. Webb	Altran Corp.
W. Weidman	Parsons Energy & Chemicals Group
J. Weiss	EPRI

J. Whetstone
M. Widmeyer
R. Wiegler
C. Williams
G. Wood

National Institute of Standards & Technology
EG&G Defense Materials
CANUS Corp.
Eastman Kodak Co.
Graeme Wood Consulting

Contents

1	Purpose.....	9
2	Scope.....	9
3	Definitions	9
4	Control valve response	14
4.1	Measurement of control valve response	14
4.2	System response	14
4.3	Test environments used to determine control valve response.....	16
4.4	Size of input signal change – regions	17
5	Maintenance and design issues affecting process control.....	17
5.1	Stem seal	18
5.2	Valve seat shutoff.....	18
5.3	Valve seat type.....	19
5.4	Process fluid effects	19
5.5	Mechanical tolerances	19
5.6	Structural stiffness.....	19
5.7	Pneumatic positioner.....	19
5.8	Actuator size/type.....	20
5.9	Electric and hydraulic actuators	20
5.10	Flow effects.....	20
5.11	Valve sizing and selection.....	20
6	Process and control design issues.....	20
6.1	Control loop process gain – range and variability	20
6.2	Over-sizing	22
6.3	Control valve inherent characteristic.....	22
6.4	Closed loop performance – control valve dynamic specification.....	23
6.5	Nonlinear regions	24
7	Static behavior tests.....	25
7.1	Important measures of static behavior	25
7.2	Applications affected and classes of performance.....	25
7.3	Testing considerations	26
7.4	Data presentation.....	28
7.5	Design and maintenance factors important to static behavior	29

8	Small amplitude and medium amplitude dynamic response tests (regions 2 and 3)	29
8.1	Important measures for regions 2 and 3	30
8.2	Applications affected and classes of performance.....	32
8.3	Testing considerations for small amplitude and medium amplitude dynamic response (regions 2 and 3)	32
8.4	Data presentation for regions 2 and 3.....	33
8.5	Design and maintenance factors at small amplitude and medium amplitude (regions 2 and 3).....	33
8.6	Oscillatory response.....	34
8.7	Performance near the closed position.....	34
9	Large amplitude dynamic response tests (region 4)	35
9.1	Important measures in region 4	35
9.2	Applications affected and classes of performance.....	36
9.3	Testing considerations for large amplitude dynamic response	36
9.4	Design and maintenance factors important at large amplitude	37
10	References.....	37

1 Purpose

This technical report describes the characteristic response of a control valve to step input signal changes. It considers the factors that affect this response, the impact of the response on the quality of process control, and the appropriate control valve specifications. In this document, a control valve is the complete control valve body, with actuator and any accessories required for normal operation assembled and ready for use. This document supports standard ANSI/ISA-75.25.01-2000, "Test Procedure for Control Valve Response Measurement from Step Inputs." See the standard for the test procedures.

Users and manufacturers have developed a better understanding of the effects of control valve response characteristics on process control. This document identifies and defines four regions of control valve response to step input changes of varying sizes. Existing standards do not include the definitions and methods to measure certain valve characteristics now understood to be important. This technical report provides guidance that can be used to relate the control valve performance to process control.

2 Scope

This technical report applies to throttling control valves in closed loop control applications. The concept has some application to open loop control applications. It does not address control valves used in on-off control service. The "control valve" in the context of this document includes the following components:

Valve: A valve is a device used for the control of fluid flow. It consists of a fluid containing valve body assembly, one or more ports between connection openings and a moveable closure member, which opens, restricts or closes the port(s) (see ANSI/ISA-75.05.01-2000, "Control Valve Terminology").

Actuator: An actuator is a device that supplies the force and causes the movement of the valve closure member. Commonly these are fluid or electrically powered (see ANSI/ISA-75.05.01-2000). Actuators often use air but other types use electric, hydraulic and electro-hydraulic power.

Motion conversion mechanism: A mechanism installed between the valve and the power unit of the actuator to convert between linear and rotary motion where required. The conversion may be from linear actuator action to rotary valve operation or from rotary actuator action to linear valve operation.

Accessories: Additional devices used in the operation of the control valve. As described in ANSI/ISA-75.05.01-2000, typical examples include a positioner, transducer, signal booster relay, air set, snubber, etc.

3 Definitions

This document and ANSI/ISA-75.25.01-2000 make use of terms as defined in ANSI/ISA-51.1-1979 (R1993) "Process Instrumentation Terminology", and some of the essential terms are repeated here for convenience. In the specific area of nonlinear dynamics, it was determined that some terms defined in ANSI/ISA-51.1-1979 (R1993) lacked the precision desired for these documents. Others were inconsistent with the terminology used in the nonlinear control literature. A common set of definitions is used in ANSI/ISA-75.25.01-2000 and this document. Those used only in this document are marked with an asterisk (*).

3.1 backlash:*

in process instrumentation, a relative movement between connected mechanical parts, resulting from looseness when motion is reversed [ANSI/ISA-51.1-1979 (R1993)]. Sometimes also referred to as slop, lost motion, or free play.