



ANSI/ISEA

Z358.1-2014

## American National Standard for Emergency Eyewash and Shower Equipment

**ANSI/ISEA Z358.1-2014**

Revision of

ANSI/ISEA Z358.1-2009

**American National Standard for  
Emergency Eyewash and Shower Equipment**

Secretariat

**International Safety Equipment Association**

Approved January 8, 2015

**American National Standards Institute, Inc.**

**American  
National  
Standard**

Approval of an American National Standard requires verification by ANSI that the requirements for due process, consensus, and other criteria for approval have been met by the standards developer. Consensus is established when, in the judgment of the ANSI Board of Standards Review, substantial agreement has been reached by directly and materially affected interests. Substantial agreement means much more than a simple majority, but not necessarily unanimity. Consensus requires that all views and objections be considered, and that a concerted effort be made toward their resolution. The use of American National Standards is completely voluntary; their existence does not in any respect preclude anyone, whether he/she has approved the standards or not, from manufacturing, marketing, purchasing, or using products, processes, or procedures not conforming to the standards. The American National Standards Institute does not develop standards and will in no circumstance give an interpretation of any American National Standard. Moreover, no person shall have the right or authority to issue an interpretation of an American National Standard in the name of the American National Standards Institute. Requests for interpretation should be addressed to the secretariat or sponsor whose name appears on the title page of this standard.

CAUTION NOTICE: This American National Standard may be revised or withdrawn at any time. The procedures of the American National Standards Institute require that action be taken to reaffirm, revise, or withdraw this standard no later than five years from the date of publication. Purchasers of American National Standards may receive current information on all standards by calling or writing the American National Standards Institute.

Published by

**International Safety Equipment Association  
1901 North Moore Street, Suite 808, Arlington, Virginia 22209**

Copyright by ISEA

All rights reserved.

No part of this publication may be reproduced in any form, in an electronic retrieval system or otherwise, without the prior written permission of the publisher.

Printed in the United States of America

**Foreword** (This Foreword is not part of American National Standard ANSI/ISEA Z358.1-2014)

This revision updates ANSI Z358.1-2009 and was prepared by the Emergency Eyewash and Shower Group of the International Safety Equipment Association, whose members are thoroughly knowledgeable in the design, installation, and use of this important safety equipment. The following companies were members of the group at the time of the approval of the standard: Bradley Corporation, Encon Safety Products, FSI International, Guardian Equipment, Honeywell Safety Products, Hughes Safety Showers, Prevor, Inc., Sellstrom Manufacturing, Speakman Company, and VisionAid.

Updates to the 2009 version of the standard are reflected in this document, including improvement in language to emphasize that the location of the fluid flow and pattern delivery for emergency eyewashes and eye/face washes is the critical aspect in designing and installing these devices, rather than the positioning of the nozzles themselves. Additionally, illustrations have been updated to reflect contemporary design configurations that are known to meet the criteria in standard.

Suggestions for the improvement of this standard are welcome. They should be sent to the ISEA, 1901 N. Moore Street, Suite 808, Arlington, VA 22209 or [isea@safetysystem.org](mailto:isea@safetysystem.org).

This standard was processed and approved using consensus procedures prescribed by the American National Standards Institute. The following organizations were contacted prior to the approval of this standard. Inclusion in this list does not necessarily imply that the organization concurred with the submittal of the proposed standard to ANSI.

Acorn Safety  
APPA, Leadership in Educational Facilities  
Alabama Power Company  
Arts, Crafts & Theater Safety Inc.  
Atlantic Health  
Atlas Industrial Contractors, LLC  
BASF Corporation  
Baylor Scott & White Health  
CalOSHA  
Cardinal Health  
County of Sacramento  
Erdman  
Green Conversion Systems  
Haws Corporation  
International Safety Equipment Association  
Intertek

Lawler Manufacturing  
Natural Resources Canada  
North Carolina Department of Labor  
Safety Equipment Institute  
Special Graphic Imaging Association  
State of Ohio Public Employment Risk Reduction  
Program  
Syracuse Utilities  
UL LLC  
University of Georgia  
University of Michigan  
US Department of the Army  
US Department of the Navy  
Williams Energy

## Contents

SECTION	PAGE
1. Scope .....	1
2. Purpose.....	1
3. Definitions .....	1
4. Emergency Showers .....	2
4.1 Performance of Emergency Showers .....	2
4.2 Performance of Control Valve .....	2
4.3 Emergency Shower Enclosures .....	2
4.4 Testing Procedures for Certification.....	2
4.5 Installation .....	3
4.6 Maintenance and Training.....	4
5. Eyewash Equipment .....	4
5.1 Performance of Eyewashes .....	4
5.2 Performance of Control Valve .....	4
5.3 Testing Procedures for Certification.....	5
5.4 Installation .....	5
5.5 Maintenance and Training.....	6
6. Eye/Face Wash Equipment .....	6
6.1 Performance of Eye/Face Washes .....	6
6.2 Performance of Control Valve .....	7
6.3 Testing Procedures for Certification.....	7
6.4 Installation .....	7
6.5 Maintenance and Training.....	8
7. Combination Units.....	8
7.1 Performance of Combination Units .....	8
7.2 Performance of Control Valve .....	8
7.3 Testing Procedures for Certification.....	8
7.4 Installation .....	8
7.5 Maintenance and Training.....	9
8. Supplemental Equipment.....	9
8.1 Personal Wash Units .....	9
8.2 Drench Hoses .....	10

SECTION	PAGE
ILLUSTRATIONS	
Illustration 1	Emergency Shower – Overhead Type ..... 11
Illustration 2	Emergency Shower – Multi-Nozzle ..... 12
Illustration 3	Emergency Shower – Multi-Nozzle with Overhead Fixture ..... 13
Illustration 4	Plumbed Eyewash ..... 14
Illustration 5	Nonpressurized Self-Contained Eyewash..... 15
Illustration 6	Pressurized Self-Contained Eyewash..... 15
Illustration 7	Typical Eyewash Gauge ..... 16
Illustration 8	Eye/Face Wash ..... 16
Illustration 9	Combination Unit ..... 17
Illustration 10	Personal Wash Units ..... 18
Illustration 11	Drench Hose ..... 18
Illustration 12	Drench Hose with Eyewash Attachment..... 18
APPENDICES	
Appendix A – Safety Considerations	..... 19
Appendix B – Installation Considerations	..... 20
REFERENCES.....	22

This is a preview of "ANSI/ISEA Z358.1-201...". [Click here to purchase the full version from the ANSI store.](#)

## American National Standard for Emergency Eyewash and Shower Equipment

### 1. Scope

This standard establishes minimum performance and use requirements for eyewash and shower equipment for the emergency treatment of the eyes or body of a person who has been exposed to hazardous materials. It covers the following types of equipment: emergency showers, eyewashes, eye/face washes, and combination units.

This standard also includes performance and use requirements for personal wash units and drench hoses, which are considered supplemental to emergency eyewash and shower equipment.

### 2. Purpose

This standard is intended to provide uniform minimum requirements for the performance, use, installation, test procedures, maintenance and training of emergency eyewash and shower equipment.

### 3. Definitions

For the purpose of this standard, the following terms apply as defined:

**certified:** A system whereby a certification organization determines that a manufacturer has demonstrated the ability to produce a product that complies with the requirements of this standard, authorizes the manufacturer to use a label on listed products that comply with the requirements of this standard, and establishes a follow-up program conducted by the certification organization as a check on the methods the manufacturer uses to determine continued compliance of labeled and listed products with the requirements of this standard.

**certification organization:** An independent third party organization that determines product compliance with the requirements of this standard with a labeling/listing/follow-up program.

**combination unit:** An interconnected assembly of emergency equipment supplied by a single source of flushing fluid.

**drench hose:** A supplemental device consisting of a flexible hose connected to a flushing fluid supply and used to provide fluid to irrigate and flush face and body areas.

**emergency shower:** A device specifically designed and intended to deliver flushing fluid in sufficient volume to cause that fluid to cascade over the entire body.

**eye/face wash:** A device used to provide fluid to irrigate and flush both the face and the eyes simultaneously.

**eyewash:** A device used to provide fluid to irrigate and flush the eyes.

**flow pressure:** The pressure in the water supply pipe near the water outlet while the faucet or outlet is fully open and flowing.

**flushing fluid:** Potable water, preserved water, preserved buffered saline solution or other medically acceptable solution manufactured and labeled in accordance with applicable government regulations.

**flushing fluid column:** The dispersion pattern of flushing fluid which is created by an emergency shower and meets the standard's prescribed coverage requirements. This pattern can be achieved by a variety of design configurations.

**freeze protected equipment:** Equipment designed to allow the emergency device to operate under freezing conditions.

**freeze protection:** A means to protect flushing fluid in an apparatus from freezing and rendering it inoperable. This can be achieved through several means including mechanical valves and electrical heat tracing.

**hazardous material:** Any substance or compound that has the capability of producing