

This is a preview of "ISO 13347-3:2004". [Click here to purchase the full version from the ANSI store.](#)

First edition
2004-08-15

Industrial fans — Determination of fan sound power levels under standardized laboratory conditions —

Part 3: Enveloping surface methods

*Ventilateurs industriels — Détermination des niveaux de puissance
acoustique des ventilateurs dans des conditions de laboratoire
normalisées —*

Partie 3: Méthodes de la surface enveloppante



Reference number
ISO 13347-3:2004(E)

© ISO 2004

This is a preview of "ISO 13347-3:2004". [Click here to purchase the full version from the ANSI store.](#)

PDF disclaimer

This PDF file may contain embedded typefaces. In accordance with Adobe's licensing policy, this file may be printed or viewed but shall not be edited unless the typefaces which are embedded are licensed to and installed on the computer performing the editing. In downloading this file, parties accept therein the responsibility of not infringing Adobe's licensing policy. The ISO Central Secretariat accepts no liability in this area.

Adobe is a trademark of Adobe Systems Incorporated.

Details of the software products used to create this PDF file can be found in the General Info relative to the file; the PDF-creation parameters were optimized for printing. Every care has been taken to ensure that the file is suitable for use by ISO member bodies. In the unlikely event that a problem relating to it is found, please inform the Central Secretariat at the address given below.

© ISO 2004

All rights reserved. Unless otherwise specified, no part of this publication may be reproduced or utilized in any form or by any means, electronic or mechanical, including photocopying and microfilm, without permission in writing from either ISO at the address below or ISO's member body in the country of the requester.

ISO copyright office
Case postale 56 • CH-1211 Geneva 20
Tel. + 41 22 749 01 11
Fax + 41 22 749 09 47
E-mail copyright@iso.org
Web www.iso.org

Published in Switzerland

This is a preview of "ISO 13347-3:2004". Click here to purchase the full version from the ANSI store.

Contents

Page

Foreword	iv
Introduction	v
1 Scope	1
2 Normative references	1
3 Acoustic environment and ducting	2
4 Determination of measurement surface	4
5 Test method	17
6 Acoustic tests: determination of sound power level	18
Annex A (normative) Determination of environmental correction K_2	20
Bibliography	21

Foreword

ISO (the International Organization for Standardization) is a worldwide federation of national standards bodies (ISO member bodies). The work of preparing International Standards is normally carried out through ISO technical committees. Each member body interested in a subject for which a technical committee has been established has the right to be represented on that committee. International organizations, governmental and non-governmental, in liaison with ISO, also take part in the work. ISO collaborates closely with the International Electrotechnical Commission (IEC) on all matters of electrotechnical standardization.

International Standards are drafted in accordance with the rules given in the ISO/IEC Directives, Part 2.

The main task of technical committees is to prepare International Standards. Draft International Standards adopted by the technical committees are circulated to the member bodies for voting. Publication as an International Standard requires approval by at least 75 % of the member bodies casting a vote.

Attention is drawn to the possibility that some of the elements of this document may be the subject of patent rights. ISO shall not be held responsible for identifying any or all such patent rights.

ISO 13347-3 was prepared by Technical Committee ISO/TC 117, *Industrial fans*.

ISO 13347 consists of the following parts, under the general title *Industrial fans — Determination of fan sound power levels under standardized laboratory conditions*:

- *Part 1: General overview*
- *Part 2: Reverberant room method*
- *Part 3: Enveloping surface methods*
- *Part 4: Sound intensity method*

This is a preview of "ISO 13347-3:2004". [Click here to purchase the full version from the ANSI store.](#)

Introduction

This part of ISO 13347 establishes a method for determining the sound power level of a fan. The method is reproducible in all laboratories which are qualified according to the requirements of this part of ISO 13347.

The method employs standard sound measurement instrumentation, applied to rooms which are restricted in certain acoustic properties. The test set-ups are generally designed to represent the physical orientation of a fan as installed, in accordance with ISO 5801.

Since sound power levels are considered independent of the acoustic environment around the fan, a good comparison may be made between two or more fans proposed for any specific air performance condition. Moreover, these values establish an accurate base for estimating the acoustical outcome of the fan installation in terms of sound pressure levels. A successful estimate of sound pressure levels requires extensive information on the fan and the environment in which it is to be located.

It is often advantageous for the equipment user to employ acoustical consultation to ensure that all factors which affect the final sound pressure levels are considered. More detailed information on the complexity of this situation may be found in acoustic text books.