

This is a preview of "ISO 16732-1:2012". [Click here to purchase the full version from the ANSI store.](#)

First edition
2012-02-15

Fire safety engineering — Fire risk assessment —

Part 1: General

*Ingénierie de la sécurité incendie — Évaluation du risque d'incendie —
Partie 1: Généralités*



Reference number
ISO 16732-1:2012(E)

© ISO 2012

This is a preview of "ISO 16732-1:2012". [Click here to purchase the full version from the ANSI store.](#)



COPYRIGHT PROTECTED DOCUMENT

© ISO 2012

All rights reserved. Unless otherwise specified, no part of this publication may be reproduced or utilized in any form or by any means, electronic or mechanical, including photocopying and microfilm, without permission in writing from either ISO at the address below or ISO's member body in the country of the requester.

ISO copyright office
Case postale 56 • CH-1211 Geneva 20
Tel. + 41 22 749 01 11
Fax + 41 22 749 09 47
E-mail copyright@iso.org
Web www.iso.org

Published in Switzerland

This is a preview of "ISO 16732-1:2012". [Click here to purchase the full version from the ANSI store.](#)

Contents

Page

Foreword	iv
Introduction	v
1 Scope	1
2 Normative references	1
3 Terms and definitions	1
4 Applicability of fire risk assessment	5
4.1 Circumstances where fire risk assessment provides advantages relative to deterministic fire safety engineering analysis	5
5 Overview of fire risk management	5
6 Steps in fire risk estimation	6
6.1 Overview of fire risk estimation	6
6.2 Use of scenarios in fire risk assessment	7
6.3 Estimation of frequency and probability	9
6.4 Estimation of consequence	12
6.5 Calculation of scenario fire risk and combined fire risk	13
7 Uncertainty, sensitivity, precision, and bias	15
7.1 Elements of uncertainty analysis	15
7.2 Validation and peer review	16
8 Fire risk evaluation	16
8.1 Individual and societal risk	16
8.2 Risk acceptance criteria	17
8.3 Safety factors and safety margins	18
Bibliography	19

Foreword

ISO (the International Organization for Standardization) is a worldwide federation of national standards bodies (ISO member bodies). The work of preparing International Standards is normally carried out through ISO technical committees. Each member body interested in a subject for which a technical committee has been established has the right to be represented on that committee. International organizations, governmental and non-governmental, in liaison with ISO, also take part in the work. ISO collaborates closely with the International Electrotechnical Commission (IEC) on all matters of electrotechnical standardization.

International Standards are drafted in accordance with the rules given in the ISO/IEC Directives, Part 2.

The main task of technical committees is to prepare International Standards. Draft International Standards adopted by the technical committees are circulated to the member bodies for voting. Publication as an International Standard requires approval by at least 75 % of the member bodies casting a vote.

Attention is drawn to the possibility that some of the elements of this document may be the subject of patent rights. ISO shall not be held responsible for identifying any or all such patent rights.

ISO 16732-1 was prepared by Technical Committee ISO/TC 92, *Fire safety*, Subcommittee SC 4, *Fire safety engineering*.

This first edition of ISO 16732-1 cancels and replaces ISO/TS 16732:2005, which has been technically revised.

ISO 16732 consists of the following parts, under the general title *Fire safety engineering — Fire risk assessment*:

— *Part 1: General*

The following parts are under preparation:

— *Part 2: Example of an office building*

— *Part 3: Example of an industrial facility* [Technical Report]

This is a preview of "ISO 16732-1:2012". [Click here to purchase the full version from the ANSI store.](#)

Introduction

This part of ISO 16732 is for use by fire safety practitioners who employ risk assessment based methods. Any fire safety practitioner can have reason to employ such methods. All fire safety decisions involve uncertainty. Probabilities are the mathematical representation of uncertainty, and risk assessment is the form of fire safety analysis that most extensively uses probabilities and so most extensively addresses all types of uncertainty.

Examples of types of such fire safety practitioners include fire safety engineers; authorities having jurisdiction, such as territorial authority officials; fire service personnel; code enforcers; code developers; insurers; fire safety managers; and risk managers. Users of this part of ISO 16732 are to be appropriately qualified and competent in the fields of fire safety engineering and risk assessment. It is particularly important that the user understand the limitations of application of any methodology that is used.

Risk assessment is preceded by two steps: establishment of a context, including the fire safety objectives to be met, the subjects of the fire risk assessment to be performed, and related facts or assumptions; and identification of the various hazards to be assessed. A "hazard" is something with the potential to cause harm.

The subjects of fire risk assessment include the design and control of any part of the built environment, such as buildings or other structures. Fire risk assessment of a design consists of analysis of the risks, e.g. frequency and severity of harm, that are predicted to result if the design is implemented, combined with an evaluation of the acceptability of those risks.

Fire risk assessment can be used to support any decisions about fire prevention or fire protection of new or existing built environments, such as buildings, where probabilistic aspects, such as fire ignition or the reliability of fire precautions, are important. Fire risk assessment can also be used to establish safety equivalent to a code, to assess the balance between the cost and the risk reduction benefit of a proposal, or to examine acceptable risk specifically for severe events. Fire risk assessment can also be used to provide general guidance or to support choices in the selection of scenarios and other elements of a deterministic analysis.

Fire risk assessment can be used as part of compliance with ISO 23932, and all the requirements of ISO 23932 apply to any application of this part of ISO 16732. ISO 23932 identifies different applications of fire risk assessment. One application is for the limited purpose of identifying a manageable number of design fire scenarios for a deterministic analysis. This use of fire risk assessment is cited in ISO 23932:2009, 9.2.2.2 and 9.2.2.3. Additional guidance for this application is contained in ISO/TS 16733.

The other application, cited in ISO 23932:2009, 10.1.1.2, is as a calculation method to assess whether a proposed or existing design plan meets fire safety objectives when the performance criteria for the fire safety objectives are expressed in a probabilistic form. That application is the one for which ISO 16732 is principally designed. In that application the concept of design fire scenario, as described in ISO 23932, is better addressed through the dual concepts of fire scenario cluster and representative fire scenario used in this part of ISO 16732. The user should regard representative fire scenarios as the types of design fire scenarios used in fire risk assessment. The term "representative" and the linkage with fire scenario clusters are necessary to establish that calculations based on the selected scenarios will produce an acceptably accurate estimate of the required performance criteria, expressed as measures of fire risk, in accordance with ISO 23932.