

This is a preview of "ISO 16890-2:2016". [Click here to purchase the full version from the ANSI store.](#)

First edition
2016-12-01

Air filters for general ventilation — Part 2: Measurement of fractional efficiency and air flow resistance

Filtres à air de ventilation générale —

*Partie 2: Mesurage de l'efficacité spectrale et de la résistance à
l'écoulement de l'air*



Reference number
ISO 16890-2:2016(E)

© ISO 2016

This is a preview of "ISO 16890-2:2016". [Click here to purchase the full version from the ANSI store.](#)



COPYRIGHT PROTECTED DOCUMENT

© ISO 2016, Published in Switzerland

All rights reserved. Unless otherwise specified, no part of this publication may be reproduced or utilized otherwise in any form or by any means, electronic or mechanical, including photocopying, or posting on the internet or an intranet, without prior written permission. Permission can be requested from either ISO at the address below or ISO's member body in the country of the requester.

ISO copyright office
Ch. de Blandonnet 8 • CP 401
CH-1214 Vernier, Geneva, Switzerland
Tel. +41 22 749 01 11
Fax +41 22 749 09 47
copyright@iso.org
www.iso.org

This is a preview of "ISO 16890-2:2016". Click here to purchase the full version from the ANSI store.

Contents

	Page
Foreword	vi
Introduction	vii
1 Scope	1
2 Normative references	1
3 Terms and definitions	2
4 Symbols and abbreviated terms	4
4.1 Symbols.....	4
4.2 Abbreviated terms.....	6
5 General test requirements	6
5.1 Test device requirements.....	6
5.2 Test device installation.....	6
5.3 Test rig requirements.....	6
6 Test materials	7
6.1 Liquid phase aerosol.....	7
6.1.1 DEHS test aerosol.....	7
6.1.2 DEHS/DES/DOS - formula.....	7
6.1.3 DEHS properties.....	7
6.1.4 Liquid phase aerosol generation.....	7
6.2 Solid phase aerosol.....	8
6.2.1 Potassium chloride (KCl) test aerosol.....	8
6.2.2 KCl - formula.....	8
6.2.3 KCl properties.....	8
6.2.4 Solid phase aerosol generation.....	9
6.3 Reference aerosols.....	10
6.3.1 Reference aerosol for 0,3 µm to 1,0 µm.....	10
6.3.2 Reference aerosol for 1,0 µm to 10,0 µm.....	10
6.3.3 Other reference aerosols.....	10
6.3.4 Matching criteria.....	11
6.4 Aerosol loading.....	11
7 Test equipment	11
7.1 Test rig.....	11
7.1.1 Dimensions.....	11
7.1.2 Construction materials.....	12
7.1.3 Test rig shape.....	12
7.1.4 Test rig air supply.....	13
7.1.5 Test rig isolation.....	13
7.1.6 D/S mixing orifice.....	13
7.1.7 Aerosol sampling.....	14
7.1.8 Test rig air flow rate measurement.....	16
7.1.9 Resistance to air flow measurement.....	16
7.1.10 Non 610 mm × 610 mm (24,0 inch × 24,0 inch) test devices.....	17
7.1.11 Dust injection testing.....	18
7.2 Aerosol particle counter.....	18
7.2.1 General.....	18
7.2.2 OPC sampled size range.....	18
7.2.3 OPC particle size ranges.....	18
7.2.4 Sizing resolution.....	19
7.2.5 Calibration.....	19
7.2.6 Air flow rate.....	19
7.2.7 Zero counting.....	19
7.2.8 Dual OPC(s).....	19
7.3 Temperature, relative humidity.....	20

8	Qualification of test rig and apparatus	20
8.1	Schedule of qualification testing requirements	20
8.1.1	General	20
8.1.2	Qualification testing	20
8.1.3	Qualification documentation	20
8.2	Qualification testing	21
8.2.1	Test rig — Pressure system testing	21
8.2.2	OPC — Air flow rate stability test	22
8.2.3	OPC — Zero test	22
8.2.4	OPC — Sizing accuracy	23
8.2.5	OPC — Overload test	23
8.2.6	Aerosol generator — Response time	24
8.2.7	Aerosol generator — Neutralizer	24
8.2.8	Test rig — Air leakage test	25
8.2.9	Test rig — Air velocity uniformity	26
8.2.10	Test rig — Aerosol uniformity	27
8.2.11	Test rig — Downstream mixing	28
8.2.12	Test rig — Empty test device section pressure	29
8.2.13	Test rig — 100 % efficiency test and purge time	30
8.2.14	Test rig — Correlation ratio	30
8.3	Maintenance	30
8.3.1	General	30
8.3.2	Test rig — Background counts	31
8.3.3	Test rig — Reference filter test	32
8.3.4	Test rig — Pressure reference test	33
8.3.5	Test rig — Final filter resistance	33
9	Test methods	33
9.1	Air flow rate	33
9.2	Measurement of resistance to air flow	33
9.3	Measurement of fractional efficiency	33
9.3.1	Aerosol sampling protocol	33
9.3.2	Background sampling	33
9.3.3	Testing sequence for a single OPC	34
9.3.4	Testing sequence for dual OPC testing	36
10	Data reduction and calculations	38
10.1	Correlation ratio	38
10.1.1	Correlation ratio general	38
10.1.2	Correlation ratio data reduction	38
10.2	Penetration and fractional efficiency	40
10.2.1	Penetration and fractional efficiency general	40
10.2.2	Penetration data reduction	40
10.3	Data quality requirements	43
10.3.1	Correlation background counts	43
10.3.2	Efficiency background counts	43
10.3.3	Correlation ratio	43
10.3.4	Penetration	44
10.4	Fractional efficiency calculation	44
11	Reporting results	45
11.1	General	45
11.2	Required reporting elements	45
11.2.1	Report general	45
11.2.2	Report values	45
11.2.3	Report summary	45
11.2.4	Report details	47
	Annex A (informative) Example	50
	Annex B (informative) Resistance to air flow calculation	57

This is a preview of "ISO 16890-2:2016". [Click here to purchase the full version from the ANSI store.](#)

Bibliography	59
---------------------------	-----------

Foreword

ISO (the International Organization for Standardization) is a worldwide federation of national standards bodies (ISO member bodies). The work of preparing International Standards is normally carried out through ISO technical committees. Each member body interested in a subject for which a technical committee has been established has the right to be represented on that committee. International organizations, governmental and non-governmental, in liaison with ISO, also take part in the work. ISO collaborates closely with the International Electrotechnical Commission (IEC) on all matters of electrotechnical standardization.

The procedures used to develop this document and those intended for its further maintenance are described in the ISO/IEC Directives, Part 1. In particular the different approval criteria needed for the different types of ISO documents should be noted. This document was drafted in accordance with the editorial rules of the ISO/IEC Directives, Part 2 (see www.iso.org/directives).

Attention is drawn to the possibility that some of the elements of this document may be the subject of patent rights. ISO shall not be held responsible for identifying any or all such patent rights. Details of any patent rights identified during the development of the document will be in the Introduction and/or on the ISO list of patent declarations received (see www.iso.org/patents).

Any trade name used in this document is information given for the convenience of users and does not constitute an endorsement.

For an explanation on the meaning of ISO specific terms and expressions related to conformity assessment, as well as information about ISO's adherence to the World Trade Organization (WTO) principles in the Technical Barriers to Trade (TBT) see the following URL: www.iso.org/iso/foreword.html.

The committee responsible for this document is ISO/TC 142, *Cleaning equipment for air and other gases*.

This first edition of ISO 16890-2, together with ISO 16890-1, ISO 16890-3 and ISO 16890-4, cancels and replaces ISO/TS 21220:2009, which has been technically revised.

ISO 16890 consists of the following parts, under the general title *Air filters for general ventilation*:

- *Part 1: Technical specifications, requirements and classification system based upon particulate matter efficiency (ePM)*
- *Part 2: Measurement of fractional efficiency and air flow resistance*
- *Part 3: Determination of the gravimetric efficiency and the air flow resistance versus the mass of test dust captured*
- *Part 4: Conditioning method to determine the minimum fractional test efficiency*

This is a preview of "ISO 16890-2:2016". [Click here to purchase the full version from the ANSI store.](#)

Introduction

The effects of particulate matter (PM) on human health have been extensively studied in the past decades. The results are that fine dust can be a serious health hazard, contributing to or even causing respiratory and cardiovascular diseases. Different classes of particulate matter can be defined according to the particle size range. The most important ones are PM₁₀, PM_{2,5} and PM₁. The U.S. Environmental Protection Agency (EPA), the World Health Organization (WHO) and the European Union define PM₁₀ as particulate matter which passes through a size-selective inlet with a 50 % efficiency cut-off at 10 µm aerodynamic diameter. PM_{2,5} and PM₁ are similarly defined. However, this definition is not precise if there is no further characterization of the sampling method and the sampling inlet with a clearly defined separation curve. In Europe, the reference method for the sampling and measurement of PM₁₀ is described in EN 12341. The measurement principle is based on the collection on a filter of the PM₁₀ fraction of ambient particulate matter and the gravimetric mass determination (see EU Council Directive 1999/30/EC of 22 April 1999).

As the precise definition of PM₁₀, PM_{2,5} and PM₁ is quite complex and not simple to measure, public authorities, like the U.S. EPA or the German Federal Environmental Agency (Umweltbundesamt), increasingly use in their publications the more simple denotation of PM₁₀ as being the particle size fraction less or equal to 10 µm. Since this deviation to the above mentioned complex "official" definition does not have a significant impact on a filter element's particle removal efficiency, the ISO 16890 series refers to this simplified definition of PM₁₀, PM_{2,5} and PM₁.

Particulate matter in the context of the ISO 16890 series describes a size fraction of the natural aerosol (liquid and solid particles) suspended in ambient air. The symbol ePM_x describes the efficiency of an air cleaning device to particles with an optical diameter between 0,3 µm and x µm. The following particle size ranges are used in the ISO 16890 series for the listed efficiency values.

Table 1 — Optical particle diameter size ranges for the definition of the efficiencies, ePM_x

Efficiency	Size range, µm
ePM_{10}	$0,3 \leq x \leq 10$
$ePM_{2,5}$	$0,3 \leq x \leq 2,5$
ePM_1	$0,3 \leq x \leq 1$

Air filters for general ventilation are widely used in heating, ventilation and air-conditioning applications of buildings. In this application, air filters significantly influence the indoor air quality and, hence, the health of people, by reducing the concentration of particulate matter. To enable design engineers and maintenance personnel to choose the correct filter types, there is an interest from international trade and manufacturing for a well-defined, common method of testing and classifying air filters according to their particle efficiencies, especially with respect to the removal of particulate matter. Current regional standards are applying totally different testing and classification methods which do not allow any comparison with each other, and thus hinder global trade with common products. Additionally, the current industry standards have known limitations by generating results which often are far away from filter performance in service, i.e. overstating the particle removal efficiency of many products. With this new ISO 16890 series, a completely new approach for a classification system is adopted, which gives better and more meaningful results compared to the existing standards.

The ISO 16890 series describes the equipment, materials, technical specifications, requirements, qualifications and procedures to produce the laboratory performance data and efficiency classification based upon the measured fractional efficiency converted into a particulate matter efficiency (ePM) reporting system.

Air filter elements according to the ISO 16890 series are evaluated in the laboratory by their ability to remove aerosol particulate expressed as the efficiency values ePM_1 , $ePM_{2,5}$ and ePM_{10} . The air filter elements can then be classified according to the procedures defined in ISO 16890-1. The particulate removal efficiency of the filter element is measured as a function of the particle size in the range of 0,3 µm to 10 µm of the unloaded and unconditioned filter element as per the procedures defined in this part of ISO 16890. After the initial particulate removal efficiency testing, the air filter element is

This is a preview of "ISO 16890-2:2016". [Click here to purchase the full version from the ANSI store.](#)

conditioned according to the procedures defined in ISO 16890-4 and the particulate removal efficiency is repeated on the conditioned filter element. This is done to provide information about the intensity of any electrostatic removal mechanism which may or may not be present with the filter element for test. The average efficiency of the filter is determined by calculating the mean between the initial efficiency and the conditioned efficiency for each size range. The average efficiency is used to calculate the ePM_x efficiencies by weighting these values to the standardized and normalized particle size distribution of the related ambient aerosol fraction. When comparing filters tested in accordance with the ISO 16890 series, the fractional efficiency values shall always be compared among the same ePM_x class (ex. ePM_1 of filter A with ePM_1 of filter B). The test dust capacity and the initial arrestance of a filter element are determined as per the test procedures defined in ISO 16890-3.