

Second edition 2007-03-01

# Fluid flow in closed conduits — Connections for pressure signal transmissions between primary and secondary elements

Débit des fluides dans les conduites fermées — Liaisons pour la transmission du signal de pression entre les éléments primaires et secondaires



### PDF disclaimer

This PDF file may contain embedded typefaces. In accordance with Adobe's licensing policy, this file may be printed or viewed but shall not be edited unless the typefaces which are embedded are licensed to and installed on the computer performing the editing. In downloading this file, parties accept therein the responsibility of not infringing Adobe's licensing policy. The ISO Central Secretariat accepts no liability in this area.

Adobe is a trademark of Adobe Systems Incorporated.

Details of the software products used to create this PDF file can be found in the General Info relative to the file; the PDF-creation parameters were optimized for printing. Every care has been taken to ensure that the file is suitable for use by ISO member bodies. In the unlikely event that a problem relating to it is found, please inform the Central Secretariat at the address given below.

### © ISO 2007

All rights reserved. Unless otherwise specified, no part of this publication may be reproduced or utilized in any form or by any means, electronic or mechanical, including photocopying and microfilm, without permission in writing from either ISO at the address below or ISO's member body in the country of the requester.

ISO copyright office
Case postale 56 • CH-1211 Geneva 20
Tel. + 41 22 749 01 11
Fax + 41 22 749 09 47
E-mail copyright@iso.org
Web www.iso.org

Published in Switzerland

Contents		Page
1	Scope	. 1
2	Normative references	. 1
3	Terms and definitions	. 1
4	General principles	. 1
4.1	Safe containment	. 1
4.2	Piping specification	2
4.3	Isolation (block) valves	. 3
4.4	Valve manifolds	. 3
4.5	Installation	4
4.6	Pressure taps	. 5
4.7	Impulse line size	. 5
4.8	Insulation	6
5	Horizontal piping installations	6
5.1	Gases	6
5.2	Liquids	6
5.3	Condensing vapours, e.g. steam	. 7
6	Vertical piping systems	. 7
6.1	General	. 7
6.2	Gases	. 7
6.3	Liquids	. 7
6.4	Condensing vapours, e.g. steam	. 8
7	Piezometer ring	. 8
8	Special cases	. 8
Ann	nex A (informative) Guidance on pipe diameters for long impulse lines	10
Ann	nex B (informative) Impulse-line dynamics	11
	nex C (informative) Elevation head example calculation	12
	nex D (informative) Supplementary figures	13
Bib	liography	20

## **Foreword**

ISO (the International Organization for Standardization) is a worldwide federation of national standards bodies (ISO member bodies). The work of preparing International Standards is normally carried out through ISO technical committees. Each member body interested in a subject for which a technical committee has been established has the right to be represented on that committee. International organizations, governmental and non-governmental, in liaison with ISO, also take part in the work. ISO collaborates closely with the International Electrotechnical Commission (IEC) on all matters of electrotechnical standardization.

International Standards are drafted in accordance with the rules given in the ISO/IEC Directives, Part 2.

The main task of technical committees is to prepare International Standards. Draft International Standards adopted by the technical committees are circulated to the member bodies for voting. Publication as an International Standard requires approval by at least 75 % of the member bodies casting a vote.

Attention is drawn to the possibility that some of the elements of this document may be the subject of patent rights. ISO shall not be held responsible for identifying any or all such patent rights.

ISO 2186 was prepared by Technical Committee ISO/TC 30, *Measurement of fluid flow in closed conduits*, Subcommittee SC 2, *Pressure differential devices*.

This second edition cancels and replaces the first edition (ISO 2186:1973), which has been technically revised.

# Introduction

The primary devices are flow meters described in ISO 5167 (all parts).

A secondary device in this context receives a differential pressure signal from a primary device and can display the differential pressure value and convert it into a signal of a different nature, i.e. an analogue or digital signal, to transmit the value of the differential pressure to another location.