

This is a preview of "ISO 29461-1:2013". [Click here to purchase the full version from the ANSI store.](#)

First edition
2013-04-01

Air intake filter systems for rotary machinery — Test methods —

Part 1: Static filter elements

*Systèmes de filtration d'air d'admission pour machines tournantes —
Méthodes d'essai —*

Partie 1: Éléments filtrants pour filtres statiques



Reference number
ISO 29461-1:2013(E)

© ISO 2013

This is a preview of "ISO 29461-1:2013". [Click here to purchase the full version from the ANSI store.](#)



COPYRIGHT PROTECTED DOCUMENT

© ISO 2013

All rights reserved. Unless otherwise specified, no part of this publication may be reproduced or utilized otherwise in any form or by any means, electronic or mechanical, including photocopying, or posting on the internet or an intranet, without prior written permission. Permission can be requested from either ISO at the address below or ISO's member body in the country of the requester.

ISO copyright office
Case postale 56 • CH-1211 Geneva 20
Tel. + 41 22 749 01 11
Fax + 41 22 749 09 47
E-mail copyright@iso.org
Web www.iso.org

Published in Switzerland

This is a preview of "ISO 29461-1:2013". Click here to purchase the full version from the ANSI store.

Contents

	Page
Foreword	v
0 Introduction	vi
1 Scope	1
2 Normative references	1
3 Terms and definitions	2
3.2 Velocity.....	2
3.3 Efficiency.....	2
3.5 Pressure drop (differential pressure).....	3
3.6 Filter area.....	3
3.7 Filters.....	3
3.8 Test aerosol.....	4
3.9 Test dust.....	5
3.10 Particle sampling.....	5
3.11 Particle shedding.....	5
4 Symbols and abbreviated terms	6
5 General requirements	8
6 Test rig and equipment	8
6.1 Test condition.....	8
6.2 Test rig.....	8
6.3 DEHS test aerosol generation.....	12
6.4 Aerosol sampling system.....	13
6.5 Flow measurement.....	14
6.6 Particle counter.....	14
6.7 Differential pressure measuring equipment.....	15
6.8 Dust feeder.....	15
6.9 Diluter equipment.....	17
7 Qualification of test rig and apparatus	18
7.1 General.....	18
7.2 Air velocity uniformity in the test duct.....	18
7.3 Aerosol uniformity in the test duct.....	19
7.4 Particle counter sizing accuracy.....	20
7.5 Particle counter zero test.....	20
7.6 Particle counter overload test.....	20
7.7 100 % efficiency test.....	21
7.8 Zero % efficiency test.....	21
7.9 Aerosol generator response time.....	21
7.10 Dilution ratio.....	22
7.11 Correlation ratio.....	22
7.12 Pressure drop checking.....	23
7.13 Dust feeder airflow rate.....	23
7.14 Reference filter check.....	24
7.15 Summary of qualification requirements.....	25
7.16 Apparatus maintenance.....	25
8 Test materials	26
8.1 Test air.....	26
8.2 Test aerosol.....	26
8.3 Loading dust.....	27
8.4 Final filter.....	27
9 Test procedure	27
9.1 Preparation of filter to be tested.....	28
9.2 Initial pressure drop.....	28

This is a preview of "ISO 29461-1:2013". Click here to purchase the full version from the ANSI store.

9.3	Initial particulate efficiency measurement.....	28
9.4	Conditioning test.....	32
9.5	Dust loading.....	32
10	Uncertainty calculation of the test results.....	33
10.1	Particulate efficiency for medium efficiency filters (initial particulate efficiency: 35 ≤ E ≤ 85 % at 0,4 μm).....	33
10.2	Particulate efficiency for high efficiency filters (initial particulate efficiency >85 % at 0,4 μm).....	34
10.3	Gravimetric efficiency.....	36
11	Reporting.....	36
11.1	General.....	36
11.2	Interpretation of test reports.....	37
11.3	Summary.....	38
11.4	Efficiency.....	40
11.5	Pressure drop and airflow rate.....	40
11.6	Marking.....	40
	Annex A (normative) Conditioning test procedure.....	47
	Annex B (informative) Shedding from filter elements.....	51
	Annex C (informative) Commentary.....	53
	Annex D (normative) Pressure drop calculation.....	57
	Annex E (normative) Net Area Calculation.....	59
	Bibliography.....	66

This is a preview of "ISO 29461-1:2013". [Click here to purchase the full version from the ANSI store.](#)

Foreword

ISO (the International Organization for Standardization) is a worldwide federation of national standards bodies (ISO member bodies). The work of preparing International Standards is normally carried out through ISO technical committees. Each member body interested in a subject for which a technical committee has been established has the right to be represented on that committee. International organizations, governmental and non-governmental, in liaison with ISO, also take part in the work. ISO collaborates closely with the International Electrotechnical Commission (IEC) on all matters of electrotechnical standardization.

International Standards are drafted in accordance with the rules given in the ISO/IEC Directives, Part 2.

The main task of technical committees is to prepare International Standards. Draft International Standards adopted by the technical committees are circulated to the member bodies for voting. Publication as an International Standard requires approval by at least 75 % of the member bodies casting a vote.

Attention is drawn to the possibility that some of the elements of this document may be the subject of patent rights. ISO shall not be held responsible for identifying any or all such patent rights.

ISO 29461-1 was prepared by Technical Committee ISO/TC 142, *Cleaning equipment for air and other gases*.

ISO 29461 consists of the following parts, under the general title *Air intake filter systems for rotary machinery — Test methods*:

— *Part 1: Static filter elements*

Cleanable (pulse jet) and surface loading filters, mechanical integrity of filter elements, *in situ* testing, marine and offshore environment filter systems, and cleanable (pulse Jet) filter elements will form the subjects of future parts.

0 Introduction

0.1 Filters in power generating/compressor applications

In rotating machinery applications, the filtering system, typically a set of filter elements arranged in a suitable manner, are an important part of the whole turbine/compressor system. The development of turbine machinery used for energy production or others has led to more sophisticated equipment and therefore the importance of good protection of these systems has become more important in the recent years. It is known that particulate contamination can deteriorate a turbine power system quite substantially if not taken care of.

This event is often described as “erosion”, “fouling” and “hot corrosion” where salt and other corrosive particles are known as potential problems. Other particulate matters may also cause significant reduction of efficiency of the systems. It is important to understand that air filter devices in such systems are located in various environmental conditions. The range of climate and particulate contamination is very wide, ranging from deserts to humid rain forests to arctic environments. The requirements on these filter systems are obviously different depending on where they will be operating.

ISO 29461 has based the performance of the air intake filter systems not only upon heavy dust collection but also particulate efficiency in a size range that is considered to be the problematic area for these applications. Both ultra-fine and fine particles, as well as larger particles, should be considered when evaluating turbine fouling. In typical outdoor air, ultra-fine and fine particles in the size range from 0,01 µm to 1 µm contribute to >99 % of the number concentration and to >90 % of the surface contamination. The majority of the mass normally comes from larger particles (>1,0 µm).

Turbo-machinery filters comprise a wide range of products from filters for very coarse particles to filters for very fine, sub-micron particles. The range of products varies from self-cleaning to depth and surface loading systems. The filters and the systems have to withstand a wide temperature and humidity range, very low to very high dust concentration and mechanical stress. The shape of products existing today can be of many different types and have different functions such as droplet separators, coalescing products, filter pads, metal filters, inertial filters, filter cells, bag filters, panel-type, self-cleanable and depth loading filter cartridges and pleated media surface filter elements.

ISO 29461 will provide a way to compare these products in a similar way and define what criteria are important for air filter intake systems for rotary machinery performance protection. The performance of products in this broad range must be compared in a good manner. Comparing different filters and filter types must be done with respect to the operating conditions they finally will be used in.

For instance, if a filter or a filter system is meant to operate in an extreme, very dusty environment, the real particulate efficiency of such a filter cannot be predicted because the dust loading of the filter plays an important role. ISO 29461-2 will address the performance of cleanable and surface loading filters.

0.2 Filtration characteristics

Initiatives to address the potential problems of particle re-entrainment, shedding and the in-service charge neutralization characteristics of certain types of media have been included in [Annexes A](#) and [B](#).

Certain types of filter media rely on electrostatic effects to achieve high efficiencies at low resistance to airflow. Exposure to some types of challenge, such as combustion particles or other fine particles, may inhibit such charges with the result that filter performance suffers. The normative test procedure, described in [Annex A](#), provides techniques for identifying this type of behaviour. This procedure is used to determine whether the filter particulate efficiency is dependent on the electrostatic removal mechanism and to provide quantitative information about the importance of the electrostatic removal. The procedure was selected because it is well established, reproducible, relatively fast and easy to perform.

In an ideal filtration process, each particle would be permanently arrested at the first contact with a filter fibre, but incoming particles may impact on a captured particle and dislodge it into the air stream. Fibres or particles from the filter itself could also be released, due to mechanical forces. From the user's point of view it might be important to know this, see [Annex B](#).

This is a preview of "ISO 29461-1:2013". [Click here to purchase the full version from the ANSI store.](#)

Filters with a low initial or conditioned particulate efficiency (<35 %) for sub-micron particles (0,4 µm) that do not increase their efficiency during the operation will typically not provide any major protection for the operating machinery when challenged with typical atmospheric aerosols where the majority of particles are smaller than 1,0 µm. However, in some cases with aerosols having a dominant fraction of coarse particles, filters with low efficiencies at sub-micron particles can serve as a protection for later filter stages and can also have a higher average particulate efficiency (e.g. surface loading filters) at 0,4 µm due to the dust loading. Therefore a gravimetric test can provide some information about capacity and gravimetric efficiency for those aerosols. In general, a lower total filtration level than 35 % at 0,4 µm should not be recommended for an air intake filter system for rotary machinery when the aerosol loading of the filters are not contributing to a significant increase of the efficiency during the operation.

0.3 Organization of ISO 29461

The methods and procedures for determining particulate efficiency, pressure drop and the corresponding reporting formats are the same for all types of static filter element.

The test methods concerning particulate efficiency, pressure drop and reported values are the same for all filters, except for loading characteristics and cleaning procedure, which are different for cleanable surface loading filters. These filters incorporate cleaning procedures and have different loading characteristics; therefore, they require appropriately modified test methods, which will be defined in Part 2.

Part 3 will provide methods for determining the mechanical integrity of filters under conditions that may be encountered in abnormal operating environments.

Part 4 will describe methods of testing installed filters under in-service operating conditions (*in situ* testing).

Part 5 will cover test methods for the specific requirement of offshore and marine application, and specify methods for determining the sea salt removal efficiency of individual filters and/or complete filter systems.

Part 6 will cover test methods for cleanable filter elements, and will not cover the system testing (e.g. cleaning device) as in Part 2.

This part of ISO 29461 describes the test methods for static filter units, typically of the depth loading type (see definitions 3.43 and 3.44). All filters can be tested in the same manner, thus obtaining comparable results. However, for surface loading filters, reverse pulse filters, marine and offshore filter systems, as well as other filter systems that are not regarded as static filter units, the appropriate part shall be used.

For multi-stage systems that use a number of components (e.g. equipment for cleaning, filters), this part of ISO 29461 may be used as long as the qualification requirements of the test rig can be fulfilled. In cases where this is not possible, Part 4 (*in situ* testing) procedures may be applied.