

This is a preview of "ISO 6358-2:2013". [Click here to purchase the full version from the ANSI store.](#)

First edition  
2013-05-01

---

---

# **Pneumatic fluid power — Determination of flow-rate characteristics of components using compressible fluids —**

## **Part 2: Alternative test methods**

*Transmissions pneumatiques — Détermination des caractéristiques  
de débit des composants traversés par un fluide compressible —*

*Partie 2: Méthodes d'essai alternatives*



Reference number  
ISO 6358-2:2013(E)

© ISO 2013



**COPYRIGHT PROTECTED DOCUMENT**

© ISO 2013

All rights reserved. Unless otherwise specified, no part of this publication may be reproduced or utilized otherwise in any form or by any means, electronic or mechanical, including photocopying, or posting on the internet or an intranet, without prior written permission. Permission can be requested from either ISO at the address below or ISO's member body in the country of the requester.

ISO copyright office  
Case postale 56 • CH-1211 Geneva 20  
Tel. + 41 22 749 01 11  
Fax + 41 22 749 09 47  
E-mail [copyright@iso.org](mailto:copyright@iso.org)  
Web [www.iso.org](http://www.iso.org)

Published in Switzerland

This is a preview of "ISO 6358-2:2013". Click here to purchase the full version from the ANSI store.

## Contents

	Page
<b>Foreword</b> .....	<b>iv</b>
<b>Introduction</b> .....	<b>v</b>
<b>1 Scope</b> .....	<b>1</b>
<b>2 Normative references</b> .....	<b>2</b>
<b>3 Terms and definitions</b> .....	<b>2</b>
<b>4 Symbols and units</b> .....	<b>2</b>
<b>5 Test installation</b> .....	<b>2</b>
5.1 Test circuit for discharge test.....	3
5.2 Test circuit for charge test.....	3
5.3 General requirements.....	4
5.4 Requirements for the tank (item 4).....	5
5.5 Special requirements.....	7
<b>6 Test procedures</b> .....	<b>8</b>
6.1 Test conditions.....	8
6.2 Measuring procedures.....	9
6.3 Calculation of characteristics.....	12
<b>7 Presentation of test results</b> .....	<b>16</b>
<b>8 Identification statement</b> (reference to this part of ISO 6358).....	<b>17</b>
<b>Annex A</b> (informative) <b>Evaluation of measurement uncertainty</b> .....	<b>18</b>
<b>Annex B</b> (normative) <b>Test method to determine and calibrate the volume of an isothermal tank</b> .....	<b>24</b>
<b>Annex C</b> (informative) <b>Isothermal tank stuffing</b> .....	<b>30</b>
<b>Annex D</b> (informative) <b>Test method to determine isothermal performance</b> .....	<b>33</b>
<b>Annex E</b> (informative) <b>Equations for calculation of flow-rate characteristics</b> .....	<b>36</b>
<b>Annex F</b> (informative) <b>Procedures for calculating critical back-pressure ratio, <math>b</math>, and subsonic index, <math>m</math>, by the least-square method using the Solver function in Microsoft Excel</b> .....	<b>39</b>
<b>Bibliography</b> .....	<b>43</b>

## Foreword

ISO (the International Organization for Standardization) is a worldwide federation of national standards bodies (ISO member bodies). The work of preparing International Standards is normally carried out through ISO technical committees. Each member body interested in a subject for which a technical committee has been established has the right to be represented on that committee. International organizations, governmental and non-governmental, in liaison with ISO, also take part in the work. ISO collaborates closely with the International Electrotechnical Commission (IEC) on all matters of electrotechnical standardization.

International Standards are drafted in accordance with the rules given in the ISO/IEC Directives, Part 2.

The main task of technical committees is to prepare International Standards. Draft International Standards adopted by the technical committees are circulated to the member bodies for voting. Publication as an International Standard requires approval by at least 75 % of the member bodies casting a vote.

Attention is drawn to the possibility that some of the elements of this document may be the subject of patent rights. ISO shall not be held responsible for identifying any or all such patent rights.

ISO 6358-2 was prepared by Technical Committee ISO/TC 131, *Fluid power systems*, Subcommittee SC 5, *Control products and components*.

This first edition of ISO 6358-2, together with ISO 6358-1 and ISO 6358-3, cancels and replaces ISO 6358:1989, which has been technically revised. However, ISO 6358-2 and ISO 6358-3 are new standards whose scopes were not included in ISO 6358:1989.

ISO 6358 consists of the following parts, under the general title *Pneumatic fluid power — Determination of flow-rate characteristics of components using compressible fluids*:

- *Part 1: General rules and test methods for steady-state flow*
- *Part 2: Alternative test methods*
- *Part 3: Method for calculating steady-state flow-rate characteristics of assemblies*

This is a preview of "ISO 6358-2:2013". [Click here to purchase the full version from the ANSI store.](#)

## Introduction

In pneumatic fluid power systems, power is transmitted and controlled through a gas under pressure within a circuit. Components that make up such a circuit are inherently resistive to the flow of the gas and it is necessary, therefore, to define and determine the flow-rate characteristics that describe their performance.

ISO 6358:1989 was developed to determine the flow-rate characteristics of pneumatic valves, based upon a model of converging nozzles. The method included two characteristic parameters: sonic conductance,  $C$ , and critical pressure ratio,  $b$ , used in a proposed mathematical approximation of the flow behaviour. The result described flow performance of a pneumatic valve from choked flow to subsonic flow, based on static pressure. This new edition uses stagnation pressure instead, to take into account the influence of flow velocity on the measurement of pressures.

Experience has demonstrated that many pneumatic valves have converging–diverging characteristics that do not fit the ISO 6358:1989 model very well. Furthermore, new developments have allowed the application of this method to additional components beyond pneumatic valves. However, this now requires the use of four parameters ( $C$ ,  $b$ ,  $m$ , and  $\Delta p_c$ ) to define the flow performance in both the choked and subsonic flow regions.

This part of ISO 6358 describes a set of three flow-rate characteristic parameters determined from test results. These parameters are described as follows and are listed in decreasing order of priority:

- The sonic conductance,  $C$ , corresponding to the maximum flow rate (choked) is the most important parameter. This parameter is defined by the upstream stagnation conditions.
- The critical back-pressure ratio,  $b$ , representing the boundary between choked and subsonic flow is second in importance. Its definition differs here from the one in ISO 6358:1989 because it corresponds to the ratio of downstream to upstream stagnation pressures.
- The subsonic index,  $m$ , is used if necessary to represent more accurately the subsonic flow behaviour. For components with a fixed flow path,  $m$  is distributed around 0,5. In these cases, only the first two characteristic parameters  $C$  and  $b$  are necessary. For many other components,  $m$  will vary widely. In these cases, it is necessary to determine  $C$ ,  $b$ , and  $m$ .

Several changes to the test equipment were made to overcome apparent violations of the theory of compressible fluid flow. This included expanded inlet pressure-measuring tubes to satisfy the assumptions of negligible inlet velocity to the item under test and to allow the inlet stagnation pressure to be measured directly. Expanded outlet tubes allow the direct measurement of downstream stagnation pressure to better accommodate the different component models. The difference between stagnation pressure at upstream and downstream of component means a loss of pressure energy.

ISO 6358-3 can be used to calculate without measurements an estimate of the overall flow-rate characteristics of an assembly of components and piping, using the characteristics of each component and piping determined in accordance with this part of ISO 6358 or ISO 6358-1.

The discharge and charge test methods specified in this part of ISO 6358 have the following advantages over the test method specified in ISO 6358-1:

- a) an air source with a large flow-rate capacity is not required;
- b) components with larger flow-rate capacity can be tested more easily;
- c) energy consumption is minimised; and
- d) test time is shortened in the discharge test, and noise level is decreased in the charge test.

It should be noted that performance characteristics measured in accordance with this edition of ISO 6358 will differ from those measured in accordance with ISO 6358:1989.