

This is a preview of "ISO 7240-1:2014". [Click here to purchase the full version from the ANSI store.](#)

Third edition
2014-06-01

Fire detection and alarm systems — Part 1: General and definitions

*Systèmes de détection et d'alarme d'incendie —
Partie 1: Généralités et définitions*



Reference number
ISO 7240-1:2014(E)

© ISO 2014



COPYRIGHT PROTECTED DOCUMENT

© ISO 2014

All rights reserved. Unless otherwise specified, no part of this publication may be reproduced or utilized otherwise in any form or by any means, electronic or mechanical, including photocopying, or posting on the internet or an intranet, without prior written permission. Permission can be requested from either ISO at the address below or ISO's member body in the country of the requester.

ISO copyright office
Case postale 56 • CH-1211 Geneva 20
Tel. + 41 22 749 01 11
Fax + 41 22 749 09 47
E-mail copyright@iso.org
Web www.iso.org

Published in Switzerland

This is a preview of "ISO 7240-1:2014". [Click here to purchase the full version from the ANSI store.](#)

Contents

Page

Foreword	iv
Introduction	vi
1 Scope	1
2 Terms and definitions and abbreviated terms	1
2.1 Definitions.....	1
2.2 Abbreviated terms	15
3 Functions	15

Foreword

ISO (the International Organization for Standardization) is a worldwide federation of national standards bodies (ISO member bodies). The work of preparing International Standards is normally carried out through ISO technical committees. Each member body interested in a subject for which a technical committee has been established has the right to be represented on that committee. International organizations, governmental and non-governmental, in liaison with ISO, also take part in the work. ISO collaborates closely with the International Electrotechnical Commission (IEC) on all matters of electrotechnical standardization.

The procedures used to develop this document and those intended for its further maintenance are described in the ISO/IEC Directives, Part 1. In particular the different approval criteria needed for the different types of ISO documents should be noted. This document was drafted in accordance with the editorial rules of the ISO/IEC Directives, Part 2 (see www.iso.org/directives).

Attention is drawn to the possibility that some of the elements of this document may be the subject of patent rights. ISO shall not be held responsible for identifying any or all such patent rights. Details of any patent rights identified during the development of the document will be in the Introduction and/or on the ISO list of patent declarations received (see www.iso.org/patents).

Any trade name used in this document is information given for the convenience of users and does not constitute an endorsement.

For an explanation on the meaning of ISO specific terms and expressions related to conformity assessment, as well as information about ISO's adherence to the WTO principles in the Technical Barriers to Trade (TBT) see the following URL: [Foreword - Supplementary information](#)

The committee responsible for this document is ISO/TC 21, *Equipment for fire protection and firefighting*, Subcommittee SC 3, *Fire detection and alarm systems*.

This third edition cancels and replaces the second edition (ISO 7240-1:2005), which has been technically revised.

ISO 7240 consists of the following parts, under the general title *Fire detection and alarm systems*:

- *Part 1: General and definitions*
- *Part 2: Control and indicating equipment*
- *Part 3: Audible alarm devices*
- *Part 4: Power supply equipment*
- *Part 5: Point-type heat detectors*
- *Part 6: Carbon monoxide fire detectors using electro-chemical cells*
- *Part 7: Point-type smoke detectors using scattered light, transmitted light or ionization*
- *Part 8: Carbon monoxide fire detectors using an electro-chemical cell in combination with a heat sensor*
- *Part 9: Test fires for fire detectors [Technical Specification]*
- *Part 10: Point-type flame detectors*
- *Part 11: Manual call points*
- *Part 12: Line type smoke detectors using a transmitted optical beam*
- *Part 13: Compatibility assessment of system components*

This is a preview of "ISO 7240-1:2014". [Click here to purchase the full version from the ANSI store.](#)

- *Part 14: Design, installation, commissioning and service of fire detection and fire alarm systems in and around buildings*
- *Part 15: Point type fire detectors using scattered light, transmitted light or ionization sensors in combination with a heat sensor*
- *Part 16: Sound system control and indicating equipment*
- *Part 17: Short-circuit-isolators*
- *Part 18: Input/output devices*
- *Part 19: Design, installation, commissioning and service of sound systems for emergency purposes*
- *Part 20: Aspirating smoke detectors*
- *Part 21: Routing equipment*
- *Part 22: Smoke-detection equipment for ducts*
- *Part 23: Visual alarm devices*
- *Part 24: Sound system loudspeakers*
- *Part 25: Components using radio transmission paths*
- *Part 27: Point-type fire detectors using a scattered-light, transmitted-light or ionization smoke sensor, an electrochemical-cell carbon-monoxide sensor and a heat sensor*
- *Part 28: Fire protection control equipment*

The following parts are in preparation

- *Part 29: Video fire detectors*

Introduction

ISO 7240 (all parts) specifies components of fire detection and alarm systems, requirements for their interconnection and installation and the performance, testing, and servicing of parts or of complete systems. It provides

- local and/or remote signals to organizations having authority to respond to fire alarms, and
- signals to initiate the operation of fire protection equipment and other systems.

A fire detection and alarm system may be activated by automatic detection devices or by manual operation and should fulfil its functions without errors or omissions, including

- detecting quickly enough to fulfil its intended function,
- reliably transmitting the detection signal to the control and indicating equipment and, if applicable, the fire alarm receiving station,
- translating the detection signal into a clear alarm signal that will attract the attention of occupants in an immediate and unmistakable way,
- remaining insensitive to phenomena other than those which its function is to detect, and
- signalling immediately and clearly any supervised fault that might jeopardize the correct performance of the fire detection and alarm system.

A fire detection and alarm system should not

- be adversely affected by any other systems whether associated with it, or not
- be rendered partially or totally inoperative by the fire or the phenomenon which it is designed to detect before the fire or phenomenon has been detected.

ISO 7240 (all parts) applies to fire detection and alarm systems installed in and around buildings. It can be used as a basis for the assessment of systems for other purposes, e.g. mines, ships, but the specific nature of each application should be considered before use. Additional performance and environmental tests may be necessary. It does not preclude the manufacture or use of systems having special characteristics suitable for protection of specific risks against specific hazards.

A fire detection and alarm system is required to function satisfactorily not only in the event of fire, but also during and after exposure to conditions likely to be met in practice such as corrosion, vibration, direct impact, indirect shock, and electromagnetic interference. Some tests specified are intended to assess the performance of system components under such conditions.

The performance of components of fire detection and alarm systems is assessed from the results obtained in the specific tests. The compliance of a component with the relevant part of ISO 7240 does not necessarily ensure that the component will function correctly when connected with another component also conforming to the relevant part of ISO 7240 (e.g. a fire detector with fire detection control and indicating equipment), unless both components have been assessed together as conforming to the requirements for a fire detection and alarm system. Requirements for the assessment of the compatibility of system components are specified in ISO 7240-13. Satisfactory operation of an installed system should be confirmed by testing after completion of the installation (see ISO 7240-14). ISO 7240 (all parts) is not intended to place any other restrictions on the design and construction of such components.

If appropriate, ISO 7240 (all parts) can be applied to the detection part of extinguishing systems, excluding sprinkler heads, although the sensitivity requirements might not be applicable in every instance.

As this revision of this part of ISO 7240 includes terms and definitions collated from other parts of ISO 7240, there may now be some duplication and minor variances which will be corrected in future revisions of the other parts of ISO 7240.