



ISO 7240-1

**Fire detection and alarm systems —
Part 1:
General and definitions**

*Systèmes de détection et d'alarme d'incendie —
Partie 1: Généralités et définitions*

**Fourth edition
2025-10**



COPYRIGHT PROTECTED DOCUMENT

© ISO 2025

All rights reserved. Unless otherwise specified, or required in the context of its implementation, no part of this publication may be reproduced or utilized otherwise in any form or by any means, electronic or mechanical, including photocopying, or posting on the internet or an intranet, without prior written permission. Permission can be requested from either ISO at the address below or ISO's member body in the country of the requester.

ISO copyright office
CP 401 • Ch. de Blandonnet 8
CH-1214 Vernier, Geneva
Phone: +41 22 749 01 11
Email: copyright@iso.org
Website: www.iso.org

Published in Switzerland

This is a preview of ISO 7240-1:2025. [Click here to purchase the full version from the ANSI store.](#)

Foreword	iv
Introduction	v
1 Scope	1
2 Normative references	1
3 Terms and definitions	1
4 Functions	13
Annex A (informative) Functions, examples and relevant standards	15
Bibliography	17

This is a preview of ISO 7240-1:2025. [Click here to purchase the full version from the ANSI store.](#)

ISO (the International Organization for Standardization) is a worldwide federation of national standards bodies (ISO member bodies). The work of preparing International Standards is normally carried out through ISO technical committees. Each member body interested in a subject for which a technical committee has been established has the right to be represented on that committee. International organizations, governmental and non-governmental, in liaison with ISO, also take part in the work. ISO collaborates closely with the International Electrotechnical Commission (IEC) on all matters of electrotechnical standardization.

The procedures used to develop this document and those intended for its further maintenance are described in the ISO/IEC Directives, Part 1. In particular, the different approval criteria needed for the different types of ISO document should be noted. This document was drafted in accordance with the editorial rules of the ISO/IEC Directives, Part 2 (see www.iso.org/directives).

ISO draws attention to the possibility that the implementation of this document may involve the use of (a) patent(s). ISO takes no position concerning the evidence, validity or applicability of any claimed patent rights in respect thereof. As of the date of publication of this document, ISO had not received notice of (a) patent(s) which may be required to implement this document. However, implementers are cautioned that this may not represent the latest information, which may be obtained from the patent database available at www.iso.org/patents. ISO shall not be held responsible for identifying any or all such patent rights.

Any trade name used in this document is information given for the convenience of users and does not constitute an endorsement.

For an explanation of the voluntary nature of standards, the meaning of ISO specific terms and expressions related to conformity assessment, as well as information about ISO's adherence to the World Trade Organization (WTO) principles in the Technical Barriers to Trade (TBT), see www.iso.org/iso/foreword.html.

This document was prepared by Technical Committee ISO/TC 21, *Equipment for fire protection and fire fighting*, Subcommittee SC 3, *Fire detection and alarm systems*.

This fourth edition cancels and replaces the third edition (ISO 7240-1:2014), which has been technically revised.

The main changes are as follows:

- wording of the scope has been simplified to improve readability;
- editorial corrections have been made to bring the document in line with current ISO drafting rules;
- some definitions (e.g. access level, detachable detector, multipoint detector, zone, etc.) have been changed or added to bring them in line with other parts of ISO 7240 or EN 54-1:2021;
- some terms have been deleted (e.g. alarm, alarm indication, alphanumeric display, combustion gas detector, etc.) because they were used as general meanings or not used in the ISO 7240 series.

A list of all parts in the ISO 7240 series can be found on the ISO website.

Any feedback or questions on this document should be directed to the user's national standards body. A complete listing of these bodies can be found at www.iso.org/members.html.

This is a preview of ISO 7240-1:2025. [Click here to purchase the full version from the ANSI store.](#)

The ISO 7240 series specifies components of fire detection and alarm systems, requirements for their interconnection and installation and the performance, testing, and servicing of parts or of complete systems. It provides:

- signals to organizations having authority to respond to fire alarms, and
- signals to initiate the operation of fire protection equipment and other systems.

A fire detection and alarm system may be activated by automatic detection devices or by manual operation and should fulfil its functions without errors or omissions, including:

- detecting quickly enough to fulfil its intended function,
- reliably transmitting the detection signal to the control and indicating equipment and, if applicable, the fire alarm receiving station,
- translating the detection signal into a clear alarm signal that will attract the attention of occupants in an immediate and unmistakable way,
- remaining insensitive to phenomena other than those which its function is to detect, and
- signalling immediately and clearly any supervised fault that can potentially jeopardize the correct performance of the fire detection and alarm system.

A fire detection and alarm system should not:

- be adversely affected by any other systems whether associated with it, or not.
- be rendered partially or totally inoperative by the fire or the phenomenon which it is designed to detect before the fire or phenomenon has been detected.

The ISO 7240 series applies to fire detection and alarm systems installed in and around buildings. It can be used as a basis for the assessment of systems for other purposes (e.g. mines, ships) but the specific nature of each application should be considered before use. Additional performance and environmental tests can be necessary. It does not preclude the manufacture or use of systems having special characteristics suitable for protection of specific risks against specific hazards.

A fire detection and alarm system is required to function satisfactorily not only in the event of fire, but also during and after exposure to conditions likely to be met in practice such as corrosion, vibration, direct impact, indirect shock, and electromagnetic interference. Some tests specified are intended to assess the performance of system components under such conditions.

The performance of components of fire detection and alarm systems is assessed from the results obtained in the specific tests. The compliance of a component with the relevant part of ISO 7240 does not necessarily ensure that the component will function correctly when connected with another component also conforming to the relevant part of ISO 7240 (e.g. a fire detector with fire detection control and indicating equipment), unless both components have been assessed together as conforming to the requirements for a fire detection and alarm system. Requirements for the assessment of the compatibility of system components are specified in ISO 7240-13. Satisfactory operation of an installed system should be confirmed by testing after completion of the installation (see ISO 7240-14 and ISO 7240-19). The ISO 7240 series is not intended to place any other restrictions on the design and construction of such components.

If appropriate, the ISO 7240 series can be applied to the detection part of extinguishing systems, excluding sprinkler heads, although the sensitivity requirements are not necessarily applicable in every instance.