First edition 2013-12-15

# Optics and photonics — Environmental test methods —

## Part 23: Low pressure combined with cold, ambient temperature and dry and damp heat

Optique et photonique — Méthodes d'essais d'environnement —

Partie 23: Essais combinés basse pression et froid, température ambiante et chaleur sèche et humide



Reference number ISO 9022-23:2013(E)



#### **COPYRIGHT PROTECTED DOCUMENT**

© ISO 2013

All rights reserved. Unless otherwise specified, no part of this publication may be reproduced or utilized otherwise in any form or by any means, electronic or mechanical, including photocopying, or posting on the internet or an intranet, without prior written permission. Permission can be requested from either ISO at the address below or ISO's member body in the country of the requester.

ISO copyright office Case postale 56 • CH-1211 Geneva 20 Tel. + 41 22 749 01 11 Fax + 41 22 749 09 47 E-mail copyright@iso.org Web www.iso.org

Published in Switzerland

Contents			Page	
Foreword				
Introduction			vi	
1		De		
2	-	mative references		
_				
3	Gen	eral information and test conditions	1	
4	Conditioning		2	
	4.1	Conditioning method 45 — Combined low pressure and ambient temperature	2	
	4.2	Conditioning method 46 — Combined low pressure and dry heat	2	
	4.3	Conditioning method 47 — Damp heat and low internal pressure, pressure	0	
	4 4	difference low		
	4.4	Conditioning method 48 — Damp heat and low internal pressure, pressure difference medium	4	
	4.5	Conditioning method 49 — Damp heat and low internal pressure, pressure	1	
	1.0	difference high	5	
	4.6	Conditioning method 50 — Combined cold, low air pressure including hoarfrost	_	
		and dew		
	4.7	Conditioning method 51 — Combined cold, low air pressure without hoarfrost and de	ew.6	
5	Procedure		7	
	5.1	General		
	5.2	Procedure for conditioning method 45		
	5.3	Procedure for conditioning method 46	7	
	5.4	Procedure for conditioning method 47		
	5.5	Procedure for conditioning method 48		
	5.6	Procedure for conditioning method 49		
	5.7	Procedure for conditioning method 50		
	5.8	Procedure for conditioning method 51		
6		Environmental test code 1		
7	Specification			
Ann	ex A (in	lformative) <b>Explanatory notes</b>	11	

#### Foreword

ISO (the International Organization for Standardization) is a worldwide federation of national standards bodies (ISO member bodies). The work of preparing International Standards is normally carried out through ISO technical committees. Each member body interested in a subject for which a technical committee has been established has the right to be represented on that committee. International organizations, governmental and non-governmental, in liaison with ISO, also take part in the work. ISO collaborates closely with the International Electrotechnical Commission (IEC) on all matters of electrotechnical standardization.

The procedures used to develop this document and those intended for its further maintenance are described in the ISO/IEC Directives, Part 1. In particular the different approval criteria needed for the different types of ISO documents should be noted. This document was drafted in accordance with the editorial rules of the ISO/IEC Directives, Part 2 (see www.iso.org/directives).

Attention is drawn to the possibility that some of the elements of this document may be the subject of patent rights. ISO shall not be held responsible for identifying any or all such patent rights. Details of any patent rights identified during the development of the document will be in the Introduction and/or on the ISO list of patent declarations received (see www.iso.org/patents).

Any trade name used in this document is information given for the convenience of users and does not constitute an endorsement.

For an explanation on the meaning of ISO specific terms and expressions related to conformity assessment, as well as information about ISO's adherence to the WTO principles in the Technical Barriers to Trade (TBT) see the following URL: Foreword - Supplementary information

The committee responsible for this document is ISO/TC 172, *Optics and photonics*, Subcommittee SC 1, *Fundamental standards*.

This edition cancels and replaces ISO 9022-5:1994, ISO 9022-18:1994, and ISO 9022-21:1998, which have been technically revised.

ISO 9022 consists of the following parts, under the general title *Optics and photonics — Environmental test methods*:

- Part 1: Definitions, extent of testing
- Part 2: Cold, heat and humidity
- Part 3: Mechanical stress
- Part 4: Salt mist
- Part 6: Dust
- Part 7: Resistance to drip or rain
- Part 8: High pressure, low pressure, immersion
- Part 9: Solar radiation
- Part 11: Mould growth
- Part 12: Contamination
- Part 14: Dew, hoarfrost, ice
- Part 17: Combined contamination, solar radiation
- Part 20: Humid atmosphere containing sulfur dioxide or hydrogen sulfide

- Part 22: Combined cold, dry heat or temperature change with bump or random vibration
- Part 23: Low pressure combined with cold, ambient temperature and dry and damp heat

### Introduction

Optical instruments are affected during their use by a number of different environmental parameters which they are required to resist without significant reduction in performance and to remain within defined specifications.

The type and severity of these parameters depend on the conditions of use of the instrument (for example, in the laboratory or workshop) and on its geographical location. The environmental effects on optical instrument performance in the tropics and subtropics are totally different from those found when they are used in arctic regions. Individual parameters cause a variety of different and overlapping effects on instrument performance.

The manufacturer attempts to ensure, and the user naturally expects, that instruments will resist the likely rigours of their environment throughout their life. This expectation can be assessed by exposure of the instrument to a range of simulated environmental parameters under controlled laboratory conditions. The severity of these conditions is often increased to obtain meaningful results in a relatively short period of time.

In order to allow assessment and comparison of the response of optical instruments to appropriate environmental conditions, ISO 9022 contains details of a number of laboratory tests which reliably simulate a variety of different environments. The tests are based largely on IEC standards, modified where necessary to take into account features special to optical instruments.

It should be noted that, as a result of continuous progress in all fields, optical instruments are no longer only precision-engineered optical products, but, depending on their range of application, also contain additional assemblies from other fields. For this reason, the principal function of the instrument must be assessed to determine which International Standard should be used for testing. If the optical function is of primary importance, then ISO 9022 is applicable, but if other functions take precedence, then the appropriate International Standard in the field concerned should be applied. Cases can arise where application both of ISO 9022 and other appropriate International Standards will be necessary.