

MSS SP-105-1996

Reaffirmed 2005

Instrument Valves for Code Applications

Standard Practice
Developed and Approved by the
Manufacturers Standardization Society of the
Valve and Fittings Industry, Inc.
127 Park Street, NE
Vienna, Virginia 22180
Phone: (703) 281- 6613
Fax: (703) 281- 6671
e-mail: info@mss.hq.com



www.mss-hq.com

This MSS Standard Practice was developed under the consensus of the MSS Technical Committees 115 and the MSS Coordinating Committee. The content of this Standard Practice is the result of the efforts of competent and concerned volunteers to provide an effective, clear, and non-exclusive specification that will benefit the industry as a whole. This MSS Standard Practice is intended as a basis for common practice by the manufacturer, the user, and the general public. The existence of an MSS Standard Practice does not in itself preclude the manufacture, sale, or use of products not conforming to the Standard Practice. Mandatory conformance is established only by reference in a code, specification, sales contract, or public law, as applicable.

Substantive changes in this 1995 edition are “flagged” by parallel bars as shown on the margins of this paragraph. The specific detail of the change may be determined by comparing the material flagged with that in the previous edition.

Other standards documents referred to herein are identified by the date of issue that was applicable to this standard at the date of issue of this standard. See Annex A. This standard shall remain silent on the applicability of those other standards of prior or subsequent dates of issue even though provisions of concern may not have changed. References contained herein which are bibliographic in nature are noted as “supplemental” in the text.

Any part of this standard may be quoted. Credit lines should read 'extracted from MSS SP-105, 1996, Reaffirmed 2005 with permission of the publisher, the Manufacturers Standardization Society.' Reproduction prohibited under copyright convention unless written permission is granted by the Manufacturers Standardization Society of the Valve and Fittings Industry, Inc.

Originally Approved July 1990

Copyright ©, 1990 by
Manufacturers Standardization Society
of the
Valve and Fittings Industry, Inc.
Printed in U.S.A.

| CONTENTS |

SECTION	PAGE
1. SCOPE	1
2. DEFINITIONS	1
3. MATERIALS	1
4. DESIGN REQUIREMENTS	2
5. QUALIFICATION	3
6. ACCEPTANCE TESTING	5
7. MARKING	5
FIGURE 1 -- DIRECT MOUNTED INSTRUMENT MANIFOLD GASKET GROOVE AND FLANGE DETAILS	4
ANNEX A -- REFERENCED STANDARDS	6

INSTRUMENT VALVES FOR CODE APPLICATIONS

1. SCOPE

1.1 This Standard Practice applies to small valves and manifolds developed for and predominately used in instrument, control and sampling piping systems. It covers steel and alloy valves of 1" nominal pipe size and smaller, and pressure ratings of 10,000 psi and lower at 100° F.

1.2 This Standard Practice applies to instrument valve designs including but not limited to needle valves, packless valves, ball valves, plug valves, check valves and manifold valves. Instrument valves are generally of proprietary design; this Standard Practice is not intended to define or limit designs, construction, performance, envelope dimensions, or valve types.

1.3 The application of valve type, size, rating, materials of construction, and suitability for the service are the responsibility of the purchaser and are outside the scope of this standard.

2. DEFINITIONS

2.1 General. Definitions given in MSS SP-96 apply to this Standard Practice.

2.2 Instrument valves: Valves designed for use in instrument, control and sampling piping systems (e.g. see ASME B31.1, Article 122.3).

2.3 Instrument piping: Piping used to interconnect pneumatically or hydraulically operated control apparatus, or to signal transmission systems.

2.4 Control piping: Piping used to interconnect pneumatically or hydraulically operated control apparatus, or to signal transmission systems.

2.5 Sampling piping: Piping used for the collection of samples (such as steam, water, oil, gas, and chemicals) from process systems.

2.6 Manifold valve: Two or more instrument valves fabricated into a single valve body.

2.7 Cold working pressure rating: The maximum allowable working pressure of a valve at ambient conditions (-20° F to 100° F), abbreviated CWP.

2.8 Pressure boundary parts: The following items are defined to be pressure boundary parts. Each item may not apply to all valve designs.

- a) Body
- b) Bonnet
- c.) Union Nut
- d) Body to Bonnet Bolting
- e) Body Bolting

2.9 Packless valve: A valve with a diaphragm or bellows stem seal instead of a packing or O-ring seal at the stem.

3. MATERIALS

3.1 General. The pressure boundary parts of the valve shall be made of the materials specified herein.

3.2 Non-pressure boundary parts (such as the stem, glands, packing nut) shall be made of materials compatible with the pressure boundary parts materials.