

MSS SP-105-2016a

Instrument Valves for Code Applications

NOTICE:

This 2016a Edition Replaces the Original 2016 Edition.

Standard Practice
Developed and Approved by the
Manufacturers Standardization Society of the
Valve and Fittings Industry, Inc.
127 Park Street, NE
Vienna, Virginia 22180-4602
Phone: (703) 281-6613
Fax: (703) 281-6671
E-mail: standards@msshq.org



www.msshq.org

This MSS Standard Practice was developed under the consensus of the MSS Technical Committee 115 and the MSS Coordinating Committee. The content of this Standard Practice is the resulting efforts of competent and experienced volunteers to provide an effective, clear, and non-exclusive standard that will benefit the industry as a whole. This MSS Standard Practice describes minimal requirements and is intended as a basis for common practice by the manufacturer, the user, and the general public. The existence of an MSS Standard Practice does not in itself preclude the manufacture, sale, or use of products not conforming to the Standard Practice. Mandatory conformance to this Standard Practice is established only by reference in other documents such as a code, specification, sales contract, or public law, as applicable. MSS has no power, nor does it undertake, to enforce or certify compliance with this document. Any certification or other statement of compliance with the requirements of this Standard Practice shall not be attributable to MSS and is solely the responsibility of the certifier or maker of the statement.

“Unless indicated otherwise within this MSS Standard Practice, other standards documents referenced to herein are identified by the date of issue that was applicable to this Standard Practice at the date of approval of this MSS Standard Practice (see Annex A). This Standard Practice shall remain silent on the validity of those other standards of prior or subsequent dates of issue even though applicable provisions may not have changed.”

By publication of this Standard Practice, no position is taken with respect to the validity of any potential claim(s) or of any patent rights in connection therewith. MSS shall not be held responsible for identifying any patent rights. Users are expressly advised that determination of patent rights and the risk of infringement of such rights are entirely their responsibility.

In this Standard Practice, all text, notes, annexes, tables, figures, and references are construed to be essential to the understanding of the message of the standard, and are considered normative unless indicated as “supplemental”. All appendices, if included, that appear in this document are construed as “supplemental”. Note that supplemental information does not include mandatory requirements.

The SI (metric) units and U.S. customary units in this Standard Practice are regarded separately as the standard; each should be used independently of the other. Combining or converting values between the two systems may result in non-conformance with this Standard Practice. The U.S. customary units in this Standard Practice are the standard, in cases of conflict or incongruity.

Substantive changes contained in this 2016a edition include those changes from the superseded 2016 edition. All substantive changes are “flagged” by parallel bars as shown on the margins of this paragraph. The specific detail of the 2016a changes may be determined by comparing the material flagged with that in the previous 2010 edition.

Excerpts of this Standard Practice may be quoted with permission. Credit lines should read ‘Extracted from MSS SP-105-2016a with permission of the publisher, Manufacturers Standardization Society of the Valve and Fittings Industry’. Reproduction and/or electronic transmission or dissemination is prohibited under copyright convention unless written permission is granted by the Manufacturers Standardization Society of the Valve and Fittings Industry Inc. All rights reserved.

Originally Approved: July 1990
Originally Published: October 1990
Superseded 2016 Edition Published: November 2016
Current 2016a Edition Approved: May 2017
Current 2016a Edition Published: June 2017

MSS is a registered trademark of Manufacturers Standardization Society of the Valve and Fittings Industry, Inc.

Copyright ©, 2017 by
Manufacturers Standardization Society
of the
Valve and Fittings Industry, Inc.
Printed in U.S.A.

TABLE OF CONTENTS

<u>SECTION</u>	<u>PAGE</u>
1 SCOPE	1
2 DEFINITIONS	1
3 MATERIALS	2
4 DESIGN REQUIREMENTS	2
5 QUALIFICATION TESTS	3
6 ACCEPTANCE TESTING	5
7 MARKING	5
FIGURE	
1 Direct Mounted Instrument Manifold Gasket Groove and Flange Details – U.S. Customary	6
2 Direct Mounted Instrument Manifold Gasket Groove and Flange Details – SI (Metric)	7
ANNEX	
A Referenced Standards and Applicable Dates	8

INSTRUMENT VALVES FOR CODE APPLICATIONS

1. SCOPE

1.1 This Standard Practice applies to small valves and manifold valves developed for and predominately used in instrument, control, and sampling piping systems for code applications. It covers steel and alloy valves of nominal pipe size (NPS) 2 and smaller, and pressure ratings of 15,000 psi (103.4 MPa) and lower at 100 °F (38 °C). See MSS SP-99 for instrument valves not involving code applications.

1.2 This Standard Practice applies to instrument valve designs including, but not limited to, needle valves, packless valves, ball valves, plug valves, check valves, and manifold valves. Instrument valves are generally of proprietary design. This Standard Practice is not intended to define or limit designs, construction, performance, envelope dimensions, or valve types.

1.3 The application of valve type, size, rating, materials of construction, and suitability for the service are the responsibility of the purchaser and are outside the scope of this Standard Practice.

2. DEFINITIONS

2.1 **General** Definitions given in MSS SP-96 apply to this Standard Practice.

2.2 **Cold Working Pressure Rating (CWP)** The maximum allowable working pressure of a valve at ambient conditions, i.e., -20 °F to 100 °F (-29 °C to 38 °C).

2.3 **Control Piping** Piping used to interconnect pneumatically or hydraulically operated control apparatuses, or to signal control systems.

2.4 **Instrument Piping** Piping used to connect instruments to main piping or other instruments.

2.5 **Instrument Valves** Valves designed for use in instrument, control, and sampling piping systems, (e.g., see ASME B31.1, Article 122.3).

2.6 **Manifold Valve** Two or more instrument valves fabricated into a single valve body.

2.7 **Packless Valve** A valve with a diaphragm or bellows stem seal instead of a packing or O-ring seal at the stem.

2.8 **Pressure Boundary Parts** The following items are defined to be pressure boundary parts. Each item may not apply to all valve designs.

- a) Body
- b) Bonnet
- c) Union Nut
- d) Body-to-Bonnet Bolting
- e) Body Bolting

2.9 **Sampling Piping** Piping used for the collection of samples (such as steam, water, oil, gas, and chemicals) from process systems.