

**MSS SP-114-2001**

**Corrosion Resistant Pipe Fittings  
Threaded and Socket Welding  
Class 150 and 1000**

**Standard Practice**  
Developed and Approved by the  
**Manufacturers Standardization Society of the  
Valve and Fittings Industry, Inc.**  
127 Park Street, NE  
Vienna, Virginia 22180  
(703) 281-6613



This MSS Standard Practice was developed under the consensus of the MSS Technical Committee 108 and the MSS Coordinating Committee. The content of this Standard Practice is the result of the efforts of competent and concerned volunteers to provide an effective, clear, and non-exclusive specification that will benefit the industry as a whole. This MSS Standard Practice is intended as a basis for common practice by the manufacturer, the user, and the general public. The existence of an MSS Standard Practice does not in itself preclude the manufacture, sale, or use of products not conforming to the Standard Practice. Mandatory conformance is established only by reference in a code, specification, sales contract, or public law, as applicable.

Unless otherwise specifically noted in this MSS SP, any standard referred to herein is identified by the date of issue that was applicable to the referenced standard(s) at the date of issue of this MSS SP. (see Annex A).

In this Standard Practice all notes, annexes, tables, and figures are construed to be essential to the understanding of the message of the standard, and are considered part of the text unless noted as "supplemental". All appendices appearing in this document are construed as "supplemental". "Supplemental" information does not include mandatory requirements.

Substantive changes in this 2001 edition are "flagged" by parallel bars as shown on the margins of the affected text. The specific detail of the changes may be determined by comparing the material flagged with that in the previous edition.

Non-toleranced dimensions in this Standard Practice are nominal, and unless otherwise specified, shall be considered "for reference only".

*Any part of this standard may be quoted. Credit lines should read "Extracted from MSS SP-114, 2001, with permission of the publisher, the Manufacturers Standardization Society." Reproduction prohibited under copyright convention unless written permission is granted by the Manufacturers Standardization Society of the Valve and Fittings Industry, Inc.*

**Originally Approved in May of 1995**

Copyright©, 1995 by  
Manufacturers Standardization Society  
of the  
Valve and Fittings Industry, Inc.  
Printed in U.S.A.

## **FOREWORD**

This document established a standard for corrosion resistant pipe fittings, threaded and socket-welding, Class 150 and 1000, produced for a number of years by various manufacturers to somewhat different dimensions although basically similar in principal. Users should note that corrosion resistant pipe fittings, threaded and socket-welding, Class 150 and 1000, furnished from existing stocks, until depleted, may have slightly different dimensions than shown herein.

This standard, originally approved May 1995, was revised in 2001 to include Class 150 and 1000 square head plugs, hex head plugs and bushings, locknuts, and threaded and socket-welding unions.

**TABLE OF CONTENTS**

<b>SECTION</b>	<b>PAGE</b>
1 SCOPE.....	1
2 PRESSURE-TEMPERATURE RATINGS.....	1
3 SIZE.....	1
4 MARKING.....	2
5 MATERIAL.....	2
6 DIMENSIONS AND TOLERANCES.....	3
7 THREADING.....	3
8 SOCKET-WELDING.....	4
9 RIBS.....	4
10 PLUGS, BUSHINGS, AND LOCKNUTS.....	4
11 FACE BEVEL.....	4
12 WELDING.....	4
13 TESTING.....	4

**TABLES**

1 – PRESSURE TEMPERATURE RATINGS.....	1
2 – CENTER-TO-END TOLERANCES.....	3
3 – DIMENSIONS OF CAST 90° ELBOWS, TEES, CROSSES, AND 45° ELBOWS.....	5
4 – DIMENSIONS OF CAST 90° STREET ELBOWS.....	6
5 – DIMENSIONS OF CAST COUPLINGS (STRAIGHT AND REDUCING SIZES).....	7
6 – DIMENSIONS OF CAST CAPS.....	8
7 – DIMENSIONS OF SOCKET-WELDING FITTINGS (CAST CLASS 150).....	9
8 – DIMENSIONS OF CAST SQUARE HEAD PLUGS.....	10
9 – DIMENSIONS OF CAST HEX HEAD PLUGS.....	11
10 – DIMENSIONS OF CAST HEX HEAD BUSHINGS.....	12
11 – DIMENSIONS OF LOCKNUTS.....	14
12 – DIMENSIONS OF CAST THREADED UNIONS.....	15
13 – DIMENSIONS OF CAST SOCKET WELDING UNIONS.....	16
14 – DIMENSIONS OF WROUGHT 90° ELBOWS, TEES, CROSSES, AND 45° ELBOWS.....	17
15 – DIMENSIONS OF WROUGHT 90 STREET ELBOWS.....	18
16 – DIMENSIONS OF WROUGHT COUPLINGS (STRAIGHT AND REDUCING SIZES) AND CAPS....	19
17 – DIMENSIONS OF SOCKET-WELDING FITTINGS (WROUGHT CLASS 1000).....	20
18 – DIMENSIONS OF WROUGHT SQUARE HEAD PLUGS.....	21
19 – DIMENSIONS OF WROUGHT HEX HEAD PLUGS.....	22
20 – DIMENSIONS OF WROUGHT HEX HEAD BUSHINGS.....	23
21 – DIMENSIONS OF WROUGHT THREADED UNIONS.....	25
22 – DIMENSIONS OF WROUGHT SOCKET-WELDING UNIONS.....	26
FIGURE 1 – IDENTIFICATION OF REDUCING FITTINGS.....	2
ANNEX A – LIST OF REFERENCED STANDARDS AND APPLICABLE DATES.....	27

**CORROSION RESISTANT PIPE FITTINGS  
THREADED AND SOCKET WELDING  
CLASS 150 AND 1000**

**1. SCOPE**

1.1 This Standard Practice for corrosion resistant pipe fittings, threaded and socket welding, Class 150 and 1000 establishes requirements for the following:

- a) Pressure-temperature ratings
- b) Size and method of designating openings of reducing fittings
- c) Marking
- d) Minimum requirements for materials
- e) Dimensions and tolerances
- f) Threading
- g) Tests

**2. PRESSURE-TEMPERATURE RATINGS**

2.1 Pressure-temperature ratings for these fittings are shown in Table 1. Ratings are independent of the contained fluid and are the maximum allowable working pressures at the tabulated temperatures. Intermediate ratings may be obtained by linear interpolation between the temperatures shown.

2.2 The temperatures shown for the corresponding pressure rating shall be the material temperature of the pressure retaining structure. It is implied that the material temperature is the same as the fluid temperature. Use of a pressure rating at a material temperature other than that of the contained fluid is the responsibility of the user and subject to the requirements of any applicable code.

2.3 For purposes of this standard, castings are included for Class 150 fittings only.

2.4 The wall thickness of the fittings covered by this standard correspond to Schedule 40 pipe. When thinner pipe of equivalent material is used, its strength may govern the rating. When Schedule 40 pipe of equivalent material is used, the strength of the fitting governs the rating.

**TABLE 1 -  
PRESSURE-TEMPERATURE  
RATINGS**

Temperature (°F)	Class 150 (castings) PSIG	Class 1000 (Wrought) PSIG
-20 to 150	300	1000
200	265	910
250	225	825
300	185	735
350	150 <sup>(a)</sup>	650
400	—	560
450	—	475
500	—	385
550	—	300

NOTE: <sup>(a)</sup> Permissible for service temperature up to 366 degrees Fahrenheit, reflecting the temperature of saturated steam at 150 psig.

**3. SIZE**

3.1 The size of the fittings listed in the following tables are identified by the corresponding nominal <sup>(b)</sup> pipe size (NPS).

NOTE: <sup>(b)</sup> the use of the word "nominal" as a modifier of a dimension or size is intended to indicate that the stated dimension or size is used for purposes of designation.