

MSS SP-115-2010

**Excess Flow Valves,
1¹/₄ NPS and Smaller,
for
Fuel Gas Service**

Standard Practice
Developed and Approved by the
**Manufacturers Standardization Society of the
Valve and Fittings Industry, Inc.**
127 Park Street, NE
Vienna, Virginia 22180
Phone: (703) 281-6613
Fax: (703) 281-6671
e-mail: info@mss-hq.org



www.mss-hq.org

This MSS Standard Practice was developed under the consensus of the MSS Technical Committee 501 and the MSS Coordinating Committee. The content of this Standard Practice is the result of the efforts of competent and concerned volunteers to provide an effective, clear, and non-exclusive specification that will benefit the industry as a whole. This MSS Standard Practice is intended as a basis for common practice by the manufacturer, the user, and the general public. The existence of an MSS Standard Practice does not in itself preclude the manufacture, sale, or use of products not conforming to the Standard Practice. Mandatory conformance is established only by reference in a code, specification, sales contract, or public law, as applicable.

"Other standards documents referred to herein are identified by the date of issue that was applicable to this Standard Practice at the date of issue of this Standard Practice. See Annex B. This Standard Practice shall remain silent on the applicability of those other standards of prior or subsequent dates of issue even though applicable provisions may not have changed. References contained herein which are bibliographic in nature are noted as 'supplemental' in the text."

Unless otherwise specifically noted in this MSS Standard Practice, any standard referred to herein is identified by the date of issue that was applicable to the referenced standard(s) at the date of issue of this MSS Standard Practice (See Annex B).

In this Standard Practice all notes, annexes, tables, and figures are construed to be essential to the understanding of the message of the standard, and are considered part of the text unless noted as "supplemental". All appendices, if included, that appear in this document are construed as "supplemental". Supplemental information does not include mandatory requirements for this Standard Practice.

Substantive changes in this 2010 edition are “flagged” by parallel bars as shown on the margins of this paragraph. The specific detail of the change may be determined by comparing the material flagged with that in the previous edition.

Any part of this Standard Practice may be quoted. Credit lines should read 'Extracted from MSS SP-115-2010 with permission of the publisher, Manufacturers Standardization Society of the Valves and Fittings Industry, Inc.'. Reproduction is prohibited under copyright convention unless written permission is granted by Manufacturers Standardization Society of the Valve and Fittings Industry Inc.

Originally Approved: July 1995
Originally Published: August 1995
Current Edition Approved: May 2010
Current Edition Published: September 2010

Copyright ©, 1995, 1999, 2006, 2010 by
Manufacturers Standardization Society
of the
Valve and Fittings Industry, Inc.
Printed in U.S.A.

TABLE OF CONTENTS

<u>SECTION</u>	<u>PAGE</u>
PURPOSE.....	1
1 SCOPE.....	1
2 DEFINITIONS AND ABBREVIATIONS.....	1
3 VALVE TYPES AND SIZES	1
4 SERVICE PRESSURE – TEMPERATURE RATINGS	2
5 MATERIALS	2
6 DESIGN	2
7 MARKING	2
8 DESIGN QUALIFICATION TESTING.....	3
9 PRODUCTION TESTING BY MANUFACTURER	5
FIGURE	
A1 Snap-Acting Loads Test Setup	7
ANNEX	
A Snap-Acting Loads Test Setup Procedure	7
B Referenced Standards and Applicable Dates	8

EXCESS FLOW VALVES, 1¹/₄ NPS AND SMALLER, FOR FUEL GAS SERVICE

PURPOSE

To provide a Standard Practice for Excess Flow Valves that are designed and installed in fuel gas piping systems to reduce the flow of gas should the flow in the service line exceed some predetermined level.

1. SCOPE

1.1 This Standard Practice covers Excess Flow Valves used in fuel gas distribution systems with operating pressures of 5 inches water column ("w.c.) and above.

2. DEFINITIONS AND ABBREVIATIONS

2.1 Requirements for Excess Flow Valves covered by this Standard Practice are classified into two pressure ranges as follows:

- a) Low Pressure – Valves for use on systems with pressures between 5" w.c. and 5 psig.
- b) High Pressure – Valves for use on systems with pressures of 5 psig and above.

2.2 **Excess Flow Valve (EFV)** A device designed to automatically stop or limit the flow of gas in the event that the flow in the fuel gas service line in which it is installed exceeds a predetermined level.

2.2.1 **Excess Flow Valve – Bypass (EFVB)** An EFV designed to limit the flow of gas upon closure to a predetermined level. EFVBs reset automatically once the service line downstream is made gas tight and pressure is equalized across the valve.

2.2.2 **Excess Flow Valve – Non-Bypass (EFVNB)** An EFV designed to stop the flow of gas upon closure and prevent equalization of pressure across the valve. EFVNBs must be manually reset.

2.3 **Closure Flow Rate** The predetermined level of gas flow through an EFV at a given inlet pressure which causes closure.

2.4 **Bleed-by Flow Rate** The amount of gas flow at a given inlet pressure through an EFVB after closure.

2.5 **Leak Rate** The amount of gas flow at a given inlet pressure through an EFVNB after closure.

2.6 **EFV Minimum Design Inlet Pressure** The minimum pressure at which the EFV is designed to function as specified by the manufacturer.

2.7 **EFV Maximum Operating Pressure** The maximum pressure at which the EFV is designed to function as specified by the manufacturer.

2.8 **Abbreviations** Abbreviations of terms used in this Standard Practice are as follows:

- a) EFV – Excess Flow Valve
- b) EFVB – Excess Flow Valve – Bypass
- c) EFVNB – Excess Flow Valve – Non-Bypass
- d) SCFH – Standard Cubic Feet per Hour
- e) psig – pounds per square inch gage pressure
- f) psia – pounds per square inch absolute pressure
- g) "w.c. – inches water column pressure
- h) SG – Specific Gravity
- i) CTS – Copper Tube Size
- j) NPS – Nominal Pipe Size
- k) °F – degrees Fahrenheit

3. VALVE TYPES AND SIZES

3.1 **Valve Types**

3.1.1 **Excess Flow Valve – Bypass (EFVB)**
See Section 2.2.1.