

MSS SP-99-2016

Instrument Valves

Standard Practice
Developed and Approved by the
Manufacturers Standardization Society of the
Valve and Fittings Industry, Inc.
127 Park Street, NE
Vienna, Virginia 22180-4602
Phone: (703) 281-6613
Fax: (703) 281-6671
E-mail: standards@msshq.org



www.msshq.org

This MSS Standard Practice was developed under the consensus of the MSS Technical Committee 115 and the MSS Coordinating Committee. The content of this Standard Practice is the resulting efforts of competent and experienced volunteers to provide an effective, clear, and non-exclusive standard that will benefit the industry as a whole. This MSS Standard Practice describes minimal requirements and is intended as a basis for common practice by the manufacturer, the user, and the general public. The existence of an MSS Standard Practice does not in itself preclude the manufacture, sale, or use of products not conforming to the Standard Practice. Mandatory conformance to this Standard Practice is established only by reference in other documents such as a code, specification, sales contract, or public law, as applicable. MSS has no power, nor does it undertake, to enforce or certify compliance with this document. Any certification or other statement of compliance with the requirements of this Standard Practice shall not be attributable to MSS and is solely the responsibility of the certifier or maker of the statement.

“Unless indicated otherwise within this MSS Standard Practice, other standards documents referenced to herein are identified by the date of issue that was applicable to this Standard Practice at the date of approval of this MSS Standard Practice (see Annex A). This Standard Practice shall remain silent on the validity of those other standards of prior or subsequent dates of issue even though applicable provisions may not have changed.”

By publication of this Standard Practice, no position is taken with respect to the validity of any potential claim(s) or of any patent rights in connection therewith. MSS shall not be held responsible for identifying any patent rights. Users are expressly advised that determination of patent rights and the risk of infringement of such rights are entirely their responsibility.

In this Standard Practice, all text, notes, annexes, tables, figures, and references are construed to be essential to the understanding of the message of the standard, and are considered normative unless indicated as “supplemental”. All appendices, if included, that appear in this document are construed as “supplemental”. Note that supplemental information does not include mandatory requirements.

Substantive changes in this 2016 edition are “flagged” by parallel bars as shown on the margins of this paragraph. The specific detail of the change may be determined by comparing the material flagged with that in the previous edition.

Excerpts of this Standard Practice may be quoted with permission. Credit lines should read ‘Extracted from MSS SP-99-2016 with permission of the publisher, Manufacturers Standardization Society of the Valve and Fittings Industry’. Reproduction and/or electronic transmission or dissemination is prohibited under copyright convention unless written permission is granted by the Manufacturers Standardization Society of the Valve and Fittings Industry Inc. All rights reserved.

Originally Approved: July 1987
Originally Published: October 1987
Current Edition Approved: August 2016
Current Edition Published: November 2016

Copyright ©, 2016 by
Manufacturers Standardization Society
of the
Valve and Fittings Industry, Inc.
Printed in U.S.A.

TABLE OF CONTENTS

<u>SECTION</u>	<u>PAGE</u>
1 SCOPE	1
2 DEFINITIONS	1
3 MATERIALS	2
4 DESIGN REQUIREMENTS	3
5 QUALIFICATION TESTS	5
6 ACCEPTANCE TESTING	6
7 MARKING	6

TABLE

1 Applicable Material Specifications	2
--	---

FIGURE

1 Direct Mounted Instrument Manifold Gasket Groove and Flange Details	4
---	---

ANNEX

A Referenced Standards and Applicable Dates	7
---	---

INSTRUMENT VALVES

1. SCOPE

1.1 This Standard Practice applies to small valves and manifold valves developed for and predominantly used in instrument, control and sampling piping systems. It covers steel and alloy valves of nominal pipe size (NPS) 2 and smaller, and pressure ratings of 15,000 psi and lower at 100 °F.

1.2 This Standard Practice applies to instrument valve designs including, but not limited to, needle valves, packless valves, ball valves, plug valves, check valves and manifold valves. Instrument valves are generally of proprietary design. This Standard Practice is not intended to define or limit designs, construction, performance, envelope dimensions, or valve types.

1.3 The application of valve type, size, rating, materials of construction, and suitability for the service is the responsibility of the purchaser and is outside the scope of this Standard Practice.

1.4 The manufacturer shall provide pressure ratings for temperatures above 100 °F. This temperature is the temperature of the pressure-containing shell of the component. In general, this temperature is the same as that of the contained fluid. Use of a pressure rating corresponding to a temperature other than that of the contained fluid is the responsibility of the user, subject to the requirements of applicable codes and regulations.

2. DEFINITIONS

2.1 **General** Definitions given in MSS SP-96 apply to this Standard Practice.

2.2 **Control Piping** Piping used to interconnect pneumatically or hydraulically operated control apparatuses, or to signal control systems.

2.3 **Cold Working Pressure Rating (CWP)** The maximum allowable working pressure of a valve at ambient conditions (-20 °F to 100 °F).

2.4 **Instrument Piping** Piping used to connect instruments to main piping or other instruments.

2.5 **Instrument Valves** Valves designed for use in instrument, control, and sampling piping systems, (e.g., see ASME B31.1, Article 122.3).

2.6 **Manifold Valve** Two or more instrument valves fabricated into a single valve body.

2.7 **Packless Valve** A valve with a diaphragm or bellows stem seal instead of a packing or O-ring seal at the stem.

2.8 **Pressure Boundary Parts** The following items are defined to be pressure boundary parts. Each item may not apply to all valve designs.

- a) Body
- b) Bonnet
- c) Union Nut
- d) Body-to-Bonnet Bolting
- e) Body Bolting

2.9 **Sampling Piping** Piping used for the collection of samples (e.g., steam, water, oil, gas, and chemicals) from process systems.