



ANSI C12.22-2012

American National Standard

*Protocol Specification for
Interfacing to Data Communication Networks*

Secretariat:

National Electrical Manufacturers Association

IEEE Number: 1703-2012

Measurement Canada Number: MC12.22-2013

Approved April 14, 2015

American National Standards Institute, Inc.

NOTICE AND DISCLAIMER

The information in this publication was considered technically sound by the consensus of persons engaged in the development and approval of the document at the time it was developed. Consensus does not necessarily mean that there is unanimous agreement among every person participating in the development of this document.

NEMA standards and guideline publications, of which the document contained herein is one, are developed through a voluntary consensus standards development process. This process brings together volunteers and/or seeks out the views of persons who have an interest in the topic covered by this publication. While NEMA administers the process and establishes rules to promote fairness in the development of consensus, it does not write the document and it does not independently test, evaluate, or verify the accuracy or completeness of any information or the soundness of any judgments contained in its standards and guideline publications.

NEMA disclaims liability for any personal injury, property, or other damages of any nature whatsoever, whether special, indirect, consequential, or compensatory, directly or indirectly resulting from the publication, use of, application, or reliance on this document. NEMA disclaims and makes no guaranty or warranty, express or implied, as to the accuracy or completeness of any information published herein, and disclaims and makes no warranty that the information in this document will fulfill any of your particular purposes or needs. NEMA does not undertake to guarantee the performance of any individual manufacturer or seller's products or services by virtue of this standard or guide.

In publishing and making this document available, NEMA is not undertaking to render professional or other services for or on behalf of any person or entity, nor is NEMA undertaking to perform any duty owed by any person or entity to someone else. Anyone using this document should rely on his or her own independent judgment or, as appropriate, seek the advice of a competent professional in determining the exercise of reasonable care in any given circumstances. Information and other standards on the topic covered by this publication may be available from other sources, which the user may wish to consult for additional views or information not covered by this publication.

NEMA has no power, nor does it undertake to police or enforce compliance with the contents of this document. NEMA does not certify, test, or inspect products, designs, or installations for safety or health purposes. Any certification or other statement of compliance with any health- or safety-related information in this document shall not be attributable to NEMA and is solely the responsibility of the certifier or maker of the statement.

AMERICAN NATIONAL STANDARD

Approval of an American National Standard requires verification by the American National Standards Institute, Inc. (ANSI) that the requirements for due process, consensus, and other criteria for approval have been met by the standards developer.

Consensus is established when, in the judgment of the ANSI Board of Standards Review, substantial agreement has been reached by directly and materially affected interests. Substantial agreement means much more than a simple majority, but not necessarily unanimity. Consensus requires that all views and objections be considered, and that a concerted effort be made toward their resolution.

The use of American National Standards is completely voluntary; their existence does not in any respect preclude anyone, whether he has approved the standards or not, from manufacturing, marketing, purchasing, or using products, processes, or procedures not conforming to the standards.

The American National Standards Institute, Inc., does not develop standards and will in no circumstances give an interpretation of any American National Standard. Moreover, no person shall have the right or authority to issue an interpretation of an American National Standard in the name of the American National Standards Institute, Inc. Requests for interpretations should be addressed to the secretariat or sponsor whose name appears on the title page of this standard.

Caution Notice: This American National Standard may be revised or withdrawn at any time. The procedures of the American National Standards Institute, Inc., require that action be taken periodically to reaffirm, revise, or withdraw this standard. Purchasers of American National Standards may receive current information on all standards by calling or writing the American National Standards Institute, Inc.

Published by

**National Electrical Manufacturers Association
1300 North 17th Street, Suite 900, Rosslyn, Virginia 22209**

© 2015 National Electrical Manufacturers Association

All rights, including translation into other languages, reserved under the Universal Copyright Convention, the Berne Convention for the Protection of Literary and Artistic Works, and the International and Pan American copyright conventions.

No part of this publication may be reproduced in any form, in an electronic retrieval system or otherwise, without prior written permission from the publisher.

Printed in the United States of America

Foreword (This Foreword is not part of American National Standard C12.22-2012.)

This standard is intended to accommodate the network messaging requirements of an advanced metering infrastructure such as that identified by the Office of Electricity Delivery and Energy Reliability of the US Department of Energy; the Smart Metering Initiative of the Ontario Ministry of Energy (Canada) and the stated requirements of Measurement Canada for the approval of a metering device for use in Canada.

The standard describes four different but related communication modes of operation. One is the operation of an End Device (Node) over any network, a feature that all C12.22 compliant nodes need to implement. The second is an exposed point-to-point interface between a C12.22 Device, e.g., a meter, and, a C12.22 Communication Module, e.g., a network adaptor. The third is the capture, translation and transmission of one way messages (blurts). The fourth is communication with the End Device over a dedicated ANSI C12.18 ANSI Type 2 optical local port.

The standard assigns roles to all of the Utility AMI network assets to enable the automated deployment and configuration of network nodes in a distributed AMI enterprise system. The roles provide for Relays, Master Relays and Gateways; simple Hosts, Authentication Hosts, and Notification Hosts; and sensory End Devices. These devices work together to realize a Utility enterprise network in a manner that provides for a universal application framework that can operate any compliant appliance so that it can be deployed, accessed and communicated with seamlessly over any network infrastructure, hardware and available bandwidth. This is accomplished through the provision of well-defined network management services (e.g., trace, resolve, register, de-register), data access service (e.g., read, write), session management (e.g., logon, logoff, terminate, disconnect), message segmentation and assembly, message playback rejection, security and privacy.

All registration authorities that recognize registrars are governed by ANSI C12 and IEEE SCC31. To be recognized, any registration authority is expected to adhere to the requirements specified in this standard. See Annex D, "(normative) Universal Identifier."

The protocol is well suited for two-way and one-way communication using an extremely wide network address space (using ApTitles). It implements subscription and Node discovery services so that any Utility enterprise (e.g., MDMS, DA, DR, or any other willing network appliance, such as a home energy monitoring system, or a thermostat) can register itself as a Notification Host so that it can receive advisory messages and alerts about network asset changes or changes in the state of the network. Network subscription services can be managed through distributed Authentication Hosts.

Altogether, this standard was designed to be simple and small. Therefore, it can meet the requirements of the smallest of AMI networks, while providing well-defined capacities that can grow and adapt to the largest of enterprise AMI networks and operations as needed. As such, this standard together with ANSI C12.19 addresses the end-to-end distributed AMI network needs from the smallest to the largest of enterprise AMI systems.

The second release of this standard is a minor release in that it establishes a new baseline document that includes all the corrections that were applied in Annex K, "Listing of Editorial Errors and Errors of Omission in ANSI C12.22-2008" of the first release of IEEE Std 1703-2012. Readers who are acquainted with ANSI C12.22-2008 should review the notable differences and corrections that exist in this release of the standard relative to its predecessor. These are listed below:

1. New clauses "1 Overview" and "1.1 Introduction" were introduced ahead of old clause "1 Scope."
2. Old clause "1 Scope" was revised as clause "1.3 Purpose."
3. New clause "1.3 Purpose" was introduced.
4. Moved clause "2.2 Other" to "Annex K, Bibliography" and adopted IEEE-style citations and references.
5. Added reference to the "IEEE-SA Standards Definitions Database" in clause "3.1 Definitions."

6. Corrected Note 1 of clause "5.2.4 "Universal Identifiers Canonical Encoding,"
7. Added new response error code <nete> in clause "5.3.2.2 Response Codes."
8. Added new response error code <nete> in clause "5.3.2.4.1 Identification Service."
9. Corrected <octet-count> in clause "5.3.2.4.2 Read Service."
10. Corrected <data> in clause 5.3.2.4.3, "Write Service."
11. Corrected request description in clause "5.3.2.4.5 Security Service."
12. Added new response error code <nete> in clause "5.3.2.4.5 "Security Service."
13. Added new response error code <nete> in clause "5.3.2.4.8 "Disconnect Service."
14. Added new response error code <nete> in clause "5.3.2.4.9 "Wait Service."
15. Documented description of domain pattern in clause "5.3.2.4.10 "Registration Service."
16. Corrected <reg-info> in clause "5.3.2.4.10 Registration Service."
17. Corrected description of clause "5.3.2.4.12 "Resolve Service."
18. Corrected description of <epsem-control> of clause "5.3.3 EPSEM Envelope Structure."
19. Corrected Use of Assigned Subbranches in Relative ApTitle in clause "5.3.4.12 Use of Subbranches of a Registered ApTitle."
20. Inserted "A.1 Description" into Annex A, and renumbered all subclauses in Annex A.
21. Corrected clause "A.6 C12.22 Master Relay ApTitle Auto-assignment."
22. Inserted "C.1 Overview" into Annex C, and renumbered all subclauses in Annex C.
23. Added Element PATTERN_LEN_MULT to clause "C.3.1 Table 130 Relay Network Control Dimension Limits Table."
24. Added Element PATTERN_LEN_MULT to clause "C.3.2 TABLE 131 Actual Network Relay Limiting Table."
25. Corrected definition of END_DEVICE_FLAG of clause "C.3.3 Table 132 Registration List Table."
26. Updated size of APTITLE_PATTERN of clause "C.3.4 Table 133 Static Routing Table."
27. Updated size of NOTIFICATION_PATTERN of clause "C.3.5 Table 134 Host Notification Table."
28. Updated size of SERIAL_NUMBER_PATTERN of clause "C.2.6 Table 135 Master Relay Assignment Table."
29. Corrected description of CIPHER_MODE of clause "C.7 Table 47 Host Access Security Table."
30. Corrected examples of clause "Annex G, Communication Examples."
31. Added note on buffering to clause "I.1 EAX' description."

Suggestions for improvement to this standard are welcome. They should be sent to:

National Electrical Manufacturers Association
Vice President, Technical Services
1300 North 17th Street
Suite 900
Rosslyn, VA 22209

This Standard was processed and approved for submittal to ANSI by Accredited Standards Committee for Electricity Metering C12. At the time the committee approved this standard, the C12 Committee had the following members:

Tom Nelson, Chairman
Paul Orr, Secretary—NEMA Staff

Name of Representative:

Larry Barto
Ron Breschini
Brent Cain
Curt Crittenden
Jim DeMars
David Ellis
Tim Everidge

Organization Represented:

Georgia Power
Underwriters Laboratories, Inc.
Itron, Inc.
GE Energy
Florida Power & Light Co.
Public Service Electric & Gas
Radian Research, Inc.

ANSI C12.22-2012

Name of Representative:

Shawn Glasgow
Bill Hardy
Bob Hughes
Brad Johnson
Lawrence Kotewa
Herman Millican
Avygdor Moise
Tim Morgan
Tom Nelson
D. Young Nguyen
Dan Nordell
Dave Scott
Aaron Snyder
George Steiner
Jim Thurber
Richard Tucker
Michel Veillette
John Voisine
H.A. Wall
Scott Weikel
James West

Organization Represented:

Milbank Manufacturing
Power Measurements
Schweitzer Engineering Labs, Inc.
Oncor Group
Center for Neighborhood Technology
Austin Energy
Future DOS R&D Inc.
Duke Energy Corp.
Nat'l Inst. of Standards & Technology (NIST)
Pacific Gas & Electric Company
Xcel Energy EMC
Plexus
EnerNex Corporation
Sensus Metering
Baltimore Gas & Electric Company
Tucker Engineering
Trilliant Networks, Inc.
Landis+Gyr
Watthour Engineering Co.
Elster Electricity
Ameren

Working Group 1 of Subcommittee 17 that developed the standard consisted of:

Ed Beroset, Chairman
Richard Tucker, Vice Chairman
Avygdor Moise, Editor
Paul Orr, Secretary—NEMA Staff

Name of Representative:

Michael Anderson
Norbert Balko
Ed Beroset
Bill Beverly
William Buckley
Martin Burns
Brent Cain
Richard Coblens
Raymond Gaudreault
Derek Gibbs
Ken Gilmer
Greg Gomez
David Haynes
Mark Iacoviello
Janice Jennings
Jean Joly
Brad Johnson
Lawrence Kotewa
Jacques Ledoux
Keith Martin
Peter Martin
Ed May
Bill Mazza

Organization Represented:

Landis+Gyr
Invensys Metering Systems
Elster Electricity
Austin International Inc.
Consultant for Itron, Inc
Hypertek Inc. for EPRI
Itron, Inc.
Schlumberger Electricity
C-MAC
Smartsynch
Itron, Inc.
Badger Meter
Aclara
Distribution Control Systems
Schlumberger Electricity
Hydro-Quebec
Oncor
Center for Neighborhood Technology
Trilliant Networks, Inc.
Tantalus Systems Corp.
Distribution Control Systems, Inc.
Itron, Inc.
Invensys Metering Systems

Name of Representative:

Robert McMichael
Avygdor Moise
John Newbury
Dan Nordell
Vuong Nguyen
James Pace
Terry Penn
Marc Purc
Bin Qiu
Wesley Ray
Jeff Richardson
Bill Rush
Ruben Salazar
Chris Schafer
Robby Simpson
Kendall Smith
Aaron Snyder
John Taylor
Richard Tucker
Michel Veillette
Ted York
Virginia Zinkowski

Organization Represented:

Itron, Inc.
Future DOS R&D Inc.
Open University
Northern States Power Co.
Measurement Canada
Silver Springs Networks
Southern Company
Schlumberger
Landis+Gyr
Duke Energy Corp.
Elster Metering
IGT
Landis+Gyr
Itron Inc.
GE Energy
Hexagram
EnerNex Corporation
American Innovations
Tucker Engineering
Trilliant Networks, Inc.
THY Consulting
GE Energy

Contents

	Page
1 Overview	1
1.1 Introduction	1
1.2 Scope	1
1.3 Purpose	2
2 Normative references.....	3
3 Definitions and syntax	5
3.1 Definitions	5
3.2 Document syntax	8
3.3 Table syntax.....	9
4 Reference topology.....	9
5 C12.22 Node to C12.22 Network Segment details	11
5.1 C12.22 Node to C12.22 Network Segment reference.....	11
5.2 Data encoding rules	12
5.2.1 Data order	12
5.2.2 Length fields encoding.....	13
5.2.3 Universal identifiers encoding	13
5.2.4 Universal identifiers canonical encoding.....	15
5.3 Layer 7—application layer	15
5.3.1 Data structure—utility industry data tables	15
5.3.2 EPSEM	15
5.3.2.1 Request codes.....	16
5.3.2.2 Response codes	16
5.3.2.3 Time-out.....	20
5.3.2.3.1 Session time-out	20
5.3.2.3.2 Application layer response time-out	20
5.3.2.4 Services.....	20
5.3.2.4.1 Identification service	20
5.3.2.4.2 Read service	23
5.3.2.4.3 Write service.....	25
5.3.2.4.4 Logon service	27
5.3.2.4.5 Security service	27
5.3.2.4.6 Logoff service.....	28
5.3.2.4.7 Terminate service	29
5.3.2.4.8 Disconnect service.....	29
5.3.2.4.9 Wait service	30
5.3.2.4.10 Registration service	31
5.3.2.4.11 Deregistration service	39
5.3.2.4.12 Resolve service	39
5.3.2.4.13 Trace service.....	40
5.3.2.5 Service sequence state control.....	41
5.3.2.6 Partial table access using index/element-count method	42
5.3.2.7 Partial table access using offset/octet-count method.....	44
5.3.3 EPSEM envelope structure	45
5.3.4 Association control—Association Control Service Element (ACSE)	46
5.3.4.1 Application Context Element (A1 _H).....	47
5.3.4.2 Called AP Title Element (A2 _H)	48
5.3.4.3 Calling AP Title Element (A6 _H).....	48
5.3.4.4 Universal Identifier of Called and Calling AP Title Element (06 _H)	48
5.3.4.5 Relative Universal Identifier of Called and Calling AP Title Element (80 _H)	48
5.3.4.6 Calling Application Entity Qualifier Element (A7 _H).....	49
5.3.4.7 Mechanism Name Element (8B _H).....	50

5.3.4.8	Calling Authentication Value Element (AC _H).....	50
5.3.4.8.1	C12.22 Security Mechanism (<application-context-oid>.2.1).....	52
5.3.4.8.2	C12.21 Security Mechanism (<application-context-oid>.2.0).....	54
5.3.4.8.3	C12.22 Other security mechanisms	57
5.3.4.9	Called AP invocation ID element (A4 _H)	57
5.3.4.10	Calling AP invocation ID element (A8 _H).....	58
5.3.4.11	User information element (BE _H)	59
5.3.4.12	Use of subbranches of a registered ApTitle	61
5.3.4.13	C12.22 Security Mechanism	64
5.3.4.13.1	C12.22 Security Mechanism (<application-context-oid>.2.1).....	64
5.3.4.13.1.1	Security modes.....	64
5.3.4.13.1.2	Rules for responses.....	65
5.3.4.13.1.3	Key ID.....	65
5.3.4.13.1.4	Access privileges.....	65
5.3.4.13.1.5	Initialization Vector.....	65
5.3.4.13.1.6	Calling AP Invocation ID.....	65
5.3.4.13.1.7	Syntax mapping.....	66
5.3.4.13.1.8	Cleartext with Authentication	66
5.3.4.13.1.9	Ciphertext with Authentication	68
5.3.4.13.1.10	Validating messages	70
5.3.5	Application Segmentation Sub-layer	70
5.3.5.1	APDU segmentation	71
5.3.5.2	APDU Segment.....	71
5.3.5.2.1	Called AE Qualifier Element (A3 _H)	71
5.3.5.2.2	Segment User Information Element (BE _H).....	72
5.3.5.2.2.1	Segment Association Information Element	72
5.3.5.2.2.2	Segment Data Elements	73
5.3.5.3	Segmentation and Reassembly	73
5.3.5.3.1	Segmentation Algorithm.....	73
5.3.5.3.2	Reassembly Algorithm	75
5.4	Layer 6—presentation layer.....	76
5.5	Layer 5—session layer.....	76
5.6	Layer 4—transport layer	76
5.7	Layer 3—network layer	76
5.8	Layer 2—data link layer	76
5.9	Layer 1—physical layer.....	76
6	Protocol Details: C12.22 Device to C12.22 Communication Module interface	77
6.1	Interface architecture	77
6.2	Interface diagram.....	77
6.3	Implementation guidelines.....	78
6.3.1	C12.22 Communication Module.....	78
6.3.2	C12.22 Device	79
6.4	Layer 7—application layer	80
6.5	Layer 6—presentation layer.....	80
6.6	Layer 5—session layer.....	80
6.7	Layer 4—transport layer.....	80
6.7.1	Negotiate Service.....	80
6.7.2	Get Configuration Service	82
6.7.3	Link Control Service.....	85
6.7.4	Send Message Service	87
6.7.5	Get Status Service.....	89
6.7.6	Get Registration Status Service	90
6.7.7	Service Time Sequence Diagrams	91
6.7.8	Service Sequence States.....	95
6.8	Layer 3—network layer	97
6.9	Layer 2—data link layer	97
6.9.1	Basic data information	98
6.9.1.1	Fixed settings	98

ANSI C12.22-2012

6.9.1.2	Variable settings.....	98
6.9.2	Packet definition	98
6.9.3	CRC selection	100
6.9.4	Acknowledgment.....	100
6.9.5	Retry attempts	101
6.9.6	Timeouts	101
6.9.6.1	Traffic Time-out.....	101
6.9.6.2	Inter-character Time-out	101
6.9.6.3	Response Time-out	101
6.9.7	Turn Around Delay	101
6.9.8	Collision.....	101
6.9.9	Duplicate packets.....	102
6.9.10	Transparency.....	102
6.9.11	Supervision of the communications link.....	102
6.9.12	Local routing.....	102
6.9.13	Service sequence states	104
6.10	Layer 1—physical layer.....	105
6.10.1	Signal definition.....	105
6.10.2	Electrical properties of the connection.....	105
6.10.3	Mechanical and environmental properties	106
6.10.4	Supervision of the communications link.....	106
7	Local Port communication protocol details	107
7.1	Protocol definition	107
7.1.1	Layer 7—Application layer	107
7.1.2	Layer 6—Presentation layer	107
7.1.3	Layer 5—Session layer	107
7.1.4	Layer 4—Transport layer.....	107
7.1.5	Layer 3—Network layer	108
7.1.6	Layer 2—Data link layer	108
7.1.7	Layer 1—Physical layer.....	108
7.2	C12.22 Local Port communication using a C12.18 Optical Port	108
7.2.1	Establishment of ANSI C12.18 protocol compatibility mode	109
7.2.2	Establishment of ANSI C12.22 protocol compatibility mode	109
8	Backward compatibility.....	109
9	Compliance.....	110
Annex A	(normative) Relays.....	111
A.1	Description.....	111
A.2	Hierarchical topology	111
A.3	C12.22 Master Relays.....	111
A.4	Registration notification	112
A.5	Registration algorithm details	112
A.6	C12.22 Node ApTitle auto-assignment.....	112
A.7	C12.22 Master Relay ApTitle auto-assignment	113
A.8	Obsolete routes	113
A.9	Multiple routes.....	113
A.10	Application layer supervision	113
A.11	Routing	114
Annex B	(informative) Routing examples	115
B.1	C12.22 Relays with a single Service Provider	115
B.2	C12.22 Relays shared by multiple Service Providers	115
Annex C	(normative) Modifications and extensions to ANSI C12.19.....	117

C.1	Overview	117
C.2	Decade 12: Node Network Control Tables	117
C.2.1	Table 120 Node Network Control Dimension Limits Table	117
C.2.2	Table 121 Actual Node Network Control Limiting Table	120
C.2.3	Table 122 Interface Control Table	123
C.2.4	Table 123 Exception Report Configuration Table	125
C.2.5	Table 124 Filtering Rules Table	127
C.2.6	Table 125 Interface Status Table	129
C.2.7	Table 126 Registration Status Table	133
C.2.8	Table 127 Network Statistics Selections Table	134
C.2.9	Table 128 Network Statistics Table	135
C.3	Decade 13: Network Relay Control Tables	137
C.3.1	Table 130 Relay Network Control Dimension Limits Table	137
C.3.2	Table 131 Actual Network Relay Limiting Table	138
C.3.3	Table 132 Registration List Table	139
C.3.4	Table 133 Static Routing Table	142
C.3.5	Table 134 Host Notification Table	144
C.3.6	Table 135 Master Relay Assignment Table	146
C.3.7	Table 136 Dynamic Routing Report Table	147
C.4	Universal ID pattern description of ApTitles	147
C.5	Additions to TABLE 07—Procedure Initiate Table	148
C.5.1	Procedure 23 Register	148
C.5.2	Procedure 24 Deregister	148
C.5.3	Procedure 25 Network Interface Control	149
C.5.4	Procedure 26 Exception Report	150
C.6	Table 46: Extended Key Table	151
C.7	Table 47: Host Access Security Table	152
Annex D	(normative) Universal Identifier	156
Annex E	(normative) One-way devices	158
Annex F	(informative) APDU Response Time-out algorithm	160
Annex G	(informative) Communication examples	161
G.1	Example #1: Unsecured session	161
G.2	Example #2: Unsecured sessionless	162
G.3	Example #3: Unsecured notification	163
G.4	Example #4: Authenticated session	163
G.5	Example #5: Authenticated sessionless	166
G.6	Example #6: Authenticated notification	167
G.7	Example #7: Encrypted session	167
G.8	Example #8: Encrypted sessionless	171
G.9	Example #9: Encrypted notification	172
Annex H	(informative) CRC examples	174
H.1	Trace	174
H.2	CRC code example	175
Annex I	(normative) The EAX' Cryptographic Mode	176
I.1	EAX' description	176
I.2	Justifications for selection of EAX rather than CCM	181
I.3	Justifications for the EAX' optimizations	182
I.4	EAX' C code example (informative)	184
I.5	AES C code example (informative)	187
Annex J	(informative) Connectionless-ACSE-1 equivalent reduced syntax for C12.22 Message transmission	193

ANSI C12.22-2012

Annex K (informative) Bibliography194
Annex L (informative) Historical Background195
L.1 Foreword of American National Standard C12.22-2008195

Figures

Figure 4-1 Reference Topology10
Figure 4-2 C12.22 Node Implementation Examples11
Figure 5-1 C12.22 Reference Network Model12
Figure 5-2 C12.22 Host Application Layer State Diagram42
Figure 5-3 Unsegmented APDU Segmentation and Reassembly Algorithm75
Figure 5-4 Segmented APDU Resegmentation and Partial Assembly Algorithm76
Figure 6-1 C12.22 Communication Module Implementation Model78
Figure 6-2 Transport Layer State Diagram for C12.22 Communication Module96
Figure 6-3 Transport Layer State Diagram for C12.22 Device97
Figure 6-4 Data Link Layer State Diagram104
Figure 6-5 Jack and Cable Plug Wiring Diagram106
Figure 7-1 Transport Layer State Diagram108
Figure B-1 C12.22 Relays and Routing Tables115
Figure B-2 C12.22 Relays and Routing Tables for Multiple Service Providers116

1 Overview

1.1 Introduction

This standard defines network Application Services for the exchange of Table data and control elements. These services must be implemented by all C12.22 Nodes, including “back-office” or “head-end” systems.

1.2 Scope

Initially, communications with electronic devices consisted of transporting memory data via proprietary protocols that were unique to each manufacturer. The desire for interoperability and support for multiple manufacturers by reading and programming systems created a need for standardization of data formats and transport protocols.

The first step was to standardize data formats. Internal data was abstracted as a set of Tables. A set of standard Table contents and formats were defined in ANSI C12.19/MC12.19/IEEE 1377, “Utility Industry End Device Data Tables.”¹

In the “Protocol Specification for ANSI Type 2 Optical Port” Standard (ANSI C12.18/MC12.18/IEEE 1701), a point-to-point protocol was developed to transport table data over an optical connection. The ANSI C12.18/MC12.18/IEEE 1701 protocol include an application language called Protocol Specification for Electric Metering (PSEM) that allows applications to read and write Tables. The “Protocol Specification for Telephone Modem Communication” (ANSI C12.21/MC12.18/IEEE 1702) was then developed to allow devices to use PSEM to transport Tables over telephone modems.

This standard extends the concepts of ANSI C12.18/MC12.18/IEEE 1701, ANSI C12.21/MC12.18/IEEE 1702, and ANSI C12.19/MC12.19/ IEEE 1377 standards to allow transport of Table data over any reliable networking communications system. Note that in this use of the word, “reliable” means that for every message sent, the sender receives a response at its option: either a positive acknowledgment or an error message. That is, messages cannot fail silently in a reliable network (see discussion of Reliable Stream Transport Service in IPPA [B1]).²

In addition, this standard describes an optionally exposed point-to-point interface between a C12.22 Device and a C12.22 Communications Module designed to attach to “any” network. The terms “C12.22 XXXX” (e.g., C12.22 Device) were introduced by ANSI C12.22-2008. These terms can be interchangeably replaced with the terms “IEEE 1703 XXXX”; i.e., the IEEE 1703 Device is the same as the ANSI C12.22 Device and the IEEE 1703 Communication Module is the same as the C12.22 Communication Module. However, since this standard was originally developed under the auspice of ANSI C12 SC17 WG1, the document terminology is based on C12.22 terms.

Furthermore, this standard defines a methodology to capture, translate, and transmit one-way device messages (blurts).

This standard defines interfaces between IEEE 1377 Devices (ANSI C12.19 Devices) and network protocols.

Specific goals identified by the committee in the creation of this standard were:

- a) Defining a Datagram that can convey ANSI C12.19 data Tables through any network

This was accomplished by:

- Assuming that the data source is ANSI C12.19 data Tables
- Defining the Application Layer services (language)

¹ Information on references can be found in clause 2.

² Numbers in brackets correspond to those of the bibliography in Annex K.

ANSI C12.22-2012

- b) Providing a full stack [ISO/IEC 7498-1] definition for interfacing a C12.22 Device to a C12.22 Communication Module

This was accomplished by:

- Defining the physical interface requirements between the C12.22 Device and the C12.22 Communication Module
- Defining the interface lower layers [ISO/IEC 7498-1]: 4 (transport), 3 (network), 2 (data link), and 1 (physical)

- c) Providing a full stack definition for point-to-point communication to be used over local ports such as optical ports or modems

This was accomplished by defining a Layer 4 (transport) and Layer 2 (data link)

- d) Providing support for efficient one-way messaging (blurts)

This was accomplished by:

- Defining a compact message format that can be easily transformed into a standard ANSI C12.22 Datagram
- Assuring that all needed layers defined in this standard can support one-way messaging

- e) Providing network architecture compatible with this protocol (some architectural concepts were derived from HCCS 1 [B5], HCCS 2 [B6], HCCS 3 [B7], DND [B4], IPPA [B1], and TCPCE [B2])

This was accomplished by:

- Defining different types of nodes such as C12.22 Relay, C12.22 Master Relay, C12.22 Host, C12.22 Authentication Host, C12.22 Notification Host, and C12.22 Gateway
- Defining the roles and responsibilities of each of these C12.22 Nodes

- f) Providing data structure definitions in support of this protocol

This was accomplished by:

- Defining an ANSI C12.19 Decade to be used by C12.22 Nodes
- Defining an ANSI C12.19 Decade to be used by C12.22 Relays
- Defining new procedures in support of this protocol
- Defining a new Table for enhanced security