



Approved as an American National Standard  
ANSI Approval Date: January 23, 2013

### **ANSI/NEMA HP 8-2013**

*Electrical and Electronic Cross-Linked, Modified Low-Smoke Polyolefin (XLPO)  
Insulated Hook-Up Wire, Types LS (rated 105°C; 600 V), ZHDM (rated 90°C; 600 V),  
ZHDH (rated 90°C; 600 V), ZH (rated 125°C; 600 V), and ZHX (rated 125°C; 1000 V)*

*Published by:*

**National Electrical Manufacturers Association**

1300 North 17<sup>th</sup> Street, Suite 900  
Rosslyn, VA 22209

[www.nema.org](http://www.nema.org)

© Copyright 2013 by the National Electrical Manufacturers Association. All rights including translation into other languages, reserved under the Universal Copyright convention, the Berne Convention for the Protection of Literary and Artistic Works, and the International and Pan American Copyright Conventions.

## NOTICE AND DISCLAIMER

The information in this publication was considered technically sound by the consensus of persons engaged in the development and approval of the document at the time it was developed. Consensus does not necessarily mean that there is unanimous agreement among every person participating in the development of this document.

The National Electrical Manufacturers Association (NEMA) standards and guideline publications, of which the document contained herein is one, are developed through a voluntary consensus standards development process. This process brings together volunteers and/or seeks out the views of persons who have an interest in the topic covered by this publication. While NEMA administers the process and establishes rules to promote fairness in the development of consensus, it does not write the document and it does not independently test, evaluate, or verify the accuracy or completeness of any information or the soundness of any judgments contained in its standards and guideline publications.

NEMA disclaims liability for any personal injury, property, or other damages of any nature whatsoever, whether special, indirect, consequential, or compensatory, directly or indirectly resulting from the publication, use of, application, or reliance on this document. NEMA disclaims and makes no guaranty or warranty, express or implied, as to the accuracy or completeness of any information published herein, and disclaims and makes no warranty that the information in this document will fulfill any of your particular purposes or needs. NEMA does not undertake to guarantee the performance of any individual manufacturer or seller's products or services by virtue of this standard or guide.

In publishing and making this document available, NEMA is not undertaking to render professional or other services for or on behalf of any person or entity, nor is NEMA undertaking to perform any duty owed by any person or entity to someone else. Anyone using this document should rely on his or her own independent judgment or, as appropriate, seek the advice of a competent professional in determining the exercise of reasonable care in any given circumstances. Information and other standards on the topic covered by this publication may be available from other sources, which the user may wish to consult for additional views or information not covered by this publication.

NEMA has no power, nor does it undertake to police or enforce compliance with the contents of this document. NEMA does not certify, test, or inspect products, designs, or installations for safety or health purposes. Any certification or other statement of compliance with any health or safety-related information in this document shall not be attributable to NEMA and is solely the responsibility of the certifier or maker of the statement.

## CONTENTS

FOREWORD .....	III
<b>SECTION 1 GENERAL .....</b>	<b>1</b>
1.1 SCOPE .....	1
1.2 REFERENCE STANDARDS AND SPECIFICATIONS .....	1
1.3 RECOMMENDED USES OF WIRE TYPES .....	1
1.3.1 TYPE LS .....	1
1.3.2 TYPE ZHDM, and ZHDH .....	2
1.3.3 TYPE ZH .....	2
1.3.4 TYPE ZHX .....	2
1.4 PART IDENTIFICATION NUMBER (PIN) .....	2
<b>SECTION 2 CONDUCTORS .....</b>	<b>4</b>
2.1 CONDUCTOR MATERIALS .....	4
2.2 CONDUCTOR COATINGS .....	4
2.2.1 Tin-Coated Conductors .....	4
2.2.2 Silver-Coated Conductors .....	4
2.3 STRANDING .....	4
2.4 WIRE DIAMETER .....	4
2.5 CONDUCTOR SPLICES .....	4
<b>SECTION 3 INSULATION .....</b>	<b>5</b>
3.1 GENERAL .....	5
3.2 XLPO INSULATION .....	5
<b>SECTION 4 WIRE IDENTIFICATION .....</b>	<b>8</b>
4.1 CIRCUIT IDENTIFICATION .....	8
4.1.1 Lay of Stripes .....	8
4.2 IDENTIFICATION BY PRINTING .....	8
4.2.1 Identification of Product .....	8
<b>SECTION 5 PHYSICAL AND ELECTRICAL REQUIREMENTS .....</b>	<b>9</b>
5.1 GENERAL .....	9
5.2 QUALITY CONFORMANCE INSPECTION OF FINISHED PRODUCT .....	9
5.2.1 Definitions .....	9
5.2.1.1 Inspection Lot .....	9
5.2.1.2 Unit of Product .....	9
5.2.2 Sampling Inspection .....	9
5.3 WORKMANSHIP .....	9
5.4 MATERIALS CERTIFICATION .....	9
<b>SECTION 6 TEST PROCEDURES .....</b>	<b>12</b>
6.1 PHYSICAL TESTS .....	12
6.1.1 Test Temperature .....	12
6.1.2 Heat Resistance .....	12
6.1.3 Insulation Tensile Strength and Elongation .....	12
6.1.4 Dimensional Inspection .....	12
6.1.4.1 Conductor Diameter .....	12
6.1.4.2 Insulation Diameter .....	12
6.1.4.3 Concentricity .....	12
6.1.5 Shrinkage .....	13
6.1.6 Flammability .....	13
6.1.7 Heat Aging Test .....	13
6.1.8 Fungus Resistance .....	13

6.1.9	<i>Cold Bend</i> .....	13
6.1.10	<i>Halogen Content</i> .....	13
6.1.11	<i>Smoke Index</i> .....	13
6.1.12	<i>Toxicity Index</i> .....	13
6.1.13	<i>Acid Gas Generation</i> .....	14
6.2	<b>ELECTRICAL TESTS</b> .....	14
6.2.1	<i>Conductor Resistance</i> .....	14
6.2.2	<i>Spark or Impulse Test</i> .....	14
6.2.3	<i>Dielectric Strength</i> .....	14
6.2.4	<i>Insulation Resistance</i> .....	14
6.2.5	<i>Characteristic Impedance</i> .....	14
<b>SECTION 7</b>	<b>NOTES</b> .....	<b>15</b>
7.1	PACKAGING REQUIREMENTS.....	15
7.2	LABELING.....	15
7.3	LENGTHS.....	15
<b>SECTION 8</b>	<b>ORDERING DATA</b> .....	<b>16</b>
8.1	ORDERING INFORMATION.....	16

**Tables**

TABLE 1-1	CONDUCTOR MATERIAL AND COATING.....	2
TABLE 1-2	AWG NOMINAL CONDUCTOR SIZE.....	2
TABLE 1-3	NUMBER OF STRANDS.....	3
TABLE 1-4	COLOR (SEE PARA 4.1).....	3
TABLE 3-1	DIMENSION BY WIRE TYPES.....	5
TABLE 3-2	IMPEDANCE PROPERTIES OF TWISTED PAIR CABLES FOR TYPE ZHDM AND ZHDH WIRES TESTED AT 1 MHZ.....	7
TABLE 4-1	LENGTH OF LAY OF STRIPES.....	8
TABLE 5-1	PHYSICAL AND ELECTRICAL REQUIREMENTS FOR TYPE LS, ZHD, ZH, AND ZHX WIRES.....	10
TABLE 7-1	MINIMUM LENGTHS.....	15

## Foreword

ANSI/NEMA HP 8-2013 (hereinafter referred to as ANSI/NEMA HP 8) was developed by the NEMA High Performance Wire and Cable Section to define hook-up cables using low smoke and low or zero halogen insulation materials that might be used as an alternative to PVC-insulated cables for applications requiring these types of characteristics.

In the preparation of ANSI/NEMA HP 8, input of users and other interested parties has been considered. Proposed revisions, comments, and suggestions for the improvement of this document are encouraged. They should be sent to:

Senior Technical Director, Operations  
National Electrical Manufacturers Association  
1300 North 17th Street, Suite 900  
Rosslyn, Virginia 22209  
[www.nema.org](http://www.nema.org)

Section approval of ANSI/NEMA HP 8 does not necessarily imply that all Section members voted for its approval or participated in its development. At the time ANSI/NEMA HP 8 was approved, the Section was composed of the following members:

- AFC Cable Systems, Inc., New Bedford, MA
- AmerCable, El Dorado, AR
- Apical Division, Kaneka North America, Pasadena, TX
- Belden, St. Louis, MO
- Berk-Tek, a Nexans Company, Elm City, NC
- Cable USA LLC, Naples, FL
- Coleman Cable Inc., Waukegan, IL
- General Cable, Highland Heights, KY
- Harbour Industries LLC, Shelburne, VT
- IWG High Performance Conductors, Inman, SC
- Leviton Manufacturing Co., Inc., Gardena, CA
- Quirk Wire Company, Inc., West Brookfield, MA
- Radix Wire, Euclid, OH
- RSCC Aerospace and Defense, East Granby, CT
- Southwire Company, Carrollton, GA
- The Monroe Cable Company, Inc., Middletown, NY
- The Okonite Company, Ramsey, NJ
- TE Connectivity, Menlo Park, CA

< This page is intentionally left blank. >

## SECTION 1 GENERAL

### 1.1 SCOPE

ANSI/NEMA HP 8 covers specific requirements for cross-linked, modified polyolefin insulated solid and stranded wire designed for the internal wiring of high-reliability electrical and electronic equipment. ANSI/NEMA HP 8 addresses 600 V (Types LS, ZHDM, ZHDH, and ZH) and 1000 V (Type ZHX) wire and permits continuous conductor temperature ratings of -40°C to 90°C, 105°C, or 125°C with either tin- or silver-coated conductors. These types of hook-up wire are used when the following requirements are called for:

- a) Moderate temperature resistance
- b) Low temperature resistance
- c) Good dielectric constant (Type ZHDM and ZHDH)
- d) Moderate dielectric constant (Type LS)
- e) Good flexibility and flex life when stranded conductors are used
- f) Solder iron resistance for easier solder terminations without potential damage
- g) Low smoke (Types LS, ZHDM, ZHDH, ZH, ZHX)
- h) Zero halogen (Types ZHDM, ZHDH, ZH, ZHX)
- i) Low toxicity (Types LS, ZHDM, ZHDH, ZH, ZHX)
- j) Low acid gas generation (Types LS, ZHDM, ZHDH, ZH, ZHX)

### 1.2 REFERENCE STANDARDS AND SPECIFICATIONS

From the American Society for Testing and Materials (ASTM):

D3032, *Methods of Testing Hook-Up Wire Insulation*

G21, *Standard Practice for Determining Resistance of Synthetic Polymeric Materials to Fungi*

From the American Society for Quality Control (ASQC):

ANSI/ASQC Z1.4, *Sampling Procedures and Tables for Inspection by Attributes*

From the Electronic Industries Alliance (EIA):

EIA-359-A, *EIA Standard Colors for Color Identification and Coding*

From the Department of Defense Index of Specifications and Standards (DODISS):

MIL-STD-2223, *Test Methods for Insulated Electronic Wire*

MIL-DTL-24643, *Cables and Cords, Electric, Low Smoke, For Shipboard Use, General Specification For*

FED-STD-228, *Methods of Testing Cable and Wire, Insulated*

From Underwriters Laboratories (UL):

UL1581, *Reference Standard for Electrical Wires, Cables, and Flexible Cords*

From the National Electrical Manufacturers Association (NEMA):

NEMA WC 52-2005, *High-Temperature and Electronic Insulated Wire, Impulse Dielectric Testing*

NEMA WC 56-1986 (R1993, R2000, R2005, R2012), *3.0 kHz Insulation Continuity Proof Testing of Wire and Cable*

ANSI/NEMA WC 67-2012, *Standard for Uninsulated Conductors Used in Electrical and Electronic Applications*

### 1.3 RECOMMENDED USES OF WIRE TYPES

#### 1.3.1 TYPE LS

Type LS wire is intended for use in 600 V, medium temperature applications (Replaces M16878/36).

**1.3.2 TYPE ZHDM and ZHDH**

Type ZHDM and ZHDH wire is intended for use in 600 V or less signal applications where a good dielectric constant is required to meet the specific electrical properties (see Table 3–2) in low temperature (90°C) applications. The insulation contains zero halogens.

**1.3.3 TYPE ZH**

Type ZHM wire is intended for use in 600 V, medium temperature (125°C) applications. The insulation contains zero halogens.

**1.3.4 TYPE ZHX**

Type ZHX wire is intended for use in 1000 V, medium temperature (125°C) applications. The insulation contains zero halogens.

**1.4 PART IDENTIFICATION NUMBER (PIN)**

The part numbers shall be of the following form:

HP 8–(TYPE)-(CONDUCTOR MATERIAL)(AWG)(STRANDS)(COLOR)

NEMA STANDARD  
for XLPO insulated wire

Example: HP 8–LS-BJE9

Type LS, Tin-Coated Copper, 16 AWG, 19 Strands White

**Table 1–1 Conductor Material and Coating**

Letter	Conductor Material & Coating
B	Tin-Coated Copper
S	Silver-Coated Copper

**Table 1–2 AWG Nominal Conductor Size**

AWG	Letter	AWG	Letter
32	A	10	M
30	B	8	N
28	C	6	P
26	D	4	R
24	E	2	S
22	F		
20	G		
18	H		
16	J		
14	K		
12	L		

**Table 1–3 Number of Strands**

<b>Letter</b>	<b>Number of Strands</b>
A	1
B	7
E	19
G	37
J	65
L	133
M	168
N	259
P	665
R	817
S	1045
T	1330

**Table 1–4 Color (see Section 4.1)**

<b>Color</b>	<b>Number Designator</b>	<b>Color</b>	<b>Number Designator</b>
Black	0	Green	5
Brown	1	Blue	6
Red	2	Violet	7
Orange	3	Gray	8
Yellow	4	White	9