



Approved as an American National Standard
ANSI Approval Date: August 15, 2017

ANSI/NEMA WC 58-2017
ICEA No. S-75-381-2017

Portable and Power Feeder Cables for Use in Mines and Similar Applications

Published by

National Electrical Manufacturers Association

1300 North 17th Street, Suite 900
Rosslyn, Virginia 22209

www.nema.org

© 2017 National Electrical Manufacturers Association and Insulated Cable Engineers Association. All rights including translation into other languages, reserved under the Universal Copyright Convention, the Berne Convention for the Protection of Literary and Artistic Works, and the International and Pan American Copyright Conventions.

NOTICE AND DISCLAIMER

The information in this publication was considered technically sound by the consensus of persons engaged in the development and approval of the document at the time it was developed. Consensus does not necessarily mean that there is unanimous agreement among every person participating in the development of this document.

The National Electrical Manufacturers Association (NEMA) and the Insulated Cable Engineers Association (ICEA) standards and guideline publications, of which the document contained herein is one, are developed through a voluntary consensus standards development process. This process brings together persons who have an interest in the topic covered by this publication. While NEMA and ICEA administer the process and establish rules to promote fairness in the development of consensus, they do not independently test, evaluate, or verify the accuracy or completeness of any information or the soundness of any judgements contained in its standards and guideline publications.

NEMA and ICEA disclaim liability for personal injury, property, or other damages of any nature whatsoever, whether special, indirect, consequential, or compensatory, directly or indirectly resulting from the publication, use of, application, or reliance on this document. NEMA and ICEA disclaim and make no guaranty or warranty, expressed or implied, as to the accuracy or completeness of any information published herein, and disclaims and makes no warranty that the information in this document will fulfill any of your particular purposes or needs. NEMA and ICEA do not undertake to guarantee the performance of any individual manufacturer or seller's products or services by virtue of this standard or guide.

In publishing and making this document available, NEMA and ICEA are not undertaking to render professional or other services for or on behalf of any person or entity, nor are NEMA and ICEA undertaking to perform any duty owed by any person or entity to someone else. Anyone using this document should rely on his or her own independent judgment or, as appropriate, seek the advice of a competent professional in determining the exercise of reasonable care in any given circumstances. Information and other standards on the topic covered by this publication may be available from other sources, which the user may wish to consult for additional views or information not covered by this publication.

NEMA and ICEA have no power, nor do they undertake to police or enforce compliance with the contents of this document. NEMA and ICEA do not certify, test, or inspect products, designs, or installations for safety or health purposes. Any certification or other statement of compliance with any health or safety-related information in this document shall not be attributable to NEMA and ICEA and is solely the responsibility of the certifier or maker of the statement.

CONTENTS

	Foreword.....	xi
Section 1	General	1
1.1	Scope	1
	Portable Cables 2,000 Volts or Less	1
	Portable Cables 2,001–5,000 Volts (100% Insulation Level).....	2
	Portable Cables 5,001–25,000 Volts (100% Insulation Level).....	2
	Mine Power 2,001–25,000 Volts (100% and 133% Insulation Level)	2
1.2	General Information	3
1.3	Information to Be Supplied by User	3
Section 2	Conductors	4
2.1	Physical and Electrical Properties	4
	2.1.1 Copper Conductors	4
	2.1.2 Aluminum Conductors	4
	2.1.3 Flexible Conductors	4
2.2	Conductor Size Units	4
2.3	Conductor DC Resistance Per Unit Length.....	5
	2.3.1 Direct Measurement of DC Resistance Per Unit Length	5
	2.3.2 Calculation of DC Resistance Per Unit Length	5
2.4	Conductor Diameter.....	5
Section 3	Portable Single and Multiple Conductor Power Cable	13
3.1	Scope	13
3.2	DC Systems	13
3.3	Single-Conductor Cables, Nonshielded, 2,000 Volts Or Less	13
3.4	Type W and G Two-Conductor Cables, 2,000 Volts Or Less	13
	3.4.1 Two-Conductor Flat Twin Cables	13
	3.4.2 Two-Conductor Round Cables	14
3.5	Types W, G, G-GC and G-CGC. Three-And Four-Conductor Cables, 2,000 Volts or Less	14
	3.5.1 Three- and Four-Conductor, Round Type W Cables without Grounding Conductors .	14
	3.5.2 Three- and Four-Conductor Round Type G Cables with Grounding Conductors.....	14
	3.5.3 Three-Conductor Flat Type G Cable with Grounding Conductors.....	14
	3.5.4 Three-Conductor Flat G-GC Cable with Grounding Conductor and Ground-Check Conductor.....	15
	3.5.5 Three-Conductor Round Types G-GC and G-CGC Cable	15
	3.5.6 Four-Conductor Flat Type W Cable Without Grounding Conductors	15
3.6	Types W and G, Five- And Six-Conductor, 2,000 Volts Or Less.....	15
	3.6.1 Five- And Six-Conductor Round Type W Cables without Grounding Conductor	15
	3.6.2 Five-Conductor Round Type G Cables with Grounding Conductor.....	16
3.7	Type PG, Two- and Three-Conductors With Grounding Conductor, 2,000 Volts or Less	16
3.8	Type PCG, Two- and Three-Conductors with Grounding Conductor and Two Control Conductors, 2,000 Volts or Less	16
3.9	Type G, Three-Conductor Round With Grounding Conductors 2,001-5,000 Volts.....	16
3.10	Shielded Cable 25,000 Volts or Less.....	16
	3.10.1 Shielded Cables 2,000 Volts or Less	16
	3.10.2 Shielded Cables 2,001 to 5,000 Volts.....	19

3.10.3	Shielded Cables 5,001 to 25,000 Volts.....	20
3.11	Power Conductors	21
3.12	Control and Ground-Check Conductors.....	21
3.12.1	Control Conductors for Types PCG and SHD-PCG Cables	21
3.12.2	Ground-Check Conductors	21
3.12.3	Ground-Check Conductor for Type SHD-PC.....	21
3.12.4	Ground-Check Conductor for Flat G-GC	21
3.13	Grounding Conductors	21
3.13.1	Size and Number	22
3.13.2	Flat Twin Type G	22
3.13.3	Flat Three-Conductor Type G.....	22
3.13.4	Round Types G, G-GC and G-CGC	22
3.13.5	Flat Three-Conductor Type G-GC	22
3.13.6	Round Five-Conductor Type G, Types PG, and PCG	22
3.14	Conductor Shield (Stress Control Layer)	23
3.14.1	Extruded (Conductor Shield)	23
3.15	Power Conductor Insulation	23
3.15.1	Insulation Physical and Electrical Requirements	23
3.15.2	Insulation Thickness	24
3.16	Ground Check And Control Conductor Insulation.....	24
3.17	Tapes And Braids	24
3.17.1	Power Conductors	24
3.17.2	Ground Check and Control Conductors	25
3.18	Conductor Identification*	28
3.18.1	Power Conductors	28
3.18.2	Control and Ground-check Conductors	28
3.19	Metallic Shielding	28
3.19.1	Metallic Braid Shields	29
3.19.2	Metal Wire Shields.....	29
3.20	Conductor Assembly	29
3.21	Jackets.....	30
3.21.1	Duty Rating	30
3.21.2	General	30
3.21.3	Thickness of Jacket	30
3.22	Completed Cable.....	30
3.22.1	Outside Diameters	30
3.22.2	Diameter Tolerances	30
3.22.3	Marking	31
3.22.4	Tests	31
Section 4	Constructions of Mine Power Feeder Cable.....	58
4.1	Scope	58
4.2	General Requirements.....	58
4.3	Conductors	58
4.3.1	Power Conductors	58
4.3.2	Conductor Stress Control Layer	58
4.3.3	Grounding Conductors	58
4.3.4	Ground-check Conductor	58
4.4	Insulation	59
4.4.1	Power Conductor	59
4.4.2	Ground-check Conductor	59
4.5	Insulation Shielding.....	59
4.5.1	Extruded Semi-Conducting Layer.....	59
4.5.2	Metal Component	59
4.6	Identification*.....	61
4.7	Conductor Assembly	61

4.8	Jacket	61
4.9	Outside Diameter	61
4.10	Tests	61
Section 5	Special Constructions	68
5.1	Portable Arc-Welding Cables.....	68
5.1.1	Scope.....	68
5.1.2	Conductor	68
5.1.3	Separator	68
5.1.4	Jackets	68
5.1.5	Number of Wires, Outside Diameters, and Diameter Tolerances	68
5.1.6	Flame Test Requirements	68
5.2	Non-Metallic Shielded Mining Cables.....	70
5.2.1	Scope.....	70
5.2.2	Power Conductors	73
5.2.3	Ground-Check Conductors.....	73
5.2.4	Grounding Conductors	73
5.2.5	Conductor Shield (Stress Control Layer)	73
5.2.6	Power Conductor Insulation.....	73
5.2.7	Extruded Semi-Conducting Layer Over Insulation (Insulation Shield)	73
5.2.8	Ground-Check Insulation	73
5.2.9	Conductor Identification	73
5.2.10	Conductor Assembly.....	74
5.2.11	Jackets	74
5.2.12	Completed Cable	74
5.2.13	Tests	75
5.3	Remote Control and Drill Cords	75
5.3.1	Scope.....	75
5.3.2	Conductors	75
5.3.3	Separator	75
5.3.4	Insulation	75
5.3.5	Conductor Assembly.....	76
5.3.6	Jackets	76
5.3.7	Tests.....	76
Section 6	Testing and Test Methods	81
6.1	Testing	81
6.2	Tests on Samples	81
6.3	Conductor Test Methods	81
6.3.1	Method for DC Resistance Determination	81
6.3.2	Methods for Cross-sectional Area Determination.....	82
6.3.3	Methods for Diameter Determination.....	82
6.4	Test Samples and Specimens for Physical And Aging Tests	82
6.4.1	General	82
6.4.2	Number of Thickness Measurements	82
6.4.3	Measurement of Thickness	82
6.4.4	Sampling of Insulation for Physical and Aging Tests.....	82
6.4.5	Sampling of Jacket for Physical and Aging Tests.....	83
6.4.6	Number of Test Specimens	83
6.4.7	Size of Specimens	84
6.4.8	Preparation of Specimens of Insulation and Jacket	84
6.4.9	Specimens with Thin Jackets Crosslinked to Insulation	84
6.4.10	Specimen for the Tear Test	84

6.4.11	Specimen for Accelerated Aging Test	85
6.4.12	Calculation of Area of Test Specimens	85
6.4.13	Physical Test Procedures	85
6.4.14	Aging Test.....	85
6.4.15	Physical Tests for Semi-Conducting Material Intended for Extrusion.....	86
6.4.16	Retests for Physical and Aging Properties and Thickness	86
6.5	Capacity and Power Factor Tests	87
6.6	Accelerated Water Absorption	87
6.6.1	General	87
6.6.2	Electrical Method (EM-60)	87
6.7	Surface Resistance.....	87
6.8	Thickness Of Tapes	87
6.9	Heat (Deformation) Distortion.....	87
6.10	Heat Shock	88
6.11	Cold Bend	88
6.12	Hot Creep Test	88
6.13	Solvent Extraction.....	88
6.14	Volume Resistivity.....	88
6.14.1	Test Samples.....	88
6.15	Stripping Test	88
6.16	Retests For Tests Covered by 6.6 Through 6.15 And 6.17	89
6.17	Electrical Tests On Completed Cables	89
6.17.1	Voltage Tests	89
6.17.2	Insulation Resistance	90
6.17.3	Partial-Discharge Test Procedure.....	90
6.18	Method Determining Permittivity (S.I.C.) And Dielectric Strength Of EXTRUDED Nonconducting Polymeric Stress Control Layers	90
6.19	Method for Measurement of Braid Shield Resistance on Flat Type SHD.....	90
Annex A (Informative) Symbols and Abbreviations		91
Annex B (Normative) Definitions for Maximum Temperature Of Conductors in Insulated Wire and Cable		92
B.1	Maximum Conductor Temperature—Operating	92
B.2	Maximum Conductor Temperature—Emergency Overload	92
B.3	Maximum Conductor Temperature—Short Circuit.....	92
Annex C (Normative) Emergency Overload Ratings for Insulated Cables		93
Annex D (Normative) ICEA Publications, ASTM, NEMA Standards and NFPA.....		94
D.1	ICEA Publications—See Note 1.....	94
D.2	ASTM Standards—See Note 2	94
D.3	NEMA Standards—See Note 3	96
D.4	NFPA—See Note 4	97
Annex E (Informative) Shielding.....		98
E.2	Functions of Shielding	98
E.2.1	Application	98
E.2.2	Functions.....	98
E.3	Use of Insulation Shielding	98
E.3.1	No Metallic Shield.....	98
E.3.2	Metallic Shield	98
E.3.3	Semi-conductive Rubber Shield.....	99
E.3.4	Shield Resistance	99
E.4	Grounding of The Insulation Shield	99

E.5	Shield Materials	99
E.5.1	Nonmetallic Shields.....	99
E.5.2	Metallic Shields	99
E.6	Splices and Terminations.....	99
Annex F (Informative) Minimum Bending Radius for Cables		100
F.1	Scope	100
F.2	Portable Cables	100
F.3	Mine Power Feeder Cables	100
Annex G (Informative) Minimum Drum Diameters of Shipping Reels		101
Annex H (Informative) Ampacities and Voltage Ratings of Portable Cables		102
H.1	Ampacities (Current-Carrying Capacity in Amperes).....	102
Annex I (Informative) Ampacities for Three-Conductor Mine Power Cables		104
Annex J (Informative) Voltage Test after Installation.....		105
ANNEX K (Informative) Additional Conductor Information		106
Annex L (Informative) Remote Control and Drill Cords		113
L.1	Ampacities	113
L.2	Maximum Voltage Ratings	113
L.3	Remote Control And Drill Cords	113
Annex M (Informative) Optional Factory DC Test		114
Tables		
2-1	Weight Increment Factors, K	6
2-2	Schedule for Establishing Maximum DC Resistance	7
2-3	Nominal DC Resistance in Ohms per 1,000 Feet at 25°C of Concentric Lay Stranded Conductors	8
2-4	Nominal DC Resistance in Ohms per 1,000 Feet at 25°C for Flexible Annealed Copper Conductors	9
2-5	Nominal Diameters for Copper and Aluminum Conductors	11
2-6	Factors for Determining Nominal Resistance of Stranded Conductors per 1,000 Feet at 25°C	12
3-1	Power Conductor Insulation Requirements	26
3-2	Ground-Check and Control Conductor Insulation Requirements	27
3-3	Extra-Heavy-Duty Crosslinked Jackets and Thermoplastic Polyurethane	33
3-4	Heavy-Duty Crosslinked Jackets	34
3-5	Maximum Length of Lay	34
3-6	2,000 Volts or Less Single-Conductor Portable Power Cable	35
3-7	2,000 Volts or Less Type W and G Two-Conductor Flat Twin Portable Power Cables.....	36
3-8	2,000 Volts or Less Type W and G Two-Conductor Round Portable Power Cables.....	36
3-9	2,000 Volts or Less Type W and G Three-Conductor Round Portable Power Cables	37
3-10	2,000 Volts or Less Type W and G Four-Conductor Round Portable Power Cables	37

3-11	2,000 Volts or Less Type G Three-Conductor Flat Portable Power Cables with Two Grounding Conductors.....	38
3-12	2,000 Volts or Less Type G-GC Three-Conductor Round Portable Power Cables with Two Grounding Conductors and One Ground-Check Conductor.....	38
3-13	2,000 Volts or Less Type G-CGC Three Conductor Round Portable Power Cables with Three Grounding Conductors and One Ground-Check Conductor	39
3-14	2,000 Volts or Less Type G-GC Three-Conductor Flat Portable Power Cables with One Grounding Conductor and One Ground-Check Conductor	39
3-15	2,000 Volts or Less Type W Four-Conductor Flat Portable Power Cables	40
3-16	2,000 Volts or Less Type W And G, Five- and Six-Conductor Round Portable Power Cables	40
3-17	2,000 Volts or Less Type PG Two- and Three-Conductor Round Portable Power Cables	40
3-18	2,000 Volts or Less Type PCG Two- and Three-Conductor Round Portable Power Cables ..	41
3-19	2,001 To 5,000 Volts Type G Three-Conductor Round Portable Power Cables	41
3-20	Type SH Single-Conductor Portable Power Cables for 100 Percent Insulation Level Only	42
3-21	2,000 Volts or Less Type SHC-GC Three-Conductor Round Portable Power Cables for 100 Percent Insulation Level Only.....	43
3-22	Type SHD and SHD-GC Three-Conductor Round Portable Power Cables for 100 Percent Insulation Level Only.....	44
3-23	Type SHD-CGC Three-Conductor Portable Power Cables with Three Grounding Conductors and One Ground-Check Conductor	47
3-24	Jacket Thicknesses for Types and Sizes of Round Portable Cables not Covered by Tables 3-6 through 3-23 and 3-26	48
3-25	Conductors	49
3-26	Type SHD-PCG Cable.....	51
3-27	2,000 Volts or Less Type SHD-Flat Three Conductor Portable Power Cable with Two Grounding Conductors.....	52
3-28	Type SHD-PC Shield Requirements.....	51
3-29	2,000 Volts or Less Type SHD-Flat Three Conductor Portable Power Cable with Two Grounding Conductors.....	51

Tables

4-1	Conductor Sizes	63
4-2	Insulation Thicknesses and Outside Diameters—2,001 to 5,000 Volts 100 and 133 Percent Insulation Levels	63
4-3	Insulation Thicknesses and Outside Diameters 5,001 to 8,000 Volts	64
4-4	Insulation Thicknesses and Outside Diameters 8,001 to 15,000 Volts	64
4-5	Insulation Thicknesses and Outside Diameters 15,001 to 25,000 Volts	65
4-6	Partial Discharge Extinction Voltage.....	65
4-7	Overall Jacket Thickness.....	65
4-8	Nominal DC Resistance of Medium Hard-Drawn Coated and Uncoated Copper Conductors Concentric Stranded, Class B and C	66
4-9	Thermoplastic Jacket Requirements	67
5-1	Heavy-Duty Jackets (Type A)	77
5-2	Medium-Duty Jackets (Type B)	78
5-3	Construction Details.....	79

5-4	Maximum Length of Lay.....	79
5-5	Extruded Semi-conductive Rubber Requirements.....	80
5-6	Type SCF-GC Two Conductor Flat Portable Power Cable with One Ground and One Ground-Check.....	81
5-7	Wall Thickness and Voltage Rating of Remote Control and Drill Cords.....	81
5-8	Remote Control and Drill Cords Outside Diameters.....	82
6-1	Number of Samples	83
6-2	Number of Test Specimens	86
6-3	Mandrel Size for Cold Bend Test.....	88
H-1	Ampacities for Portable Power Cables, Amperes per Power Conductor.....	102
I-1	Ampacities for Three-Conductor Mine Power Cables	103
J-1	DC Test Voltages after Installation, kV	104
K-1	Concentric Stranded Class B Aluminum and Copper Conductors	105
K-2	Concentric Stranded Class C and D Aluminum and Copper Conductors	106
K-3	Rope-Lay Copper Conductors Class G	107
K-4	Rope-Lay Copper Conductors Class H	108
K-5	Copper Conductors Class I – Each Individual Strand 24 AWG, 0.0201 in. (0.511 mm)	109
K-6	Copper Conductors Class K – Each Individual Strand 30 AWG, 0.0100 in. (0.254 mm)	110
K-7	Copper Conductors Class M – Each Individual Strand 34 AWG, 0.0063 in. (0.160 mm)	111
L-1	Ampacities of Remote Control and Drill Cords.....	112
L-2	Correction Factors for Remote Control and Drill Cord Ampacities	113
M-1	Optional Factory DC Test.....	114

ANSI/NEMA WC 58-2017
ICEA S-75-381-2017
Page xi

Foreword

This standards publication for mining cable was developed by the Insulated Cable Engineers Association, Incorporated (ICEA) and was approved by the National Electrical Manufacturers Association (NEMA).

ICEA/NEMA standards are adopted in the public interest and are designed to eliminate misunderstandings between the manufacturers and the user and to assist the user in selecting and obtaining the proper product for his or her particular need. The existence of an ICEA/NEMA standard does not in any respect preclude the manufacture or use of products not conforming to the standard. The user of this standards publication is cautioned to observe any health or safety regulations and rules relative to the use of cable made in conformity with this standard.

Requests for interpretation of this standard must be submitted in writing to:

Insulated Cable Engineers Association, Inc.
P.O. Box 2694
Alpharetta, GA 30023

An official interpretation will be made by the ICEA.

Suggestions for improvement gained in the use of this publication will be welcomed by ICEA.

Working Group Chair: Mark A. Fuller, Nexans Americable

< This page left blank intentionally. >

This is a preview of "ANSI/NEMA WC 58/ICEA...". [Click here to purchase the full version from the ANSI store.](#)

Section 1 General

1.1 Scope

These standards apply to materials, construction, and testing of insulated cables used for the utilization of electrical energy in surface and underground mines and similar applications. Included are portable cables for use in mining machines, dredges, shovels and similar equipment, and mine power cables for use as connections between units of mine distribution systems, and remote control and drill cords for mining and similar applications. The cables are of the following types:

Portable Cables 2,000 Volts or Less

Type	W without grounding conductors
Type	G with grounding conductors
Type	G-GC with grounding conductors and one ground-check conductor
Type	G-CGC with grounding conductors and one ground-check conductor in center
Type	SC-W without grounding conductors
Type	SC-G with grounding conductors
Type	SC-GC with grounding conductors and one ground-check conductor
Type	SC-CGC with grounding conductors and one ground-check conductor in center
Type	PG with single grounding conductor
Type	PCG with single grounding conductor and two control conductors
Type	SHC-GC multiconductor with two grounding conductors, one ground-check conductor and overall shield
Type	SHD multiconductor with individually shielded power conductors, and three grounding conductors
Type	SHD-GC multiconductor with individually shielded power conductors, two grounding conductors, one ground-check conductor
Type	SHD-CGC with individually shielded power conductors, three grounding conductors, and one ground-check conductor in center
Type	SHD-PCG multiconductor with individually shielded power conductors, center grounding conductor, and one or more control conductors
Type	SHD Flat multiconductor with individually shielded power conductors, and grounding conductors covered with a conducting extrusion layer
Type	SHD-PC multiconductor with individually shielded power conductors, and one shielded ground-check conductor
Type	SCE multiconductor with individually shielded power conductors, and two grounding conductors.
Type	SCE-GC multiconductor with individually shielded power conductors, two grounding conductors, and one ground-check conductor
Type	SCE-CGC multiconductor with individually shielded power conductors, three grounding conductors, and one ground-check conductor in the center
Type	SCF-GC with one grounding conductor and one ground-check conductor
Type	Flexible remote control and drill cords