

NEMA Standards Publication No. WC 26-2008
EEMAC Standards Publication 201-2008

Binational Wire and Cable Packaging Standard

Published by

National Electrical Manufacturers Association

1300 North 17th Street, Suite 1752

Rosslyn, Virginia 22209

www.nema.org

© Copyright 2008 by the National Electrical Manufacturers Association. All rights including translation into other languages, reserved under the Universal Copyright Convention, the Berne Convention or the Protection of Literary and Artistic Works, and the International and Pan American Copyright Conventions.

NOTICE AND DISCLAIMER

The information in this publication was considered technically sound by the consensus of persons engaged in the development and approval of the document at the time it was developed. Consensus does not necessarily mean that there is unanimous agreement among every person participating in the development of this document.

The National Electrical Manufacturers Association (NEMA) standards and guideline publications, of which the document contained herein is one, are developed through a voluntary consensus standards development process. This process brings together volunteers and/or seeks out the views of persons who have an interest in the topic covered by this publication. While NEMA administers the process and establishes rules to promote fairness in the development of consensus, it does not write the document and it does not independently test, evaluate, or verify the accuracy or completeness of any information or the soundness of any judgments contained in its standards and guideline publications.

NEMA disclaims liability for any personal injury, property, or other damages of any nature whatsoever, whether special, indirect, consequential, or compensatory, directly or indirectly resulting from the publication, use of, application, or reliance on this document. NEMA disclaims and makes no guaranty or warranty, expressed or implied, as to the accuracy or completeness of any information published herein, and disclaims and makes no warranty that the information in this document will fulfill any of your particular purposes or needs. NEMA does not undertake to guarantee the performance of any individual manufacturer or seller's products or services by virtue of this standard or guide.

In publishing and making this document available, NEMA is not undertaking to render professional or other services for or on behalf of any person or entity, nor is NEMA undertaking to perform any duty owed by any person or entity to someone else. Anyone using this document should rely on his or her own independent judgment or, as appropriate, seek the advice of a competent professional in determining the exercise of reasonable care in any given circumstances. Information and other standards on the topic covered by this publication may be available from other sources, which the user may wish to consult for additional views or information not covered by this publication.

NEMA has no power, nor does it undertake to police or enforce compliance with the contents of this document. NEMA does not certify, test, or inspect products, designs, or installations for safety or health purposes. Any certification or other statement of compliance with any health or safety-related information in this document shall not be attributable to NEMA and is solely the responsibility of the certifier or maker of the statement.

CONTENTS

	Page
Foreword	iii
Section 1 GENERAL	1
1.1 Scope.....	1
1.2 Definitions.....	1
Section 2 CONSTRUCTION OF PACKAGE TYPES	2
2.1 Returnable Reels.....	2
2.1.1 Gas-Tight Returnable Steel Shipping Reels	2
2.1.2 Steel Fluted Reels.....	2
2.1.3 Engineered Plastic Reels.....	2
2.1.4 Extra Heavy Duty Wood Reels.....	2
2.2 Reusable Wood Reels.....	2
2.2.1 Wood Reels.....	3
2.3 Nonreturnable Reels.....	3
2.3.1 Steel Reels.....	3
2.3.2 Wood Reels.....	3
2.3.3 Engineered Plastic Reels.....	3
2.3.4 Plywood Reels and Spools	3
Section 3 MINIMUM DRUM DIAMETERS	13
Section 4 REEL COVERINGS	15
4.1 Reel Coverings.....	15
Section 5 MARKING AND IDENTIFICATION	18
Section 6 HANDLING AND STORING OF CABLE REELS	19
6.1 Handling Recommendations	19
Section 7 CAPACITIES OF PACKAGE TYPES	20
7.1 Calculation of Reel Capacity for Round Cables	20
7.1.1 Reel Capacity in Feet.....	20
7.1.2 Reel Capacities in Meters	20
7.1.3 Reel Capacity Parameters	20
7.2 Non-round Cables	20
Figures	
2-1 Flat Bar Tire Fluted Steel Reel—Type RM.....	4
2-2 I-Beam Tire Fluted Steel Reel—Type RMT.....	5
Tables	
2-1 Gas Tight Returnable Steel Shipping Reels for Pipe-Type Cable	6
2-2 General Purpose Steel Fluted Returnable Reels for Wire and Cables—Class 1	7
2-3 Heavy Duty Steel Fluted Returnable Reels for Wire and Cables—Class 2.....	8
2-4 General Purpose Reusable Wood Reels—Class 1	9
2-5 Heavy Duty Reuseable Wood Reels—Class 2	10
2-6 Extra Heavy Duty Returnable Wood Reels—Class 3	11
2-7 Plywood Reels and Spools.....	12
3-1 Minimum Drum Diameters of Reels for Cables	14

WC 26-2008
EEMAC 201-2008
Page ii

4-1	Recommended Product Level Protection.....	16
4-2	Recommended Packaging Materials	17

Foreword

The purpose of this Standards Publication is to provide practical information concerning the packaging of wire and cable for the North American wire and cable industry. There are, however, scores of different sizes and types of wire and cable products; and the determination of the most desirable standard packages for each, from both the manufacturer's and users' points of view, requires careful consideration of the many variables.

The issuance or existence of these standards does not in any respect prevent or restrict any member or nonmember of NEMA or EFC from supplying customers with reels or packages not in conformance with these standards.

User input has been considered throughout the development of this Standards Publication.

This Standards Publication was developed by the Technical Harmonization Committee (THC) on Wire and Cable Packaging which consists of representatives from the Electrical Equipment Manufacturers Advisory Council (EEMAC), an affiliate of Electro-Federation Canada, and the National Electrical Manufacturers Association (NEMA). This standards publication will be reviewed periodically by THC and revised as necessary to keep it current with advancing technology. Comments or proposed revisions are welcomed and should be submitted to:

Vice President, Engineering
National Electrical Manufacturers Association
17th Street, Suite 1752
Rosslyn, Virginia 22209
United States

Vice President, EEMAC
Electro-Federation Canada Inc.
5800 Explorer Drive
Suite 200
Mississauga, Ontario L4W 5K9

This Standards Publication was developed by the Building Wire and Cable Section and the Power and Control Cable Section of NEMA. Section approval of the standard does not necessarily imply that all section members voted for its approval or participated in its development. At the time it was approved, the sections were composed of the following members:

AFC Cable Systems—New Bedford, MA
Alcan Cable—Atlanta, GA
Americable—El Dorado, AR
American Insulated Wire Corporation—Pawtucket, RI
AXA Cables—San Nicolas De Los Garza NL
Cable USA—Dekoron Division, Houston, TX
Colonial Wire & Cable Co., Inc.—Hauppauge, NY
Encore Wire Corporation—McKinney, TX
Essex Electric Inc., Ft. Wayne, Indiana
Furon Company—Aurora, OH
General Cable—Highland Heights, Kentucky
Hendrix Wire & Cable Co.—Milford, NH

WC 26-2008
EEMAC 201-2008
Page iv

Prysmian Power Cables & Systems USA, LLC
Service Wire Company—Culloden, WV
Southwire Company—Carrollton, GA
The Kerite Company—Seymour, CT
The Okonite Company—Ramsey, NJ
The Rockbestos-Surprenant Corporation -- East Granby, CT
United Copper Industries—Denton, TX

This standard was developed in conjunction with EEMAC, the Electrical Equipment Manufacturers Association of Canada, a Council within Electro-Federation Canada. EEMAC is composed of:

Alcan Cable—Mississauga, ON
Alcatel Canada Wire, Inc.—Markham, ON
Belden CDT (Canada) Inc. —Cobourg, ON General Cable Corporation—West Nyack, NY
BIW Cable Systems, Ltd.—Burlington, ON
Cable Tech., a Division of Noma, Inc.—Stouffville, ON
Domtech Holdings, Inc.—Trenton, ON
General Cable—Toronto, ON
Nexans Canada, Inc—Markham, ON
Noma Consumer Electrical—Scarborough, ON
Prysmian Power Cables & Systems Canada Ltd.—St. Jean-Sur-Richelieu, PQ
Shawflex—Etobicoke, ON

Section 1 GENERAL

1.1 SCOPE

This standard covers uniform requirements for packaging electrical wire and cable and replaces the following NEMA/EEMAC standards:

NEMA WC 26-2000	<i>Wire and Cable Packaging</i>
EEMAC 200-1-1996	<i>Returnable and Nonreturnable Reels</i>
EEMAC 201-2000	<i>Wire and Cable Packaging</i>

No longer active:

PC 1-1973	<i>Gas Tight Returnable Steel Shipping Reels for Pipe-type Cable</i>
WC 6-1980	<i>Minimum Drum Diameters of Reels for Cables</i>
WC 20-1976	<i>Dimensions and Capacities of Returnable Reels for Wires and Cables</i>
WC 21-1978	<i>Nonreturnable Reels for Wires and Cables</i>
WC 22-1979	<i>Construction of Steel Fluted Returnable Reels for Wires and Cables</i>
WC 25-1975	<i>Protective Coverings for Wire and Cable Reels</i>
WC 26-1990	<i>Wire and Cable Packaging (Rev 1-8-93)</i>
EEMAC 200-1-1995	<i>Returnable and Nonreturnable Reels</i>

1.2 DEFINITIONS

maximum overall width: The maximum overall width of the reel such that no portion of the reel exceeds this value.

maximum strength capacity: Maximum capacity defines the total conductor or cable weight that can be carried by a particular size and construction of reel or spool. The maximum capacity values listed in the tables of this document have been determined to be typical values based on experience from users. It should be noted that for all types of wood reels, over and above the thicknesses and number of tie rods used, the maximum capacity can vary depending on factors such as wood species, assembly methods, moisture content, and products that are tightly wound such as ACSR, etc. Therefore, these values should be used as a guide only.