



NFPA

Solutions through motion technology

**NFPA Recommended Standard
NFPA/T2.9.16-1995 (R2002)**

First edition
6 December 1995

AN INDUSTRY STANDARD FOR FLUID POWER

**Information report – Hydraulic fluid power —
Determination of particulate contaminant level
using automatic optical particle counters**

Descriptors: automatic optical particle counters; particulate contaminant; hydraulic fluid power

PUBLISHED BY

NATIONAL FLUID POWER ASSOCIATION, INC.

3333 N. MAYFAIR ROAD / MILWAUKEE, WI 53222-3219 USA
PHONE: +1 414 778 3344 / FAX: +1 414 778 3361 / E-MAIL: NFPA@NFPA.COM

Copyright 1995 by the

NATIONAL FLUID POWER ASSOCIATION, INC.

Printed in the USA

All technical reports, citations, references and related data including standards and practices approved and/or recommended are advisory only. Use thereof by anyone for any purpose is entirely voluntary and in any event without risk of any nature to the National Fluid Power Association, Inc., its officers, directors or authors of such work. There is no agreement by or between anyone to adhere to any NFPA Recommended Standard, policy or practice, and related matters. In formulating and approving technical reports, the Technical Board, its councils and committees and/or the National Fluid Power Association, Inc. will not investigate or consider citations, references or patents which may or may not apply to such subject matter since prospective users of such reports and data alone are responsible for establishing necessary safeguards in connection with utilization of such matters, including technical data, proprietary rights or patentable materials.

Recommended standards and/or policies and procedures are subject to periodic review and may be changed without notice. Recommended standards, after publication, may be revised or withdrawn at any time and current information on all approved recommended standards may be received by calling or writing the National Fluid Power Association, Inc.

An approved NFPA Recommended Standard implies a consensus of those substantially concerned with its scope and provisions and is intended as a guide to aid the manufacturer, the consumer and the general public. The publication of the NFPA Recommended Standard does not in any respect preclude anyone, whether they have participated in the development of or approved the recommended standard or not, from manufacturing, marketing, purchasing, or using of products, processes or procedures not conforming to the recommended standard. An approved NFPA Recommended Standard does not constitute or indicate a warranty of any sort, express or implied, including but not limited to a warranty or representation as to quality, merchantability or fitness for a particular use or purpose.

Participation by federal agency representative(s) or person(s) affiliated with the industry is not to be interpreted as government or industry endorsement of this standard and/or policy and procedure.

NOTICE

An approved NFPA recommended standard does not express or imply any judgment, certification or endorsement of or with respect to, the safety, design or performance of any product, component, or its use.

NFPA does not examine, investigate, test, recommend, or certify the design, use or safety of any product or component, even those which may incorporate one or more NFPA recommended standards. Approved NFPA recommended standards therefore have no application to and do not express or imply any recommendation, representation or warranty, with respect to the safety, design, use, performance, or functional interchangeability of components or products which incorporate NFPA recommended standards

This publication may not be reproduced in whole or in part without the written permission of the National Fluid Power Association, Inc.

Foreword

This Foreword is not part of NFPA Information Report *Hydraulic fluid power — Determination of particulate contaminant level using automatic optical particle counters*, NFPA/T2.9.16-1995 (R2002).

This project was started at the T2.9 Contamination meeting on 22 August 1990. A Particle Counter Calibration Seminar was held at the Milwaukee School of Engineering on the 25th and 26th of September 1990. The seminars purpose was to review the particle counter calibration procedure as described in ANSI/(NFPA)T2.9.6 R1, and to demonstrate or develop the proper handling procedures for processing a field oil sample as in ANSI/(NFPA)T2.9.11.

The committee reviewed the first draft of the document, dated 13 November 1991, and CETOP RP94H. A letter, indicating that a round robin test for T2.9.16 was in order, was circulated 27 April 1992. The Project Group met on 19 August 1992 to review and prepare responses to the comments received on the document. Also, the TSP was revised at this meeting.

The NFPA Technical Board approved the TSP on 17 September 1992. A letter dated 7 October 1992 informed the Project Group that the preliminary information received on the round robin indicated that the sample made up from a field oil was not a homogeneous sample and therefore most of the round robin testing needed to be repeated.

The document was revised and Draft No 2, dated 13 October 1992, was sent out for the Project Group to review on 20 October 1992.

NFPA Technical Staff prepared the General Review Draft on 18 March 1993. The General Review closed with comments from seven companies. Project Co-Chairman Gram wrote letters responding to the commentators and updated the document. All off the commentators had signed off by September 1993.

The Project Group met on 19 August 1993 during the T2.9 meeting and updated the document again. On 17 November 1993 the Project Group again met to discuss and update the document. The Project Group met on 9 February 1994 to review the updated draft and make additional changes to the document. It was agreed upon at this meeting to send the document out for a Second General Review after the changes discussed at the meeting were incorporated into the document.

Project Co-Chairman Gram sent a revised document to Headquarters on 19 March 1994. The document was updated and sent out for a Second General Review on 30 March 1994. Comments were received from six companies. Responses to the commentators were reviewed at the 21 September 1994 Project Group meeting. Letters to the commentators were sent out on 8 November 1994.

The document was updated and approved for Ballot at the 17 August 1995 Technical Board meeting. The document was sent out for Ballot on 21 August 1995. Balloting closed with three approval comments and no negative votes. The approval comments were discussed at the 20 September T2.9 meeting. Letters were written to the commentators and the document updated at Headquarters on 27 October 1995.

The Technical Board granted the document final approval at their 6 December 1995 meeting.

Project group members who developed this standard:

Marvin Gram

Project Co-Chairman and
Committee Vice Chairman
Donaldson Co.

Tom Wanke

Project Co-Chairman
Milwaukee School of Engineering

Barry Verdegan

Committee Chairman
Nelson Division

James Miller

Technical Auditor
Deere & Co.

Linda E. Gasso

Technical Coordinator
National Fluid Power Association

Shirley C. Seal

Manager of Standards Development
Industry/National
National Fluid Power Association

Dave Carson

Pall Corp.

Craig Gustafson

Met One

Holly Hill

Kaydon Corp.

Al Lieberman

Particle Measuring Systems

Charles Montague

HIAC/Royco

Larry Moore

Donaldson Co.

Anthony Simone

Purolator Products

Abbas Vijlee

Schroeder Industries

/leg

This is a preview of "NFPA/T2.9.16-1995 (R...)". [Click here to purchase the full version from the ANSI store.](#)

Introduction

The establishment of national and international standards for the purpose of calibrating automatic optical particle counters (ANSI/(NFPA)T2.9.6 R1 and ISO 4402) and a standard indicating the process to evaluate a field oil sample (ANSI/(NFPA)T2.9.11) several years ago gave hope that the analysis of a common sample by any two technologists at any two locations would be able to provide particle counts within 30 % of each other (20 % calibration differential and 10 % location).

Unfortunately, it did not take long to find out that this was not happening. The reasons are many, the primary ones being equipment differences, calibration dust variation, and failure of technologists to follow procedure.

The primary factor that standards development can help to control is the calibration material. For this reason, an intensive effort was made to establish a new calibration procedure which could be traceable, and ANSI/(NFPA)T2.9.6 R1 was initiated. This standard utilized mono-sized latex spheres in oil as the calibration suspension. Subsequent to the adoption of ANSI/(NFPA)T2.9.6 R1, it was found that particle counters utilizing different technologies produced a wide range of results, and it was determined that the standard should be revised again to use a controlled test dust as the calibration material. ANSI/(NFPA)T2.9.6 R2 was therefore initiated to specify a NIST (National Institute for Standards Testing) material. This work is presently in process.

It is the intent of the NFPA T2.9 Contamination Technology Committee, that the former ACFTD calibration procedure (ISO 4402) be dropped after NFPA/T2.9.6 R2 has been finalized and a reasonable implementation period for NFPA/T2.9.6 R2 has passed. The implementation of NFPA/T2.9.6 R2 has three major impacts on data accumulated using the former calibration procedure, NFPA/T2.9.6 R1 or ISO 4402.

- A. The particle size that formerly was defined as a 10 μm particle (measured by longest chord) is now defined by NIST traceable materials.
- B. The stated number of particles per mL in 1 mg/L of ACFTD changes.
- C. The third most important factor the document will impact is the equipment used to conduct the analysis. NFPA/T2.9.6 R2 establishes particle counter performance specifications.

This information report expands on ANSI/(NFPA)T2.9.11 by providing additional information intended to help the particle technologist from falling into traps that others have fallen into.

Information report — Hydraulic fluid power — Determination of particulate contaminant level using automatic optical particle counters

1 Scope

To include guidelines for proper sample handling, preparation, and counting of petroleum based fluids with liquid-borne automatic optical particle counters calibrated with either ACFTD (Air Cleaner Fine Test Dust) or NIST traceable standards.

To provide information summarizing experience and guidelines concerning sample handling and counting of hydraulic fluid bottle samples using a liquid automatic optical particle counter calibrated with either ACFTD or NIST traceable standards.

2 Normative references

The following documents contain provisions which, through reference in this text, constitute provisions of this NFPA document. At the time of publication, the editions indicated were valid. All documents are subject to revision, and parties to agreements based on this NFPA document are encouraged to investigate the possibility of applying the most recent editions of the documents indicated below. NFPA maintains registers of currently valid documents.

ANSI/(NFPA)T2.9.6 R1-1990, *Hydraulic Fluid Power — Liquid automatic particle counters — Method for calibration.*

ANSI/(NFPA)T2.9.11-1989, *Hydraulic Fluid Power — Method for determining the particle count of an oil sample from a system (using liquid automatic counters).*

ANSI/(NFPA)T2.9.14-1993, *Hydraulic Fluid Power — Fluid Contamination — Determination of Solid Contaminant level by the gravimetric method.*

ANSI/B93.2-1986, *Fluid power systems and products — Glossary.*

ANSI/B93.20M-1972 (R1980), *Hydraulic fluid power — Fluid sample containers — Qualifying and controlling cleaning methods.*

ANSI/B93.30M-1980, *Hydraulic Fluid Power — Contamination analysis data — Reporting Method.*

ANSI/ASQC Z1.4-1981, *Sampling Procedures and Tables for Inspection by Attributes.*

ISO 1000:1992, *SI units and recommendations for the use of their multiples and of certain other units.*

ISO 4402:1991, *Hydraulic Fluid Power — Calibration of liquid automatic particle count instruments — Method using Air Cleaner Fine Test Dust Contaminant.*

ISO 4407:1991, *Hydraulic fluid power — Fluid contamination — Determination of particulate contamination by the counting method using a microscope.*

MIL-H-5606-1984, *Hydraulic fluids — Petroleum Base Aircraft Missile and Ordinance.*