

NFSI B101.1-2020

National Floor Safety Institute

B101.1 Test Method for Measuring the Wet SCOF of Hard-Surface Walkways



The National Floor Safety Institute
P.O. Box 92607
Southlake, TX 76092
(817) 749-1700
standards@nfsi.org

Suggestions for improvement of this standard should be sent to the Standards Developer:
National Floor Safety Institute, P.O. Box 92607, Southlake, TX 76092.

This standard was processed and approved for submittal by the NFSI B101 Main Standards Committee on Safety Requirements for Slip, Trip and Fall Prevention. Approval of the standard does not necessarily imply that all committee members voted for its approval. At the time it approved this standard procedure, the B101 Main Standards Committee had the following members:

Chairman

Howard Harris, M.D.

Committee Secretary

Russell J. Kendzior

Organization Represented

Representative

American Slip Meter

Craig Stephenson

AWAC Services Company

Thad Whittier

Bologna-Bosson, Alyssa

Alyssa Bologna-Bosson

Bresnahan Consulting Associates

Thomas F. Bresnahan, CSP, *Chairman Emeritus*

CED Investigative Technologies

Douglas M. Hrobak

Centerline Risk Solutions, LLC

John Leyenberger

Cintas Corporation

Richard Bing

Crossville, Inc.

Noah Chitty

Ecolab

Traci Gioino

Engineering Systems, Inc. (ESI)

Zdenek Hejzlar

Forensic Human Factors, LLC

Kevin A. Rider, PhD, PE, CPE

GT Grandstands, Inc.

Brian Wilson

IEHA/ISSA

Michael Patterson

Impact General, Inc.

Bill King (P)

Dr. Fred Johnson (Alt)

Jessup Manufacturing

Bill Bruhn

Mountville Mills, Inc.

David Watterson

National Floor Safety Institute

Russell J. Kendzior

New Pig

Heidi Shetler

Professional Safety Consultants

Jim E. Lapping, *Assistant Secretary Emeritus*

Safer Walkways Association

Rob McNealy

Safety Priority Consultants, LLC

Franklin A. "Chip" Darius, Jr.

SlipDoctors

Greg Cohen

Stripe-A-Zone

David Sargent

Texas Orthopedic Specialists, P.L.L.C.

Howard Walker Harris, MD

Traction Auditing, LLC

Brent Johnson

University of Pittsburgh

Kurt Beschorner

At the time of approval, the NFSI B101.1 subcommittee had the following members:

Chairman

Steve Spencer

Organization Represented

National Floor Safety Institute
Spencer Consulting
Traction Auditing

Representative

Russell J. Kendzior
Steve Spencer
Brent Johnson

In Memory of Ms. Amber Morris

Table of Contents

B101 Main Committee Members	2
B101.1 Subcommittee Members	3
Section 1: Scope/Purpose/Application/Exception	5
1.1 Scope	5
1.2 Purpose.....	5
1.3 Application.....	5
1.4 Exceptions	5
Section 2: Reference to other Standards and Publications	5
Section 3: Definitions	6
Section 4: Test Procedure	7
4.1 Testing Device	7
4.2 Measuring the Reference Check Tile.....	7
4.3 Measuring the Wet SCOF of Uninstalled Flooring Materials/Walking Surfaces (Laboratory Procedure).....	7
4.4 Measuring the Wet SCOF of Installed Flooring Material (In-Situ Procedure).....	9
Section 5: Calculations/Data Interpretation	11
Section 6: Test Report	11
Section 7: Safety & Environmental Information	12
7.1 Potential Hazards in Test Area Vicinity	12
7.2 Testing Environment	12
Appendix A	13
Appendix B	17
Appendix C	18
Appendix D	19
Attachment 1 to Appendix D	26
Attachment 2 to Appendix D	27
Attachment 3 to Appendix D	28
Attachment 4 to Appendix D	29

Test Method for Measuring the Wet SCOF of Hard-Surface Walkways

Section 1: Scope/Purpose/Application/Exception

1.1 Scope

This test method specifies the procedures and devices used for both laboratory and field-testing to measure the wet static coefficient of friction (SCOF) of hard-surface walkways.

1.2 Purpose

This test method provides a measurement procedure setting forth SCOF ranges which facilitate remediation of walkway surfaces when warranted.

1.3 Application

This test method does not apply to carpeting of any type, however, does address the common hard-surfaced walkway materials such as ceramic and porcelain tile, polished and un-polished concrete, stone, vinyl, wood and synthetic laminates, and such materials with coatings or polishes applied.

Note: This test method does not purport to address all of the safety concerns, if any, associated with its use. It is the responsibility of the user to establish appropriate safety and health practices and determine the applicability of regulatory limitations prior to use. No express or implied representation or warranty is made regarding the accuracy or significance of any test results in terms of slip resistance.

1.4 Exceptions

This test method is not recommended for dry surface testing and does not propose to be an accurate measurement method for determining dry surface slip resistance. DRY SURFACE TEST DATA SHOULD NOT BE COMPARED TO WET SURFACE TEST DATA. No inferences should be implied or concluded regarding dry vs. wet SCOF test results or data.

Section 2: Reference to other Standards and Publications

The specification for the SBR sensor material called for in this standard is covered by the following DIN Standards: DIN EN 1392, DIN EN ISO 1183-1, 53504, DIN ISO 7619-1, DIN ISO 34-1, DIN ISO 4649. See Appendix B for the related values.

Inter-Laboratory Study (ILS) for Tribometers Designed to Measure the Wet Static Coefficient of Friction (SCOF) of Hard Surface Walkways (See Appendix D).