




*NSF International Standard /
American National Standard*

NSF/ANSI 223 - 2015

Conformity Assessment Requirements for
Certification Bodies that Certify Products
Pursuant to NSF/ANSI 60: Drinking Water
Treatment Chemicals - Health Effects



NSF International, an independent, not-for-profit, non-governmental organization, is dedicated to being the leading global provider of public health and safety-based risk management solutions while serving the interests of all stakeholders.

*This Standard is subject to revision.
Contact NSF to confirm this revision is current.*

Users of this Standard may request clarifications and interpretations, or propose revisions by contacting:

Chair, Joint Committee on Drinking Water Additives
c/o NSF International
789 North Dixboro Road, P.O. Box 130140
Ann Arbor, Michigan 48113-0140 USA
Phone: (734) 769-8010 Telex: 753215 NSF INTL
FAX: (734) 769-0109
E-mail: info@nsf.org
Web: <http://www.nsf.org>

NSF/ANSI 223 – 2015

NSF International Standard/
American National Standard
for Drinking Water Additives –

**Conformity Assessment Requirements for
Certification Bodies that Certify Products
Pursuant to NSF/ANSI 60: Drinking Water
Treatment Chemicals – Health Effects**

Standard Developer

NSF International

Designated as an ANSI Standard

June 7, 2015

American National Standards Institute

Prepared by
The NSF Joint Committee on Drinking Water Additives

Recommended for Adoption by
The NSF Council of Public Health Consultants

Adopted by
NSF International
May 2012

Revised January 2014
Revised June 2015

Published by

NSF International
PO Box 130140, Ann Arbor, Michigan 48113-0140, USA

For ordering copies or for making inquiries with regard to this Standard, please reference the designation "NSF/ANSI 223 – 2015."

Copyright 2017 NSF International
Previous editions © 2013, 2012

Unless otherwise specified, no part of this publication may be reproduced or utilized in any form or by any means, electronic or mechanical, including photocopying and microfilm, without permission in writing from NSF International.

Printed in the United States of America.

Disclaimers¹

NSF, in performing its functions in accordance with its objectives, does not assume or undertake to discharge any responsibility of the manufacturer or any other party. The opinions and findings of NSF represent its professional judgment. NSF shall not be responsible to anyone for the use of or reliance upon this Standard by anyone. NSF shall not incur any obligation or liability for damages, including consequential damages, arising out of or in connection with the use, interpretation of, or reliance upon this Standard.

NSF Standards provide basic criteria to promote sanitation and protection of the public health. Provisions for mechanical and electrical safety have not been included in this Standard because governmental agencies or other national standards-setting organizations provide safety requirements.

Participation in NSF Standards development activities by regulatory agency representatives (federal, local, state) shall not constitute their agency's endorsement of NSF or any of its Standards.

Preference is given to the use of performance criteria measurable by examination or testing in NSF Standards development when such performance criteria may reasonably be used in lieu of design, materials, or construction criteria.

The illustrations, if provided, are intended to assist in understanding their adjacent standard requirements. However, the illustrations may not include **all** requirements for a specific product or unit, nor do they show the only method of fabricating such arrangements. Such partial drawings shall not be used to justify improper or incomplete design and construction.

Unless otherwise referenced, the annexes are not considered an integral part of NSF Standards. The annexes are provided as general guidelines to the manufacturer, regulatory agency, user, or certifying organization.

¹ The information contained in this Disclaimer is not part of this American National Standard (ANS) and has not been processed in accordance with ANSI's requirements for an ANS. Therefore, this Disclaimer may contain material that has not been subjected to public review or a consensus process. In addition, it does not contain requirements necessary for conformance to the Standard.

This is a preview of "NSF/ANSI 223-2015". [Click here to purchase the full version from the ANSI store.](#)

This page is intentionally left blank.

Contents

1	General	1
1.1	Purpose	1
1.2	Scope	1
1.3	Normative references	1
2	Definitions	2
3	General requirements	3
4	Product testing (during initial certification and on-going surveillance)	3
5	Facility audits	3
5.1	Facility audit requirements	3
5.2	Facility audits during surveillance	4
	Annex A Examples of Conformity Assessment Activities	7

This is a preview of "NSF/ANSI 223-2015". [Click here to purchase the full version from the ANSI store.](#)

This page is intentionally left blank.

Foreword²

NSF/ANSI 223 establishes minimum requirements for certification organizations to be used when certifying products to NSF/ANSI 60.

Background

A change was made to the California Code of Regulations (CCR, adopted on March 9, 2008) that required annual recertification of drinking water treatment chemicals to NSF/ANSI 60: *Drinking Water Treatment Chemicals-Health Effects*. This was prompted by concerns that while some certification organizations provided annual retesting of treatment chemicals other organizations allowed for up to five years to pass in between retests.

In 2009 Section 3.8 Conformity Assessment, which contained product testing and facility inspection requirements, was incorporated into NSF/ANSI 60-2009a. However, there were concerns that requirements for the conformity assessment process (facility inspections and periodic retest requirements) in NSF/ANSI 60 would not receive sufficient attention from ANSI during the periodic reviews, as they constitute only a small portion of the issues governed by that standard. It was determined that there would be more focus on conformity assessment if the requirements were placed in a separate standard for conformity assessment. A task group was formed to develop the Standard, and included representatives from industry, certification organizations, water utilities, and public health agencies. In 2010, the task group was expanded further to include the input of many more manufacturers' representatives.

It was noted during the discussion that when NSF/ANSI 60 was originally devised, most production of direct additives occurred in or was overseen by owners from countries where corruption played an insignificant role in business. Today, a substantial portion of the production of direct additives to water has moved to countries where this is no longer the case. Transparency International's Corruption Perceptions Index (CPI) is perhaps the most famous of a number of such indexes constructed to aid international businesses in understanding the conditions they will face in the different countries in which they do business. Such conditions include labor rates, public holidays, endemic diseases, labor laws, business etiquette and corruption. The index has been constructed annually since 1995 for Transparency International by Prof. Johann Graf Lambsdorff of the University of Passau. The process sources 16 independent surveys of countries, and a country must appear in at least three of these sources in order for a score to be calculated. The CPI was revised in 2012 from a scale of 0-10 to 0-100, where the lowest possible level of perceived corruption would equal a score of 100 and the highest possible level of perceived corruption would equal a score of 0. As production moves to a wider variety of source countries and raw material sourcing is further diversified due to cost considerations, there must be a method to differentiate locations where oversight can be relaxed, and where it must be maintained. Therefore NSF/ANSI 223 establishes additional requirements for locations in countries with a CPI score of < 50. This external source of such judgments is the method most commonly used worldwide and is used in this Standard as one of the determinants as to where oversight shall be maintained.

This Standard is intended to provide structured requirements for certifications performed to NSF/ANSI 60. The requirements of NSF/ANSI 223 are supplemental to those contained in ISO Guide 65 or ISO Guide 17020 and do not replace the requirements in either ISO standard. The requirements include (but are not limited to) documentation reviews, product testing, and facility inspections conducted during surveillance. Minimum facility inspection requirements are defined (section 5.1), as are the conditions under which announced inspections are allowed in lieu of unannounced inspections. In addition, an informative Annex has been included to provide examples of conformity assessment activities drawn from the experiences of multiple certification bodies.

² The information contained in this Foreword is not part of this American National Standard (ANS) and has not been processed in accordance with ANSI's requirements for an ANS. Therefore, this Foreword may contain material that has not been subjected to public review or a consensus process. In addition, it does not contain requirements necessary for conformance to the Standard.

This version of NSF/ANSI 223 – 2013 includes the following revisions:

Issue 5

This issue updated the Normative Reference of ISO/IEC Guide 65 with ISO/IEC 17065.

This Standard was developed by the NSF Joint Committee on Drinking Water Additives – Treatment Chemicals using the consensus process described by the American National Standards Institute.

Suggestions for improvement of this Standard are welcome. This Standard is maintained on a Continuous Maintenance schedule and can be opened for comment at any time. Comments should be sent to Chair, Joint Committee on Drinking Water Additives – Treatment Chemicals at standards@nsf.org, or c/o NSF International, Standards Department, P.O. Box 130140, Ann Arbor, MI 48113-0140, USA.

NSF International Standard
for Drinking Water Additives –

Conformity Assessment Requirements for Certification
Bodies that Certify Products Pursuant to NSF/ANSI 60:
Drinking Water Treatment Chemicals – Health Effects

1 General

1.1 Purpose

This Standard establishes minimum requirements for certification bodies to be used when certifying products to NSF/ANSI 60 - Drinking Water Treatment Chemicals – Health Effects. These requirements are supplemental to those contained in ISO/IEC 17065 or ISO/IEC 17020 and do not replace the requirements of either ISO standard. By specifying this Standard, users of product certifications can communicate their expectation that certification activities addressed herein are performed in the particular manner described.

1.2 Scope

This Standard establishes requirements for activities to be performed when certification bodies certify products to NSF/ANSI 60, including documentation reviews, product testing, and facility audits conducted during surveillance.

1.3 Normative references

The following documents contain provisions that, through reference, constitute provisions of this NSF Standard. At the time this Standard was balloted, the editions listed below were valid. All documents are subject to revision, and parties are encouraged to investigate the possibility of applying the recent editions of the documents indicated below. The most recent published edition of the document shall be used for undated references.

ISO/IEC 17020: 1998 *General criteria for the operation of various types of bodies performing inspection*³

ISO/IEC 17065: *Conformity Assessment – Requirements for Bodies Certifying Products, Processes and Services*³

NSF/ANSI 60 - *Drinking Water Treatment Chemicals – Health Effects*

Transparency International *Corruption Perception Index, 2012*⁴

³ International Standardization Organization, 1 ch. De la Voie-Creuse, Case postale 56, CH 1211 Geneva, 20 Switzerland, <www.iso.org>.

⁴ Transparency International, Alt-Moablt 961, 10559 Berlin, Germany, <www.transparency.org>.