



*NSF International Standard /  
American National Standard*

## NSF/ANSI 244 - 2018

Drinking Water Treatment Units -  
Supplemental Microbiological Water  
Treatment Systems - Filtration



*NSF International, an independent, not-for-profit, non-governmental organization, is dedicated to being the leading global provider of public health and safety-based risk management solutions while serving the interests of all stakeholders.*

This Standard is subject to revision.  
Contact NSF to confirm this revision is current.

Users of this Standard may request clarifications and interpretations, or propose revisions by contacting:

Chair, Joint Committee on Drinking Water Treatment Units  
c/o NSF International  
789 North Dixboro Road, P.O. Box 130140  
Ann Arbor, Michigan 48113-0140 USA  
Phone: (734) 769-8010 Telex: 753215 NSF INTL  
Fax: (734) 769-0109  
E-mail: [info@nsf.org](mailto:info@nsf.org)  
Web: [www.nsf.org](http://www.nsf.org)

**NSF/ANSI 244 – 2018**

NSF International Standard /  
American National Standard  
for Drinking Water Treatment Units –  
**Supplemental microbiological water  
treatment systems – Filtration**

Standard Developer  
**NSF International**

**Designated as an ANSI Standard**  
April 23, 2018  
**American National Standards Institute**

Prepared by  
**The NSF Joint Committee on Drinking Water Treatment Units**

Recommended for adoption by  
**The NSF Council of Public Health Consultants**

Adopted by  
**NSF International**  
**May 2018**

Published by  
**NSF International**  
**P.O. Box 130140, Ann Arbor, Michigan 48113-0140, USA**

For ordering copies or for making inquiries with regard to this Standard, please reference the designation "NSF/ANSI 244 – 2018."

Copyright 2018 NSF International

Unless otherwise specified, no part of this publication may be reproduced or utilized in any form or by any means, electronic or mechanical, including photocopying and microfilm, without permission in writing from NSF International.

Printed in the United States of America.

## Disclaimers<sup>1</sup>

NSF, in performing its functions in accordance with its objectives, does not assume or undertake to discharge any responsibility of the manufacturer or any other party. The opinions and findings of NSF represent its professional judgment. NSF shall not be responsible to anyone for the use of or reliance upon this Standard by anyone. NSF shall not incur any obligation or liability for damages, including consequential damages, arising out of or in connection with the use, interpretation of, or reliance upon this Standard.

NSF Standards provide basic criteria to promote sanitation and protection of the public health. Provisions for mechanical and electrical safety have not been included in this Standard because governmental agencies or other national standards-setting organizations provide safety requirements.

Participation in NSF Standards development activities by regulatory agency representatives (federal, local, state) shall not constitute their agency's endorsement of NSF or any of its Standards.

Preference is given to the use of performance criteria measurable by examination or testing in NSF Standards development when such performance criteria may reasonably be used in lieu of design, materials, or construction criteria.

The illustrations, if provided, are intended to assist in understanding their adjacent standard requirements. However, the illustrations may not include all requirements for a specific product or unit, nor do they show the only method of fabricating such arrangements. Such partial drawings shall not be used to justify improper or incomplete design and construction.

Unless otherwise referenced, the Annexes are not considered an integral part of NSF Standards. The Annexes are provided as general guidelines to the manufacturer, regulatory agency, user, or certifying organization.

---

<sup>1</sup> The information contained in this Disclaimer is not part of this American National Standard (ANS) and has not been processed in accordance with ANSI's requirements for an ANS. Therefore, this Disclaimer may contain material that has not been subjected to public review or a consensus process. In addition, it does not contain requirements necessary for conformance to the Standard.

This page is intentionally left blank.

## Contents

1	General .....	1
1.1	Purpose.....	1
1.2	Scope .....	1
1.3	Minimum requirements .....	1
1.4	Alternate materials, designs and construction .....	1
1.5	Mechanical and microbial reduction performance claims.....	1
1.6	Treatment train.....	2
1.7	Standard review .....	2
2	Normative references .....	3
3	Definitions .....	3
4	Materials .....	4
4.1	Materials in contact with drinking water .....	4
4.2	Materials evaluation .....	5
4.3	Gas chromatography / mass spectroscopy (GC/MS) analysis .....	6
4.4	Materials in contact with the user's mouth.....	8
5	Structural performance .....	12
5.1	Structural integrity .....	12
5.2	Acceptance .....	12
5.3	Working pressure.....	13
5.4	Structural integrity test methods .....	14
6	Minimum performance requirements.....	18
6.1	General .....	18
6.2	End-of-life indication of mechanical reduction capacity or maximum expected life .....	18
6.3	End-of-life indicator device verification test .....	19
6.4	Elements .....	21
6.5	Flow control.....	21
6.6	Waste connections for devices with reject or flush streams.....	21
6.7	Product water dispensing outlets.....	22
6.8	Hazards.....	22
6.9	Systems used in bottled water plants .....	22
6.10	Operation temperature.....	22
6.11	POE rated pressure drop.....	22
6.12	Minimum service flow.....	22
6.13	Rated service flow.....	23
6.14	Active agents and additives .....	23
7	Microbiological performance claims – Test methods .....	24
7.1	General requirements .....	24
7.2	Microbiological reduction claims .....	25
7.3	Microbiological reduction test methods .....	25
8	Instruction and information .....	47
8.1	Installation, operation, and maintenance instructions.....	47
8.2	Data plate.....	49
8.3	Replacement components .....	50
8.4	Performance data sheet .....	51

Annex A	Methods for preparing and analyzing bacteria surrogates .....	55
Annex B	Filtration water treatment systems microbial reduction .....	59
Annex C	Test method for evaluating mouth drawn water treatment units .....	67
Annex D	Test method for evaluating squeeze bottle drinking water treatment units .....	71
Annex E	.....	75
Annex F	Evaluation methods for systems with multiple technologies – Treatment train.....	77



## Foreword<sup>2</sup>

The purpose of this Standard is to establish minimum requirements for the reduction of microorganisms using mechanical filtration devices for supplemental treatment of microbiologically safe drinking water. This Standard is in keeping with the other NSF/ANSI DWTU standards that stress the supplemental drinking water treatment concept for reduction of certain aesthetic and health related contaminants from water supplies that have been treated to public water system standards or otherwise are determined to be microbiologically safe as demonstrated by routine testing. The devices covered under this Standard are intended only for protection against intermittent incursions or accidental microbiological contamination of otherwise safe drinking water. This Standard also specifies the minimum product literature and labeling information that a manufacturer shall supply to authorized representatives and system owners as well as the minimum service-related obligations that the manufacturer shall extend to system owners. This Standard and the accompanying text are intended for voluntary use by certifying organizations, laboratories, and/or manufacturers to verify the requirements therein. It is the responsibility of the manufacturer to investigate and comply with applicable state and federal regulations such as registration to the USEPA Federal Insecticide, Fungicide, and Rodenticide Act (FIFRA), and regulatory requirements in all other countries and territories where the products are sold.

It is recognized that the federal, state and local objectives are to provide safe water supplies without further user treatment. However, many users are concerned about the potential presence of contaminants of both aesthetic and health concern in their water supplies and need guidance as to the availability and reliability of tested and certified point-of-entry (POE) and point-of-use (POU) water treatment systems, especially those that claim microbiological reduction. This Standard will help to meet this need but cannot be expected to address claims beyond those covered in this Standard.

Over the last century both public and private water utilities, with regulatory guidance from federal and state agencies, have made significant improvements in water treatment to protect public health. This has been achieved through a multi-barrier approach utilizing successive treatment technologies including source water management, slow sand filtration, chlorination and other advanced treatment technologies. It is a goal of this standard to make available to consumers tested and certified supplemental water treatment devices for an additional 'final barrier'. These devices can further reduce the risks associated with microbial contamination especially when unknown incursions or accidental contamination occurs hours or days prior to issuance of a boil water advisory or warning (reference: "*Rational for Supplemental Microbial Water Treatment Devices*", NSF International, Microbial Water Treatment Task Group, September 14, 2010).

Prior to adoption of this standard, several other NSF/ANSI standards and NSF protocols have addressed microbiological treatment of drinking water for residential and individual consumer use:

- NSF Protocol P231 – Microbiological Water Purifiers: Protocol P231 addresses systems that use chemical, mechanical, and/or physical technologies to filter and treat waters of unknown microbiological quality, but otherwise are presumed to be potable (adopted from the USEPA's Guide Standard and Protocol for Testing Microbiological Water Purifiers<sup>3</sup>).

---

<sup>2</sup> The information contained in this Foreword is not part of this American National Standard (ANS) and has not been processed in accordance with ANSI's requirements for an ANS. Therefore, this Foreword may contain material that has not been subjected to public review or a consensus process. In addition, it does not contain requirements necessary for conformance to the Standard.

<sup>3</sup> *Guide Standard and Protocol for Testing Microbiological Water Purifiers*, Report of Task Force, submitted by Steven A. Schaub to the USEPA, April 1987.

- NSF/ANSI 55 – Ultraviolet Microbiological Water Treatment Systems: This Standard establishes requirements for POU and POE ultraviolet systems for use on non-public water supplies (non-PWS) and includes two optional classifications. Class A systems (40 mJ/cm<sup>2</sup>) are designed to disinfect and/or remove microorganisms from contaminated water, including bacteria and viruses, to a safe level. Class B systems (16 mJ/cm<sup>2</sup>) are designed for supplemental bactericidal treatment of public drinking water or other drinking water, which has been deemed acceptable by a local health agency.
- NSF/ANSI 62: Drinking Water Distillation Systems: This Standard covers distillation systems designed to reduce several specific inorganic contaminants and includes provisions for testing and claiming reduction of microorganisms from public and private water supplies. These systems are intended for use only on disinfected potable water systems. The microbiological reduction test utilizes *Bacillus atropheus* spores as a surrogate organism for bacterial, viral and protozoan organisms.
- NSF/ANSI 53 – Drinking Water Treatment Units – Health Effects, and NSF/ANSI 58 – Reverse Osmosis Drinking Water Units: These standards cover many different contaminant reduction claims but allow only one microbiological claim for protozoan cyst reduction. Either 3 μ latex spheres or live *Cryptosporidium* can be selected as a surrogate for the protozoan cyst reduction test. These devices are for use on microbiologically safe drinking water.

It is of note that the precedent of making microbiological reduction claims for systems used on microbiologically safe water has previously been established in NSF/ANSI 55 with Class B systems (for bacteria only), NSF/ANSI 62 – Drinking Water Distillation Systems (for bacteria, viruses and protozoan cysts) and in NSF/ANSI 53 and 58 (for protozoan cysts only).

The protocols in this Standard require testing with surrogate microorganisms to demonstrate a device's capability for reducing pathogenic bacteria, viruses and protozoan cysts utilizing mechanical filtration as the primary removal mechanism. The surrogate microorganisms utilized and the rationale for selecting them are:

- *Raoultella terrigena* (*Rt*): This non-pathogenic bacterium is previously known as *Klebsiella terrigena* and was selected as the surrogate bacterium for use in the original USEPA Guide Standard and Protocol (ref. 2). *Rt* is a rod-shaped organism ranging in size from 0.3 μ to 1.5 μ by 0.6 μ to 6.0 μ. Its successful use as a surrogate bacterium in NSF P231 is well documented.
- MS2 coliphage virus: This non-pathogenic phage viral particle is hydrophobic, is small in size (0.025 μ to 25 nm), has an isoelectric point<sup>4</sup> (pI) of 3.9, and has been successfully used by NSF and researchers for many years to test sub-micron membrane filters.
- φr coliphage virus: This non-pathogenic phage viral particle is very small (0.019 μ to 19 nm) and has a pI of 8.9. It also has been successfully used by NSF and researchers to test sub-micron membrane filters.

Protozoan cyst reduction can be claimed without testing only if the devices meet the reduction requirements for both bacteria and viruses. Reduction claims cannot be made only for bacteria or only for viruses. This standard also includes requirements for the manufacturer's quality control verification, maximum shelf life, effective life indication, maximum use life (one year for dead end filters and two years for membrane filters with reject or waste streams) and simulated accidental contamination event test (SACET) at the end of the 3 wk test to simulate 'worst case' water with microbiological incursion.

The microbiological reduction requirements' acceptance criteria are consistent with the *USEPA Guide Standard and Protocol for Microbiological Water Purifiers*: 99.9999% bacteria reduction (6 log), 99.99% virus reduction (4 log) and 99.95% cyst reduction (3.3 log).

---

<sup>4</sup> Isoelectric point (pI or IEP) is the pH at which a protein or viral particle carries a net neutral charge. Below the isoelectric point the particle carries a net positive charge, above it a net negative charge.

This Standard was developed by the NSF Joint Committee on Drinking Water Treatment Units using the consensus process described by the American National Standards Institute.

Suggestions for improvement of this Standard are welcome. This Standard is maintained on a Continuous Maintenance schedule and can be opened for comment at any time. Comments should be sent to Chair, Joint Committee on Drinking Water Treatment Units at [standards@nsf.org](mailto:standards@nsf.org), or c/o NSF International, Standards Department, P.O. Box 130140, Ann Arbor, Michigan 48113-0140, USA.

This page is intentionally left blank.

## NSF/ANSI Standard for Drinking Water Treatment Units –

# Supplemental Microbiological Water Treatment Systems – Filtration

## 1 General

### 1.1 Purpose

It is the purpose of this Standard to establish minimum requirements for the reduction of microorganisms using mechanical filtration devices for supplemental treatment of microbiologically safe drinking water. Mechanical filtration devices covered by this Standard are intended for use only on water supplies that have been treated to public water system standards or otherwise are determined to be microbiologically safe as demonstrated by routine testing. They are intended only for protection against intermittent incursions or accidental microbiological contamination of otherwise safe drinking water. This Standard also specifies the minimum product literature and labeling information that a manufacturer shall supply to authorized representatives and system owners as well as the minimum service related obligations that the manufacturer shall extend to system owners.

### 1.2 Scope

The point-of-use (POU) and point-of-entry (POE) systems addressed by this Standard are designed to be used for the supplemental microbial control of specific organisms that may occasionally be present in drinking water (public or private) because of intermittent incursions. Certain of these specific organisms that may be introduced into the drinking water are considered established or potential health hazards. This Standard establishes requirements for POU and POE drinking water treatment systems, and the materials and components used in these systems.

### 1.3 Minimum requirements

This Standard establishes minimum requirements. Variations may be permitted when it is verified that compared to the systems covered in this Standard the alternate systems are as resistant to wear and physical damage or provide equivalent operation or performance. Systems with components or functions covered under other NSF or NSF/ANSI Standards or Criteria shall comply with those applicable requirements.

### 1.4 Alternate materials, designs and construction

While specific materials, designs and construction may be stipulated in this Standard, systems that incorporate alternate materials, designs and construction may be acceptable when it is verified that such systems meet the applicable requirements stated herein.

### 1.5 Mechanical and microbial reduction performance claims

**1.5.1** All NSF/ANSI 244 performance claims shall be verified and substantiated by test data generated under the requirements of NSF/ANSI 244.